

东丽供电公司10千伏配电线路可开放容量信息表(2024年第三季度)

序号	变电站名称	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷 日后需预留容量(kVA)	可开放容量(kVA)	备注
1	保税路	10kV-41	保11	8434.84	487	72.15	14.82%	0	7185	
2	保税路	10kV-41	保12	8434.84	487	45.96	9.44%	0	4089	
3	保税路	10kV-41	保13	8434.84	487	347.94	71.45%	0	2408	
4	保税路	10kV-41	保14	8434.84	487	289.07	59.36%	0	3428	
5	保税路	10kV-41	保15	8434.84	487	144.41	29.65%	0	5934	
6	保税路	10kV-41	保16	8434.84	487	150.39	30.88%	0	5830	
7	保税路	10kV-41	保17	8434.84	487	112.33	23.07%	0	6489	
8	保税路	10kV-42	保21	8434.84	487	176.28	36.20%	630	5066	
9	保税路	10kV-42	保22	8434.84	487	167.23	34.34%	0	5538	
10	保税路	10kV-42	保23	8434.84	487	286.37	58.80%	750	3100	
11	保税路	10kV-42	保24	8434.84	487	280.01	57.50%	0	3585	
12	保税路	10kV-43	保25	8434.84	487	273.27	56.11%	0	3702	
13	保税路	10kV-43	保26	8434.84	487	146.86	30.16%	750	5516	
14	保税路	10kV-43	保27	8434.84	487	23.64	4.85%	0	8026	
15	保税路	10kV-44	保31	8434.84	487	94.19	19.34%	0	6804	
16	保税路	10kV-44	保32	8434.84	487	309.41	63.53%	0	3076	
17	保税路	10kV-44	保33	8434.84	487	108.99	22.38%	6400	3347	
18	保税路	10kV-44	保34	8434.84	487	191.11	39.24%	0	5125	
19	保税路	10kV-44	保35	8434.84	487	145.24	29.82%	0	5920	
20	保税路	10kV-44	保36	8434.84	487	315.3	64.74%	400	2774	
21	保税路	10kV-44	保37	8434.84	487	133.64	27.44%	0	6120	
22	茶金路	10kV-41	茶11	8434.84	487	77.89	15.99%	0	7086	
23	茶金路	10kV-41	茶12	8434.84	487	284.17	58.35%	400	3313	
24	茶金路	10kV-41	茶13	8434.84	487	276.46	56.77%	0	3646	

25	茶金路	10kV-41	茶15	8434.84	487	116.06	23.83%	0	6425	
26	茶金路	10kV-41	茶16	8434.84	487	1.68	0.34%	0	8406	
27	茶金路	10kV-41	茶18	8434.84	487	301.13	61.83%	0	3220	
28	茶金路	10kV-42	茶21	8434.84	487	333.81	68.54%	0	2654	
29	茶金路	10kV-42	茶22	8434.84	487	46.94	9.64%	0	7622	
30	茶金路	10kV-42	茶23	8434.84	487	1.47	0.30%	0	8410	
31	茶金路	10kV-43	茶25	8434.84	487	265.56	54.53%	0	3835	
32	茶金路	10kV-43	茶26	8434.84	487	160.77	33.01%	315	5492.5	
33	茶金路	10kV-43	茶27	8434.84	487	2.96	0.61%	0	8383	
34	茶金路	10kV-44	茶31	8434.84	487	253.36	52.02%	0	4047	
35	茶金路	10kV-44	茶32	8434.84	487	45.72	9.39%	0	7643	
36	茶金路	10kV-44	茶33	8434.84	487	73.51	15.09%	0	7162	
37	茶金路	10kV-44	茶34	8434.84	487	113.68	23.34%	0	6466	
38	茶金路	10kV-44	茶35	8434.84	487	3.4	0.70%	0	8376	
39	茶金路	10kV-44	茶36	8434.84	487	3.47	0.71%	0	8375	
40	大毕庄	10kV-4	521	6928	400	167.09	41.77%	0	4034	
41	大毕庄	10kV-4	523	6928	400	138.97	34.74%	800	4121	
42	大毕庄	10kV-4	525	6928	400	196.5	49.13%	0	3524	
43	大毕庄	10kV-4	527 (DL)	6928	400	172.24	43.06%	0	3945	
44	大毕庄	10kV-5	520	6928	400	269.15	67.29%	0	2266	
45	大毕庄	10kV-5	522	6928	400	297.35	74.34%	190	1683	
46	大毕庄	10kV-5	524	6928	400	315.36	78.84%	315	1308.5	
47	大毕庄	10kV-5	526	6928	400	313.67	78.42%	0	1495	
48	大毕庄	10kV-5	528 (DL)	6928	400	306.24	76.56%	0	1624	
49	东堽	10kV-41	东11	8434.84	487	281.91	57.89%	0	3552	
50	东堽	10kV-41	东12	8434.84	487	382.08	78.46%	0	1817	
51	东堽	10kV-41	东13	8434.84	487	162.36	33.34%	0	5623	
52	东堽	10kV-41	东14	8434.84	487	336.03	69.00%	0	2615	
53	东堽	10kV-41	东15	9664.56	558	105.99	18.99%	0	7829	

54	东塍	10kV-41	东16	9664.56	558	171.77	30.78%	0	6690	
55	东塍	10kV-42	东22	8434.84	487	216.43	44.44%	0	4686	
56	东塍	10kV-42	东23	8434.84	487	257.39	52.85%	0	3977	
57	东塍	10kV-42	东24	9664.56	558	158.9	28.48%	0	6912	
58	东塍	10kV-42	东25	9664.56	558	168.01	30.11%	0	6755	
59	东塍	10kV-42	东26	9664.56	558	108.06	19.37%	0	7793	
60	东塍	10kV-43	东31	8434.84	487	186.89	38.38%	0	5198	
61	东塍	10kV-43	东32	8434.84	487	156.41	32.12%	0	5726	
62	东塍	10kV-43	东33	8434.84	487	289.04	59.35%	0	3429	
63	东塍	10kV-43	东34	8434.84	487	172.24	35.37%	0	5451	
64	东塍	10kV-43	东35	9664.56	558	65.12	11.67%	0	8537	
65	东塍	10kV-43	东36	9664.56	558	98.6	17.67%	0	7957	
66	东塍	10kV-44	东42	8434.84	487	140.66	28.88%	0	5999	
67	东塍	10kV-44	东43	8434.84	487	252.24	51.79%	0	4066	
68	东塍	10kV-44	东44	9664.56	558	158.68	28.44%	0	6916	
69	东塍	10kV-44	东45	9664.56	558	157.79	28.28%	0	6931	
70	东塍	10kV-44	东46	9664.56	558	201.82	36.17%	0	6169	
71	东丽湖	10kV-41	912	9664.56	558	150.34	26.94%	0	7061	
72	东丽湖	10kV-41	914	9664.56	558	266.47	47.75%	0	5050	
73	东丽湖	10kV-42	921	8434.84	487	158.62	32.57%	0	5688	
74	东丽湖	10kV-42	922	8434.84	487	307.16	63.07%	0	3115	
75	东丽湖	10kV-42	923	8434.84	487	328.52	67.46%	0	2745	
76	东丽湖	10kV-43	924	8434.84	487	233.96	48.04%	0	4383	
77	东丽湖	10kV-43	925	8434.84	487	191.73	39.37%	1600	4314	
78	东丽湖	10kV-43	926	8434.84	487	196.65	40.38%	0	5029	
79	东丽湖	10kV-44	931	8434.84	487	187.78	38.56%	0	5182	
80	东丽湖	10kV-44	933	8434.84	487	314.83	64.65%	0	2982	
81	东丽湖	10kV-44	934	8434.84	487	202.52	41.59%	1600	4127	
82	东丽湖	10kV-44	932 (DL)	8434.84	487	64.06	13.15%	0	7326	

83	东文路	10kV-41	文11	9664.56	558	137.34	24.61%	0	7286	
84	东文路	10kV-41	文12	9664.56	558	171.56	30.75%	0	6693	
85	东文路	10kV-41	文13	9664.56	558	237.66	42.59%	0	5548	
86	东文路	10kV-41	文14	9664.56	558	154.92	27.76%	0	6982	
87	东文路	10kV-41	文15	9664.56	558	310.31	55.61%	0	4290	
88	东文路	10kV-41	文16	9664.56	558	191.95	34.40%	0	6340	
89	东文路	10kV-42	文21	9664.56	558	144.84	25.96%	0	7156	
90	东文路	10kV-42	文22	9664.56	558	373.13	66.87%	0	3202	
91	东文路	10kV-42	文23	9664.56	558	280.31	50.23%	0	4810	
92	东文路	10kV-42	文24	9664.56	558	325.08	58.26%	1600	3234	
93	东文路	10kV-43	文31	9664.56	558	374.53	67.12%	0	3178	
94	东文路	10kV-43	文32	9664.56	558	88.59	15.88%	0	8130	
95	东文路	10kV-43	文33大馈	9664.56	558	237.7	42.60%	0	5547	
96	东文路	10kV-43	文34	9664.56	558	74.53	13.36%	0	8373	
97	顾庄	10kV-41	顾11	9664.56	558	174.24	31.23%	0	6646	
98	顾庄	10kV-41	顾12	9664.56	558	182.05	32.63%	0	6511	
99	顾庄	10kV-41	顾14	9664.56	558	207.28	37.15%	0	6074	
100	顾庄	10kV-41	顾16	9664.56	558	209.15	37.48%	0	6042	
101	顾庄	10kV-41	顾20	9664.56	558	205.66	36.86%	3030	4587	
102	顾庄	10kV-41	顾21大馈	9664.56	558	49.33	8.84%	0	8810	
103	顾庄	10kV-42	顾24	9664.56	558	99.42	17.82%	0	7942	
104	顾庄	10kV-42	顾25大馈	9664.56	558	142.93	25.61%	0	7189	
105	顾庄	10kV-42	顾26	9664.56	558	270.9	48.55%	3030	3457	
106	顾庄	10kV-43	顾29大馈	9664.56	558	223.49	40.05%	0	5794	
107	顾庄	10kV-43	顾31	9664.56	558	133.76	23.97%	0	7348	
108	顾庄	10kV-43	顾32	9664.56	558	169.4	30.36%	0	6730	
109	顾庄	10kV-43	顾33大馈	9664.56	558	28.36	5.08%	0	9174	
110	顾庄	10kV-43	顾34大馈	9664.56	558	69.31	12.42%	0	8464	
111	湖西路	10kV-4	715	6928	400	261.44	65.36%	1100	1850	

112	湖西路	10kV-4	717	8434.84	487	103.84	21.32%	0	6637	
113	湖西路	10kV-4	719	6928	400	162	40.50%	2850	2697	
114	湖西路	10kV-4	721	8434.84	487	210.88	43.30%	0	4783	
115	湖西路	10kV-4	711 (DL)	6928	400	315.36	78.84%	0	1466	
116	湖西路	10kV-4	713 (DL)	6928	400	188.32	47.08%	0	3666	
117	湖西路	10kV-5	716	8434.84	487	123.44	25.35%	0	6297	
118	湖西路	10kV-5	718	6928	400	80.56	20.14%	0	5533	
119	湖西路	10kV-5	720	6928	400	128.72	32.18%	0	4699	
120	湖西路	10kV-5	712 (DL)	6928	400	167.04	41.76%	2850	2610	
121	湖西路	10kV-5	714 (DL)	6928	400	228.24	57.06%	1600	2175	
122	华明	10kV-41	华11	8434.84	487	154.51	31.73%	0	5758	
123	华明	10kV-41	华12	8434.84	487	66.09	13.57%	0	7290	
124	华明	10kV-41	华13	8434.84	487	252.07	51.76%	0	4069	
125	华明	10kV-41	华15	8434.84	487	81.39	16.71%	0	7025	
126	华明	10kV-41	华16	8434.84	487	81.39	16.71%	0	7025	
127	华明	10kV-41	华17	8434.84	487	90	18.48%	0	6876	
128	华明	10kV-41	华18	8434.84	487	107.23	22.02%	0	6577	
129	华明	10kV-42	华21	8434.84	487	278.61	57.21%	0	3609	
130	华明	10kV-42	华22	8434.84	487	120.23	24.69%	0	6352	
131	华明	10kV-42	华23	8434.84	487	32.52	6.68%	0	7871	
132	华明	10kV-42	华24	8434.84	487	53.61	11.01%	0	7506	
133	华明	10kV-43	华25	8434.84	487	79.63	16.35%	0	7056	
134	华明	10kV-43	华26	8434.84	487	190.37	39.09%	0	5138	
135	华明	10kV-43	华27	8434.84	487	230.1	47.25%	0	4449	
136	华明	10kV-43	华28	8434.84	487	45.7	9.38%	0	7644	
137	华明	10kV-44	华31	8434.84	487	152.4	31.29%	0	5796	
138	华明	10kV-44	华32	8434.84	487	103.89	21.33%	0	6636	
139	华明	10kV-44	华34	8434.84	487	67.32	13.82%	0	7269	
140	华明	10kV-44	华35	8434.84	487	51.5	10.57%	0	7543	

141	华明	10kV-44	华36	8434.84	487	353.67	72.62%	1250	1684	
142	华明	10kV-41	华14出线	8434.84	487	92.64	19.02%	0	6831	
143	华瑞路	10kV-41	瑞11	8434.84	487	297.98	61.19%	0	3274	
144	华瑞路	10kV-41	瑞12	8434.84	487	196.37	40.32%	0	5034	
145	华瑞路	10kV-41	瑞13	8434.84	487	290.25	59.60%	0	3408	
146	华瑞路	10kV-41	瑞14	8434.84	487	291.65	59.89%	0	3383	
147	华瑞路	10kV-41	瑞15	8434.84	487	176.68	36.28%	0	5375	
148	华瑞路	10kV-41	瑞16	8434.84	487	316.62	65.01%	0	2951	
149	华瑞路	10kV-41	瑞18 (DL) 大	8434.84	487	170.53	35.02%	0	5481	
150	华瑞路	10kV-42	瑞21	8434.84	487	275.13	56.49%	0	3670	
151	华瑞路	10kV-42	瑞22大馈	9664.56	558	265.46	47.57%	0	5067	
152	华瑞路	10kV-42	瑞23	8434.84	487	228.54	46.93%	0	4476	
153	华瑞路	10kV-42	瑞24	8434.84	487	272.84	56.02%	1250	3085	
154	华瑞路	10kV-43	瑞25	8434.84	487	240.32	49.35%	0	4272	
155	华瑞路	10kV-43	瑞26	8434.84	487	313.98	64.47%	0	2997	
156	华瑞路	10kV-43	瑞27	8434.84	487	130.97	26.89%	0	6167	
157	华瑞路	10kV-44	瑞31	8434.84	487	266.34	54.69%	0	3822	
158	华瑞路	10kV-44	瑞32	8434.84	487	96.87	19.89%	0	6757	
159	华瑞路	10kV-44	瑞33大馈	9664.56	558	107.06	19.19%	0	7810	
160	华瑞路	10kV-44	瑞36	8434.84	487	342.63	70.36%	0	2500	
161	华瑞路	10kV-44	瑞37	8434.84	487	306.24	62.88%	0	3131	
162	华瑞路	10kV-44	瑞38 (DL) 大	8434.84	487	374.28	76.85%	0	1953	
163	环河路	10kV-41	环11	9664.56	558	248	44.44%	0	5370	
164	环河路	10kV-41	环12	8434.84	487	321.72	66.06%	0	2863	
165	环河路	10kV-41	环13	8434.84	487	146.4	30.06%	2000	4899	
166	环河路	10kV-41	环14	8434.84	487	200.52	41.17%	0	4962	
167	环河路	10kV-41	环16	8434.84	487	171.48	35.21%	0	5465	

168	环河路	10kV-41	环17	8434.84	487	307.68	63.18%	1250	2481	
169	环河路	10kV-41	环18	8434.84	487	300.96	61.80%	0	3222	
170	环河路	10kV-42	环21	8434.84	487	310.44	63.75%	0	3058	
171	环河路	10kV-42	环22	9664.56	558	105.72	18.95%	0	7833	
172	环河路	10kV-42	环24	8434.84	487	54.48	11.19%	0	7491	
173	环河路	10kV-43	环25	8434.84	487	191.52	39.33%	450	4892	
174	环河路	10kV-43	环26	8434.84	487	152.16	31.24%	0	5800	
175	环河路	10kV-43	环27	8434.84	487	306.12	62.86%	0	3133	
176	环河路	10kV-43	环28	8434.84	487	367.32	75.43%	0	2072	
177	环河路	10kV-44	环31	8434.84	487	107.4	22.05%	0	6575	
178	环河路	10kV-44	环32	8434.84	487	227.52	46.72%	1250	3869	
179	环河路	10kV-44	环33	8434.84	487	331.44	68.06%	0	2694	
180	环河路	10kV-44	环34	8434.84	487	111.36	22.87%	0	6506	
181	环河路	10kV-44	环35	8434.84	487	326.28	67.00%	0	2783	
182	货运路	10kV-41	货11	8434.84	487	23.44	4.81%	0	8029	
183	货运路	10kV-41	货12	8434.84	487	103.6	21.27%	0	6641	
184	货运路	10kV-41	货13	8434.84	487	118.56	24.34%	0	6382	
185	货运路	10kV-41	货14	9664.56	558	190	34.05%	2500	5124	
186	货运路	10kV-41	货15	8434.84	487	83.84	17.22%	0	6982	
187	货运路	10kV-41	货16	9664.56	558	45.04	8.07%	0	8885	
188	货运路	10kV-41	货17	9664.56	558	23.04	4.13%	0	9265	
189	货运路	10kV-41	货18	8434.84	487	336.48	69.09%	1600	1807	
190	货运路	10kV-42	货21	8434.84	487	143.52	29.47%	0	5949	
191	货运路	10kV-42	货23	9664.56	558	222.8	39.93%	100	5756	
192	货运路	10kV-42	货24	9664.56	558	294	52.69%	1600	3772	
193	货运路	10kV-42	货25	9664.56	558	128.16	22.97%	2500	6195	
194	货运路	10kV-42	货26	8434.84	487	97.12	19.94%	0	6753	
195	货运路	10kV-42	货27	9664.56	558	31.6	5.66%	0	9118	
196	货运路	10kV-42	货28	9664.56	558	48.72	8.73%	0	8821	

197	九车地	10kV-4	261	8434.84	487	228.5	46.92%	0	4477	
198	九车地	10kV-4	263	8434.84	487	311	63.86%	0	3048	
199	九车地	10kV-4	267	8434.84	487	179.5	36.86%	0	5326	
200	九车地	10kV-4	269	8434.84	487	78.6	16.14%	0	7073	
201	九车地	10kV-4	275	9664.56	558	74.1	13.28%	0	8381	
202	九车地	10kV-4	271 (DL)	8434.84	487	206.1	42.32%	0	4865	
203	九车地	10kV-5	252	8434.84	487	277.8	57.04%	0	3624	
204	九车地	10kV-5	262	8434.84	487	57.4	11.79%	0	7440	
205	崂山道	10kV-42	崂21大馈	9664.56	558	163.12	29.23%	0	6840	
206	崂山道	10kV-42	崂22大馈	9664.56	558	50.98	9.14%	0	8781	
207	南大桥	10kV-41	桥11	8434.84	487	283.05	58.12%	0	3533	
208	南大桥	10kV-41	桥12	8434.84	487	45.16	9.27%	0	7653	
209	南大桥	10kV-41	桥13	9664.56	558	69.1	12.38%	0	8468	
210	南大桥	10kV-41	桥18	8434.84	487	271.92	55.84%	0	3725	
211	南大桥	10kV-42	桥21	8434.84	487	194.82	40.00%	0	5061	
212	南大桥	10kV-42	桥22	8434.84	487	195.84	40.21%	0	5043	
213	南大桥	10kV-43	桥25	8434.84	487	213.1	43.76%	0	4744	
214	南大桥	10kV-43	桥26	8434.84	487	200.79	41.23%	0	4957	
215	南大桥	10kV-44	桥31	8434.84	487	232.61	47.76%	0	4406	
216	南大桥	10kV-44	桥32	8434.84	487	213.28	43.79%	0	4741	
217	南大桥	10kV-44	桥37	8434.84	487	256.84	52.74%	0	3986	
218	南何庄	10kV-41	何11	8434.84	487	114.02	23.41%	0	6460	
219	南何庄	10kV-41	何12	8434.84	487	89.64	18.41%	0	6882	
220	南何庄	10kV-41	何13	8434.84	487	241.09	49.51%	0	4259	
221	南何庄	10kV-41	何14	8434.84	487	68.37	14.04%	0	7251	
222	南何庄	10kV-41	何15	9664.56	558	59.54	10.67%	0	8633	
223	南何庄	10kV-41	何16	9664.56	558	43.93	7.87%	0	8904	
224	南何庄	10kV-41	何17	9664.56	558	74.93	13.43%	660	8037	
225	南何庄	10kV-42	何21	8434.84	487	94.28	19.36%	0	6802	

226	南何庄	10kV-42	何22	8434.84	487	35.96	7.38%	0	7812	
227	南何庄	10kV-42	何23	8434.84	487	250.75	51.49%	715	3734.5	
228	南何庄	10kV-42	何24	8434.84	487	42.54	8.74%	0	7698	
229	南何庄	10kV-43	何31	8434.84	487	149.9	30.78%	0	5839	
230	南何庄	10kV-43	何32	8434.84	487	95.21	19.55%	0	6786	
231	南何庄	10kV-43	何33	8434.84	487	87.08	17.88%	0	6927	
232	南何庄	10kV-43	何34	9664.56	558	76.78	13.76%	0	8335	
233	南何庄	10kV-44	何41	8434.84	487	162.55	33.38%	0	5619	
234	南何庄	10kV-44	何42	8434.84	487	122.75	25.21%	0	6308	
235	南何庄	10kV-44	何43	8434.84	487	122.91	25.24%	0	6306	
236	南何庄	10kV-44	何44	8434.84	487	281.91	57.89%	110	3497	
237	南何庄	10kV-44	何45	8434.84	487	76.47	15.70%	0	7111	
238	南何庄	10kV-44	何46	8434.84	487	22.15	4.55%	0	8051	
239	南何庄	10kV-44	何47	9664.56	558	3.01	0.54%	1700	8762	
240	南何庄	10kV-44	何48	9664.56	558	28.38	5.09%	0	9173	
241	山青道	10kV-41	山12	9664.56	558	206.24	36.96%	0	6093	
242	山青道	10kV-41	山13	8434.84	487	200.96	41.26%	0	4955	
243	山青道	10kV-41	山14	9664.56	558	278.72	49.95%	0	4837	
244	山青道	10kV-42	山21	9664.56	558	278.4	49.89%	0	4843	
245	山青道	10kV-42	山22	9664.56	558	104.32	18.70%	2400	6657	
246	山青道	10kV-42	山24	9664.56	558	241.12	43.21%	0	5489	
247	山青道	10kV-42	山25大馈	9664.56	558	36.16	6.48%	0	9038	
248	山青道	10kV-42	山26	8434.84	487	217.6	44.68%	0	4666	
249	山青道	10kV-43	山31	8434.84	487	200.96	41.26%	0	4955	
250	山青道	10kV-43	山32	9664.56	558	26.88	4.82%	2230	8084	
251	山青道	10kV-43	山33	9664.56	558	155.52	27.87%	0	6971	
252	山青道	10kV-44	山42	8434.84	487	175.36	36.01%	0	5397	
253	山青道	10kV-44	山43	8434.84	487	149.76	30.75%	0	5841	
254	山青道	10kV-44	山44	6928	400	242.56	60.64%	0	2727	

255	山青道	10kV-44	山45大馈	9664.56	558	25.11	4.50%	0	9230	
256	山青道	10kV-44	山46	8434.84	487	262.02	53.80%	0	3897	
257	纬五道	10kV-41	纬11	8434.84	487	382.08	78.46%	0	1817	
258	纬五道	10kV-41	纬12	8434.84	487	290.4	59.63%	0	3405	
259	纬五道	10kV-41	纬13大馈	9664.56	558	251.68	45.10%	0	5306	
260	纬五道	10kV-41	纬14	8434.84	487	249.12	51.15%	0	4120	
261	纬五道	10kV-41	纬15	9664.56	558	124.8	22.37%	0	3953	
262	纬五道	10kV-41	纬16大馈	9664.56	558	27.36	4.90%	0	9191	
263	纬五道	10kV-42	纬21	8434.84	487	206.24	42.35%	500	4613	
264	纬五道	10kV-42	纬22	8434.84	487	299.2	61.44%	0	3252	
265	纬五道	10kV-42	纬23	8434.84	487	342.56	70.34%	630	2187	
266	纬五道	10kV-42	纬24大馈	9664.56	558	175.36	31.43%	0	6627	
267	纬五道	10kV-42	纬25大馈	9664.56	558	17.92	3.21%	815	8946.5	
268	纬五道	10kV-42	纬26	8434.84	487	221.28	45.44%	0	4602	
269	纬五道	10kV-43	纬31	8434.84	487	385.28	79.11%	0	1762	
270	纬五道	10kV-43	纬32	8434.84	487	55.04	11.30%	0	7482	
271	纬五道	10kV-43	纬33大馈	9664.56	558	202.08	36.22%	2500	4914	
272	纬五道	10kV-43	纬34大馈	9664.56	558	323.04	57.89%	0	4070	
273	纬五道	10kV-43	纬35大馈	9664.56	558	23.84	4.27%	0	9252	
274	纬五道	10kV-43	纬36	8434.84	487	209.76	43.07%	0	4802	
275	纬五道	10kV-44	纬41	8434.84	487	281.12	57.72%	500	3316	
276	纬五道	10kV-44	纬42	8434.84	487	313.44	64.36%	0	3006	
277	纬五道	10kV-44	纬43	9664.56	558	155.2	27.81%	0	6977	
278	纬五道	10kV-44	纬44	8434.84	487	335.52	68.90%	0	2623	
279	纬五道	10kV-44	纬45大馈	9664.56	558	17.92	3.21%	815	8946.5	
280	纬五道	10kV-44	纬46大馈	9664.56	558	40.8	7.31%	0	5408	
281	魏王	10kV-41	魏11	8434.84	487	94.57	19.42%	0	6797	
282	魏王	10kV-41	魏12	8434.84	487	231.34	47.50%	0	4428	
283	魏王	10kV-41	魏16	8434.84	487	167.47	34.39%	0	5534	

284	魏王	10kV-41	魏17	8434.84	487	142.97	29.36%	0	5958	
285	魏王	10kV-42	魏22	8434.84	487	337.75	69.35%	0	2585	
286	魏王	10kV-42	魏23	8434.84	487	281.73	57.85%	0	3555	
287	魏王	10kV-43	魏25	8434.84	487	311.03	63.87%	0	3048	
288	魏王	10kV-43	魏26	8434.84	487	139.34	28.61%	0	6022	
289	魏王	10kV-43	魏27	6928	400	164.89	41.22%	0	4072	
290	魏王	10kV-43	魏28	8434.84	487	245.75	50.46%	0	4179	
291	魏王	10kV-44	魏31大馈	9664.56	558	237	42.47%	0	5560	
292	无暇街	10kV-41	暇11	8434.84	487	210	43.12%	0	4798	
293	无暇街	10kV-41	暇12	8434.84	487	289.57	59.46%	0	3419	
294	无暇街	10kV-41	暇13	8434.84	487	201.68	41.41%	3200	3342	
295	无暇街	10kV-41	暇14	6928	400	218.09	54.52%	0	3151	
296	无暇街	10kV-42	暇21	8434.84	487	253.95	52.15%	0	4036	
297	无暇街	10kV-42	暇22	6928	400	70.66	17.67%	0	5704	
298	无暇街	10kV-44	暇31	6928	400	138.87	34.72%	0	4523	
299	无暇街	10kV-44	暇32	8434.84	487	129.84	26.66%	0	6186	
300	无暇街	10kV-44	暇35	6928	400	157.5	39.38%	0	4200	
301	无暇街	10kV-44	暇36	8434.84	487	170.86	35.08%	3200	3876	
302	无暇街	10kV-44	暇37	6928	400	177.19	44.30%	0	3859	
303	五经路	10kV-41	经11	9664.56	558	261.58	46.88%	0	5134	
304	五经路	10kV-41	经12	9664.56	558	244.8	43.87%	0	5425	
305	五经路	10kV-41	经13	9664.56	558	104.12	18.66%	0	7861	
306	五经路	10kV-41	经14	9664.56	558	108.26	19.40%	0	7790	
307	五经路	10kV-41	经15	9664.56	558	169.47	30.37%	0	6729	
308	五经路	10kV-41	经16	9664.56	558	360.86	64.67%	0	3414	
309	五经路	10kV-42	经22	9664.56	558	242.27	43.42%	0	5468	
310	五经路	10kV-42	经23	9664.56	558	163.34	29.27%	0	6836	
311	五经路	10kV-42	经24	9664.56	558	88.97	15.94%	0	8124	
312	五经路	10kV-43	经32	9664.56	558	281.52	50.45%	0	4789	

313	五经路	10kV-43	经33	9664.56	558	227.1	40.70%	0	5731	
314	五经路	10kV-43	经34	9664.56	558	187.07	33.53%	0	6424	
315	五经路	10kV-44	经42	9664.56	558	331.08	59.33%	0	3931	
316	五经路	10kV-44	经44	9664.56	558	119.62	21.44%	0	7592	
317	五经路	10kV-44	经45	9664.56	558	323.25	57.93%	0	4066	
318	物流	10kV-41	物11	8434.84	487	140.67	28.89%	0	5998	
319	物流	10kV-41	物12	9664.56	558	144.17	25.84%	0	7167	
320	物流	10kV-41	物13大馈	9664.56	558	24.17	4.33%	0	9246	
321	物流	10kV-41	物14	8434.84	487	228.8	46.98%	0	4472	
322	物流	10kV-41	物15	8434.84	487	234.65	48.18%	0	4371	
323	物流	10kV-41	物16	8434.84	487	141.73	29.10%	0	5980	
324	物流	10kV-41	物17	8434.84	487	303.29	62.28%	0	3182	
325	物流	10kV-42	物21	8434.84	487	163.73	33.62%	0	5599	
326	物流	10kV-42	物22	8434.84	487	339.34	69.68%	0	2557	
327	物流	10kV-42	物23	8434.84	487	57.31	11.77%	0	7442	
328	物流	10kV-42	物24	8434.84	487	181.28	37.22%	0	5295	
329	物流	10kV-43	物31	8434.84	487	95.31	19.57%	0	6784	
330	物流	10kV-43	物32	8434.84	487	334.93	68.77%	0	2634	
331	物流	10kV-43	物33大馈	9664.56	558	19.41	3.48%	0	9328	
332	物流	10kV-44	物41	8434.84	487	141.52	29.06%	0	5984	
333	物流	10kV-44	物42	8434.84	487	182.23	37.42%	0	5279	
334	物流	10kV-44	物43	8434.84	487	294.43	60.46%	0	3335	
335	物流	10kV-44	物44	8434.84	487	222.77	45.74%	0	4577	
336	物流	10kV-44	物45	8434.84	487	194.74	39.99%	0	5062	
337	物流	10kV-44	物46	8434.84	487	316.59	65.01%	0	2951	
338	物流	10kV-44	物47	8434.84	487	183.92	37.77%	0	5249	
339	先锋路	10kV-41	先11	8434.84	487	177.02	36.35%	0	5369	
340	先锋路	10kV-41	先12	8434.84	487	285.13	58.55%	0	3496	
341	先锋路	10kV-41	先13	8434.84	487	193.35	39.70%	0	5086	

342	先锋路	10kV-41	先14	8434.84	487	192.97	39.62%	0	5093	
343	先锋路	10kV-41	先15	8434.84	487	325.8	66.90%	0	2792	
344	先锋路	10kV-41	先16	8434.84	487	12.5	2.57%	0	8218	
345	先锋路	10kV-41	先17	8434.84	487	300.35	61.67%	0	3233	
346	先锋路	10kV-42	先21	8434.84	487	158.79	32.61%	0	5684	
347	先锋路	10kV-42	先22	8434.84	487	171.95	35.31%	0	5456	
348	先锋路	10kV-42	先24	8434.84	487	338.89	69.59%	0	2565	
349	先锋路	10kV-43	先26	8434.84	487	164.59	33.80%	0	5584	
350	先锋路	10kV-43	先27	8434.84	487	71.58	14.70%	0	7195	
351	先锋路	10kV-43	先28	8434.84	487	192.42	39.51%	0	5102	
352	先锋路	10kV-44	先31	8434.84	487	321.76	66.07%	0	2862	
353	先锋路	10kV-44	先32	8434.84	487	310.5	63.76%	0	3057	
354	先锋路	10kV-44	先33	8434.84	487	190.9	39.20%	0	5128	
355	先锋路	10kV-44	先34	8434.84	487	228.88	47.00%	0	4470	
356	先锋路	10kV-44	先35	8434.84	487	30.07	6.17%	0	7914	
357	先锋路	10kV-44	先36	8434.84	487	126.85	26.05%	0	6238	
358	先锋路	10kV-44	先37	8434.84	487	89.05	18.29%	0	6892	
359	小马场	10kV-4	31	8434.84	487	89.01	18.28%	0	6893	
360	小马场	10kV-4	33	8434.84	487	109.71	22.53%	0	6534	
361	小马场	10kV-4	35	8434.84	487	218.26	44.82%	0	4654	
362	小马场	10kV-4	37	8434.84	487	18.96	3.89%	0	8107	
363	小马场	10kV-5	32	8434.84	487	98.28	20.18%	0	6733	
364	小马场	10kV-5	36	8434.84	487	142.8	29.32%	0	5962	
365	小马场	10kV-5	38	8434.84	487	65.52	13.45%	0	7300	
366	小马场	10kV-5	40	8434.84	487	107.26	22.02%	0	6577	
367	新贯庄	10kV-41	新11	8434.84	487	124.11	25.48%	0	6286	
368	新贯庄	10kV-41	新12	8434.84	487	241.52	49.59%	0	4252	
369	新贯庄	10kV-41	新13	8434.84	487	102.47	21.04%	0	6660	
370	新贯庄	10kV-41	新14大馈	8434.84	487	213.31	43.80%	0	4740	

371	新贯庄	10kV-41	新16	8434.84	487	256.98	52.77%	0	3984	
372	新贯庄	10kV-41	新17	8434.84	487	262.65	53.93%	0	3886	
373	新贯庄	10kV-41	新18	8434.84	487	143.05	29.37%	0	5958	
374	新贯庄	10kV-42	新21	8434.84	487	224.12	46.02%	0	4553	
375	新贯庄	10kV-42	新22	8434.84	487	176.07	36.15%	0	5386	
376	新贯庄	10kV-42	新23	8434.84	487	151	31.01%	0	5819	
377	新贯庄	10kV-42	新24	8434.84	487	333.68	68.52%	0	2655	
378	新贯庄	10kV-43	新25	8434.84	487	162.36	33.34%	0	5623	
379	新贯庄	10kV-43	新26	8434.84	487	61.34	12.60%	0	7372	
380	新贯庄	10kV-43	新27	8434.84	487	103.3	21.21%	0	6646	
381	新贯庄	10kV-43	新28	8434.84	487	166.66	34.22%	0	5548	
382	新贯庄	10kV-44	新31	8434.84	487	119.58	24.55%	0	6364	
383	新贯庄	10kV-44	新32大馈	8434.84	487	274.36	56.34%	0	3683	
384	新贯庄	10kV-44	新33	8434.84	487	320.85	65.88%	0	2878	
385	新贯庄	10kV-44	新34	8434.84	487	269.62	55.36%	0	3765	
386	新贯庄	10kV-44	新35	8434.84	487	109.78	22.54%	0	6534	
387	新贯庄	10kV-44	新36	8434.84	487	96.32	19.78%	0	6766	
388	新贯庄	10kV-44	新37	8434.84	487	60.9	12.51%	0	7380	
389	新贯庄	10kV-44	新38	8434.84	487	336.03	69.00%	0	2615	
390	新立园	10kV-41	立11	8434.84	487	323.33	66.39%	0	2835	
391	新立园	10kV-41	立12	8434.84	487	212.97	43.73%	0	4746	
392	新立园	10kV-41	立13	8434.84	487	336.13	69.02%	0	2613	
393	新立园	10kV-41	立15	8434.84	487	262.83	53.97%	0	3883	
394	新立园	10kV-41	立16	8434.84	487	261.32	53.66%	0	3909	
395	新立园	10kV-41	立17	8434.84	487	181.29	37.23%	0	5295	
396	新立园	10kV-42	立21	8434.84	487	255.14	52.39%	0	4016	
397	新立园	10kV-42	立22	8434.84	487	181.72	37.31%	0	5288	
398	新立园	10kV-42	立24	8434.84	487	257.88	52.95%	0	3969	
399	新立园	10kV-43	立31	8434.84	487	174.48	35.83%	0	5413	

400	新立园	10kV-43	立32	8434.84	487	198.04	40.67%	0	5004	
401	新立园	10kV-43	立33	8434.84	487	200.07	41.08%	0	4970	
402	新立园	10kV-43	立34	8434.84	487	150.46	30.90%	0	5828	
403	新立园	10kV-44	立42	8434.84	487	192.34	39.49%	0	5104	
404	新立园	10kV-44	立43	8434.84	487	222.25	45.64%	0	4585	
405	新立园	10kV-44	立44	8434.84	487	148.77	30.55%	0	5858	
406	新立园	10kV-44	立45	8434.84	487	267.77	54.98%	0	3797	
407	新立园	10kV-44	立46	8434.84	487	330.82	67.93%	0	2705	
408	新立园	10kV-44	立47	8434.84	487	206.93	42.49%	0	4851	
409	新中村	10kV-41	村11	8434.84	487	150.4	30.88%	0	5830	
410	新中村	10kV-41	村12	8434.84	487	96.8	19.88%	0	6758	
411	新中村	10kV-41	村13	8434.84	487	86	17.66%	0	6945	
412	新中村	10kV-41	村14	8434.84	487	162.8	33.43%	0	5615	
413	新中村	10kV-41	村15	8434.84	487	125.6	25.79%	0	6259	
414	新中村	10kV-41	村16	8434.84	487	210.8	43.29%	0	4783	
415	新中村	10kV-42	村21	8434.84	487	90.8	18.64%	0	6863	
416	新中村	10kV-42	村22	8434.84	487	301.2	61.85%	0	3218	
417	新中村	10kV-42	村23	9664.56	558	366	65.59%	0	3326	
418	新中村	10kV-42	村24	8434.84	487	62	12.73%	0	7361	
419	新中村	10kV-42	村25	9664.56	558	148	26.52%	1250	6477	
420	新中村	10kV-43	村31	8434.84	487	229.6	47.15%	0	4458	
421	新中村	10kV-43	村32	9664.56	558	206.4	36.99%	1250	5465	
422	新中村	10kV-43	村34	8434.84	487	51.2	10.51%	0	7548	
423	新中村	10kV-43	村36	8434.84	487	224	46.00%	0	4555	
424	新中村	10kV-44	村41	8434.84	487	119.6	24.56%	0	6363	
425	新中村	10kV-44	村42	8434.84	487	113.2	23.24%	0	6475	
426	新中村	10kV-44	村43	8434.84	487	198	40.66%	0	5005	
427	新中村	10kV-44	村44	8434.84	487	95.6	19.63%	0	6779	
428	新中村	10kV-44	村45	8434.84	487	81.6	16.76%	0	7021	

429	新中村	10kV-44	村46	8434.84	487	157.2	32.28%	0	5712	
430	驯海路	10kV-4	111	8434.84	487	44.9	9.22%	0	7657	
431	驯海路	10kV-5	112	8434.84	487	187.4	38.48%	0	5189	
432	驯海路	10kV-4	113	8434.84	487	286.1	58.75%	0	3479	
433	驯海路	10kV-5	114	6928	400	238.8	59.70%	0	2792	
434	驯海路	10kV-4	115	8434.84	487	105.6	21.68%	0	6606	
435	驯海路	10kV-5	116	8434.84	487	254.4	52.24%	0	4028	
436	驯海路	10kV-5	118	8434.84	487	301.4	61.89%	0	3215	
437	驯海路	10kV-4	117 (DL)	6928	400	159.2	39.80%	0	4171	
438	么六桥	10kV-4	821	8434.84	487	285.61	58.65%	0	3488	
439	么六桥	10kV-4	823	8434.84	487	155.82	32.00%	0	5736	
440	么六桥	10kV-4	825	8434.84	487	317.97	65.29%	1600	2128	
441	么六桥	10kV-4	827	8434.84	487	132.25	27.16%	0	6144	
442	么六桥	10kV-4	829	8434.84	487	178.33	36.62%	0	5346	
443	么六桥	10kV-5	822	8434.84	487	29.19	5.99%	0	7930	
444	么六桥	10kV-5	824	8434.84	487	79.14	16.25%	0	7064	
445	么六桥	10kV-5	826	8434.84	487	310.93	63.85%	0	3049	
446	么六桥	10kV-5	828	8434.84	487	115.02	23.62%	0	6443	
447	么六桥	10kV-5	830	8434.84	487	66.13	13.58%	0	7289	
448	么六桥	10kV-5	832	8434.84	487	279.63	57.42%	0	3592	
449	袁家河	10kV-41	袁11	8434.84	487	260.65	53.52%	0	3921	
450	袁家河	10kV-41	袁12	8434.84	487	251.74	51.69%	315	3917.5	
451	袁家河	10kV-41	袁13	8434.84	487	142.28	29.22%	0	5970	
452	袁家河	10kV-41	袁14	8434.84	487	251.04	51.55%	0	4087	
453	袁家河	10kV-41	袁15	8434.84	487	131.97	27.10%	0	6149	
454	袁家河	10kV-41	袁16	8434.84	487	223.85	45.97%	0	4557	
455	袁家河	10kV-41	袁17	9664.56	558	58.37	10.46%	0	8654	
456	袁家河	10kV-41	袁18	8434.84	487	214.24	43.99%	0	4724	
457	袁家河	10kV-42	袁21	8434.84	487	132.67	27.24%	315	5979.5	

458	袁家河	10kV-42	袁22	8434.84	487	268.62	55.16%	0	3782	
459	袁家河	10kV-42	袁23	8434.84	487	284.56	58.43%	0	3506	
460	袁家河	10kV-42	袁24	8434.84	487	370.11	76.00%	0	2024	
461	袁家河	10kV-42	袁25	8434.84	487	219.87	45.15%	0	4627	
462	袁家河	10kV-42	袁26	8434.84	487	83.91	17.23%	400	6782	
463	袁家河	10kV-43	袁31	8434.84	487	60.71	12.47%	0	7383	
464	袁家河	10kV-43	袁32	8434.84	487	363.08	74.55%	0	2147	
465	袁家河	10kV-43	袁33	8434.84	487	103.14	21.18%	0	6648	
466	袁家河	10kV-43	袁34	8434.84	487	169.47	34.80%	0	5500	
467	袁家河	10kV-43	袁35	8434.84	487	339.88	69.79%	0	2548	
468	袁家河	10kV-43	袁36	8434.84	487	196.66	40.38%	0	5029	
469	袁家河	10kV-44	袁41	8434.84	487	225.49	46.30%	0	4530	
470	袁家河	10kV-44	袁42	8434.84	487	133.37	27.39%	0	6125	
471	袁家河	10kV-44	袁44	8434.84	487	260.65	53.52%	0	3921	
472	袁家河	10kV-44	袁45	8434.84	487	278.23	57.13%	0	3616	
473	袁家河	10kV-44	袁47	8434.84	487	75.94	15.59%	0	7120	
474	袁家河	10kV-44	袁48大馈	9664.56	558	187.75	33.65%	0	6412	
475	中河	10kV-41	中11	8434.84	487	323.28	66.38%	0	2836	
476	中河	10kV-41	中12	8434.84	487	96.24	19.76%	0	6768	
477	中河	10kV-41	中13	8434.84	487	188.16	38.64%	0	5176	
478	中河	10kV-41	中14	8434.84	487	129.84	26.66%	0	6186	
479	中河	10kV-41	中15	8434.84	487	332.64	68.30%	0	2674	
480	中河	10kV-41	中16	8434.84	487	17.16	3.52%	0	8138	
481	中河	10kV-41	中17	8434.84	487	42.84	8.80%	0	7693	
482	中河	10kV-41	中18	8434.84	487	91.92	18.87%	0	6843	
483	中河	10kV-42	中21	8434.84	487	101.88	20.92%	0	6670	
484	中河	10kV-42	中22	8434.84	487	159.84	32.82%	0	5667	
485	中河	10kV-42	中23	8434.84	487	32.52	6.68%	0	7871	
486	中河	10kV-42	中24	8434.84	487	233.76	48.00%	0	4386	

487	中河	10kV-43	中25	8434.84	487	277.8	57.04%	0	3624	
488	中河	10kV-43	中26	8434.84	487	306.96	63.03%	0	3118	
489	中河	10kV-43	中27	8434.84	487	131.16	26.93%	0	6163	
490	中河	10kV-43	中28	8434.84	487	261.48	53.69%	0	3906	
491	程林庄	10kV-4	733（DL）	6928	400	159.04	39.76%	0	4173	