

宝坻供电公司10千伏配电线路可开放容量信息表（2024年第四季度）

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
1	宝坻.八门城站	0	10kV-4	小甸八13	7274.4	400	245.23	61.31%	2023/12/22 20:02:00	0	1360	
2		0		西十村八14	7274.4	400	198.41	49.60%	2024/7/29 17:04:00	0	2211	
3		0		八门城八15	6546.96	360	213.10	59.20%	2024/7/31 13:19:00	0	1362	
4		0	10kV-5	箭杆河八21	6546.96	360	128.87	35.80%	2024/8/3 9:53:00	0	2894	
5		0		袁罗八22	7274.4	400	66.78	16.70%	2023/10/11 15:14:00	0	4605	
6		0		康庄八23	7274.4	400	159.24	39.81%	2024/8/5 15:04:00	0	2924	
7	宝坻.北申庄站	0	10kV-41	八间房申11	9147.558	503	88.99	17.69%	2023/12/21 8:13:00	0	5700	
8		0		南业东申12	9147.558	503	145.08	28.84%	2023/12/21 8:35:00	0	4680	
9		0		北辛庄申13	9147.558	503	99.79	19.84%	2024/4/15 15:50:00	0	5503	
10		0		张兰庄申14	9147.558	503	75.83	15.08%	2024/2/26 7:28:00	0	5939	
11		0		潭东申15	9147.558	503	83.15	16.53%	2023/12/20 21:02:00	0	5806	
12		0		艾家口申16	9147.558	503	92.41	18.37%	2024/6/19 10:18:00	0	5637	
13		0		李家口申21	9147.558	503	101.21	20.12%	2023/12/6 9:41:00	0	5477	
14		0		马厂申22	9147.558	503	8.68	1.72%	2023/12/4 12:15:00	0	7160	
15		0		西庄沽申23	9147.558	503	104.64	20.80%	2023/12/21 7:48:00	0	5415	
16		0	10kV-42	小陈申31	9147.558	503	135.66	26.97%	2024/4/19 10:51:00	0	4851	
17		0		南庄申32	9147.558	503	0.00	0.00%	2024/6/19 0:00:00	0	7318	
18		0		老艾口申33	9147.558	503	42.01	8.35%	2023/12/21 7:11:00	0	6554	
19		0		苗家庄申34	9147.558	503	83.04	16.51%	2023/12/7 15:18:00	0	5808	
20		0	10kV-43	埝北村申41	9147.558	503	222.20	44.18%	2024/6/22 14:14:00	0	3277	
21		0		车辋村申42	9147.558	503	114.22	22.71%	2024/4/15 15:50:00	0	5241	
22		0		潭西申43	9147.558	503	0.00	0.00%	2023/10/24 0:00:00	0	7318	
23		0		小苑庄申44	9147.558	503	79.55	15.81%	2023/12/6 9:41:00	0	5871	
24		0		大赵庄申45	9147.558	503	108.38	21.55%	2023/12/21 16:54:00	0	5347	
25		0	10kV-44	张家庄申51	9147.558	503	72.64	14.44%	2023/12/21 7:35:00	0	5997	
26		0		张松申52	9147.558	503	0.00	0.00%	2024/5/27 0:00:00	0	7318	
27		0		工部申53	9147.558	503	159.55	31.72%	2024/4/19 10:51:00	0	4416	
28		0		佟家庄申54	9147.558	503	67.28	13.38%	2023/12/21 8:05:00	0	6094	
29		0		窑上村申55	9147.558	503	72.88	14.49%	2023/12/21 7:04:00	0	5993	
30		0		伍麻村申56	9147.558	503	70.43	14.00%	2023/12/21 7:39:00	0	6037	
31		0		边家庄申61	9147.558	503	46.67	9.28%	2023/12/20 17:51:00	0	6469	
32		0		北芮村申62	9147.558	503	37.32	7.42%	2023/11/26 15:22:00	0	6639	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
33	宝坻.菜园站	0	10kV-4	韩庄园13	6546.96	360	124.98	34.72%	2023/11/15 17:28:00	0	2965	
34		0		高四台园14	9147.558	503	379.87	75.52%	2023/12/22 17:18:00	0	410	
35		0		区东园15	6546.96	360	285.00	79.17%	2023/12/28 9:48:00	0	55	
36		0		庞家湾园16	6546.96	360	166.82	46.34%	2023/10/23 17:38:00	0	2204	
37		0	10kV-5	林场园23	9147.558	503	117.78	23.41%	2023/12/27 13:57:00	0	5176	
38		0		吴家牌园24	9147.558	503	291.80	58.01%	2024/6/13 17:28:00	0	2011	
39		0		华尖园25	9147.558	503	106.53	21.18%	2024/7/24 12:09:00	0	5381	
40		0		区西园26	9147.558	503	149.59	29.74%	2024/6/20 16:20:00	0	4598	
41	宝坻.城东站	0	10kV-41	钰华东11	8547.42	470	234.11	49.81%	2023/12/21 9:39:00	0	2580	
42		0		区委二东12	8547.42	470	321.05	68.31%	2024/6/26 10:59:00	0	999	
43		0		顺驰东13	8547.42	470	291.96	62.12%	2024/7/12 10:04:00	0	1528	
44		0		泰富东14	8547.42	470	197.54	42.03%	2023/12/20 17:13:00	0	3246	
45		0		金玉一东15	8547.42	470	112.44	23.92%	2024/7/23 20:20:00	0	4793	
46		0		怡锦一东16	9729.51	535	12.22	2.28%	2024/7/21 9:16:00	0	7561	
47		0		玉六园东17	9729.51	535	119.21	22.28%	2024/7/21 20:41:00	0	5616	
48		0	10kV-42	双站路东23	9729.51	535	56.88	10.63%	2024/7/23 20:30:00	0	6749	
49		0		怡锦二东27	9729.51	535	0.62	0.12%	2024/7/14 0:08:00	0	7772	
50		0	10kV-44	龙熙东31	6546.96	360	247.74	68.82%	2024/7/10 21:35:00	0	732	
51		0		玺悦Ⅱ东32	9729.51	535	3.96	0.74%	2023/10/16 8:09:00	0	7712	
52		0		金玉二东33	8547.42	470	63.12	13.43%	2024/7/23 20:39:00	0	5690	
53				玺悦Ⅰ东34	9729.51	535	4.04	0.76%	2024/7/24 2:25:00	0	7710	
54		0		苑北东35	8547.42	470	101.27	21.55%	2024/7/29 10:07:00	0	4996	
55		0		广电二东36	8547.42	470	312.09	66.40%	2024/7/29 11:10:00	0	1162	
56		0		祥和东37	8547.42	470	251.96	53.61%	2024/7/23 20:17:00	0	2256	
57	宝坻.城关站	0	10kV-4	宝鑫I111	7274.4	400	269.97	67.49%	2024/7/19 21:15:00	0	910	
58		0	10kV-4	城关乡112	6546.96	360	286.44	79.57%	2024/7/23 21:11:00	0	28	
59		0	10kV-4	海滨115	6546.96	360	127.44	35.40%	2024/2/22 11:12:00	0	2920	
60		0	10kV-5	宝鑫II122	7274.4	400	70.54	17.63%	2024/7/23 21:06:00	0	4537	
61		0	10kV-5	城关镇II124	6546.96	360	265.00	73.61%	2024/7/30 15:25:00	0	418	
62		0	10kV-5	城关镇II125	6546.96	360	281.61	78.22%	2024/7/24 12:17:00	0	116	
63		0	10kV-4	工贸城13	6546.96	360	139.53	38.76%	2023/11/20 17:08:00	0	2700	
64		0	10kV-4	瑞祥城14	7274.4	400	236.37	59.09%	2024/7/24 10:53:00	0	1521	
65		0	10kV-5	霍各庄城21	6546.96	360	0.00	0.00%	2023/10/20 0:00:00	0	5238	
66		0	10kV-5	铸件城23	6546.96	360	272.70	75.75%	2024/7/23 14:52:00	0	278	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
67	宝坻.城南站	0	10kV-41	帝景南11	8547.42	470	191.57	40.76%	2024/7/23 19:20:00	0	3354	
68		0		潮阳花园南12	8547.42	470	118.28	25.17%	2024/9/29 9:37:00	0	4687	
69		0		嘉兴园南13	8547.42	470	266.26	56.65%	2023/12/10 15:38:00	0	1996	
70		0		金和园南14	8547.42	470	112.67	23.97%	2024/7/23 20:54:00	0	4789	
71		0		宝境南15	8547.42	470	258.04	54.90%	2023/11/23 20:14:00	0	2145	
72		0		万兆南16	8547.42	470	284.88	60.61%	2024/7/21 20:51:00	0	1657	
73		0		吾悦一南17	8547.42	470	228.31	48.58%	2023/12/13 10:27:00	0	2686	
74		0		原筑一南18	8547.42	470	147.01	31.28%	2024/7/23 20:49:00	0	4164	
75		0	10kV-42 10kV-43	体育馆南23	8547.42	470	167.76	35.69%	2024/7/24 11:50:00	0	3787	
76		0		观潮园南24	8547.42	470	65.56	13.95%	2024/8/30 21:18:00	0	5646	
77		0		润和南25	8547.42	470	284.03	60.43%	2023/12/13 10:12:00	0	1673	
78		0		泰达南26	8547.42	470	182.21	38.77%	2023/12/5 11:36:00	0	3524	
79		0		北岸南27	8547.42	470	108.23	23.03%	2024/7/23 20:36:00	0	4870	
80		0		馨和南28	8547.42	470	286.79	61.02%	2024/7/23 18:51:00	0	1622	
81		0		翰墨园南29	6546.96	360	43.75	12.15%	2023/12/21 18:00:00	0	4442	
82		0		吾悦二南30	8547.42	470	190.13	40.45%	2023/11/23 20:18:00	0	3380	
83		0		原筑二南31	8547.42	470	143.17	30.46%	2024/7/23 21:58:00	0	4234	
84	宝坻.城西站	0	10kV-4	三岔口116	9147.558	503	24.24	4.82%	2023/12/26 8:46:00	0	6877	
85		0		天宝甲西13	6546.96	360	239.20	66.44%	2024/8/17 17:31:00	0	887	
86		0		高家庄西14	9147.558	503	139.44	27.72%	2023/11/8 17:09:00	0	4782	
87		0		宝中道西15	9729.51	535	36.08	6.74%	2023/12/24 10:34:00	0	7127	
88		0		中关村一西17	9729.51	535	76.24	14.25%	2024/6/19 9:01:00	0	6397	
89		0	10kV-5	四中西23	8547.42	470	134.72	28.66%	2024/5/16 17:45:00	0	4388	
90		0		中关村南西24	9729.51	535	20.00	3.74%	2024/9/9 10:29:00	0	7420	
91		0		牛道口东西25	6546.96	360	224.00	62.22%	2024/9/11 12:25:00	0	1164	
92		0		星源西26	9147.558	503	298.48	59.34%	2023/12/21 10:17:00	0	1890	
93		0		天宝乙西27	6546.96	360	225.36	62.60%	2023/12/6 9:07:00	0	1139	
94		0	10kV-41	小刘坡白11	6546.96	360	215.12	59.75%	2024/5/26 16:07:00	0	1325	
95		0		晋铝白12	9147.558	503	401.67	79.85%	2024/9/9 14:39:00	0	13	
96		0		无纺白13	8547.42	470	245.00	52.13%	2024/5/13 17:10:00	0	2382	
97		0		小杨庄白14	8547.42	470	287.63	61.20%	2023/12/11 9:07:00	0	1607	
98		0		贝特瑞白15	9147.558	503	147.04	29.23%	2023/10/30 17:18:00	0	4644	
99		0		盟固利白16	9729.51	535	365.61	68.34%	2024/5/14 22:01:00	0	1135	
100		0		孙校白17	9147.558	503	202.20	40.20%	2024/5/17 13:30:00	0	3641	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
101	宝坻.大白庄站	0		园二路白18	9147.558	503	398.12	79.15%	2024/5/13 18:11:00	0	78	
102		0	10kV-42	首高白21	9147.558	503	382.97	76.14%	2024/8/16 11:37:00	0	353	
103		0		九贸白22	9147.558	503	268.56	53.39%	2024/5/13 17:25:00	0	2434	
104		0		嘉诺缘白23	8547.42	470	371.98	79.14%	2024/5/13 17:35:00	0	73	
105		0		八道沽白24	6546.96	360	178.77	49.66%	2024/3/29 12:08:00	0	1986	
106		0		勇猛白25	8547.42	470	234.48	49.89%	2024/5/13 17:10:00	0	2574	
107		0		天普白26	9729.51	535	14.55	2.72%	2024/5/13 18:10:00	0	7519	
108		0		东皋一白27	9729.51	535	370.05	69.17%	2024/5/13 17:01:00	0	1054	
109		0		彭元白28	9147.558	503	224.35	44.60%	2024/5/13 18:05:00	0	3238	
110	宝坻.大口电站	0	10kV-4	程马庄屯11	9147.558	503	98.44	19.57%	2024/7/19 20:55:00	0	5528	
111		0		大薄甸屯12	9147.558	503	0.00	0.00%	2024/6/11 0:00:00	0	7318	
112		0		大五登屯13	6546.96	360	201.45	55.96%	2023/11/1 6:59:00	0	1574	
113		0		大口屯镇屯14	6546.96	360	223.95	62.21%	2024/7/24 16:42:00	0	1165	
114		0		屯开发屯15	9147.558	503	23.73	4.72%	2024/7/29 12:11:00	0	6886	
115		0	10kV-5	天骄屯21	9147.558	503	281.78	56.02%	2024/7/24 10:57:00	0	2194	
116		0		大口屯东屯22	9147.558	503	53.26	10.59%	2023/12/16 14:38:00	0	6349	
117		0		尹家铺屯23	6546.96	360	169.45	47.07%	2023/10/31 7:49:00	0	2156	
118		0		镇东屯24	9147.558	503	0.00	0.00%	2023/10/24 0:00:00	0	7318	
119		0	10kV-4	新安镇214	7274.4	400	148.08	37.02%	2024/6/19 22:43:00	0	3127	
120	宝坻.大钟庄站	0		盛松I钟11	7274.4	400	196.88	49.22%	2024/6/19 22:37:00	0	2239	
121		0		宝芝钟12	7274.4	400	251.55	62.89%	2024/6/19 22:40:00	0	1245	
122		0		何仇钟13	7274.4	400	221.14	55.29%	2024/6/19 22:42:00	0	1798	
123		0	10kV-5	盛松II钟21	7274.4	400	137.58	34.40%	2024/6/27 14:19:00	0	3317	
124		0		工业园区钟22	6546.96	360	171.45	47.63%	2024/6/26 18:31:00	0	2120	
125		0		冯庄水钟23	7274.4	400	317.82	79.46%	2024/1/4 16:35:00	0	40	
126		0		钟芝钟24	7274.4	400	44.65	11.16%	2024/6/26 18:34:00	0	5008	
127	宝坻.东老口站	0	10kV-4	老鸦口老12	7274.4	400	64.82	16.21%	2023/10/2 9:38:00	0	4641	
128		0		精密老13	6546.96	360	178.41	49.56%	2024/7/24 13:59:00	0	1993	
129		0		珠江老14	6546.96	360	126.95	35.26%	2024/7/20 13:07:00	0	2929	
130		0		农场老15	6546.96	360	152.03	42.23%	2024/7/18 13:27:00	0	2473	
131		0	10kV-5	牛家牌老21	6546.96	360	148.95	41.38%	2024/9/10 8:52:00	0	2529	
132		0		孙庄老22	6546.96	360	72.19	20.05%	2024/7/20 5:31:00	0	3925	
133		0		前坨老23	6546.96	360	213.29	59.25%	2024/7/24 9:00:00	0	1359	
134		0		东滨老24	6546.96	360	15.30	4.25%	2023/12/16 4:38:00	0	4959	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
135	宝坻.尔王庄站	0	10kV-41	李家河尔11	6546.96	360	140.35	38.99%	2024/7/23 13:31:00	0	2685	
136		0		郑贵庄尔12	9147.558	503	50.96	10.13%	2024/1/31 13:46:00	0	6391	
137		0		尔辛庄尔13	6546.96	360	51.86	14.40%	2024/1/26 10:06:00	0	4295	
138		0		东安子尔15	6546.96	360	134.88	37.47%	2024/7/23 22:01:00	0	2785	
139		0	10kV-42	黄花淀尔21	6546.96	360	86.54	24.04%	2024/8/15 13:33:00	0	3664	
140		0		小宝庄尔23	6546.96	360	285.17	79.21%	2024/7/19 13:15:00	0	51	
141		0	10kV-43	潘套尔25	6546.96	360	243.46	67.63%	2024/3/31 8:11:00	0	810	
142		0		小董庄尔26	6546.96	360	66.88	18.58%	2024/7/19 20:46:00	0	4021	
143	宝坻.海滨站	0	10kV-41	大吴路海11	9729.51	535	131.38	24.56%	2023/11/8 10:01:00	0	5394	
144		0		张古海12	6546.96	360	230.56	64.04%	2024/4/13 8:08:00	0	1045	
145		0		前五里海13	9147.558	503	64.92	12.91%	2024/7/30 23:32:00	0	6137	
146		0		剑桥Ⅱ海14	8547.42	470	266.86	56.78%	2023/11/8 17:37:00	0	1985	
147		0		翡翠Ⅱ海15	9729.51	535	111.87	20.91%	2024/7/23 21:08:00	0	5749	
148		0		东城海16	9147.558	503	132.88	26.42%	2023/12/21 9:52:00	0	4901	
149		0	10kV-42	区医院海21	8547.42	470	50.47	10.74%	2024/7/23 19:51:00	0	5920	
150		0		白龙港海22	6546.96	360	186.47	51.80%	2023/11/8 17:38:00	0	1846	
151		0		小刘庄海23	6546.96	360	239.93	66.65%	2023/11/8 17:00:00	0	874	
152		0		剑桥Ⅰ海24	8547.42	470	244.99	52.13%	2024/7/23 20:41:00	0	2383	
153		0		翡翠Ⅰ海25	8547.42	470	152.72	32.49%	2024/7/23 21:42:00	0	4060	
154		0		西城海26	9147.558	503	222.22	44.18%	2024/7/21 19:16:00	0	3277	
155		0	10kV-4	黑狼口黑11	6546.96	360	198.53	55.15%	2023/12/19 17:49:00	0	1627	
156		0		老庄子黑12	9147.558	503	200.08	39.78%	2024/5/19 13:20:00	0	3679	
157		0		农场黑13	9147.558	503	126.29	25.11%	2024/7/23 22:09:00	0	5021	
158		0		塑料一黑14	9147.558	503	136.41	27.12%	2024/8/14 10:08:00	0	4837	
159	宝坻.黑狼口站	0	10kV-5	塑料二黑21	9147.558	503	108.17	21.51%	2024/8/14 9:24:00	0	5351	
160		0		久大黑22	6546.96	360	132.31	36.75%	2023/10/25 13:33:00	0	2831	
161		0		糙甸乡黑23	6546.96	360	192.54	53.48%	2024/4/24 11:56:00	0	1736	
162		0		发达纸厂黑24	6546.96	360	120.91	33.59%	2023/10/6 23:31:00	0	3039	
163		0	10kV-42	陈塘欢19	9147.558	503	185.80	36.94%	2023/12/25 14:57:00	0	3939	
164		0		高康马欢20	9147.558	503	132.34	26.31%	2024/7/17 6:18:00	0	4911	
165		0		水流庄欢21	9147.558	503	279.00	55.47%	2024/4/17 15:43:00	0	2244	
166		0	10kV-43	五道沽欢23	9147.558	503	5.00	0.99%	2024/4/17 15:46:00	0	7227	
167		0		李宦庄欢24	9147.558	503	137.05	27.25%	2024/5/13 13:19:00	0	4826	
168		0		曹家沽欢25	9147.558	503	70.00	13.92%	2024/4/17 15:51:00	0	6045	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
169	宝坻.欢喜庄站	0		周家庄欢26	9147.558	503	212.35	42.22%	2023/12/21 16:12:00	0	3456	
170		0	10kV-44	后辛欢27	9147.558	503	188.09	37.39%	2023/12/20 17:34:00	0	3897	
171		0		回庄欢28	9147.558	503	338.38	67.27%	2024/2/28 8:50:00	0	1164	
172		0		工业园欢29	9147.558	503	395.51	78.63%	2024/3/14 14:24:00	0	125	
173		0		尹庄欢30	9147.558	503	1.23	0.24%	2023/10/3 2:19:00	0	7296	
174		0		清白沽欢31	9147.558	503	98.61	19.61%	2024/4/20 9:37:00	0	5525	
175		0		南辛码欢33	9147.558	503	174.55	34.70%	2024/1/23 13:33:00	0	4144	
176		0		葫芦窝欢34	9147.558	503	257.90	51.27%	2024/8/6 13:21:00	0	2628	
177		0		杜家台黄11	9147.558	503	177.26	35.24%	2024/4/12 9:42:00	0	4094	
178	宝坻.黄庄站	0	10kV-41	东走线黄12	9147.558	503	114.73	22.81%	2023/12/23 17:08:00	0	5232	
179		0		南燕东黄13	9147.558	503	0.00	0.00%	2024/6/19 0:00:00	0	7318	
180		0		张头窝东黄14	9147.558	503	1.24	0.25%	2023/10/17 10:52:00	0	7296	
181		0		小甸西黄15	9147.558	503	0.00	0.00%	2024/6/6 0:00:00	0	7318	
182		0		鲁家铺黄16	9147.558	503	229.32	45.59%	2023/11/9 9:12:00	0	3148	
183		0		水流东黄21	9147.558	503	43.66	8.68%	2024/2/2 5:38:00	0	6524	
184		0		黄庄北黄22	9147.558	503	0.00	0.00%	2023/10/24 0:00:00	0	7318	
185		0	10kV-42	大塔沽黄31	9147.558	503	8.80	1.75%	2024/5/21 5:17:00	0	7158	
186		0		郭庄子黄32	9147.558	503	135.08	26.86%	2024/3/2 16:22:00	0	4861	
187		0		苑家场黄33	9147.558	503	100.00	19.88%	2024/6/30 5:50:00	0	5500	
188		0		黄庄西黄34	9147.558	503	111.85	22.24%	2023/12/9 9:35:00	0	5284	
189		0	10kV-43	王木庄黄41	9147.558	503	27.50	5.47%	2024/4/13 7:03:00	0	6818	
190		0		西走线黄42	9147.558	503	0.00	0.00%	2023/10/1 0:00:00	0	7318	
191		0		张头窝西黄43	9147.558	503	133.43	26.53%	2023/10/13 6:41:00	0	4892	
192		0		黄庄东黄44	9147.558	503	180.46	35.88%	2023/12/21 6:29:00	0	4036	
193		0	10kV-44	前辛庄黄51	9147.558	503	66.43	13.21%	2023/12/13 15:14:00	0	6110	
194		0		小塔沽黄52	9147.558	503	144.40	28.71%	2023/11/25 11:50:00	0	4692	
195		0		南燕北黄53	9147.558	503	79.75	15.86%	2024/1/21 8:01:00	0	5868	
196		0		小甸东黄54	9147.558	503	110.62	21.99%	2023/12/19 13:37:00	0	5306	
197		0		王家铺黄55	9147.558	503	31.98	6.36%	2023/12/27 6:58:00	0	6736	
198		0		水流西黄61	9147.558	503	293.58	58.37%	2023/12/21 9:14:00	0	1979	
199		0		黄庄南黄62	9147.558	503	241.79	48.07%	2024/8/1 1:11:00	0	2921	
200		0		貉子沽黄63	9147.558	503	0.00	0.00%	2024/6/5 0:00:00	0	7318	
201		0		华苑112	7274.4	400	102.24	25.56%	2024/7/24 12:27:00	0	3960	
202		0		三中113	6546.96	360	119.52	33.20%	2024/7/24 10:40:00	0	3064	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
203	宝坻.开发区站	0	10kV-4	摩托车114	7274.4	400	55.44	13.86%	2024/1/24 10:10:00	0	4811	
204		0		景苑 I 116	5637.66	310	146.04	47.11%	2024/7/23 21:55:00	0	1854	
205		0		纸厂117	7274.4	400	81.60	20.40%	2023/10/26 8:26:00	0	4336	
206		0	10kV-5	县委122	6546.96	360	130.44	36.23%	2024/7/24 12:13:00	0	2865	
207		0		四小123	6546.96	360	278.80	77.44%	2024/3/21 17:23:00	0	167	
208		0		东区124	7274.4	400	128.88	32.22%	2024/7/23 19:53:00	0	3476	
209		0		香港园区125	7274.4	400	203.52	50.88%	2023/11/9 17:12:00	0	2118	
210		0		景苑II126	5637.66	310	98.28	31.70%	2023/10/9 16:18:00	0	2723	
211		0		党校127	6546.96	360	287.52	79.87%	2024/7/24 9:47:00	0	9	
212		0	10kV-4	西区区15	6546.96	360	236.76	65.77%	2023/11/23 17:21:00	0	932	
213	宝坻.口东站	0	10kV-41	口东园区 I 口1	6546.96	360	222.89	61.91%	2024/1/4 10:48:00	0	1184	
214		0		前齐口12	6546.96	360	161.89	44.97%	2024/9/14 12:15:00	0	2293	
215		0		园区西口13	9147.558	503	397.48	79.02%	2023/12/20 8:54:00	0	89	
216		0		工业东口14	9147.558	503	342.42	68.08%	2023/11/25 15:13:00	0	1091	
217		0	10kV-42	口东园区 II 口2	6546.96	360	262.97	73.05%	2024/6/21 11:28:00	0	455	
218		0		东辛口22	9147.558	503	106.35	21.14%	2024/9/14 12:09:00	0	5384	
219		0		园区南口23	9147.558	503	394.73	78.48%	2024/1/16 11:12:00	0	139	
220		0		工业北口24	9147.558	503	143.26	28.48%	2023/10/10 14:27:00	0	4713	
221		0	10kV-43	首端口25	9147.558	503	182.28	36.24%	2024/1/19 15:52:00	0	4003	
222		0		福礼口26	9147.558	503	1.05	0.21%	2024/3/7 20:58:00	0	7299	
223		0	10kV-44	爱康口31	9147.558	503	344.88	68.57%	2023/12/21 9:13:00	0	1046	
224		0		黄辛口32	9147.558	503	81.56	16.22%	2023/12/18 12:09:00	0	5835	
225		0		大张庄口33	9147.558	503	389.64	77.46%	2024/5/19 10:05:00	0	232	
226		0		潮阳东口34	9147.558	503	0.00	0.00%	2023/10/23 0:00:00	0	7318	
227	宝坻.莲子营站	0	10kV-41	莲唐一营11	9729.51	535	89.28	16.69%	2023/12/17 21:06:00	0	6160	
228		0		浩润营12	6546.96	360	265.67	73.80%	2023/10/19 16:01:00	0	406	
229		0		香坻营13	9729.51	535	44.51	8.32%	2024/7/28 21:54:00	0	6974	
230		0		西郝营14	9147.558	503	226.57	45.04%	2023/12/29 17:42:00	0	3198	
231		0	10kV-42	兴华营31	9147.558	503	243.38	48.39%	2023/10/19 10:00:00	0	2892	
232		0		津侨一营32	9729.51	535	2.47	0.46%	2023/12/4 21:09:00	0	7739	
233		0	10kV-43	莲唐二营41	9729.51	535	0.06	0.01%	2024/4/15 20:03:00	0	7783	
234		0		润悦营42	9729.51	535	28.37	5.30%	2024/7/23 21:34:00	0	7268	
235		0		万和营43	8547.42	470	83.80	17.83%	2024/6/25 12:04:00	0	5314	
236		0		小套营51	6546.96	360	215.07	59.74%	2023/12/21 15:44:00	0	1326	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
237		0	10kV-44	水岸营52	9729.51	535	164.90	30.82%	2024/7/23 20:31:00	0	4785	
238		0		官庄营53	6546.96	360	107.20	29.78%	2024/9/21 12:42:00	0	3288	
239		0		津侨二营54	9729.51	535	2.47	0.46%	2023/12/31 13:08:00	0	7739	
240	宝坻.林亭口站	0	10kV-4	张庄子林11	7274.4	400	133.04	33.26%	2023/12/28 16:44:00	0	3400	
241		0		大靳庄林12	7274.4	400	0	0.00%	2023/12/28 16:50:00	0	5820	
242		0		林亭口西林13	7274.4	400	144.61	36.15%	2023/12/26 17:44:00	0	3190	
243		0		科宝林14	7274.4	400	74.3	18.58%	2023/12/26 17:48:00	0	4468	
244		0		龙亭苑林15	7274.4	400	0	0.00%	2023/12/28 16:58:00	0	5820	
245		0	10kV-5	众河林21	7274.4	400	40.2	10.05%	2023/12/22 10:15:00	0	5088	
246		0		南五村林22	7274.4	400	253.13	63.28%	2023/12/22 10:21:00	0	1216	
247		0		林亭口林23	6546.96	360	169.34	47.04%	2023/12/22 10:24:00	0	2158	
248		0		季家庄林24	7274.4	400	7.73	1.93%	2023/12/22 10:27:00	0	5679	
249		0		轻集林25	7274.4	400	1.17	0.29%	2023/12/20 16:31:00	0	5798	
250		0	10kV-4	下五庄牛11	9147.558	503	286.41	56.94%	2023/12/27 16:46:00	0	2109	
251		0		塘头牛12	9147.558	503	148.59	29.54%	2024/5/8 18:14:00	0	4616	
252		0		庞庄牛13	9147.558	503	104.53	20.78%	2024/7/24 10:34:00	0	5417	
253		0		三赵牛14	7619.934	419	202.73	48.39%	2023/12/18 15:28:00	0	2409	
254		0	10kV-5	西四庄牛21	9147.558	503	171.80	34.15%	2024/7/29 14:53:00	0	4194	
255		0		高家深牛22	6546.96	360	160.08	44.47%	2024/7/23 20:15:00	0	2326	
256		0		高各庄牛23	9147.558	503	233.91	46.50%	2024/6/13 16:56:00	0	3064	
257		0		卢各庄牛24	9147.558	503	249.14	49.53%	2023/12/11 17:30:00	0	2787	
258		0		集利牛25	6546.96	360	150.00	41.67%	2024/6/11 13:23:00	0	2510	
259	宝坻.史各庄站	0	10kV-4	扬水站史11	6546.96	360	241.87	67.19%	2023/12/19 9:24:00	0	839	
260		0		西苑庄史12	6546.96	360	123.22	34.23%	2024/7/24 11:01:00	0	2997	
261		0		通威史13	6546.96	360	286.97	79.71%	2023/12/16 13:15:00	0	19	
262		0		宜城史14	6546.96	360	235.90	65.53%	2024/7/23 18:15:00	0	948	
263		0		朱孔史15	6546.96	360	239.41	66.50%	2024/7/23 20:17:00	0	884	
264		0		彪家店史16	9147.558	503	102.48	20.37%	2024/5/10 17:32:00	0	5454	
265		0	10kV-5	正大史21	6546.96	360	138.52	38.48%	2023/12/13 10:32:00	0	2719	
266		0		史各庄史22	6546.96	360	165.76	46.04%	2024/9/21 13:18:00	0	2223	
267		0		郭杨史23	6546.96	360	180.88	50.24%	2024/6/13 21:26:00	0	1948	
268		0		庞各庄史24	6546.96	360	281.60	78.22%	2024/7/4 17:41:00	0	116	
269		0		大刘辛史25	9147.558	503	268.42	53.36%	2024/6/13 17:13:00	0	2437	
270		0		屯东双11	6546.96	360	175.40	48.72%	2023/12/26 16:40:00	0	2048	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
271	宝坻.双王寺站	0	10kV-4	双唐一双12	9729.51	535	0.00	0.00%	2023/10/6 0:00:00	0	7784	
272		0		郝各庄双13	6546.96	360	234.72	65.20%	2024/9/18 12:08:00	0	969	
273		0		马家店双14	6546.96	360	265.65	73.79%	2023/12/21 15:21:00	0	406	
274		0	10kV-5	屯西双21	6546.96	360	167.87	46.63%	2023/12/20 17:44:00	0	2185	
275		0		南仁孚双22	9147.558	503	381.97	75.94%	2024/7/30 16:41:00	0	372	
276		0		新开口双23	6546.96	360	174.78	48.55%	2023/11/12 16:31:00	0	2059	
277		0		宝联双24	6546.96	360	167.32	46.48%	2024/1/18 9:46:00	0	2195	
278		0		双唐二双25	9729.51	535	95.57	17.86%	2023/12/16 19:11:00	0	6046	
279		0	10kV-41	东淀隋11	9147.558	503	285.61	56.78%	2023/12/28 16:39:00	0	2124	
280	宝坻.隋庄子站	0		大刘坡隋12	8547.42	470	259.96	55.31%	2024/7/8 13:40:00	0	2110	
281		0		迈克隋13	9729.51	535	303.62	56.75%	2024/5/30 16:04:00	0	2262	
282		0		腾飞隋14	9729.51	535	179.00	33.46%	2023/10/19 15:31:00	0	4528	
283		0	10kV-42	尔王庄隋21	6546.96	360	72.80	20.22%	2023/12/15 10:34:00	0	3914	
284		0		九园东隋22	9147.558	503	215.00	42.74%	2024/5/17 18:03:00	0	3408	
285		0		大白庄东隋23	8547.42	470	57.20	12.17%	2024/7/23 20:49:00	0	5798	
286		0		董塔隋24	6546.96	360	145.24	40.34%	2024/7/24 6:17:00	0	2596	
287		0	10kV-43	石材一隋25	9147.558	503	175.12	34.82%	2023/11/25 16:53:00	0	4133	
288		0		诺宝一隋26	9147.558	503	257.63	51.22%	2023/10/12 15:02:00	0	2633	
289		0		南李隋27	9147.558	503	208.11	41.37%	2024/7/23 13:47:00	0	3533	
290		0		轻纺隋28	8547.42	470	286.07	60.87%	2023/10/24 6:57:00	0	1636	
291		0	10kV-44	九园西隋32	6546.96	360	280.90	78.03%	2023/10/16 10:04:00	0	129	
292		0		大白庄西隋33	6546.96	360	193.47	53.74%	2023/11/30 13:55:00	0	1719	
293		0		大唐庄隋34	6546.96	360	276.00	76.67%	2023/12/14 10:54:00	0	218	
294		0		石材二隋35	9147.558	503	216.61	43.06%	2023/12/13 8:32:00	0	3379	
295		0		诺宝二隋36	9147.558	503	147.66	29.36%	2023/12/7 8:50:00	0	4633	
296		0		石材隋37	9147.558	503	119.93	23.84%	2023/11/26 8:15:00	0	5137	
297		0		新城隋38	9147.558	503	228.01	45.33%	2024/5/26 16:07:00	0	3171	
298		0	10kV-4	双盛太12	6546.96	360	228.48	63.47%	2024/5/8 12:37:00	0	1082	
299	宝坻.太平庄站	0		昌兴太13	6546.96	360	185.64	51.57%	2024/7/19 21:16:00	0	1862	
300		0		馨园 I 太14	9729.51	535	279.24	52.19%	2024/7/19 21:16:00	0	2705	
301		0		九中 I 太15	9729.51	535	249.24	46.59%	2024/7/23 21:24:00	0	3251	
302		0		润阳一太16	9729.51	535	75.60	14.13%	2024/7/23 21:44:00	0	6409	
303		0		津宝太17	6546.96	360	286.87	79.69%	2024/7/5 14:28:00	0	21	
304		0		宸宝太22	6546.96	360	88.08	24.47%	2023/10/18 8:35:00	0	3636	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
305		0	10kV-5	人防太23	6546.96	360	233.16	64.77%	2024/7/23 21:06:00	0	997	
306		0		馨园Ⅱ太24	9729.51	535	268.80	50.24%	2024/7/23 17:18:00	0	2895	
307		0		九中Ⅱ太25	9729.51	535	176.04	32.90%	2024/7/23 21:13:00	0	4582	
308		0		润阳二太26	9729.51	535	78.96	14.76%	2024/9/21 1:54:00	0	6348	
309		0		中专太27	6546.96	360	141.12	39.20%	2024/3/22 10:30:00	0	2671	
310	宝坻.王卜庄站	0	10kV-4	陈山王11	6546.96	360	166.42	46.23%	2024/9/14 10:36:00	0	2211	
311		0		王卜庄西王12	6546.96	360	157.46	43.74%	2023/12/21 17:12:00	0	2374	
312		0		大华王13	6546.96	360	114.42	31.78%	2024/9/7 17:16:00	0	3157	
313		0		方庄子王14	9147.558	503	100.32	19.94%	2024/7/23 20:28:00	0	5494	
314		0		赵二王15	9147.558	503	0.00	0.00%	2024/6/6 0:00:00	0	7318	
315		0		小赵王16	9147.558	503	80.02	15.91%	2024/5/13 16:44:00	0	5863	
316		0		何家庄王17	9147.558	503	208.65	41.48%	2024/1/9 9:59:00	0	3524	
317		0		司各庄王18	9147.558	503	110.58	21.98%	2023/12/24 8:58:00	0	5307	
318		0	10kV-5	砖厂王21	6546.96	360	46.88	13.02%	2024/7/23 18:19:00	0	4385	
319		0		北坛王22	9147.558	503	28.01	5.57%	2023/10/23 13:12:00	0	6809	
320		0		王卜庄东王23	6546.96	360	160.80	44.67%	2024/7/4 13:21:00	0	2313	
321		0		南家庄王24	9147.558	503	104.81	20.84%	2024/7/24 15:47:00	0	5412	
322		0		龙坛王25	9147.558	503	186.26	37.03%	2023/12/19 17:25:00	0	3931	
323		0		庞家庄王26	9147.558	503	401.78	79.88%	2023/12/19 16:30:00	0	11	
324		0		于街王27	6546.96	360	140.96	39.16%	2023/12/23 17:20:00	0	2674	
325		0		西泗王28	9147.558	503	151.54	30.13%	2024/9/11 13:10:00	0	4562	
326	宝坻.五里铺站	0	10kV-41	轧钢厂铺12	6546.96	360	134.71	37.42%	2024/7/24 11:39:00	0	2788	
327		0		石桥铺13	6546.96	360	152.83	42.45%	2024/8/23 17:21:00	0	2458	
328		0		杨家口铺14	6546.96	360	124.63	34.62%	2023/11/25 13:28:00	0	2971	
329		0		张台铺15	6546.96	360	176.77	49.10%	2024/9/11 10:00:00	0	2023	
330		0		泉州铺16	9147.558	503	97.09	19.30%	2024/1/22 12:53:00	0	5552	
331		0	10kV-42	畜牧局铺22	6546.96	360	283.64	78.79%	2024/7/24 12:30:00	0	79	
332		0		棉纺厂铺23	9147.558	503	361.15	71.80%	2024/7/12 10:04:00	0	750	
333		0	10kV-43	霍各庄铺25	6546.96	360	68.22	18.95%	2023/12/31 17:23:00	0	3997	
334		0		口东铺26	9147.558	503	143.55	28.54%	2023/12/18 12:09:00	0	4707	
335		0		金水Ⅰ铺28	8547.42	470	186.69	39.72%	2024/7/23 21:04:00	0	3443	
336		0	10kV-44	林海铺31	9729.51	535	173.18	32.37%	2024/9/28 18:54:00	0	4634	
337		0		北郝铺32	6546.96	360	114.29	31.75%	2024/7/21 23:30:00	0	3159	
338		0		大角甸铺33	9147.558	503	92.18	18.33%	2023/12/20 16:57:00	0	5642	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
339		0		监管所铺34	9147.558	503	283.18	56.30%	2024/7/24 12:43:00	0	2168	
340		0		金水Ⅱ铺38	8547.42	470	182.09	38.74%	2024/7/23 21:17:00	0	3526	
341	宝坻.小辛码站	0	10kV-4	欢喜小12	6546.96	360	48.96	13.60%	2024/4/25 14:36:00	0	4347	
342		0		黄庄小13	6546.96	360	180.32	50.09%	2024/7/18 5:17:00	0	1958	
343		0		苑洪桥小14	9147.558	503	126.24	25.10%	2023/11/24 6:45:00	0	5022	
344		0		辛庄南小15	9147.558	503	111.84	22.23%	2024/4/11 15:22:00	0	5284	
345		0	10kV-5	北里沽小21	6546.96	360	139.04	38.62%	2024/5/18 14:36:00	0	2709	
346		0		扬水站小22	6546.96	360	109.60	30.44%	2024/8/31 9:05:00	0	3244	
347	宝坻.新安镇站	0		小辛码小23	6546.96	360	163.36	45.38%	2024/6/16 13:37:00	0	2267	
348		0		马庄小24	9147.558	503	39.36	7.83%	2024/7/20 20:31:00	0	6602	
349		0		吴辛小25	9147.558	503	140.00	27.83%	2024/4/22 13:35:00	0	4772	
350	宝坻.新安镇站	0	10kV-41	于家口一安11	9147.558	503	39.00	7.75%	2023/12/21 19:37:00	0	6609	
351		0		王善庄一安12	9147.558	503	47.40	9.42%	2023/12/21 7:39:00	0	6456	
352		0		南业安13	9183.93	505	0.00	0.00%	2024/5/27 0:00:00	0	7347	
353		0		王庄安17	9147.558	503	343.40	68.27%	2024/1/23 11:02:00	0	1073	
354		0		木业安18	9147.558	503	394.58	78.45%	2024/7/24 12:54:00	0	142	
355		0	10kV-42	于家口二安21	9147.558	503	65.20	12.96%	2023/12/17 7:40:00	0	6132	
356		0		王善庄二安22	9147.558	503	55.10	10.95%	2023/12/20 19:38:00	0	6316	
357		0	10kV-43	曹口安27	9147.558	503	191.20	38.01%	2023/11/11 16:51:00	0	3841	
358		0		业西安28	9147.558	503	182.80	36.34%	2024/8/18 9:25:00	0	3994	
359	宝坻.新开口站	0	10kV-4	园区新11	6546.96	360	193.95	53.88%	2023/11/17 11:02:00	0	1710	
360		0		中粮新12	6546.96	360	53.79	14.94%	2023/11/17 11:00:00	0	4259	
361		0		种西新13	6546.96	360	250.79	69.66%	2023/11/15 10:22:00	0	677	
362		0		前寒河新14	7274.4	400	105.36	26.34%	2023/11/17 10:51:00	0	3903	
363		0		新开口东新15	6546.96	360	187.86	52.18%	2023/11/17 10:37:00	0	1821	
364		0	10kV-5	新开口西新21	6546.96	360	188.8	52.44%	2023/11/23 17:32:00	0	1804	
365		0		彭家务新22	6546.96	360	157.62	43.78%	2023/11/23 17:41:00	0	2371	
366		0		石辛庄新23	7274.4	400	132.54	33.14%	2023/11/23 17:43:00	0	3409	
367		0		洛水坨新24	7274.4	400	290	72.50%	2023/11/19 4:22:00	0	546	
368		0		新开口南新25	6546.96	360	78	21.67%	2023/11/23 17:46:00	0	3819	
369		0		大卦庄袁11	9147.558	503	91.79	18.25%	2023/12/21 17:53:00	0	5649	
370		0		刘兰袁12	9147.558	503	61.03	12.13%	2024/3/6 7:05:00	0	6208	
371		0		北王庄袁13	9147.558	503	148.30	29.48%	2023/10/26 7:03:00	0	4621	
372		0		金厂袁14	9147.558	503	159.60	31.73%	2023/12/21 7:46:00	0	4416	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
373	宝坻.袁罗站	0	10kV-41	东鲁沽袁15	9147.558	503	72.68	14.45%	2023/12/21 20:09:00	0	5996	
374		0		八二村袁16	9147.558	503	0.00	0.00%	2024/6/1 0:00:00	0	7318	
375		0		袁罗北袁21	9147.558	503	255.00	50.70%	2023/12/26 7:05:00	0	2681	
376		0		杨庄子袁22	9147.558	503	159.71	31.75%	2024/3/17 7:02:00	0	4414	
377		0		凌沿村袁23	9147.558	503	0.00	0.00%	2023/10/12 0:00:00	0	7318	
378		0		米四庄袁24	9147.558	503	0.00	0.00%	2024/6/1 0:00:00	0	7318	
379		0		大米北袁25	9147.558	503	159.38	31.69%	2024/6/26 13:15:00	0	4419	
380		0	10kV-42	宝芝麻窝袁31	9147.558	503	145.27	28.88%	2023/11/29 14:28:00	0	4676	
381		0		马郭村袁32	9147.558	503	117.68	23.40%	2023/12/21 7:20:00	0	5178	
382		0		岳家楼袁33	9147.558	503	96.55	19.20%	2024/4/16 12:24:00	0	5562	
383		0		王山南袁34	9147.558	503	105.53	20.98%	2024/4/1 15:25:00	0	5399	
384		0		康庄西袁35	9147.558	503	236.62	47.04%	2024/4/28 16:20:00	0	3015	
385		0	10kV-43	大米南袁41	9147.558	503	73.30	14.57%	2023/12/21 17:54:00	0	5985	
386		0		孔家庄袁42	9147.558	503	4.44	0.88%	2024/4/19 15:37:00	0	7237	
387		0		八一村袁43	9147.558	503	0.00	0.00%	2023/10/2 0:00:00	0	7318	
388		0		大钟庄袁44	9147.558	503	102.77	20.43%	2023/12/21 7:00:00	0	5449	
389		0		二米庄袁45	9147.558	503	150.71	29.96%	2023/11/29 7:14:00	0	4577	
390		0	10kV-44	米东袁51	9147.558	503	0.00	0.00%	2023/10/12 0:00:00	0	7318	
391		0		船窝村袁52	9147.558	503	234.65	46.65%	2023/10/25 15:24:00	0	3051	
392		0		大陈庄袁53	9147.558	503	63.62	12.65%	2023/12/25 14:37:00	0	6161	
393		0		勾家庄袁54	9147.558	503	94.80	18.85%	2023/11/13 17:30:00	0	5594	
394		0		焦王庄袁55	9147.558	503	17.94	3.57%	2024/3/17 18:28:00	0	6992	
395		0		后鲁沽袁56	9147.558	503	0.00	0.00%	2024/6/18 0:00:00	0	7318	
396		0		王山北袁61	9147.558	503	103.90	20.66%	2024/4/1 15:25:00	0	5429	
397		0		康庄东袁62	9147.558	503	236.22	46.96%	2024/4/28 16:20:00	0	3022	
398		0		张五庄袁63	9147.558	503	44.59	8.87%	2024/4/21 16:13:00	0	6507	
399		0		杨木村袁64	9147.558	503	128.64	25.57%	2024/6/15 13:36:00	0	4979	
400		0		厂家窝袁65	9147.558	503	179.45	35.68%	2023/12/26 15:59:00	0	4055	
401		0	10kV-41	天祥 I 岳11	6546.96	360	186.48	51.80%	2023/12/21 15:20:00	0	1846	
402		0		天恒岳12	8547.42	470	171.72	36.54%	2024/2/24 17:20:00	0	3715	
403		0		黑豆窝岳13	6546.96	360	83.66	23.24%	2023/10/18 8:34:00	0	3716	
404		0		天跃一岳14	9147.558	503	225.50	44.83%	2023/12/20 8:58:00	0	3217	
405		0		蝶恋一岳15	9729.51	535	329.73	61.63%	2024/7/23 21:23:00	0	1787	
406		0		鑫海一岳16	9729.51	535	9.49	1.77%	2023/12/30 10:11:00	0	7611	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
407	宝坻.岳家庄站	0	10kV-42	赵各庄岳17	6546.96	360	156.78	43.55%	2024/1/22 8:42:00	0	2386	
408		0		天宝 I 岳19	6546.96	360	76.99	21.39%	2024/3/18 10:56:00	0	3837	
409		0		鑫海二岳20	9729.51	535	4.39	0.82%	2024/8/10 1:58:00	0	7704	
410		0		沟头岳21	6546.96	360	240.47	66.80%	2023/12/19 10:17:00	0	864	
411		0		宝旺岳22	9147.558	503	386.02	76.74%	2024/6/13 1:13:00	0	298	
412		0	10kV-43	天跃二岳23	9147.558	503	291.27	57.91%	2024/8/29 16:20:00	0	2021	
413		0		松江 I 岳24	9729.51	535	381.10	71.23%	2024/7/29 16:17:00	0	853	
414		0		天祥 II 岳25	6546.96	360	284.12	78.92%	2024/1/19 10:13:00	0	71	
415		0	10kV-44	天宝 II 岳27	6546.96	360	165.24	45.90%	2023/12/20 10:26:00	0	2233	
416		0		牛道口岳28	6546.96	360	183.69	51.03%	2023/11/17 15:49:00	0	1897	
417		0		黄沙务岳29	9147.558	503	318.87	63.39%	2023/12/19 10:28:00	0	1519	
418		0		宝富岳30	9147.558	503	394.55	78.44%	2024/6/27 9:51:00	0	143	
419		0		石佛营岳31	6546.96	360	203.56	56.54%	2024/6/13 21:13:00	0	1536	
420		0		松江 II 岳32	9729.51	535	287.58	53.75%	2023/12/21 9:39:00	0	2554	
421		0		蝶恋二岳33	9729.51	535	354.20	66.21%	2024/7/23 20:51:00	0	1342	
422	宝坻.中关村站	0	10kV-41	曙光一关11	9729.51	535	112.44	21.02%	2023/12/21 11:38:00	0	5739	
423		0		元中一关12	9729.51	535	1.17	0.22%	2024/1/25 11:25:00	0	7762	
424		0		于家观关13	6546.96	360	217.72	60.48%	2023/11/20 17:27:00	0	1278	
425		0		宝善一关14	9729.51	535	43.53	8.14%	2024/4/19 15:30:00	0	6992	
426		0		宝康一关15	8547.42	470	24.34	5.18%	2024/6/24 11:16:00	0	6395	
427		0		宝德一关16	9729.51	535	42.33	7.91%	2023/10/24 16:00:00	0	7014	
428		0		梦泽一关21	9729.51	535	103.67	19.38%	2024/7/23 21:19:00	0	5898	
429		0		科景轩一关22	9729.51	535	275.03	51.41%	2024/7/23 17:41:00	0	2782	
430		0		宝志一关23	9729.51	535	139.92	26.15%	2024/3/12 16:49:00	0	5239	
431		0	10kV-42	元中二关31	9729.51	535	1.16	0.22%	2023/10/1 21:42:00	0	7762	
432		0		宝善二关32	9729.51	535	57.91	10.82%	2024/6/4 15:20:00	0	6730	
433		0		科景轩二关33	9729.51	535	153.13	28.62%	2023/11/24 9:01:00	0	4999	
434		0		宝志二关34	9729.51	535	55.00	10.28%	2024/5/13 15:38:00	0	6783	
435		0	10kV-43	曙光二关41	9729.51	535	316.21	59.11%	2023/12/21 10:42:00	0	2033	
436		0		宝康二关42	8547.42	470	12.18	2.59%	2023/12/20 17:09:00	0	6616	
437		0		宝德二关43	9729.51	535	31.11	5.81%	2023/11/30 9:00:00	0	7218	
438		0		梦泽二关44	9729.51	535	283.90	53.06%	2024/7/21 16:25:00	0	2621	
439		0	10kV-41	嵘园 I 216	8547.42	470	15.49	3.29%	2024/7/31 12:05:00	0	6556	
440		0		顺园 I 217	8547.42	470	60.39	12.85%	2024/3/21 20:34:00	0	5740	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
441	宝坻.周良庄站	0	10kV-42 10kV-43	财大 I 218	8547.42	470	371.23	78.99%	2023/12/20 18:44:00	0	87	
442		0		财大 II 231	8547.42	470	365.39	77.74%	2024/9/19 12:14:00	0	193	
443		0		顺园 II 232	8547.42	470	37.08	7.89%	2023/12/15 7:43:00	0	6164	
444		0		嵘园 II 233	8547.42	470	316.39	67.32%	2024/3/22 22:58:00	0	1084	
445		0	10kV-41	嘉园 I 周11	8547.42	470	247.20	52.60%	2023/12/16 20:27:00	0	2342	
446		0		九园南周12	8547.42	470	109.28	23.25%	2024/8/3 12:48:00	0	4851	
447		0		东皋周13	10311.462	567	2.38	0.42%	2024/1/16 0:00:00	0	8206	
448		0		森林岛 I 周14	8547.42	470	177.38	37.74%	2024/2/27 9:02:00	0	3612	
449		0	10kV-42 10kV-43	康园 I 周15	8547.42	470	24.76	5.27%	2024/7/20 14:18:00	0	6388	
450		0		嘉园 II 周21	8547.42	470	44.75	9.52%	2023/12/21 10:00:00	0	6024	
451		0		香江周22	8547.42	470	241.71	51.43%	2024/7/14 14:47:00	0	2442	
452		0		九园北周23	8547.42	470	58.89	12.53%	2023/12/21 16:53:00	0	5767	
453		0	10kV-43	森林岛 II 周24	8547.42	470	187.38	39.87%	2024/7/23 21:23:00	0	3430	
454		0		安盟周34	8547.42	470	0.98	0.21%	2023/11/7 13:34:00	0	6820	
455	宝坻.马家店站	0	10kV-41	后寒河马11	6546.96	360	111.56	30.99%	2024/6/5 19:52:00	0	3209	
456		0		刘举人马12	6546.96	360	111.94	31.10%	2024/6/26 17:42:00	0	3202	
457		0		天玺园马13	6546.96	360	115.87	32.19%	2024/7/20 20:57:00	0	3130	
458		0	10kV-42 10kV-43	烧角马31	6546.96	360	250.66	69.63%	2024/6/13 16:36:00	0	679	
459		0		西寨马41	6546.96	360	60.57	16.83%	2024/7/21 18:11:00	0	4136	
460		0		后六口马51	6546.96	360	94.29	26.19%	2024/9/8 17:51:00	0	3523	
461	宝坻.温泉城站	0	10kV-41	马营温11	6546.96	360	145.63	40.45%	2024/7/24 14:14:00	0	2589	
462		0		李台温12	9147.558	503	289.78	57.61%	2024/8/9 23:47:00	0	2048	
463		0		田邢庄温13	6546.96	360	67.50	18.75%	2024/7/24 5:38:00	0	4010	
464		0		香榭一温14	8547.42	470	94.29	20.06%	2024/5/22 17:26:00	0	5123	
465		0		橄榄树一温15	8547.42	470	0.44	0.09%	2024/6/7 4:05:00	0	6830	
466		0		邮政一温16	8547.42	470	178.21	37.92%	2024/6/14 11:37:00	0	3597	
467		0	10kV-43 10kV-44	菜家铺温41	6546.96	360	111.67	31.02%	2024/3/24 19:04:00	0	3207	
468		0		后五登温42	6546.96	360	133.34	37.04%	2024/7/27 23:00:00	0	2813	
469		0		香榭二温43	8547.42	470	138.66	29.50%	2024/5/22 17:02:00	0	4316	
470		0		四里港温51	6546.96	360	95.42	26.51%	2024/7/23 21:46:00	0	3502	
471		0		橄榄树二温52	8547.42	470	0.46	0.10%	2024/7/30 7:27:00	0	6830	
472		0		邮政二温53	8547.42	470	139.52	29.68%	2024/6/14 11:38:00	0	4301	