

滨海供电公司10千伏配电线路可开放容量信息表(2024年第四季度)

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1	安达	0	10kV-1	831	6928	400	278.32	69.58%	2024/3/25	0	721.90	
2		0		832	6928	400	95.898	23.97%	2024/7/23	0	3881.45	
3		0		833	6928	400	212.31	53.08%	2024/1/22	0	1865.28	
4		0		834	6928	400	216.99	54.25%	2024/1/24	0	1784.10	
5		0	10kV-2	841	6928	400	301.95	75.49%	2024/1/2	0	312.57	
6		0	10kV-3	845	6928	400	132.227	33.06%	2024/7/21	0	3252.23	
7		0		846	6928	400	165.04	41.26%	2024/2/21	0	2683.92	
8		0		848	6928	400	277.93	69.48%	2024/7/30	0	728.65	
9		0	10kV-4	851	6928	400	230.66	57.67%	2024/1/11	0	1547.30	
10		0		852	6928	400	102.148	25.54%	2024/7/24	0	3773.20	
11		0		853	6928	400	305.27	76.32%	2024/7/26	0	255.07	
12		0		854	6928	400	130.66	32.67%	2024/1/2	0	3279.30	
13		0		855	6928	400	128.906	32.23%	2024/7/29	0	3309.75	
14	宝山道	0	10kV-41	宝11	8833.2	510	60.85	11.93%	2024/7/29	0	6012.64	
15		0		宝12	8833.2	510	20.401	4.00%	2024/7/21	0	6713.21	
16		0		宝13	8833.2	510	59.44	11.66%	2024/6/28	0	6037.01	
17		0		宝14	8833.2	510	276.815	54.28%	2024/7/23	0	2272.12	
18		0		宝17	8833.2	510	143.507	28.14%	2024/7/23	0	4581.02	
19		0		宝18	8833.2	510	1.06	0.21%	2024/2/11	0	7048.29	
20		0	10kV-42	宝21	8833.2	510	132.252	25.93%	2024/7/1	0	4775.96	
21		0		宝22	9214.24	532	171.998	32.33%	2024/7/23	0	4392.39	
22		0		宝23	9214.24	532	186.419	35.04%	2024/7/23	0	4142.61	
23		0	10kV-43	宝25	8833.2	510	324.65	63.66%	2024/7/23	0	1443.62	
24		0	10kV-44	宝31	8833.2	510	116.776	22.90%	2024/7/24	0	5044.00	
25		0		宝32	8833.2	510	75.623	14.83%	2024/7/23	0	5756.77	
26		0		宝33	8833.2	510	228.275	44.76%	2024/7/30	0	3112.84	
27		0		宝34	8833.2	510	204.01	40.00%	2024/1/6	0	3533.18	
28		0		宝35	8833.2	510	170.943	33.52%	2024/7/23	0	4105.83	
29		0		宝36	8833.2	510	135.769	26.62%	2024/7/19	0	4715.04	
30		0		宝37	8833.2	510	98.837	19.38%	2024/7/23	0	5354.70	
31		0		茶11	6928	400	162.305	40.58%	2024/7/23	0	2731.28	
32		0		茶12	6928	400	312.656	78.16%	2024/7/5	0	127.20	
33		0		茶13	6928	400	52.734	13.18%	2024/7/29	0	4629.05	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
34	茶淀	0	10kV-41	茶14	6928	400	271.289	67.82%	2024/7/18	0	843.67	
35		0		茶15	6928	400	221.836	55.46%	2024/7/23	0	1700.20	
36		0		茶16	6928	400	296.13	74.03%	2024/6/21	0	413.38	
37		0		茶17	6928	400	95.273	23.82%	2024/7/23	0	3892.27	
38		0		茶18	6495	375	22.97	6.13%	2024/2/21	0	4798.18	
39		0	10kV-42	茶21	6928	400	71.484	17.87%	2024/7/23	0	4304.30	
40		0		茶22	6928	400	42.891	10.72%	2024/7/23	0	4799.53	
41		0		茶23	6928	400	187.852	46.96%	2024/7/23	0	2288.80	
42		0		茶24	6928	400	196.76	49.19%	2024/3/22	0	2134.55	
43		0	10kV-43	茶25	6928	400	256.76	64.19%	2024/6/30	0	1095.35	
44		0		茶26	6928	400	275.742	68.94%	2024/7/24	0	766.55	
45		0		茶27	6928	400	161.84	40.46%	2024/2/25	0	2739.40	
46		0		茶28	6928	400	279.609	69.90%	2024/7/5	0	699.57	
47	厂东路	0	10kV-41	厂13	9006.4	520	0.00	0.00%	2024/6/1	0	7205.12	
48		0		厂14	8486.8	490	45.88	9.36%	2024/1/22	0	5994.82	
49		0		厂15	10045.6	580	98.64	17.01%	2024/3/20	0	6328.12	
50		0	10kV-42	厂21	9006.4	520	187.78	36.11%	2024/6/28	0	3952.81	
51		0		厂22	10392	600	3.34	0.56%	2024/6/2	0	8255.75	
52		0		厂23	9006.4	520	138.19	26.57%	2024/6/12	0	4811.74	
53		0		厂24	17320	1000	305.93	30.59%	2024/6/18	0	8557.24	
54		0	10kV-43	厂34	10045.6	580	0.00	0.00%	2024/6/1	0	8036.48	
55		0		厂35	9352.8	540	42.891	7.94%	2024/7/30	0	6739.37	
56		0	10kV-44	厂41	17320	1000	279.27	27.93%	2024/6/26	0	9019.01	
57		0		厂42	17320	1000	13.48	1.35%	2024/1/22	0	13622.58	
58		0		厂43	6928	400	19.69	4.92%	2024/1/29	0	5201.40	
59	潮立寺	0	10kV-4	潮10	6928	400	63.032	15.76%	2024/7/23	0	4450.69	
60		0		潮12	6928	400	32.80	8.20%	2024/2/4	0	4974.34	
61		0		潮13	6928	400	195.688	48.92%	2024/7/23	0	2153.08	
62		0		潮14	6928	400	106.392	26.60%	2024/7/23	0	3699.69	
63		0		潮15	6928	400	158.188	39.55%	2024/7/29	0	2802.58	
64		0		潮16	6928	400	304.438	76.11%	2024/7/23	0	269.53	
65		0		潮17	6928	400	252.876	63.22%	2024/7/20	0	1162.59	
66		0		潮18	6928	400	0.22	0.06%	2024/6/1	0	5538.59	
67		0		潮19	6928	400	119.05	29.76%	2024/3/26	0	3480.49	
68		0		潮20	6928	400	315.485	78.87%	2024/7/23	0	78.20	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
69	潮日寸	0	10kV-5	潮30	6928	400	119.99	30.00%	2024/3/25	0	3464.26	
70		0		潮32	6928	400	138.74	34.68%	2024/3/26	0	3139.51	
71		0		潮33	6928	400	271.626	67.91%	2024/7/23	0	837.84	
72		0		潮34	6928	400	209.751	52.44%	2024/7/23	0	1909.51	
73		0		潮35	6928	400	318.032	79.51%	2024/7/23	0	34.09	
74		0		潮36	6928	400	109.907	27.48%	2024/7/23	0	3638.81	
75		0		潮37	6928	400	51.78	12.95%	2024/6/20	0	4645.54	
76		0		潮38	6928	400	213.97	53.49%	2024/7/24	0	1836.44	
77		0		潮39	5975.4	345	47.33	13.72%	2024/1/2	0	3960.58	
78		0		潮40	6928	400	288.032	72.01%	2024/7/23	0	553.69	
79	潮宗桥	0	10kV-4	宗11	6928	400	249.552	62.39%	2024/7/6	0	1220.16	
80		0		宗12	6928	400	191.41	47.85%	2024/3/24	0	2227.21	
81		0		宗14	6928	400	74.656	18.66%	2024/7/23	0	4249.36	
82		0		宗15	6928	400	19.08	4.77%	2024/1/14	0	5211.93	
83		0		宗16	6928	400	15.392	3.85%	2024/7/26	0	5275.81	
84		0	10kV-5	宗21	6928	400	0.00	0.00%	2024/6/1	0	5542.40	
85		0		宗22	6928	400	146.696	36.67%	2024/7/24	0	3001.63	
86		0		宗24	6928	400	139.608	34.90%	2024/7/23	0	3124.39	
87		0		宗26	6928	400	268.47	67.12%	2024/1/8	0	892.46	
88	崇义路	0	10kV-41	崇11	8660	500	143.927	28.79%	2024/7/23	0	4435.18	
89		0	10kV-43	崇31	8660	500	315.356	63.07%	2024/7/24	0	1466.03	
90	大丰路	0	10kV-43	丰31	6928	400	46.523	11.63%	2024/7/23	0	4736.62	
91		0		丰32	6928	400	133.594	33.40%	2024/7/23	0	3228.55	
92		0		丰33	6928	400	51.094	12.77%	2024/7/24	0	4657.45	
93		0		丰34	6928	400	166.758	41.69%	2024/7/23	0	2654.15	
94		0		丰35	6928	400	236.48	59.12%	2024/3/29	0	1446.50	
95		0		丰36	6928	400	88.83	22.21%	2024/6/27	0	4003.90	
96		0	10kV-44	丰41	6928	400	183.867	45.97%	2024/7/23	0	2357.82	
97		0		丰42	6928	400	170.16	42.54%	2024/6/20	0	2595.30	
98		0		丰43	6928	400	121.523	30.38%	2024/7/29	0	3437.62	
99		0		丰44	6928	400	219.141	54.79%	2024/7/23	0	1746.88	
100		0		丰45	6928	400	97.5	24.38%	2024/7/23	0	3853.70	
101		0	10kV-45	丰51	6928	400	83.086	20.77%	2024/7/23	0	4103.35	
102		0		丰52	6928	400	177.539	44.38%	2024/7/23	0	2467.42	
103		0		丰53	6928	400	94.10	23.53%	2024/3/17	0	3912.55	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
104		0		丰54	6928	400	88.828	22.21%	2024/7/23	0	4003.90	
105		0		丰55	6928	400	58.945	14.74%	2024/7/24	0	4521.47	
106		0	10kV-46	丰61	6928	400	58.477	14.62%	2024/7/23	0	4529.58	
107		0		丰62	6928	400	140.508	35.13%	2024/7/24	0	3108.80	
108		0		丰63	6928	400	81.211	20.30%	2024/7/24	0	4135.83	
109		0		丰65	6928	400	88.83	22.21%	2024/6/27	0	4003.90	
110		0		丰65	6928	400	88.83	22.21%	2024/6/27	0	4003.90	
111	大学城	0	10kV-41	大13	6928	400	181.79	45.45%	2024/6/11	0	2393.76	
112		0		大15	6928	400	197.27	49.32%	2024/6/15	0	2125.65	
113		0		大16	6928	400	286.752	71.69%	2024/7/23	0	575.86	
114		0		大17	6928	400	315.576	78.89%	2024/7/21	0	76.62	
115		0		大18	6928	400	38.68	9.67%	2024/7/30	0	4872.46	
116		0	10kV-42	大21	6928	400	201.82	50.46%	2024/6/13	0	2046.88	
117		0		大22	6928	400	49.102	12.28%	2024/7/24	0	4691.95	
118		0		大24	6928	400	319.848	79.96%	2024/7/21	0	2.63	
119	大众园	0	10kV-41	大25	6928	400	268.34	67.09%	2024/6/13	0	894.75	
120		0		众11	17320	1000	478.235	47.82%	2024/7/19	0	5572.97	
121		0		众12	17320	1000	3.22	0.32%	2024/6/1	0	13800.18	
122		0		众13	9006.4	520	231.02	44.43%	2024/1/24	0	3203.84	
123		0		众15	10045.6	580	104.79	18.07%	2024/3/18	0	6221.55	
124		0	10kV-42	众16	9006.4	520	260.57	50.11%	2024/3/26	0	2691.98	
125		0		众22	9352.8	540	121.31	22.47%	2024/1/25	0	5381.13	
126		0	10kV-43	众23	9006.4	520	0.00	0.00%	2024/6/1	0	7205.12	
127		0		众31	17320	1000	521.887	52.19%	2024/7/5	0	4816.92	
128		0		众34	10045.6	580	0.00	0.00%	2024/6/1	0	8036.48	
129		0	10kV-44	众35	10392	600	36.74	6.12%	2024/1/8	0	7677.30	
130	邓善沽	0	10kV-42	众42	17320	1000	545.03	54.50%	2024/6/26	0	4416.05	
131		0		邓21	8486.8	490	204.082	41.65%	2024/7/23	0	3254.74	
132		0		邓22	7257.08	419	237.305	56.64%	2024/7/30	0	1695.54	
133		0		邓23	7257.08	419	213.574	50.97%	2024/7/30	0	2106.56	
134		0	10kV-43	邓24	7257.08	419	93.69	22.36%	2024/2/2	0	4182.94	
135		0		邓25	8833.2	510	184.57	36.19%	2024/7/7	0	3869.81	
136		0		邓26	8833.2	510	268.418	52.63%	2024/7/23	0	2417.56	
137		0		邓27	8573.4	495	11.43	2.31%	2024/6/11	0	6660.82	
138		0		邓31	7257.08	419	168.926	40.32%	2024/7/23	0	2879.87	
		0		邓32	7257.08	419	248.906	59.40%	2024/7/23	0	1494.61	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
139		0	10kV-44	邓33	7257.08	419	263.32	62.84%	2024/6/17	0	1244.96	
140		0		邓34	8833.2	510	164.355	32.23%	2024/7/23	0	4219.93	
141		0		邓35	8833.2	510	92.812	18.20%	2024/7/23	0	5459.06	
142		0		邓36	8833.2	510	333.281	65.35%	2024/7/19	0	1294.13	
143		0		邓37	8573.4	495	4.746	0.96%	2024/7/11	0	6776.52	
144	东尹	0	10kV-42	尹21	6928	400	125.39	31.35%	2024/1/22	0	3370.63	
145		0		尹22	6928	400	201.09	50.27%	2024/1/9	0	2059.45	
146		0		尹23	6928	400	164.06	41.02%	2024/1/9	0	2700.85	
147		0	10kV-44	尹35	6928	400	226.875	56.72%	2024/7/24	0	1612.93	
148		0		尹36	6928	400	213.281	53.32%	2024/7/24	0	1848.37	
149		0		尹37	6928	400	172.5	43.13%	2024/7/24	0	2554.70	
150		0										
151	窦庄子	0	10kV-4	窦11	6928	400	65.742	16.44%	2024/7/25	0	4403.75	
152		0	10kV-5	窦16	6928	400	0.00	0.00%	2024/6/1	0	5542.40	
153		0		窦21	6928	400	149.414	37.35%	2024/7/25	0	2954.55	
154		0		窦22	6928	400	104.88	26.22%	2024/1/5	0	3725.83	
155		0		窦23	6928	400	59.648	14.91%	2024/7/3	0	4509.30	
156	福州道	0	10kV-41	福11	6928	400	205.4	51.35%	2024/7/23	0	1984.87	
157		0		福13	6928	400	48.768	12.19%	2024/7/23	0	4697.74	
158		0		福14	6928	400	244.824	61.21%	2024/7/24	0	1302.05	
159		0		福15	6928	400	142.368	35.59%	2024/7/23	0	3076.59	
160		0		福16	6928	400	69.864	17.47%	2024/7/23	0	4332.36	
161		0		福17	6928	400	89.392	22.35%	2024/7/23	0	3994.13	
162		0		福18	6928	400	62.576	15.64%	2024/7/29	0	4458.58	
163		0	10kV-42	福21	6928	400	110.664	27.67%	2024/7/23	0	3625.70	
164		0		福23	6928	400	275.008	68.75%	2024/7/23	0	779.26	
165		0	10kV-43	福26	6928	400	70.584	17.65%	2024/7/23	0	4319.89	
166		0		福27	6928	400	124.536	31.13%	2024/7/23	0	3385.44	
167		0		福28	6928	400	254.936	63.73%	2024/7/23	0	1126.91	
168		0	10kV-44	福31	6928	400	124.536	31.13%	2024/7/23	0	3385.44	
169		0		福32	6928	400	217.168	54.29%	2024/7/23	0	1781.05	
170		0		福34	6928	400	193.968	48.49%	2024/7/23	0	2182.87	
171		0		福35	6928	400	129.608	32.40%	2024/7/23	0	3297.59	
172		0		福38	6928	400	148.43	37.11%	2024/3/17	0	2971.56	
173		0	10kV-4	付14	6928	400	86.4	21.60%	2024/7/23	0	4045.95	
174		0		付15	5196	300	195.6	65.20%	2024/7/23	0	769.01	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
174	付庄	0	10kV-4	付16	6928	400	184.24	46.06%	2024/1/26	0	2351.36	
175		0		付17	5196	300	209.84	69.95%	2024/7/18	0	522.37	
176		0	10kV-5	付21	5196	300	0.00	0.00%	2024/6/1	0	4156.80	
177		0		付22	5196	300	12.00	4.00%	2024/6/11	0	3948.96	
178		0		付23	6928	400	148.24	37.06%	2024/7/5	0	2974.88	
179		0		付24	6928	400	117.76	29.44%	2024/2/23	0	3502.80	
180		0		付25	6928	400	204.24	51.06%	2024/2/4	0	2004.96	
181		0										
182	港发	0	10kV-41	发11	7257.08	419	26.191	6.25%	2024/7/30	0	5352.04	
183		0		发12	7257.08	419	259.45	61.92%	2024/6/17	0	1311.94	
184		0		发13	7257.08	419	243.63	58.15%	2024/6/30	0	1585.94	
185		0		发14	7257.08	419	114.43	27.31%	2024/6/13	0	3823.67	
186		0		发15	7257.08	419	168.398	40.19%	2024/7/24	0	2889.01	
187		0		发16	8660	500	272.812	54.56%	2024/7/12	0	2202.90	
188		0		发17	8833.2	510	48.34	9.48%	2024/7/23	0	6229.31	
189		0		发18	8833.2	510	2.29	0.45%	2024/3/17	0	7026.98	
190		0	10kV-44	发31	8833.2	510	227.64	44.63%	2024/1/5	0	3123.89	
191		0		发32	7257.08	419	197.754	47.20%	2024/7/23	0	2380.56	
192		0		发33	7257.08	419	0.00	0.00%	2024/6/1	0	5805.66	
193		0		发34	7257.08	419	305.15	72.83%	2024/7/23	0	520.47	
194		0		发35	7257.08	419	92.812	22.15%	2024/7/21	0	4198.16	
195		0		发36	8660	500	255.586	51.12%	2024/7/23	0	2501.25	
196		0		发37	8833.2	510	0.00	0.00%	2024/6/1	0	7066.56	
197	港塘路	0	10kV-5	610	5196	300	132.177	44.06%	2024/7/23	0	1867.49	
198		0		612	5196	300	45.176	15.06%	2024/7/12	0	3374.35	
199		0	10kV-4	615	5196	300	111.061	37.02%	2024/7/30	0	2233.22	
200		0		619	5196	300	63.84	21.28%	2024/1/13	0	3051.06	
201	港湾	0	10kV-41	湾11	8833.2	510	42.9	8.41%	2024/7/2	0	6323.53	
202		0		湾12	7257.08	419	319.39	76.23%	2024/2/17	0	273.79	
203		0		湾13	8660	500	257.57	51.51%	2024/1/19	0	2466.92	
204		0		湾14	7257.08	419	84.912	20.27%	2024/7/29	0	4334.99	
205		0		湾15	7257.08	419	223.01	53.22%	2024/1/3	0	1943.17	
206		0		湾16	8486.8	490	182.02	37.15%	2024/6/21	0	3636.92	
207		0		湾17	8833.2	510	297.396	58.31%	2024/7/19	0	1915.66	
208		0		湾18	8833.2	510	144.24	28.28%	2024/6/14	0	4568.32	
		0		湾21	8833.2	510	7.93	1.56%	2024/1/27	0	6929.18	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
209		0	10kV-42	湾22	8660	500	114.28	22.86%	2024/1/22	0	4948.74	
210		0		湾23	8486.8	490	251.976	51.42%	2024/7/2	0	2425.22	
211		0		湾24	7257.08	419	104.06	24.84%	2024/3/2	0	4003.28	
212		0	10kV-43	湾25	7257.08	419	253.188	60.43%	2024/7/22	0	1420.45	
213		0		湾26	8486.8	490	105.52	21.53%	2024/6/30	0	4961.90	
214		0		湾27	8833.2	510	151.14	29.64%	2024/6/11	0	4448.82	
215		0		湾28	8833.2	510	207.29	40.64%	2024/1/3	0	3476.33	
216		0	10kV-43	高31	6928	400	127.214	31.80%	2024/7/24	0	3339.05	
217	高新园	0		高32	6928	400	49.10	12.27%	2024/6/13	0	4692.02	
218		0		高33	6928	400	25.04	6.26%	2024/1/8	0	5108.71	
219		0		高36	6928	400	150.628	37.66%	2024/7/25	0	2933.52	
220		0	10kV-44	高41	6928	400	70.98	17.75%	2024/3/6	0	4312.97	
221		0		高42	6928	400	14.96	3.74%	2024/1/11	0	5283.29	
222		0		高43	6928	400	20.63	5.16%	2024/3/29	0	5185.14	
223		0		高44	6928	400	22.37	5.59%	2024/1/10	0	5154.90	
224		0		高45	6928	400	193.73	48.43%	2024/6/14	0	2187.05	
225		0		高46	6928	400	2.60	0.65%	2024/1/3	0	5497.33	
226		0	10kV-45	高52	6928	400	2.88	0.72%	2024/1/13	0	5492.59	
227		0		高53	6928	400	1.12	0.28%	2024/1/2	0	5523.02	
228		0		高54	6928	400	103.71	25.93%	2024/3/2	0	3746.18	
229		0	10kV-46	高61	6928	400	263.809	65.95%	2024/7/23	0	973.23	
230		0		高62	6928	400	180.33	45.08%	2024/1/16	0	2419.05	
231		0		高63	6928	400	122.53	30.63%	2024/1/19	0	3420.22	
232		0		高64	6928	400	67.572	16.89%	2024/7/8	0	4372.05	
233		0		高65	6928	400	1.40	0.35%	2024/3/12	0	5518.22	
234	工农村	0	10kV-41	工11	6928	400	113.44	28.36%	2024/1/1	0	3577.65	
235		0		工12	6928	400	221.484	55.37%	2024/7/29	0	1706.30	
236		0		工13	6928	400	269.41	67.35%	2024/1/10	0	876.15	
237		0		工14	6928	400	284.18	71.05%	2024/2/28	0	620.40	
238		0		工15	6928	400	282.77	70.69%	2024/6/26	0	644.77	
239		0		工16	6928	400	252.19	63.05%	2024/1/12	0	1174.50	
240		0		工17	6928	400	238.36	59.59%	2024/1/11	0	1414.02	
241		0		工18	6928	400	127.15	31.79%	2024/1/9	0	3340.20	
242		0	10kV-42	工21	6928	400	110.98	27.74%	2024/1/17	0	3620.28	
243		0		工22	6928	400	315.66	78.92%	2024/1/2	0	75.10	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
244		0	10kV-42	工23	6928	400	279.26	69.81%	2024/1/8	0	705.65	
245		0		工24	6928	400	127.03	31.76%	2024/6/18	0	3342.22	
246		0	10kV-43	工25	6928	400	220.195	55.05%	2024/7/21	0	1728.62	
247		0		工26	6928	400	249.49	62.37%	2024/6/26	0	1221.20	
248		0		工27	6928	400	307.73	76.93%	2024/7/16	0	212.45	
249		0		工28	6928	400	0.00	0.00%	2024/6/1	0	5542.40	
250	光辉	0	10kV-41	光21	10392	600	63.204	10.53%	2024/7/23	0	7218.91	
251		0		光22	10392	600	226.88	37.81%	2024/6/13	0	4383.97	
252		0		光11	9422.08	544	126.264	23.21%	2024/7/24	0	5350.77	
253		0		光23	8313.6	480	54.372	11.33%	2024/7/23	0	5709.16	
254		0		光12	10166.84	587	200.89	34.22%	2024/7/12	0	4654.02	
255		0		光13	10166.84	587	174.44	29.72%	2024/7/23	0	5112.10	
256		0		光14	6928	400	134.89	33.72%	2024/7/8	0	3206.07	
257		0		光15	7967.2	460	0.00	0.00%	2024/7/1	0	6373.76	
258		0	10kV-43	光41	10392	600	58.99	9.83%	2024/3/30	0	7291.86	
259		0		光42	10392	600	184.50	30.75%	2024/6/13	0	5118.06	
260		0		光46	9006.4	520	0.00	0.00%	2024/7/1	0	7205.12	
261		0	10kV-44	光51	9422.08	544	111.768	20.55%	2024/7/24	0	5601.84	
262		0		光52	10166.84	587	69.76	11.88%	2024/7/19	0	6925.30	
263		0		光53	6928	400	132.84	33.21%	2024/7/23	0	3241.61	
264		0		光54	6928	400	161.22	40.31%	2024/7/21	0	2750.07	
265		0		光55	7967.2	460	0.00	0.00%	2024/7/1	0	6373.76	
266		0		光61	8313.6	480	41.808	8.71%	2024/7/21	0	5926.77	
267	郭庄子	0	10kV-4	郭11	6928	400	251.08	62.77%	2024/3/27	0	1193.64	
268		0		郭12	6928	400	186.00	46.50%	2024/3/28	0	2320.90	
269		0		郭13	6928	400	191.18	47.79%	2024/3/24	0	2231.20	
270		0		郭14	6928	400	85.73	21.43%	2024/3/24	0	4057.52	
271		0		郭15	6928	400	200.85	50.21%	2024/3/24	0	2063.75	
272		0	10kV-5	郭22	6928	400	141.80	35.45%	2024/3/26	0	3086.35	
273		0		郭23	6928	400	145.40	36.35%	2024/3/24	0	3024.16	
274		0		郭25	6928	400	190.38	47.60%	2024/1/4	0	2244.95	
275		0		郭26	6928	400	237.00	59.25%	2024/3/25	0	1437.63	
276	海滨浴场	0	10kV-4	783	5888.8	340	224.393	66.00%	2024/7/29	0	824.55	
277		0		787	4676.4	270	36.94	13.68%	2024/6/20	0	3101.35	
278		0	10kV-5	782	6928	400	1.42	0.36%	2024/3/12	0	5517.81	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
279		0	10kV-3	786	4503.2	260	51.76	19.91%	2024/6/12	0	2706.16	
280	海防路	0	10kV-41	防11	7257.08	419	66.995	15.99%	2024/7/28	0	4645.31	
281		0		防12	7534.2	435	68.752	15.81%	2024/7/10	0	4836.58	
282		0		防13	8833.2	510	75.43	14.79%	2024/1/21	0	5760.08	
283		0	10kV-42	防21	7257.08	419	103.38	24.67%	2024/1/27	0	4015.11	
284		0		防23	8833.2	510	47.64	9.34%	2024/1/6	0	6241.49	
285		0										
286	海河花园	0	10kV-1	711	6928	400	164.337	41.08%	2024/7/25	0	2696.08	
287		0		712	6928	400	284.132	71.03%	2024/7/11	0	621.23	
288		0		714	6928	400	253.421	63.36%	2024/7/23	0	1153.15	
289		0		716	6928	400	220.952	55.24%	2024/7/24	0	1715.51	
290		0		717	6928	400	24.615	6.15%	2024/7/19	0	5116.07	
291		0	10kV-2甲	721	6928	400	44.07	11.02%	2024/1/5	0	4779.06	
292		0		722	6928	400	30.24	7.56%	2024/1/9	0	5018.61	
293		0		723	6928	400	171.25	42.81%	2024/6/22	0	2576.30	
294		0	10kV-2乙	725	6928	400	267.018	66.75%	2024/7/24	0	917.65	
295		0		727	6928	400	27.077	6.77%	2024/7/24	0	5073.43	
296		0	10kV-3	731	6928	400	194.579	48.64%	2024/7/25	0	2172.29	
297		0		732	6928	400	291.634	72.91%	2024/7/16	0	491.30	
298		0		733	6928	400	168.088	42.02%	2024/7/18	0	2631.12	
299		0		734	6928	400	141.71	35.43%	2024/6/28	0	3087.91	
300		0		735	6928	400	65.29	16.32%	2024/6/30	0	4411.59	
301		0		736	6928	400	184.733	46.18%	2024/7/23	0	2342.82	
302		0		737	6928	400	86.62	21.66%	2024/6/1	0	4042.09	
303		0		738	6928	400	1.99	0.50%	2024/2/29	0	5507.88	
304		0	10kV-41	海11	6928	400	193.711	48.43%	2024/7/23	0	2187.33	
305		0		海12	6928	400	118.71	29.68%	2024/3/4	0	3486.33	
306		0		海15	6928	400	30.00	7.50%	2024/6/17	0	5022.80	
307		0		海16	6928	400	286.875	71.72%	2024/7/23	0	573.73	
308	海景路	0	10kV-42	海21	6928	400	194.297	48.57%	2024/7/23	0	2177.18	
309		0		海22	6928	400	315.586	78.90%	2024/7/23	0	76.45	
310		0		海23	6928	400	93.984	23.50%	2024/7/21	0	3914.60	
311		0		海24	6928	400	82.266	20.57%	2024/7/23	0	4117.55	
312		0	10kV-43	海33	6928	400	82.266	20.57%	2024/7/23	0	4117.55	
313		0		海35	6928	400	8.32	2.08%	2024/6/11	0	5398.30	
		0		海36	6928	400	270.352	67.59%	2024/7/23	0	859.90	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
314		0	10kV-44	海41	6928	400	213.867	53.47%	2024/7/23	0	1838.22	
315		0		海42	6928	400	249.023	62.26%	2024/7/23	0	1229.32	
316		0		海43	6928	400	105.82	26.46%	2024/7/23	0	3709.60	
317		0		海44	6928	400	80.391	20.10%	2024/7/30	0	4150.03	
318	海平路	0	10kV-41	平11	8313.6	480	95.553	19.91%	2024/7/29	0	4995.90	
319		0	10kV-42	平31	8313.6	480	181.507	37.81%	2024/7/19	0	3507.18	
320	海洋	0	10kV-2甲	421	7257.08	419	133.136	31.77%	2024/7/30	0	3499.75	
321		0		422	7257.08	419	154.64	36.91%	2024/1/17	0	3127.39	
322		0		423	8833.2	510	151.841	29.77%	2024/7/23	0	4436.67	
323		0		424	8833.2	510	71.89	14.10%	2024/1/10	0	5821.37	
324		0	10kV-2乙	425	8833.2	510	213.149	41.79%	2024/7/24	0	3374.82	
325		0		426	8833.2	510	247.502	48.53%	2024/7/24	0	2779.83	
326		0		427	8833.2	510	73.67	14.44%	2024/1/31	0	5790.61	
327		0		428	8833.2	510	209.67	41.11%	2024/6/3	0	3435.16	
328		0	10kV-3	431	8486.8	490	123.57	25.22%	2024/1/23	0	4649.21	
329		0		432	7257.08	419	152.334	36.36%	2024/7/23	0	3167.24	
330		0		433	8833.2	510	168.442	33.03%	2024/7/30	0	4149.14	
331		0		434	8833.2	510	117.62	23.06%	2024/7/23	0	5029.38	
332		0		435	8833.2	510	170.68	33.47%	2024/1/31	0	4110.43	
333		0		436	8833.2	510	377.71	74.06%	2024/6/18	0	524.59	
334		0		437	8833.2	510	172.09	33.74%	2024/1/22	0	4085.94	
335		0		438	7257.08	419	48.42	11.56%	2024/3/17	0	4966.99	
336	航园	0	10kV-41	航11	9006.4	520	60.47	11.63%	2024/1/22	0	6157.80	
337		0		航12	6408.4	370	128.87	34.83%	2024/1/23	0	2894.69	
338		0		航13	7257.08	419	12.96	3.09%	2024/1/1	0	5581.13	
339		0		航14	8833.2	510	192.239	37.69%	2024/7/19	0	3736.98	
340		0		航16	8486.8	490	110.149	22.48%	2024/7/23	0	4881.66	
341		0		航17	7257.08	419	244.072	58.25%	2024/7/23	0	1578.34	
342		0		航18	7257.08	419	174.95	41.75%	2024/6/9	0	2775.60	
343		0	10kV-42	航21	7707.4	445	63.347	14.24%	2024/7/19	0	5068.75	
344		0		航22	7707.4	445	107.27	24.11%	2024/6/20	0	4307.99	
345		0		航23	9006.4	520	3.60	0.69%	2024/6/12	0	7142.70	
346		0		航24	7447.6	430	305.99	71.16%	2024/6/19	0	658.32	
347		0	10kV-43	航25	8486.8	490	108.72	22.19%	2024/6/16	0	4906.39	
348		0		航27	8486.8	490	60.47	12.34%	2024/1/11	0	5742.12	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
349		0		航28	8486.8	490	3.60	0.74%	2024/6/3	0	6727.02	
350		0	10kV-44	航31	8833.2	510	179.275	35.15%	2024/7/19	0	3961.52	
351		0		航32	8486.8	490	264.22	53.92%	2024/3/1	0	2213.13	
352		0		航33	8486.8	490	119.51	24.39%	2024/1/9	0	4719.54	
353		0		航34	8486.8	490	54.71	11.17%	2024/1/5	0	5841.83	
354		0		航35	9093	525	379.424	72.27%	2024/7/23	0	702.78	
355		0		航36	10045.6	580	99.36	17.13%	2024/7/25	0	6315.56	
356		0		航37	8140.4	470	184.58	39.27%	2024/2/23	0	3315.45	
357		0		航38	8833.2	510	259.92	50.96%	2024/3/25	0	2564.83	
358	和畅路	0	10kV-41	畅11	6928	400	203.01	50.75%	2024/2/23	0	2026.21	
359		0		畅12	6928	400	221.736	55.43%	2024/7/23	0	1701.93	
360		0		畅13	6928	400	306.96	76.74%	2024/7/23	0	225.85	
361		0		畅14	6928	400	155.152	38.79%	2024/7/23	0	2855.17	
362		0		畅15	6928	400	11.312	2.83%	2024/7/25	0	5346.48	
363		0		畅16	6928	400	240.8	60.20%	2024/7/24	0	1371.74	
364		0	10kV-42	畅21	6928	400	167.696	41.92%	2024/7/12	0	2637.91	
365		0		畅22	6928	400	198.48	49.62%	2024/7/19	0	2104.73	
366		0		畅23	6928	400	238.55	59.64%	2024/3/3	0	1410.71	
367		0		畅24	6928	400	314.576	78.64%	2024/7/8	0	93.94	
368		0		畅25	6928	400	313.23	78.31%	2024/7/23	0	117.22	
369		0	10kV-43	畅31	6928	400	236.15	59.04%	2024/3/29	0	1452.33	
370		0		畅32	6928	400	70.01	17.50%	2024/2/29	0	4329.91	
371		0		畅33	6928	400	201.096	50.27%	2024/7/30	0	2059.42	
372		0		畅34	6928	400	135.92	33.98%	2024/1/17	0	3188.21	
373		0		畅36	6928	400	205.328	51.33%	2024/7/21	0	1986.12	
374		0	10kV-44	畅41	6928	400	193.32	48.33%	2024/6/23	0	2194.10	
375		0		畅42	6928	400	176.528	44.13%	2024/7/23	0	2484.94	
376		0		畅43	6928	400	318.76	79.69%	2024/7/23	0	21.48	
377		0		畅44	6928	400	163.128	40.78%	2024/7/23	0	2717.02	
378		0		畅45	6928	400	6.96	1.74%	2024/1/4	0	5421.89	
379		0		畅46	6928	400	245.56	61.39%	2024/7/30	0	1289.30	
380		0	10kV-45	畅51	6928	400	127.58	31.90%	2024/6/20	0	3332.65	
381		0		畅52	6928	400	212.248	53.06%	2024/7/23	0	1866.26	
382		0		畅53	6928	400	256.07	64.02%	2024/3/3	0	1107.28	
383		0		畅54	6928	400	186.42	46.60%	2024/6/9	0	2313.67	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
384		0		畅55	6928	400	310.94	77.74%	2024/6/3	0	156.85	
385		0		畅56	6928	400	42.70	10.68%	2024/6/26	0	4802.77	
386		0	10kV-46	畅61	6928	400	195.31	48.83%	2024/6/5	0	2159.60	
387		0		畅62	6928	400	303.144	75.79%	2024/7/12	0	291.95	
388		0		畅63	6928	400	316.376	79.09%	2024/7/12	0	62.77	
389		0		畅64	6928	400	194.92	48.73%	2024/6/28	0	2166.39	
390		0		畅65	6928	400	81.20	20.30%	2024/1/23	0	4136.09	
391		0		畅66	6928	400	228.648	57.16%	2024/7/19	0	1582.22	
392	后沽	0	10kV-4	后15	7257.08	419	53.808	12.84%	2024/7/23	0	4873.71	
393		0		后16	7257.08	419	46.308	11.05%	2024/7/23	0	5003.61	
394		0		后17	7257.08	419	152.448	36.38%	2024/7/24	0	3165.26	
395		0	10kV-5	后21	7257.08	419	154.044	36.76%	2024/7/24	0	3137.62	
396		0		后22	7257.08	419	74.652	17.82%	2024/7/23	0	4512.69	
397		0		后23	7257.08	419	74.58	17.80%	2024/1/12	0	4513.94	
398		0		后27	6495	375	11.13	2.97%	2024/1/13	0	5003.23	
399		0	10kV-41	胡11	6928	400	23.20	5.80%	2024/1/3	0	5140.52	
400	胡家园	0		胡12	6928	400	28.95	7.24%	2024/1/21	0	5041.07	
401		0		胡13	6928	400	269.77	67.44%	2024/6/26	0	870.05	
402		0		胡15	6928	400	193.01	48.25%	2024/1/2	0	2199.50	
403		0	10kV-42	胡20	6928	400	273.047	68.26%	2024/7/23	0	813.23	
404		0		胡21	6928	400	252.422	63.11%	2024/7/24	0	1170.45	
405		0		胡22	6928	400	165.938	41.48%	2024/7/23	0	2668.35	
406		0		胡23	6928	400	149.30	37.32%	2024/1/9	0	2956.58	
407		0	10kV-43	胡24	6928	400	118.594	29.65%	2024/7/23	0	3488.35	
408		0		胡25	6928	400	290.63	72.66%	2024/1/22	0	508.78	
409		0		胡26	6928	400	297.539	74.38%	2024/7/23	0	389.02	
410		0		胡27	6928	400	179.883	44.97%	2024/7/23	0	2426.83	
411		0	10kV-44	胡28	6928	400	171.68	42.92%	2024/7/23	0	2568.90	
412		0		胡31	6928	400	232.969	58.24%	2024/7/10	0	1507.38	
413		0		胡32	6928	400	29.414	7.35%	2024/7/23	0	5032.95	
414		0		胡33	6928	400	301.758	75.44%	2024/7/23	0	315.95	
415		0		胡34	6928	400	249.609	62.40%	2024/7/23	0	1219.17	
416		0		胡35	6928	400	15.94	3.98%	2024/6/4	0	5266.35	
417		0		胡36	6928	400	283.94	70.99%	2024/1/12	0	624.56	
418		0		胡37	6928	400	238.711	59.68%	2024/7/23	0	1407.93	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
419		0		胡38	6928	400	215.98	53.99%	2024/1/3	0	1801.68	
420		0		胡39	6928	400	201.45	50.36%	2024/6/11	0	2053.37	
421	琥珀溪	0	10kV-42	琥32	9474.04	547	391.332	71.54%	2024/7/23	0	801.36	
422		0		琥33	8660	500	8.208	1.64%	2024/7/23	0	6785.84	
423		0	10kV-43	琥41	8660	500	43.38	8.68%	2024/7/30	0	6176.66	
424		0		琥43	9352.8	540	327.66	60.68%	2024/3/1	0	1807.17	
425		0	10kV-44	琥46	9352.8	540	29.988	5.55%	2024/7/23	0	6962.85	
426		0		琥52	9352.8	540	323.484	59.90%	2024/7/23	0	1879.50	
427		0		琥53	8660	500	6.94	1.39%	2024/6/4	0	6807.87	
428		0		琥61	8660	500	39.36	7.87%	2024/7/10	0	6246.28	
429		0		琥63	9352.8	540	0.80	0.15%	2024/1/1	0	7468.31	
430		0		琥66	9352.8	540	115.848	21.45%	2024/7/5	0	5475.75	
431	华山道	0	10kV-41	山11	6928	400	96.445	24.11%	2024/7/3	0	3871.97	
432		0		山12	6928	400	225.00	56.25%	2024/6/26	0	1645.40	
433		0		山13	6928	400	267.42	66.86%	2024/1/19	0	910.65	
434		0		山14	6928	400	193.83	48.46%	2024/6/18	0	2185.30	
435		0		山15	6928	400	218.203	54.55%	2024/7/23	0	1763.12	
436		0		山16	6928	400	214.219	53.55%	2024/7/23	0	1832.13	
437		0	10kV-42	山21	6928	400	103.125	25.78%	2024/7/24	0	3756.28	
438		0		山22	6928	400	227.461	56.87%	2024/7/24	0	1602.78	
439		0		山23	6928	400	172.5	43.13%	2024/7/23	0	2554.70	
440		0		山24	6928	400	56.72	14.18%	2024/6/5	0	4560.03	
441		0		山25	6928	400	3.75	0.94%	2024/7/17	0	5477.45	
442		0		山26	6928	400	210.00	52.50%	2024/6/9	0	1905.20	
443		0	10kV-45	山51	6928	400	247.97	61.99%	2024/6/18	0	1247.58	
444		0		山52	6928	400	215.742	53.94%	2024/7/23	0	1805.75	
445		0		山53	6928	400	216.45	54.11%	2024/1/20	0	1793.57	
446		0		山54	6928	400	250.43	62.61%	2024/7/23	0	1204.95	
447		0		山55	6928	400	216.094	54.02%	2024/7/23	0	1799.65	
448		0		山56	6928	400	3.75	0.94%	2024/7/17	0	5477.45	
449		0	10kV-46	山61	6928	400	33.63	8.41%	2024/1/22	0	4959.88	
450		0		山62	6928	400	12.539	3.13%	2024/7/19	0	5325.22	
451		0		山63	6928	400	80.27	20.07%	2024/1/22	0	4152.07	
452		0		山64	6928	400	288.75	72.19%	2024/7/24	0	541.25	
453		0		山65	6928	400	152.70	38.17%	2024/6/9	0	2897.72	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
454		0		山66	10392	600	4.45	0.74%	2024/6/3	0	8236.47	
455	化工园	0	10kV-4	952	6928	400	48.24	12.06%	2024/6/28	0	4706.85	
456		0		953	6928	400	156.45	39.11%	2024/1/4	0	2832.77	
457		0		956	6928	400	25.20	6.30%	2024/3/20	0	5106.02	
458		0		961	6928	400	171.09	42.77%	2024/3/5	0	2579.05	
459		0	10kV-5	962	6928	400	3.50	0.88%	2024/6/27	0	5481.78	
460		0		963	6928	400	275.00	68.75%	2024/1/11	0	779.40	
461		0		966	6928	400	37.50	9.38%	2024/3/25	0	4892.90	
462		0		966	6928	400	37.50	9.38%	2024/3/25	0	4892.90	
462	惠居	0	10kV-43	惠31	8833.2	510	255.586	50.11%	2024/7/23	0	2639.81	
463		0		惠34	9526	550	8.09	1.47%	2024/7/30	0	7480.75	
464		0	10kV-44	惠41	9560.64	552	300.94	54.52%	2024/1/10	0	2436.27	
465		0		惠42	10392	600	79.629	13.27%	2024/7/26	0	6934.43	
466		0		惠43	8867.84	512	132.72	25.92%	2024/1/23	0	4795.65	
467		0		惠45	10392	600	37.793	6.30%	2024/7/21	0	7659.03	
468		0	10kV-45	惠51	9352.8	540	199.16	36.88%	2024/3/26	0	4032.79	
469		0		惠53	9352.8	540	275.977	51.11%	2024/7/20	0	2702.32	
470		0		惠54	9526	550	119.36	21.70%	2024/7/23	0	5553.57	
471		0	10kV-46	惠61	8867.84	512	199.512	38.97%	2024/7/23	0	3638.72	
472		0		惠62	8867.84	512	153.984	30.08%	2024/7/12	0	4427.27	
473		0		惠63	10392	600	72.773	12.13%	2024/7/30	0	7053.17	
474		0		惠64	9560.64	552	100.195	18.15%	2024/7/11	0	5913.13	
475		0		惠65	10218.8	590	149.06	25.26%	2024/6/14	0	5593.29	
476		0	10kV-41	碱11	8833.2	510	345.586	67.76%	2024/7/21	0	1081.01	
477		0		碱12	8833.2	510	31.093	6.10%	2024/7/21	0	6528.03	
478		0		碱13	8833.2	510	119.831	23.50%	2024/7/23	0	4991.09	
479		0		碱14	9352.8	540	135.527	25.10%	2024/7/19	0	5134.91	
480		0		碱15	8400.2	485	120.76	24.90%	2024/7/21	0	4628.56	
481		0	10kV-43	碱31	8833.2	510	200.08	39.23%	2024/6/13	0	3601.19	
482		0		碱32	7291.72	421	199.84	47.47%	2024/6/13	0	2372.20	
483		0		碱33	8833.2	510	199.59	39.13%	2024/6/13	0	3609.70	
484		0		碱34	8833.2	510	62.009	12.16%	2024/7/18	0	5992.56	
485		0		碱35	8833.2	510	348.505	68.33%	2024/7/10	0	1030.45	
486		0		碱36	8833.2	510	323.40	63.41%	2024/6/19	0	1465.20	
487		0		碱37	8833.2	510	227.74	44.65%	2024/6/18	0	3122.17	
488		0		碱38	8833.2	510	119.93	23.51%	2024/6/13	0	4989.44	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
489	碱渣山	0	10kV-44	碱41	8833.2	510	154.02	30.20%	2024/6/16	0	4398.93	
490		0		碱42	7291.72	421	69.96	16.62%	2024/1/12	0	4621.65	
491		0		碱43	8833.2	510	42.19	8.27%	2024/3/13	0	6335.86	
492		0		碱44	8833.2	510	221.31	43.39%	2024/2/18	0	3233.49	
493		0		碱45	8833.2	510	146.806	28.79%	2024/7/24	0	4523.88	
494		0		碱46	8833.2	510	81.385	15.96%	2024/7/23	0	5656.97	
495		0		碱47	8833.2	510	147.024	28.83%	2024/7/23	0	4520.10	
496		0		碱48	8833.2	510	143.769	28.19%	2024/7/21	0	4576.48	
497		0	10kV-45	碱51	8833.2	510	237.48	46.56%	2024/3/13	0	2953.41	
498		0		碱52	8833.2	510	117.573	23.05%	2024/7/23	0	5030.20	
499		0		碱53	8833.2	510	190.692	37.39%	2024/7/23	0	3763.77	
500		0		碱54	8833.2	510	208.756	40.93%	2024/7/29	0	3450.91	
501		0		碱55	7291.72	421	236.07	56.07%	2024/3/23	0	1744.57	
502		0		碱56	8833.2	510	201.131	39.44%	2024/7/24	0	3582.97	
503		0		碱57	8833.2	510	157.31	30.84%	2024/6/18	0	4342.00	
504		0		碱58	8833.2	510	147.997	29.02%	2024/7/18	0	4503.25	
505		0	10kV-46	碱61	8833.2	510	209.16	41.01%	2024/6/25	0	3444.00	
506		0		碱62	8833.2	510	312.72	61.32%	2024/6/13	0	1650.34	
507		0		碱63	8833.2	510	210.06	41.19%	2024/6/16	0	3428.34	
508		0		碱64	8833.2	510	119.93	23.51%	2024/6/18	0	4989.44	
509		0		碱65	7291.72	421	219.90	52.23%	2024/6/16	0	2024.67	
510		0		碱66	8833.2	510	120.03	23.53%	2024/6/18	0	4987.68	
511		0		碱67	9352.8	540	139.04	25.75%	2024/1/12	0	5074.02	
512		0		碱68	8833.2	510	169.22	33.18%	2024/6/18	0	4135.74	
513	金源路	0	10kV-41	源11	6928	400	92.99	23.25%	2024/6/28	0	3931.85	
514		0		源12	6928	400	186.99	46.75%	2024/6/17	0	2303.79	
515		0		源13	6928	400	220.99	55.25%	2024/1/19	0	1714.92	
516		0		源14	6928	400	278.00	69.50%	2024/1/21	0	727.47	
517		0		源15	6928	400	189.99	47.50%	2024/6/17	0	2251.77	
518		0		源16	6928	400	144.99	36.25%	2024/6/18	0	3031.17	
519		0		源17	6928	400	250.99	62.75%	2024/6/17	0	1195.32	
520		0		源18	6928	400	222.99	55.75%	2024/6/17	0	1680.16	
521		0	10kV-42	源21	6928	400	222.00	55.50%	2024/6/17	0	1697.41	
522		0		源22	6928	400	274.995	68.75%	2024/7/24	0	779.49	
523		0		源23	6928	400	225.00	56.25%	2024/6/17	0	1645.40	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
524		0	10kV-43	源24	6928	400	245.00	61.25%	2024/6/19	0	1299.09	
525		0		源25	6928	400	186.99	46.75%	2024/6/17	0	2303.79	
526		0		源26	6928	400	102.00	25.50%	2024/7/20	0	3775.81	
527		0		源27	6928	400	264.99	66.25%	2024/7/23	0	952.77	
528		0		源28	6928	400	275.99	69.00%	2024/6/17	0	762.24	
529	精细园	0	10kV-41	精11	8833.2	510	291.95	57.25%	2024/1/30	0	2009.97	
530		0		精12	8833.2	510	119.75	23.48%	2024/6/25	0	4992.47	
531		0		精13	8573.4	495	44.14	8.92%	2024/6/19	0	6094.16	
532		0		精15	8660	500	52.78	10.56%	2024/6/24	0	6013.89	
533		0	10kV-42	精21	8573.4	495	218.01	44.04%	2024/6/19	0	3082.73	
534		0		精22	7863.28	454	0.00	0.00%	2024/6/1	0	6290.62	
535		0		精23	8573.4	495	39.22	7.92%	2024/1/18	0	6179.41	
536		0		精24	10392	600	44.03	7.34%	2024/1/28	0	7550.95	
537		0	10kV-43	精31	8833.2	510	159.46	31.27%	2024/6/29	0	4304.78	
538		0		精32	8833.2	510	101.27	19.86%	2024/6/25	0	5312.53	
539		0		精33	8573.4	495	43.55	8.80%	2024/1/19	0	6104.43	
540		0		精35	8660	500	72.949	14.59%	2024/7/9	0	5664.52	
541		0	10kV-44	精41	8573.4	495	227.131	45.89%	2024/7/30	0	2924.81	
542		0		精42	7863.28	454	0.00	0.00%	2024/6/1	0	6290.62	
543		0		精43	8573.4	495	43.07	8.70%	2024/1/18	0	6112.82	
544		0		精44	8573.4	495	114.24	23.08%	2024/3/29	0	4880.15	
545		0		精45	5542.4	320	11.51	3.60%	2024/1/7	0	4234.50	
546		0		精46	10392	600	83.496	13.92%	2024/7/17	0	6867.45	
547	科学园	0	10kV-42	科21	6928	400	49.34	12.33%	2024/6/11	0	4687.90	
548		0		科22	6928	400	219.609	54.90%	2024/7/18	0	1738.77	
549		0		科23	6928	400	78.047	19.51%	2024/7/30	0	4190.63	
550		0		科24	6928	400	132.656	33.16%	2024/7/23	0	3244.80	
551		0	10kV-43	科25	6928	400	277.383	69.35%	2024/7/24	0	738.13	
552		0		科26	6928	400	156.68	39.17%	2024/7/24	0	2828.70	
553		0		科27	6928	400	110.859	27.71%	2024/7/24	0	3622.32	
554		0	10kV-44	科31	6928	400	44.06	11.02%	2024/1/29	0	4779.25	
555		0		科32	6928	400	193.711	48.43%	2024/7/25	0	2187.33	
556		0		科33	6928	400	179.297	44.82%	2024/7/23	0	2436.98	
557		0		科34	6928	400	166.875	41.72%	2024/7/23	0	2652.13	
558		0		科35	6928	400	43.95	10.99%	2024/2/28	0	4781.27	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
559		0		科36	6928	400	170.977	42.74%	2024/7/11	0	2581.08	
560		0		科37	6928	400	134.414	33.60%	2024/7/24	0	3214.35	
561	临津园	0	10kV-4	津11	7257.08	419	251.98	60.14%	2024/6/29	0	1441.34	
562		0		津12	9006.4	520	10.811	2.08%	2024/7/26	0	7017.87	
563		0		津13	9006.4	520	321.00	61.73%	2024/1/2	0	1645.42	
564		0		津14	7897.92	456	41.40	9.08%	2024/3/7	0	5601.36	
565		0	10kV-5	津21	7257.08	419	227.40	54.27%	2024/1/23	0	1867.18	
566		0		津22	9006.4	520	199.80	38.42%	2024/1/2	0	3744.64	
567		0		津23	9006.4	520	317.99	61.15%	2024/1/2	0	1697.57	
568		0		津24	7897.92	456	311.99	68.42%	2024/1/5	0	914.67	
569	刘岗	0	10kV-4	刘11	6062	350	165.94	47.41%	2024/1/2	0	1975.55	
570		0		刘13	7257.08	419	216.21	51.60%	2024/1/14	0	2060.89	
571		0		刘14	7257.08	419	169.45	40.44%	2024/6/22	0	2870.74	
572		0	10kV-5	刘22	6373.76	368	0.352	0.10%	2024/7/1	0	5092.91	
573		0		刘23	6373.76	368	66.445	18.06%	2024/7/29	0	3948.18	
574		0		刘24	6062	350	182.11	52.03%	2024/1/7	0	1695.47	
575	美洲路	0	10kV-41	美11	6928	400	151.641	37.91%	2024/7/20	0	2915.98	
576		0		美12	6928	400	98.44	24.61%	2024/6/18	0	3837.45	
577		0		美16	6928	400	94.922	23.73%	2024/7/19	0	3898.35	
578		0		美17	6928	400	82.97	20.74%	2024/1/4	0	4105.38	
579		0		美18	6928	400	61.41	15.35%	2024/1/31	0	4478.85	
580		0	10kV-42	美21	6928	400	42.54	10.63%	2024/3/16	0	4805.62	
581		0		美22	6928	400	71.60	17.90%	2024/1/2	0	4302.25	
582		0		美23	6928	400	37.62	9.40%	2024/1/4	0	4890.87	
583		0	10kV-43	美25	6928	400	154.805	38.70%	2024/7/20	0	2861.18	
584		0		美26	6928	400	51.094	12.77%	2024/7/29	0	4657.45	
585	南环	0	10kV-41	南11	6928	400	10.547	2.64%	2024/7/26	0	5359.73	
586		0		南12	6928	400	134.41	33.60%	2024/6/27	0	3214.35	
587		0		南13	6928	400	249.14	62.29%	2024/6/15	0	1227.28	
588		0		南14	6928	400	191.48	47.87%	2024/6/4	0	2225.90	
589		0		南15	6928	400	63.87	15.97%	2024/6/18	0	4436.22	
590		0		南16	6928	400	136.64	34.16%	2024/1/4	0	3175.78	
591		0		南17	6928	400	213.40	53.35%	2024/6/13	0	1846.35	
592		0		南18	6928	400	0.00	0.00%	2024/6/1	0	5542.40	
593		0		南21	6928	400	0.00	0.00%	2024/6/1	0	5542.40	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
594		0	10kV-42	南22	6928	400	0.00	0.00%	2024/6/1	0	5542.40	
595		0		南23	6928	400	113.32	28.33%	2024/7/9	0	3579.70	
596		0		南24	6928	400	55.66	13.92%	2024/6/15	0	4578.30	
597		0	10kV-43	南25	6928	400	196.52	49.13%	2024/6/11	0	2138.62	
598		0		南26	6928	400	67.383	16.85%	2024/7/3	0	4375.33	
599		0		南27	6928	400	112.73	28.18%	2024/1/6	0	3589.85	
600		0		南28	6928	400	252.89	63.22%	2024/1/13	0	1162.33	
601		0	10kV-4	车11	5196	300	210.696	70.23%	2024/7/26	0	507.55	
602	宁车沽	0		车12	6408.4	370	181.19	48.97%	2024/3/25	0	1988.56	
603		0	10kV-5	车21	5196	300	61.19	20.40%	2024/6/26	0	3096.92	
604		0		车22	5196	300	183.472	61.16%	2024/7/24	0	979.06	
605	宁夏道	0	10kV-42	夏31	7707.4	445	86.75	19.49%	2024/7/20	0	4663.41	
606		0		夏32	8660	500	93.12	18.62%	2024/2/22	0	5315.25	
607		0		夏33	10894.28	629	49.92	7.94%	2024/7/1	0	7850.81	
608		0		夏34	9560.64	552	169.568	30.72%	2024/7/22	0	4711.59	
609		0	10kV-43	夏41	9924.36	573	16.90	2.95%	2024/7/14	0	7646.71	
610		0		夏42	8278.96	478	120.71	25.25%	2024/7/30	0	4532.54	
611		0	10kV-44	夏51	8660	500	77.42	15.48%	2024/1/23	0	5587.15	
612		0		夏52	7707.4	445	107.46	24.15%	2024/7/20	0	4304.71	
613		0		夏53	10894.28	629	50.66	8.05%	2024/1/11	0	7837.99	
614		0		夏54	9560.64	552	177.11	32.08%	2024/1/2	0	4581.04	
615		0		夏 ₆₁	9006.4	520	52.72	10.14%	2024/7/24	0	6292.06	
616		0		夏 ₆₂	8278.96	478	10.97	2.29%	2024/7/3	0	6433.18	
617		0		夏63	7534.2	435	57.98	13.33%	2024/2/13	0	5023.22	
618	农场	0	10kV-4	农11	5196	300	153.72	51.24%	2024/3/13	0	1494.35	
619		0		农12	5196	300	104.94	34.98%	2024/1/29	0	2339.22	
620		0	10kV-5	农21	5196	300	148.45	49.48%	2024/2/17	0	1585.70	
621		0		农22	5196	300	167.871	55.96%	2024/7/20	0	1249.27	
622		0		农23	5196	300	152.40	50.80%	2024/1/22	0	1517.20	
623		0		农24	5196	300	125.33	41.78%	2024/1/31	0	1986.05	
624	清河	0	10kV-4	931	4330	250	52.73	21.09%	2024/1/23	0	2550.65	
625		0		933	3464	200	131.953	65.98%	2024/7/24	0	485.77	
626		0		935	3464	200	44.297	22.15%	2024/7/8	0	2003.98	
627		0		937	4156.8	240	184.69	76.95%	2024/6/12	0	126.64	
628		0		932	4156.8	240	58.359	24.32%	2024/7/24	0	2314.66	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流（A）	最高负载 率（%）	最大负荷发生 日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注	
629		0	10kV-5	934	3464	200	148.125	74.06%	2024/7/30	0	205.68		
630		0		936	3464	200	107.11	53.55%	2024/1/23	0	916.07		
631		0		938	3464	200	158.91	79.45%	2024/6/12	0	18.95		
632	轻纺城	0	10kV-41	纺15	4433.92	256	41.88	16.36%	2024/3/27	0	2821.74		
633		0		纺16	6928	400	51.20	12.80%	2024/7/6	0	4655.55		
634		0		纺17	6928	400	134.35	33.59%	2024/7/1	0	3215.53		
635		10kV-42	纺25	6928	400	100.89	25.22%	2024/7/27	0	3795.00			
636			0	纺26	6928	400	307.54	76.88%	2024/7/2	0	215.88		
637		三道桥	0	10kV-41	桥11	7257.08	419	288.63	68.89%	2024/1/10	0	806.54	
638	0		桥13		8833.2	510	178.945	35.09%	2024/7/23	0	3967.23		
639	0		桥15		8833.2	510	180.703	35.43%	2024/7/23	0	3936.78		
640	0		桥16		7257.08	419	55.723	13.30%	2024/7/23	0	4840.54		
641	0		桥17		8833.2	510	211.641	41.50%	2024/7/23	0	3400.94		
642	10kV-42		桥22	7257.08	419	108.81	25.97%	2024/7/23	0	3921.09			
643			0	桥24	7257.08	419	194.94	46.53%	2024/6/30	0	2429.29		
644			0	桥25	7257.08	419	242.754	57.94%	2024/7/23	0	1601.16		
645	10kV-43		桥26	7257.08	419	180.53	43.09%	2024/1/7	0	2678.94			
646			0	桥27	8833.2	510	179.824	35.26%	2024/7/23	0	3952.01		
647			0	10kV-44	桥31	8833.2	510	186.504	36.57%	2024/7/23	0	3836.31	
648	0		桥32		7257.08	419	271.758	64.86%	2024/7/24	0	1098.82		
649	0		桥33		8833.2	510	168.047	32.95%	2024/7/23	0	4155.99		
650	0		桥34		7257.08	419	161.367	38.51%	2024/7/23	0	3010.79		
651	沙井子		0	10kV-4	井11	6928	400	209.30	52.32%	2024/1/4	0	1917.38	
652			0		井12	6928	400	222.888	55.72%	2024/7/30	0	1681.98	
653		0	10kV-5	井21	6928	400	77.168	19.29%	2024/7/29	0	4205.85		
654		0		井22	6928	400	168.608	42.15%	2024/7/19	0	2622.11		
655		0		井23	6928	400	75.92	18.98%	2024/7/25	0	4227.47		
656	胜利村	0	10kV-4	640	6928	400	65.98	16.49%	2024/7/22	0	4399.68		
657		0		641	6928	400	344.41	86.10%	2024/7/21	0	0.00		
658		0		643	6928	400	292.35	73.09%	2024/7/24	0	478.86		
659		0		645	6928	400	328.24	82.06%	2024/7/23	0	0.00		
660		0		647	6928	400	319.96	79.99%	2024/7/23	0	0.68		
661		0	10kV-5	642	6928	400	292.078	73.02%	2024/7/23	0	483.61		
662		0		644	6928	400	114.02	28.51%	2024/6/27	0	3567.52		
663		0		646	6928	400	103.48	25.87%	2024/7/24	0	3750.18		

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
664		0	10kV-3	648	6928	400	197.695	49.42%	2024/7/24	0	2118.32	
665		0		652	6928	400	291.49	72.87%	2024/7/24	0	493.76	
666		0		654	6928	400	175.195	43.80%	2024/7/5	0	2508.02	
667	双桥	0	10kV-4	双11	7257.08	419	8.79	2.10%	2024/1/6	0	5653.44	
668		0	10kV-5	双27	5196	300	206.59	68.86%	2024/3/1	0	578.71	
669	太平村	0	10kV-4	太11	7257.08	419	175.936	41.99%	2024/7/23	0	2758.45	
670		0		太13	7257.08	419	62.288	14.87%	2024/7/23	0	4726.84	
671		0		太14	7257.08	419	247.04	58.96%	2024/3/25	0	1526.93	
672		0	10kV-5	太21	7257.08	419	217.52	51.91%	2024/7/15	0	2038.22	
673		0		太22	7257.08	419	255.23	60.91%	2024/3/14	0	1385.05	
674		0		太23	7257.08	419	193.76	46.24%	2024/7/23	0	2449.74	
675	塘沽	0	10kV-1	141	8140.4	470	141.596	30.13%	2024/7/23	0	4059.88	
676		0		142	8833.2	510	276.35	54.19%	2024/7/23	0	2280.14	
677		0		143	8140.4	470	252.712	53.77%	2024/7/23	0	2135.35	
678		0		144	8140.4	470	131.156	27.91%	2024/7/23	0	4240.70	
679		0		145	8140.4	470	161.035	34.26%	2024/7/23	0	3723.19	
680		0		146	8833.2	510	158.995	31.18%	2024/7/23	0	4312.77	
681		0		147	7257.08	419	282.23	67.36%	2024/3/16	0	917.42	
682		0		148	8140.4	470	276.952	58.93%	2024/7/23	0	1715.51	
683		0	10kV-2甲	151	8140.4	470	357.109	75.98%	2024/7/23	0	327.19	
684		0		152	8833.2	510	184.43	36.16%	2024/3/24	0	3872.16	
685		0		153	7257.08	419	269.152	64.24%	2024/7/24	0	1143.95	
686		0		154	7257.08	419	80.638	19.25%	2024/7/30	0	4409.01	
687		0	10kV-2乙	155	8833.2	510	39.84	7.81%	2024/2/21	0	6376.55	
688		0		156	8140.4	470	182.634	38.86%	2024/7/20	0	3349.10	
689		0		157	8833.2	510	197.634	38.75%	2024/7/28	0	3643.54	
690		0		158	7257.08	419	258.95	61.80%	2024/6/24	0	1320.62	
691		0	10kV-3	161	7257.08	419	281.031	67.07%	2024/7/23	0	938.21	
692		0		162	8140.4	470	322.31	68.58%	2024/1/23	0	929.91	
693		0		163	8140.4	470	192.47	40.95%	2024/1/13	0	3178.67	
694		0		164	8140.4	470	247.672	52.70%	2024/7/23	0	2222.64	
695		0		165	8833.2	510	219.473	43.03%	2024/7/23	0	3265.29	
696		0		166	8140.4	470	307.551	65.44%	2024/7/23	0	1185.54	
697		0		167	8833.2	510	126.356	24.78%	2024/7/24	0	4878.07	
698		0		168	7257.08	419	226.79	54.13%	2024/6/22	0	1877.61	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
699	腾深	0	10kV-43	深31	13509.6	780	146.237	18.75%	2024/7/21	0	8274.86	
700		0		深32	12245.24	707	152.61	21.58%	2024/6/14	0	7153.07	
701		0		深34	8053.8	465	174.62	37.55%	2024/1/23	0	3418.62	
702		0	10kV-44	深41	5109.4	295	10.50	3.56%	2024/1/1	0	3905.61	
703		0		深46	9006.4	520	77.94	14.99%	2024/7/3	0	5855.22	
704		0	10kV-45	深51	13509.6	780	139.004	17.82%	2024/7/21	0	8400.13	
705		0		深52	12245.24	707	94.73	13.40%	2024/6/14	0	8155.56	
706		0	10kV-46	深61	5109.4	295	14.77	5.01%	2024/1/12	0	3831.74	
707		0		深66	9006.4	520	73.80	14.19%	2024/7/23	0	5926.90	
708	体育场	0	10kV-41	体11	8867.84	512	174.066	34.00%	2024/7/21	0	4079.45	
709		0		体12	9352.8	540	24.79	4.59%	2024/6/19	0	7052.86	
710		0		体13	9352.8	540	372.747	69.03%	2024/7/24	0	1026.26	
711		0		体14	9352.8	540	24.26	4.49%	2024/3/12	0	7061.99	
712		0	10kV-44	体31	8867.84	512	128.176	25.03%	2024/7/30	0	4874.26	
713		0		体32	9352.8	540	389.275	72.09%	2024/7/24	0	740.00	
714		0		体33	9352.8	540	171.429	31.75%	2024/7/24	0	4513.09	
715		0		体34	9352.8	540	5.451	1.01%	2024/7/30	0	7387.83	
716	填海	0	10kV-41	填11	8833.2	510	31.32	6.14%	2024/1/22	0	6524.13	
717		0		填12	9352.8	540	1.76	0.33%	2024/6/1	0	7451.79	
718		0		填13	7863.28	454	90.996	20.04%	2024/7/29	0	4714.57	
719		0		填17	7153.16	413	0.15	0.04%	2024/7/1	0	5720.00	
720		0		填18	9093	525	19.98	3.81%	2024/1/2	0	6928.35	
721		0	10kV-42	填21	7863.28	454	42.54	9.37%	2024/6/7	0	5553.85	
722		0		填22	9352.8	540	26.54	4.92%	2024/1/18	0	7022.52	
723		0		填23	7863.28	454	149.21	32.87%	2024/6/24	0	3706.32	
724		0		填27	9093	525	46.06	8.77%	2024/1/2	0	6476.73	
725		0		填28	9093	525	35.98	6.85%	2024/1/8	0	6651.28	
726	同进	0	10kV-41	同11	8677.32	501	137.17	27.38%	2024/1/13	0	4566.07	
727		0		同12	8677.32	501	244.095	48.72%	2024/7/24	0	2714.13	
728		0		同13	9352.8	540	23.946	4.43%	2024/7/11	0	7067.50	
729		0		同14	8677.32	501	2.14	0.43%	2024/2/26	0	6904.79	
730		0		同15	7534.2	435	171.07	39.33%	2024/6/6	0	3064.36	
731		0	10kV-42	同31	8677.32	501	141.78	28.30%	2024/1/10	0	4486.21	
732		0		同32	8677.32	501	146.01	29.14%	2024/1/25	0	4413.01	
733		0		同33	9352.8	540	176.42	32.67%	2024/1/10	0	4426.59	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
734		0	10kV-42	同34	8677.32	501	2.04	0.41%	2024/1/5	0	6906.56	
735		0		同35	7534.2	435	233.802	53.75%	2024/7/12	0	1977.91	
736		0		同36	9352.8	540	34.735	6.43%	2024/7/12	0	6880.63	
737	团结路	0	10kV-41	团11	7257.08	419	165.41	39.48%	2024/1/8	0	2940.76	
738		0		团12	7257.08	419	164.36	39.23%	2024/6/20	0	2959.04	
739		0		团14	7257.08	419	21.09	5.03%	2024/1/6	0	5440.32	
740		0		团15	8486.8	490	140.80	28.73%	2024/1/4	0	4350.77	
741		0		团16	7257.08	419	1.06	0.25%	2024/6/1	0	5787.39	
742		0		团17	8660	500	227.285	45.46%	2024/7/26	0	2991.42	
743		0		团18	8833.2	510	159.43	31.26%	2024/1/23	0	4305.16	
744		0	10kV-42	团21	7257.08	419	162.42	38.76%	2024/1/6	0	2992.51	
745		0		团22	8833.2	510	253.13	49.63%	2024/1/18	0	2682.44	
746		0		团23	7257.08	419	0.53	0.13%	2024/3/19	0	5796.54	
747		0		团24	8660	500	1.934	0.39%	2024/7/22	0	6894.50	
748		0	10kV-43	团25	8486.8	490	71.719	14.64%	2024/7/2	0	5547.27	
749		0		团26	7257.08	419	44.30	10.57%	2024/1/20	0	5038.44	
750		0		团27	7257.08	419	111.27	26.56%	2024/3/20	0	3878.47	
751		0		团28	7257.08	419	91.58	21.86%	2024/1/10	0	4219.46	
752	王庄镇	0	10kV-4	王11	7257.08	419	51.24	12.23%	2024/2/26	0	4918.19	
753		0		王12	7257.08	419	59.45	14.19%	2024/6/26	0	4776.02	
754		0		王14	7257.08	419	91.112	21.75%	2024/7/23	0	4227.60	
755		0		王15	6928	400	77.35	19.34%	2024/6/24	0	4202.66	
756		0	10kV-5	王21	7257.08	419	84.568	20.18%	2024/7/23	0	4340.95	
757		0		王22	6235.2	360	87.56	24.32%	2024/7/24	0	3471.62	
758		0		王24	7257.08	419	124.512	29.72%	2024/7/23	0	3649.12	
759		0		王25	7257.08	419	148.616	35.47%	2024/7/21	0	3231.63	
760		0		王26	7257.08	419	91.66	21.87%	2024/1/25	0	4218.18	
761		0	10kV-41	西11	6928	400	99.14	24.79%	2024/1/2	0	3825.28	
762		0		西12	6928	400	187.266	46.82%	2024/7/23	0	2298.95	
763		0		西13	6928	400	80.742	20.19%	2024/7/30	0	4143.95	
764		0		西14	6928	400	154.10	38.53%	2024/1/23	0	2873.35	
765		0		西15	6928	400	76.76	19.19%	2024/6/20	0	4212.95	
766		0		西16	6928	400	239.30	59.82%	2024/6/28	0	1397.78	
767		0		西21	6928	400	113.32	28.33%	2024/7/23	0	3579.70	
768		0		西22	6928	400	15.94	3.98%	2024/7/28	0	5266.35	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
769	西沽	0	10kV-42	西23	6928	400	257.58	64.39%	2024/1/24	0	1081.15	
770		0		西24	6928	400	247.5	61.88%	2024/7/23	0	1255.70	
771		0		西25	6928	400	54.023	13.51%	2024/7/30	0	4606.72	
772		0		西26	6928	400	126.68	31.67%	2024/7/20	0	3348.30	
773		0		西31	6928	400	90.94	22.73%	2024/1/22	0	3967.35	
774		0	10kV-43	西32	6928	400	239.414	59.85%	2024/7/23	0	1395.75	
775		0		西33	6928	400	114.84	28.71%	2024/2/26	0	3553.30	
776		0		西34	6928	400	214.453	53.61%	2024/7/29	0	1828.07	
777		0		西35	6928	400	237.656	59.41%	2024/7/23	0	1426.20	
778		0		西36	6928	400	128.20	32.05%	2024/3/30	0	3321.92	
779		0		西41	6928	400	127.5	31.88%	2024/7/23	0	3334.10	
780		0	10kV-44	西42	6928	400	8.79	2.20%	2024/7/24	0	5390.17	
781		0		西43	6928	400	143.91	35.98%	2024/3/30	0	3049.95	
782		0		西44	6928	400	96.094	24.02%	2024/7/23	0	3878.05	
783	新北路	0	10kV-5	582	6928	400	183.98	46.00%	2024/6/22	0	2355.80	
784		0		583	6928	400	76.641	19.16%	2024/7/23	0	4214.98	
785		0		584	6928	400	181.406	45.35%	2024/7/23	0	2400.45	
786		0		585	6928	400	273.281	68.32%	2024/7/29	0	809.17	
787		0		586	6928	400	84.84	21.21%	2024/3/4	0	4072.90	
788		0	10kV-4	588	6928	400	10.31	2.58%	2024/6/5	0	5363.80	
789		0		589	6928	400	48.281	12.07%	2024/7/23	0	4706.17	
790		0		590	6928	400	193.83	48.46%	2024/6/20	0	2185.30	
791		0		591	6928	400	55.55	13.89%	2024/1/23	0	4580.33	
792		0		592	6928	400	274.688	68.67%	2024/7/30	0	784.80	
793		0		593	6928	400	197.578	49.39%	2024/7/24	0	2120.35	
794	新村	0	10kV-41	村11	8833.2	510	172.22	33.77%	2024/6/22	0	4083.64	
795		0		村13	8833.2	510	297.06	58.25%	2024/6/22	0	1921.48	
796		0		村14	8833.2	510	152.34	29.87%	2024/1/22	0	4428.03	
797		0		村15	8833.2	510	114.252	22.40%	2024/7/24	0	5087.72	
798		0		村16	8833.2	510	38.39	7.53%	2024/1/8	0	6401.68	
799		0		村17	7257.08	419	291.348	69.53%	2024/7/23	0	759.52	
800		0	10kV-42	村21	8833.2	510	228.06	44.72%	2024/7/24	0	3116.56	
801		0		村22	8833.2	510	118.416	23.22%	2024/7/23	0	5015.59	
802		0	10kV-43	村25	8833.2	510	103.14	20.22%	2024/6/18	0	5280.18	
803		0		村26	8833.2	510	158.4	31.06%	2024/7/23	0	4323.07	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
804		0	10kV-43	村27	8833.2	510	161.38	31.64%	2024/3/14	0	4271.53	
805		0		村28	8833.2	510	137.16	26.89%	2024/7/23	0	4690.95	
806		0	10kV-44	村31	8833.2	510	96.78	18.98%	2024/7/23	0	5390.33	
807		0		村32	8833.2	510	44.604	8.75%	2024/7/29	0	6294.02	
808		0		村33	7257.08	419	140.112	33.44%	2024/7/30	0	3378.92	
809		0		村34	8833.2	510	311.856	61.15%	2024/7/24	0	1665.21	
810		0		村35	8833.2	510	195.25	38.28%	2024/6/20	0	3684.80	
811		0		村36	8833.2	510	142.14	27.87%	2024/3/13	0	4604.70	
812		0		村38	8833.2	510	9.08	1.78%	2024/1/4	0	6909.23	
813	新港	0	10kV-41	港11	8833.2	510	174.02	34.12%	2024/6/11	0	4052.48	
814		0		港12	8833.2	510	61.70	12.10%	2024/1/21	0	5997.93	
815		0		港13	8833.2	510	89.648	17.58%	2024/7/23	0	5513.86	
816		0		港14	8833.2	510	169.629	33.26%	2024/7/23	0	4128.59	
817		0		港17	8833.2	510	117.60	23.06%	2024/3/1	0	5029.76	
818		0		港18	8833.2	510	136.055	26.68%	2024/7/6	0	4710.09	
819		0	10kV-42	港21	8833.2	510	272.637	53.46%	2024/7/24	0	2344.49	
820		0		港24	8833.2	510	219.727	43.08%	2024/7/21	0	3260.89	
821		0	10kV-43	港25	8833.2	510	323.086	63.35%	2024/7/24	0	1470.71	
822		0		港26	8833.2	510	177.715	34.85%	2024/7/23	0	3988.54	
823		0		港27	8486.8	490	305.508	62.35%	2024/7/23	0	1498.04	
824		0		港28	8833.2	510	192.305	37.71%	2024/7/29	0	3735.84	
825	新河	0	10kV-41	河11	7257.08	419	193.887	46.27%	2024/7/23	0	2447.54	
826		0		河12	8486.8	490	76.99	15.71%	2024/3/18	0	5455.94	
827		0		河13	7257.08	419	148.711	35.49%	2024/7/23	0	3229.99	
828		0		河14	7257.08	419	176.484	42.12%	2024/7/23	0	2748.96	
829		0		河15	8486.8	490	209.707	42.80%	2024/7/23	0	3157.31	
830		0		河16	8833.2	510	36.74	7.20%	2024/3/26	0	6430.26	
831		0		河17	8833.2	510	258.926	50.77%	2024/7/23	0	2581.96	
832		0	10kV-42	河21	7309.04	422	17.93	4.25%	2024/7/23	0	5536.68	
833		0		河23	8486.8	490	37.44	7.64%	2024/1/10	0	6140.96	
834		0		河24	8486.8	490	190.898	38.96%	2024/7/24	0	3483.09	
835		0	10kV-43	河25	7257.08	419	191.777	45.77%	2024/7/19	0	2484.09	
836		0		河26	8833.2	510	80.508	15.79%	2024/7/23	0	5672.16	
837		0		河27	7257.08	419	193.008	46.06%	2024/7/23	0	2462.77	
838		0		河31	8833.2	510	260.684	51.11%	2024/7/23	0	2551.51	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
839		0	10kV-44	河32	8833.2	510	0.00	0.00%	2024/6/1	0	7066.56	
840		0		河33	8486.8	490	271.23	55.35%	2024/7/23	0	2091.74	
841		0		河34	7309.04	422	17.75	4.21%	2024/7/19	0	5539.73	
842		0		河36	8486.8	490	178.242	36.38%	2024/7/23	0	3702.29	
843		0		河37	8833.2	510	116.543	22.85%	2024/7/8	0	5048.04	
844	新民路	0	10kV-41	471	6928	400	192.48	48.12%	2024/7/21	0	2208.65	
845		0		472	6928	400	43.52	10.88%	2024/1/2	0	4788.63	
846		0		473	9352.8	540	263.96	48.88%	2024/7/21	0	2910.45	
847		0		474	9352.8	540	88.478	16.38%	2024/7/23	0	5949.80	
848		0	10kV-42	481	8833.2	510	93.12	18.26%	2024/3/7	0	5453.72	
849		0		482	7257.08	419	137.60	32.84%	2024/2/25	0	3422.43	
850		0		483	7257.08	419	238.72	56.97%	2024/7/26	0	1671.03	
851		0		484	7257.08	419	206.08	49.18%	2024/1/15	0	2236.36	
852		0	10kV-43	485	8833.2	510	82.88	16.25%	2024/7/21	0	5631.08	
853		0		486	8833.2	510	221.92	43.51%	2024/7/15	0	3222.91	
854		0		487	7257.08	419	163.04	38.91%	2024/7/24	0	2981.81	
855		0		488	9560.64	552	161.28	29.22%	2024/7/19	0	4855.14	
856		0	10kV-44	461	9352.8	540	92.255	17.08%	2024/7/23	0	5884.38	
857		0		462	9352.8	540	178.881	33.13%	2024/7/30	0	4384.02	
858		0		491	7257.08	419	305.12	72.82%	2024/7/19	0	520.99	
859		0		492	10392	600	144.48	24.08%	2024/7/19	0	5811.21	
860		0		493	7257.08	419	293.4	70.02%	2024/7/18	0	723.98	
861		0		494	11933.48	689	20.48	2.97%	2024/1/11	0	9192.07	
862		0		495	8833.2	510	234.72	46.02%	2024/1/17	0	3001.21	
863		0		496	8833.2	510	195.68	38.37%	2024/7/23	0	3677.38	
864		0		497	8486.8	490	189.92	38.76%	2024/6/12	0	3500.03	
865		0		498	9560.64	552	102.72	18.61%	2024/7/29	0	5869.40	
866	新义路	0	10kV-41	圣13	9439.4	545	399.501	73.30%	2024/7/19	0	632.16	
867		0	10kV-42	圣21	7257.08	419	195.57	46.68%	2024/1/29	0	2418.36	
868		0		圣23	8053.8	465	151.313	32.54%	2024/7/24	0	3822.30	
869		0		圣24	8486.8	490	240.254	49.03%	2024/7/16	0	2628.24	
870		0	10kV-43	圣25	7257.08	419	140.422	33.51%	2024/7/22	0	3373.55	
871		0		圣26	7534.2	435	105.705	24.30%	2024/7/29	0	4196.55	
872		0		圣27	9283.52	536	276.15	51.52%	2024/6/27	0	2643.92	
873		0		圣28	8053.8	465	67.659	14.55%	2024/7/22	0	5271.19	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
874	柳全路	0	10kV-44	圣31	7257.08	419	102.64	24.50%	2024/1/11	0	4027.94	
875		0		圣32	8833.2	510	170.876	33.51%	2024/7/29	0	4106.99	
876		0		圣33	8833.2	510	286.819	56.24%	2024/7/8	0	2098.85	
877		0		圣34	9785.8	565	165.302	29.26%	2024/7/29	0	4965.61	
878		0		圣35	9439.4	545	165.469	30.36%	2024/7/17	0	4685.60	
879		0		圣36	8833.2	510	140.24	27.50%	2024/6/6	0	4637.57	
880		0		圣37	9785.8	565	173.557	30.72%	2024/7/27	0	4822.63	
881		0		圣38	8053.8	465	184.888	39.76%	2024/7/25	0	3240.78	
882	兴塘	0	10kV-41	兴11	6928	400	265.43	66.36%	2024/7/24	0	945.15	
883		0		兴12	6928	400	180.59	45.15%	2024/1/22	0	2414.65	
884		0		兴13	6928	400	230.39	57.60%	2024/1/19	0	1552.03	
885		0		兴14	6928	400	318.047	79.51%	2024/7/23	0	33.83	
886		0		兴15	6928	400	4.805	1.20%	2024/7/26	0	5459.18	
887		0	10kV-42	兴21	6928	400	5.39	1.35%	2024/1/23	0	5449.03	
888		0		兴22	6928	400	249.844	62.46%	2024/7/24	0	1215.10	
889		0		兴23	6928	400	174.96	43.74%	2024/1/19	0	2512.08	
890		0		兴24	6928	400	252.891	63.22%	2024/7/23	0	1162.33	
891		0		兴25	6928	400	5.391	1.35%	2024/7/26	0	5449.03	
892		0	10kV-43	兴32	6928	400	272.70	68.17%	2024/1/3	0	819.32	
893		0		兴33	6928	400	5.625	1.41%	2024/7/26	0	5444.98	
894		0		兴34	6928	400	187.734	46.93%	2024/7/23	0	2290.85	
895		0		兴35	6928	400	74.53	18.63%	2024/2/20	0	4251.52	
896		0		兴36	6928	400	281.133	70.28%	2024/7/24	0	673.18	
897		0	10kV-44	兴41	6928	400	4.805	1.20%	2024/7/26	0	5459.18	
898		0		兴42	6928	400	87.66	21.91%	2024/6/30	0	4024.20	
899		0		兴43	6928	400	250.31	62.58%	2024/7/19	0	1207.00	
900		0		兴44	6928	400	181.06	45.26%	2024/1/19	0	2406.53	
901		0		兴45	6928	400	153.40	38.35%	2024/1/29	0	2885.55	
902		0		兴46	6928	400	42.42	10.61%	2024/1/2	0	4807.65	
903	杨柳庄	0	10kV-4	杨11	6928	400	60.94	15.24%	2024/6/29	0	4486.90	
904		0		杨12	6928	400	211.45	52.86%	2024/6/4	0	1880.16	
905		0		杨13	6928	400	64.221	16.06%	2024/7/21	0	4430.09	
906		0		杨14	6928	400	131.929	32.98%	2024/7/18	0	3257.39	
907		0		杨15	6928	400	87.53	21.88%	2024/3/24	0	4026.43	
908		0		杨21	6928	400	97.51	24.38%	2024/1/22	0	3853.61	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
909		0	10kV-5	杨22	6928	400	34.907	8.73%	2024/7/24	0	4937.81	
910		0		杨23	6928	400	238.76	59.69%	2024/6/3	0	1407.13	
911		0		杨24	6928	400	126.41	31.60%	2024/3/18	0	3353.07	
912		0		杨25	6928	400	125.39	31.35%	2024/1/22	0	3370.63	
913	营城	0	10kV-42	营21	8313.6	480	319.82	66.63%	2024/1/16	0	1111.53	
914		0		营22	8313.6	480	199.736	41.61%	2024/7/12	0	3191.45	
915		0		营23	8313.6	480	296.439	61.76%	2024/7/24	0	1516.56	
916		0		营24	7257.08	419	220.48	52.62%	2024/1/1	0	1986.90	
917		0	10kV-43	营25	7257.08	419	296.44	70.75%	2024/6/25	0	671.34	
918		0		营26	7447.6	430	203.78	47.39%	2024/7/16	0	2428.61	
919		0		营27	8660	500	48	9.60%	2024/7/18	0	6096.64	
920		0		营28	9266.2	535	0.00	0.00%	2024/7/1	0	7412.96	
921		0	10kV-44	营31	9352.8	540	106.725	19.76%	2024/7/23	0	5633.76	
922		0		营32	7257.08	419	186.02	44.40%	2024/1/1	0	2583.76	
923		0		营33	7257.08	419	299.60	71.50%	2024/6/18	0	616.52	
924		0		营34	8313.6	480	10.20	2.12%	2024/1/29	0	6474.25	
925		0		营36	7447.6	430	168.62	39.21%	2024/1/4	0	3037.67	
926		0		营37	8660	500	10.198	2.04%	2024/7/16	0	6751.37	
927		0		营38	9006.4	520	0.00	0.00%	2024/7/1	0	7205.12	
928		0	10kV-41	永13	7863.28	454	271.42	59.78%	2024/6/15	0	1589.70	
929		0		永14	7447.6	430	183.74	42.73%	2024/7/25	0	2775.63	
930		0		永22	9577.96	553	283.92	51.34%	2024/6/25	0	2744.87	
931		0	10kV-42	永33	7863.28	454	275.34	60.65%	2024/1/9	0	1521.74	
932	游乐港	0	10kV-41	乐11	10392	600	49.06	8.18%	2024/1/1	0	7463.85	
933		0		乐12	6928	400	296.706	74.18%	2024/7/23	0	403.45	
934		0		乐13	6928	400	55.643	13.91%	2024/7/28	0	4578.66	
935		0		乐14	6928	400	263.85	65.96%	2024/7/12	0	972.52	
936		0		乐15	6928	400	260.745	65.19%	2024/7/23	0	1026.30	
937		0		乐16	6928	400	118.70	29.68%	2024/1/23	0	3486.46	
938		0	10kV-42	乐21	10392	600	49.06	8.18%	2024/1/1	0	7463.85	
939		0		乐22	6928	400	293.867	73.47%	2024/7/23	0	452.62	
940		0		乐23	6928	400	69.08	17.27%	2024/7/23	0	4345.93	
941		0		乐24	6928	400	90.50	22.63%	2024/1/3	0	3974.92	
942		0		乐25	6928	400	90.187	22.55%	2024/7/23	0	3980.36	
943		0		乐26	6928	400	48.53	12.13%	2024/7/26	0	4701.86	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
944		0	10kV-43	乐31	6928	400	262.75	65.69%	2024/7/12	0	991.57	
945	友谊路	0	10kV-4	561	6928	400	93.567	23.39%	2024/7/23	0	3921.82	
946		0		562	6928	400	174.907	43.73%	2024/7/24	0	2513.01	
947		0		563	6928	400	271.52	67.88%	2024/6/24	0	839.74	
948		0		564	6928	400	180.623	45.16%	2024/7/24	0	2414.01	
949		0	10kV-5	565	6928	400	199.39	49.85%	2024/6/20	0	2088.98	
950		0		566	6928	400	182.46	45.61%	2024/6/20	0	2382.24	
951		0		567	6928	400	196.145	49.04%	2024/7/24	0	2145.17	
952		0		568	6928	400	115.194	28.80%	2024/7/23	0	3547.24	
953	于家堡	0	10kV-41	于11	6928	400	43.51	10.88%	2024/2/15	0	4788.88	
954		0		于12	6928	400	117.74	29.44%	2024/1/2	0	3503.07	
955		0		于13	6928	400	38.88	9.72%	2024/6/5	0	4869.05	
956		0		于14	6928	400	264.287	66.07%	2024/7/21	0	964.95	
957		0	10kV-42	于21	6928	400	44.68	11.17%	2024/1/24	0	4768.58	
958		0		于22	6928	400	36.05	9.01%	2024/1/22	0	4918.01	
959		0		于23	6928	400	41.001	10.25%	2024/7/30	0	4832.26	
960		0		于24	6928	400	8.013	2.00%	2024/7/26	0	5403.61	
961		0	10kV-43	于25	6928	400	59.50	14.88%	2024/1/23	0	4511.83	
962		0		于26	6928	400	50.903	12.73%	2024/7/25	0	4660.76	
963		0		于31	6928	400	40.58	10.14%	2024/1/25	0	4839.62	
964		0		于32	6928	400	58.62	14.66%	2024/1/3	0	4527.05	
965		0		于33	6928	400	36.87	9.22%	2024/7/22	0	4903.81	
966		0		于34	6928	400	56.31	14.08%	2024/1/4	0	4567.13	
967		0	10kV-44	于35	6928	400	19.03	4.76%	2024/2/1	0	5212.84	
968		0		于41	6928	400	32.75	8.19%	2024/1/22	0	4975.10	
969		0		于42	6928	400	290.303	72.58%	2024/7/24	0	514.35	
970		0		于43	6928	400	60.029	15.01%	2024/7/23	0	4502.70	
971		0		于44	6928	400	60.029	15.01%	2024/7/23	0	4502.70	
972	海江	0	10kV-41	鲤11	8833.2	510	116.873	22.92%	2024/7/30	0	5042.32	
973		0		鲤12	7257.08	419	170.398	40.67%	2024/7/30	0	2854.37	
974		0		鲤13	8140.4	470	121.79	25.91%	2024/6/21	0	4402.85	
975		0		鲤14	9560.64	552	123.838	22.43%	2024/7/30	0	5503.64	
976		0		鲤15	9093	525	193.799	36.91%	2024/7/25	0	3917.80	
977		0		鲤16	9560.64	552	18.589	3.37%	2024/7/30	0	7326.55	
978		0		鲤17	9560.64	552	2.88	0.52%	2024/6/2	0	7598.67	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
979	泗港	0	10kV-42	鲤21	8833.2	510	221.265	43.39%	2024/7/20	0	3234.25	
980		0		鲤22	7257.08	419	145.547	34.74%	2024/7/12	0	3284.79	
981		0	10kV-44	鲤31	8833.2	510	105.117	20.61%	2024/7/30	0	5245.93	
982		0		鲤32	7257.08	419	103.07	24.60%	2024/1/24	0	4020.42	
983		0		鲤33	9560.64	552	39.485	7.15%	2024/7/30	0	6964.63	
984		0		鲤36	9560.64	552	18.721	3.39%	2024/7/20	0	7324.26	
985		0		鲤37	9560.64	552	2.88	0.52%	2024/6/1	0	7598.67	
986		0										
987	玉辰	0	10kV-42	辰31	10392	600	252.731	42.12%	2024/7/30	0	3936.30	
988		0		辰32	10392	600	316.467	52.74%	2024/7/28	0	2832.39	
989		0		辰33	10392	600	419.914	69.99%	2024/7/24	0	1040.69	
990		0		辰34	8053.8	465	202.75	43.60%	2024/1/27	0	2931.50	
991		0		辰35	9560.64	552	120.06	21.75%	2024/3/2	0	5569.09	
992		0	10kV-43	辰41	10392	600	2.71	0.45%	2024/1/2	0	8266.61	
993		0		辰42	10392	600	2.74	0.46%	2024/3/1	0	8266.18	
994		0		辰44	9560.64	552	11.442	2.07%	2024/7/28	0	7450.34	
995		0		辰46	10340.04	597	128.932	21.60%	2024/7/5	0	6038.93	
996		0	10kV-44	辰51	10392	600	420.87	70.14%	2024/1/30	0	1024.22	
997		0		辰52	10392	600	326.894	54.48%	2024/7/22	0	2651.80	
998		0		辰53	10392	600	262.204	43.70%	2024/7/23	0	3772.23	
999		0		辰54	8053.8	465	44.34	9.54%	2024/1/29	0	5675.11	
1000		0		辰55	9560.64	552	53.597	9.71%	2024/7/23	0	6720.21	
1001		0		辰63	10392	600	2.73	0.46%	2024/3/13	0	8266.25	
1002		0		辰64	9560.64	552	121.666	22.04%	2024/7/12	0	5541.26	
1003		0		辰66	10340.04	597	19.031	3.19%	2024/7/5	0	7942.42	
1004	漳州道	0	10kV-41	漳11	8833.2	510	216.562	42.46%	2024/7/23	0	3315.71	
1005		0		漳12	8486.8	490	142.207	29.02%	2024/7/23	0	4326.41	
1006		0		漳13	8486.8	490	167.876	34.26%	2024/7/29	0	3881.83	
1007		0		漳14	8486.8	490	214.45	43.77%	2024/1/19	0	3075.11	
1008		0		漳15	8833.2	510	164.531	32.26%	2024/7/23	0	4216.88	
1009		0		漳16	8486.8	490	196.70	40.14%	2024/2/23	0	3382.61	
1010		0		漳17	8833.2	510	154.51	30.30%	2024/2/26	0	4390.41	
1011		0		漳18	8833.2	510	187.56	36.78%	2024/6/13	0	3818.04	
1012		0		漳21	8486.8	490	242.93	49.58%	2024/7/29	0	2581.89	
1013		0		漳22	8486.8	490	158.379	32.32%	2024/7/23	0	4046.32	
		0		漳23	8486.8	490	122.168	24.93%	2024/7/24	0	4673.49	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1014		0	10kV-43	漳24	8486.8	490	172.793	35.26%	2024/7/29	0	3796.67	
1015		0		漳25	8833.2	510	185.801	36.43%	2024/7/23	0	3848.49	
1016		0		漳26	8833.2	510	180.53	35.40%	2024/6/13	0	3939.83	
1017		0		漳27	8833.2	510	102.83	20.16%	2024/2/23	0	5285.51	
1018		0		漳28	8330.92	481	222.539	46.27%	2024/7/23	0	2810.36	
1019	中塘	0	10kV-41	中11	7257.08	419	178.42	42.58%	2024/7/14	0	2715.46	
1020		0		中15	7257.08	419	217.09	51.81%	2024/7/23	0	2045.67	
1021		0		中17	7257.08	419	217.969	52.02%	2024/7/15	0	2030.44	
1022		0	10kV-42	中21	7257.08	419	182.52	43.56%	2024/7/21	0	2644.42	
1023		0		中22	7257.08	419	280.66	66.98%	2024/1/24	0	944.56	
1024		0	10kV-43	中24	8573.4	495	194.24	39.24%	2024/1/17	0	3494.52	
1025		0		中26	7257.08	419	295.90	70.62%	2024/1/10	0	680.71	
1026		0	10kV-44	中31	8573.4	495	130.957	26.46%	2024/7/23	0	4590.54	
1027		0		中32	7257.08	419	304.10	72.58%	2024/3/8	0	538.62	
1028		0		中34	7257.08	419	129.49	30.91%	2024/1/6	0	3562.86	
1029		0		中36	7257.08	419	298.83	71.32%	2024/1/3	0	629.96	
1030	珠江道	0	10kV-41	珠11	6928	400	58.02	14.51%	2024/3/14	0	4537.46	
1031		0		珠12	6928	400	86.92	21.73%	2024/6/18	0	4036.88	
1032		0		珠13	6928	400	137.23	34.31%	2024/6/21	0	3165.63	
1033		0		珠14	7620.8	440	349.15	79.35%	2024/7/30	0	49.43	
1034		0		珠15	6928	400	275.786	68.95%	2024/7/12	0	765.79	
1035		0	10kV-42	珠21	6928	400	152.212	38.05%	2024/7/30	0	2906.09	
1036		0		珠22	6928	400	98.936	24.73%	2024/7/27	0	3828.83	
1037		0		珠23	6928	400	42.85	10.71%	2024/3/26	0	4800.29	
1038		0		珠24	6928	400	94.25	23.56%	2024/3/18	0	3910.02	
1039		0	10kV-45	珠51	6928	400	92.842	23.21%	2024/7/3	0	3934.38	
1040		0		珠52	6928	400	109.75	27.44%	2024/6/4	0	3641.60	
1041		0		珠53	6928	400	112.56	28.14%	2024/1/16	0	3592.88	
1042		0		珠54	6928	400	207.36	51.84%	2024/6/25	0	1950.87	
1043		0	10kV-46	珠61	6928	400	76.04	19.01%	2024/3/12	0	4225.39	
1044		0		珠62	6928	400	107.534	26.88%	2024/7/29	0	3679.91	
1045		0		珠63	6928	400	48.49	12.12%	2024/1/24	0	4702.62	
1046		0		珠64	6928	400	271.201	67.80%	2024/7/29	0	845.20	