

宝坻供电公司10千伏配电线路可开放容量信息表（2025年第一季度）

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
1	宝坻.八门城站	0	10kV-4	小甸八13	7274.4	400	203.72	50.93%	2024/1/1 16:38:00	0	2115	
2		0		西十村八14	7274.4	400	198.41	49.60%	2024/7/29 17:04:00	0	2211	
3		0		八门城八15	6546.96	360	213.10	59.19%	2024/7/31 13:19:00	0	1362	
4		0	10kV-5	箭杆河八21	6546.96	360	128.87	35.80%	2024/8/3 9:53:00	0	2894	
5		0		袁罗八22	7274.4	400	9.37	2.34%	2024/2/9 7:52:00	0	5649	
6		0		康庄八23	7274.4	400	159.24	39.81%	2024/8/5 15:04:00	0	2924	
7	宝坻.北申庄站	0	10kV-41	八间房申11	9147.558	503	87.52	17.40%	2024/12/24 22:18:00	0	5726	
8		0		南业东申12	9147.558	503	177.22	35.23%	2024/12/24 8:34:00	0	4095	
9		0		北辛庄申13	9147.558	503	179.30	35.65%	2024/12/7 17:34:00	0	4057	
10		0		张兰庄申14	9147.558	503	75.83	15.08%	2024/2/26 7:28:00	0	5939	
11		0		谭东申15	9147.558	503	65.51	13.02%	2024/1/22 7:11:00	0	6127	
12		0		艾家口申16	9147.558	503	92.41	18.37%	2024/6/19 10:18:00	0	5637	
13		0		李家口申21	9147.558	503	46.85	9.31%	2024/1/2 7:16:00	0	6466	
14		0		马厂申22	9147.558	503	5.57	1.11%	2024/9/29 7:09:00	0	7217	
15		0		西庄沽申23	9147.558	503	81.16	16.14%	2024/1/22 7:18:00	0	5842	
16		0	10kV-42	小陈申31	9147.558	503	205.98	40.95%	2024/12/16 20:32:00	0	3572	
17		0		南庄申32	9147.558	503	0.00	0.00%	2024/9/16 0:00:00	0	7318	
18		0		老艾口申33	9147.558	503	85.82	17.06%	2024/11/7 9:01:00	0	5757	
19		0		苗家庄申34	9147.558	503	65.66	13.05%	2024/1/22 7:24:00	0	6124	
20		0	10kV-43	埝北村申41	9147.558	503	243.49	48.41%	2024/12/18 9:00:00	0	2890	
21		0		车轱村申42	9147.558	503	156.90	31.19%	2024/12/24 8:39:00	0	4465	
22		0		谭西申43	9147.558	503	0.00	0.00%	2024/1/14 0:00:00	0	7318	
23		0		小苑庄申44	9147.558	503	28.75	5.72%	2024/12/28 7:40:00	0	6795	
24		0		大赵庄申45	9147.558	503	93.14	18.52%	2024/1/8 8:48:00	0	5624	
25		0		张家庄申51	9147.558	503	82.74	16.45%	2024/12/18 20:22:00	0	5813	
26		0		张松申52	9147.558	503	241.90	48.09%	2024/12/16 20:32:00	0	2919	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
27		0	10kV-44	工部申53	9147.558	503	180.46	35.88%	2024/12/17 9:44:00	0	4036	
28		0		佟家庄申54	9147.558	503	56.52	11.24%	2024/1/2 9:35:00	0	6290	
29		0		窑上村申55	9147.558	503	58.00	11.53%	2024/1/22 7:31:00	0	6263	
30		0		伍麻村申56	9147.558	503	56.08	11.15%	2024/2/18 15:20:00	0	6298	
31		0		边家庄申61	9147.558	503	92.05	18.30%	2024/11/7 9:00:00	0	5644	
32		0		北芮村申62	9147.558	503	30.74	6.11%	2024/12/27 20:05:00	0	6759	
33	宝坻.菜园站	0	10kV-4	韩庄园13	6546.96	360	84.20	23.39%	2024/1/23 17:54:00	0	3706	
34		0		高四台园14	9147.558	503	283.36	56.33%	2024/8/3 13:16:00	0	2165	
35		0		区东园15	6546.96	360	286.51	79.59%	2024/1/5 9:09:00	0	27	
36		0		庞家湾园16	6546.96	360	134.30	37.31%	2024/1/23 17:27:00	0	2795	
37		0	10kV-5	林场园23	9147.558	503	121.82	24.22%	2024/12/10 17:17:00	0	5103	
38		0		吴家牌园24	9147.558	503	291.80	58.01%	2024/6/13 17:28:00	0	2011	
39		0		华尖园25	9147.558	503	186.16	37.01%	2024/11/14 8:52:00	0	3933	
40		0		区西园26	9147.558	503	171.21	34.04%	2024/11/1 10:30:00	0	4204	
41	宝坻.城东站	0	10kV-41	钰华东11	8547.42	470	217.05	46.18%	2024/1/22 13:19:00	0	2891	
42		0		区委二东12	8547.42	470	321.05	68.31%	2024/6/26 10:59:00	0	999	
43		0		顺驰东13	8547.42	470	291.96	62.12%	2024/7/12 10:04:00	0	1528	
44		0		泰富东14	8547.42	470	236.48	50.31%	2024/11/28 10:39:00	0	2537	
45		0		金玉一东15	8547.42	470	131.08	27.89%	2024/11/7 10:34:00	0	4454	
46		0		怡锦一东16	9729.51	535	12.22	2.28%	2024/7/21 9:16:00	0	7561	
47		0		玉六园东17	9729.51	535	119.21	22.28%	2024/7/21 20:41:00	0	5616	
48		0	10kV-42	双站路东23	9729.51	535	56.88	10.63%	2024/7/23 20:30:00	0	6749	
49		0		怡锦二东27	9729.51	535	0.79	0.15%	2024/11/7 9:42:00	0	7769	
50		0	10kV-44	龙熙东31	6546.96	360	247.74	68.82%	2024/7/10 21:35:00	0	732	
51		0		玺悦Ⅱ东32	9729.51	535	4.48	0.84%	2024/11/7 9:43:00	0	7702	
52		0		金玉二东33	8547.42	470	63.12	13.43%	2024/7/23 20:39:00	0	5690	
53				玺悦Ⅰ东34	9729.51	535	4.48	0.84%	2024/11/7 9:43:00	0	7702	
54		0		苑北东35	8547.42	470	101.27	21.55%	2024/7/29 10:07:00	0	4996	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
55		0		广电二东36	8547.42	470	312.09	66.40%	2024/7/29 11:10:00	0	1162	
56		0		祥和东37	8547.42	470	305.23	64.94%	2024/11/17 17:24:00	0	1287	
57	宝坻.城关站	0	10kV-4	宝鑫I111	7274.4	400	269.97	67.49%	2024/7/19 21:15:00	0	910	
58		0	10kV-4	城关乡112	6546.96	360	286.51	79.59%	2024/7/23 21:11:00	0	27	
59		0	10kV-4	海滨115	6546.96	360	127.44	35.40%	2024/2/22 11:12:00	0	2920	
60		0	10kV-5	宝鑫II122	7274.4	400	70.54	17.64%	2024/7/23 21:06:00	0	4537	
61		0	10kV-5	城关镇II124	6546.96	360	265.00	73.61%	2024/7/30 15:25:00	0	418	
62		0	10kV-5	城关镇I125	6546.96	360	281.61	78.23%	2024/7/24 12:17:00	0	116	
63		0	10kV-4	工贸城13	6546.96	360	275.77	76.60%	2024/12/18 17:28:00	0	222	
64		0	10kV-4	瑞祥城14	7274.4	400	236.37	59.09%	2024/7/24 10:53:00	0	1521	
65		0	10kV-5	霍各庄城21	6546.96	360	0.00	0.00%	2024/1/12 0:00:00	0	5238	
66		0	10kV-5	铸件城23	6546.96	360	272.70	75.75%	2024/7/23 14:52:00	0	278	
67	宝坻.城南站	0	10kV-41	帝景南11	8547.42	470	191.57	40.76%	2024/7/23 19:20:00	0	3354	
68		0		潮阳花园南12	8547.42	470	129.70	27.60%	2024/11/22 8:35:00	0	4479	
69		0		嘉兴园南13	8547.42	470	196.67	41.84%	2024/7/24 12:38:00	0	3261	
70		0		金和园南14	8547.42	470	112.67	23.97%	2024/7/23 20:54:00	0	4789	
71		0		宝境南15	8547.42	470	118.26	25.16%	2024/2/26 20:53:00	0	4687	
72		0		万兆南16	8547.42	470	284.88	60.61%	2024/7/21 20:51:00	0	1657	
73		0		吾悦一南17	8547.42	470	92.12	19.60%	2024/6/12 21:18:00	0	5163	
74		0		原筑一南18	8547.42	470	147.01	31.28%	2024/7/23 20:49:00	0	4164	
75		0	10kV-42 10kV-43	体育馆南23	8547.42	470	167.76	35.69%	2024/7/24 11:50:00	0	3787	
76		0		观潮园南24	8547.42	470	72.19	15.36%	2024/12/27 20:34:00	0	5525	
77		0		润和南25	8547.42	470	113.35	24.12%	2024/8/28 10:50:00	0	4777	
78		0		泰达南26	8547.42	470	119.62	25.45%	2024/7/24 12:24:00	0	4663	
79		0		北岸南27	8547.42	470	165.22	35.15%	2024/10/19 16:33:00	0	3833	
80		0		馨和南28	8547.42	470	286.79	61.02%	2024/7/23 18:51:00	0	1622	
81		0		翰墨园南29	6546.96	360	40.34	11.21%	2024/1/21 21:35:00	0	4504	
82		0		吾悦二南30	8547.42	470	142.56	30.33%	2024/7/21 20:40:00	0	4245	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
83		0		原筑二南31	8547.42	470	143.17	30.46%	2024/7/23 21:58:00	0	4234	
84	宝坻.城西站	0	10kV-4	三岔口116	9147.558	503	96.96	19.28%	2024/12/24 14:44:00	0	5555	
85		0		天宝甲西13	6546.96	360	228.23	63.40%	2024/11/21 16:25:00	0	1087	
86		0		高家庄西14	9147.558	503	83.20	16.54%	2024/3/18 22:01:00	0	5805	
87		0		宝中道西15	9729.51	535	147.04	27.48%	2024/12/26 0:12:00	0	5110	
88		0		中关村一西17	9729.51	535	93.04	17.39%	2024/12/24 16:33:00	0	6092	
89		0		四中西23	8547.42	470	290.40	61.79%	2024/12/24 16:41:00	0	1557	
90		0	10kV-5	中关村南西24	9729.51	535	69.68	13.02%	2024/12/16 7:14:00	0	6516	
91		0		牛道口东西25	6546.96	360	256.32	71.20%	2024/12/15 17:28:00	0	576	
92		0		星源西26	9147.558	503	376.72	74.89%	2024/12/26 8:48:00	0	467	
93		0		天宝乙西27	6546.96	360	0.72	0.20%	2024/1/11 0:03:00	0	5224	
94		0										
95	宝坻.大白庄站	0	10kV-41	小刘坡白11	6546.96	360	215.12	59.76%	2024/5/26 16:07:00	0	1325	
96		0		晋铝白12	9147.558	503	326.41	64.89%	2024/9/9 14:39:00	0	1382	
97		0		无纺白13	8547.42	470	232.10	49.38%	2024/5/13 17:10:00	0	2617	
98		0		小杨庄白14	8547.42	470	273.32	58.15%	2024/10/9 9:20:00	0	1867	
99		0		贝特瑞白15	9147.558	503	109.62	21.79%	2024/9/15 22:58:00	0	5324	
100		0		盟固利白16	9729.51	535	365.61	68.34%	2024/5/14 22:01:00	0	1135	
101		0		孙校白17	9147.558	503	202.20	40.20%	2024/5/17 13:30:00	0	3641	
102		0		园二路白18	9147.558	503	390.11	77.56%	2024/5/13 18:11:00	0	224	
103		0	10kV-42	首高白21	9147.558	503	393.54	78.24%	2024/10/20 14:27:00	0	161	
104		0		九贸白22	9147.558	503	268.56	53.39%	2024/5/13 17:25:00	0	2434	
105		0		嘉诺缘白23	8547.42	470	375.98	80.00%	2024/5/13 17:35:00	0	0	
106		0		八道沽白24	6546.96	360	178.77	49.66%	2024/3/29 12:08:00	0	1986	
107		0		勇猛白25	8547.42	470	234.18	49.83%	2024/5/13 17:10:00	0	2579	
108		0		天普白26	9729.51	535	17.16	3.21%	2024/5/13 18:10:00	0	7472	
109		0		东皋一白27	9729.51	535	380.73	71.16%	2024/5/13 17:01:00	0	860	
110		0		彭元白28	9147.558	503	224.35	44.60%	2024/5/13 18:05:00	0	3238	
110		0		程马庄屯11	9147.558	503	98.44	19.57%	2024/7/19 20:55:00	0	5528	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
111	宝坻.大口屯站	0	10kV-4	大薄甸屯12	9147.558	503	0.00	0.00%	2024/9/15 0:00:00	0	7318	
112		0		大五登屯13	6546.96	360	165.76	46.04%	2024/1/13 18:03:00	0	2223	
113		0		大口屯镇屯14	6546.96	360	223.95	62.21%	2024/7/24 16:42:00	0	1165	
114		0		屯开发屯15	9147.558	503	184.39	36.66%	2024/11/5 8:23:00	0	3965	
115		0	10kV-5	天骄屯21	9147.558	503	281.78	56.02%	2024/7/24 10:57:00	0	2194	
116		0		大口屯东屯22	9147.558	503	140.10	27.85%	2024/12/5 17:22:00	0	4770	
117		0		尹家铺屯23	6546.96	360	159.61	44.34%	2024/7/7 22:43:00	0	2335	
118		0		镇东屯24	9147.558	503	0.00	0.00%	2024/1/6 0:00:00	0	7318	
119	宝坻.大钟庄站	0	10kV-4	新安镇214	7274.4	400	129.15	32.29%	2024/7/21 15:14:00	0	3471	
120		0		盛松I钟11	7274.4	400	79.60	19.90%	2024/7/23 18:51:00	0	4372	
121		0		宝芝钟12	7274.4	400	282.42	70.61%	2024/8/1 4:30:00	0	683	
122		0		何仇钟13	7274.4	400	91.31	22.83%	2024/7/8 16:11:00	0	4159	
123		0	10kV-5	盛松II钟21	7274.4	400	26.20	6.55%	2024/8/22 18:21:00	0	5343	
124		0		工业园区钟22	6546.96	360	163.92	45.53%	2024/7/21 13:42:00	0	2257	
125		0		冯庄水钟23	7274.4	400	261.92	65.48%	2024/7/8 16:04:00	0	1056	
126		0		钟芝钟24	7274.4	400	19.38	4.85%	2024/8/28 12:37:00	0	5467	
127	宝坻.东老口站	0	10kV-4	老鸦口老12	7274.4	400	61.55	15.39%	2024/6/19 14:49:00	0	4700	
128		0		精密老13	6546.96	360	178.41	49.56%	2024/7/24 13:59:00	0	1993	
129		0		珠江老14	6546.96	360	126.95	35.26%	2024/7/20 13:07:00	0	2929	
130		0		农场老15	6546.96	360	152.03	42.23%	2024/7/18 13:27:00	0	2473	
131		0	10kV-5	牛家牌老21	6546.96	360	148.95	41.38%	2024/9/10 8:52:00	0	2529	
132		0		孙庄老22	6546.96	360	72.19	20.05%	2024/7/20 5:31:00	0	3925	
133		0		前坨老23	6546.96	360	213.29	59.25%	2024/7/24 9:00:00	0	1359	
134		0		东滨老24	6546.96	360	13.67	3.80%	2024/12/12 17:07:00	0	4989	
135	宝坻.东王庄站	0	10kV-41	李家河老11	6546.96	360	140.35	38.99%	2024/7/23 13:31:00	0	2685	
136		0		郑贵庄老12	9147.558	503	50.96	10.13%	2024/1/31 13:46:00	0	6391	
137		0		尔辛庄老13	6546.96	360	51.86	14.41%	2024/1/26 10:06:00	0	4294	
138		0		东安子老15	6546.96	360	134.88	37.47%	2024/7/23 22:01:00	0	2785	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
139	宝坻.小上庄站	0	10kV-42	黄花淀尔21	6546.96	360	86.54	24.04%	2024/8/15 13:33:00	0	3664	
140		0		小宝庄尔23	6546.96	360	287.73	79.93%	2024/7/19 13:15:00	0	5	
141		0	10kV-43	潘套尔25	6546.96	360	243.46	67.63%	2024/3/31 8:11:00	0	810	
142		0		小董庄尔26	6546.96	360	66.88	18.58%	2024/7/19 20:46:00	0	4021	
143	宝坻.海滨站	0	10kV-41	大吴路海11	9729.51	535	57.00	10.65%	2024/9/13 15:24:00	0	6747	
144		0		张古海12	6546.96	360	230.56	64.04%	2024/4/13 8:08:00	0	1045	
145		0		前五里海13	9147.558	503	64.92	12.91%	2024/7/30 23:32:00	0	6137	
146		0		剑桥II海14	8547.42	470	258.35	54.97%	2024/7/23 21:27:00	0	2140	
147		0		翡翠II海15	9729.51	535	111.87	20.91%	2024/7/23 21:08:00	0	5749	
148		0		东城海16	9147.558	503	129.27	25.70%	2024/2/22 15:46:00	0	4967	
149		0	10kV-42	区医院海21	8547.42	470	70.27	14.95%	2024/11/6 21:47:00	0	5560	
150		0		白龙港海22	6546.96	360	165.62	46.01%	2024/10/1 12:53:00	0	2226	
151		0		小刘庄海23	6546.96	360	230.21	63.95%	2024/12/24 17:34:00	0	1051	
152		0		剑桥I海24	8547.42	470	375.19	79.83%	2024/10/24 12:49:00	0	15	
153		0		翡翠I海25	8547.42	470	152.72	32.49%	2024/7/23 21:42:00	0	4061	
154		0		西城海26	9147.558	503	222.22	44.18%	2024/7/21 19:16:00	0	3277	
155	宝坻.黑狼口站	0	10kV-4	黑狼口黑11	6546.96	360	235.32	65.37%	2024/11/25 16:57:00	0	958	
156		0		老庄子黑12	9147.558	503	200.08	39.78%	2024/5/19 13:20:00	0	3679	
157		0		农场黑13	9147.558	503	126.29	25.11%	2024/7/23 22:09:00	0	5021	
158		0		塑料一黑14	9147.558	503	272.97	54.27%	2024/11/27 15:56:00	0	2354	
159		0	10kV-5	塑料二黑21	9147.558	503	108.17	21.50%	2024/8/14 9:24:00	0	5351	
160		0		久大黑22	6546.96	360	183.71	51.03%	2024/11/26 17:12:00	0	1897	
161		0		糙甸乡黑23	6546.96	360	192.54	53.48%	2024/4/24 11:56:00	0	1736	
162		0		发达纸厂黑24	6546.96	360	50.06	13.90%	2024/8/4 1:18:00	0	4327	
163		0	10kV-42	陈塘欢19	9147.558	503	116.37	23.14%	2024/1/16 10:06:00	0	5202	
164		0		高康马欢20	9147.558	503	132.34	26.31%	2024/7/17 6:18:00	0	4911	
165		0		水流庄欢21	9147.558	503	297.16	59.08%	2024/7/16 9:49:00	0	1914	
166		0		五道沽欢23	9147.558	503	4.93	0.98%	2024/7/19 15:42:00	0	7228	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
167	宝坻.欢喜庄站	0	10kV-43	李宦庄欢24	9147.558	503	137.05	27.25%	2024/5/13 13:19:00	0	4826	
168		0		曹家沽欢25	9147.558	503	69.29285	13.78%	2024/7/14 5:45:00	0	6058	
169		0		周家庄欢26	9147.558	503	181.58	36.10%	2024/1/23 10:47:00	0	4016	
170		0	10kV-44	后辛欢27	9147.558	503	142.74	28.38%	2024/1/2 18:04:00	0	4722	
171		0		回庄欢28	9147.558	503	338.38	67.27%	2024/2/28 8:50:00	0	1164	
172		0		工业园欢29	9147.558	503	395.51	78.63%	2024/3/14 14:24:00	0	125	
173		0		尹庄欢30	9147.558	503	1.05	0.21%	2024/2/16 0:01:00	0	7299	
174		0		清白沽欢31	9147.558	503	98.61	19.60%	2024/4/20 9:37:00	0	5525	
175		0		南辛码欢33	9147.558	503	174.55	34.70%	2024/1/23 13:33:00	0	4144	
176		0		葫芦窝欢34	9147.558	503	257.90	51.27%	2024/8/6 13:21:00	0	2628	
177		0	10kV-41	杜家台黄11	9147.558	503	177.26	35.24%	2024/4/12 9:42:00	0	4094	
178		0		东走线黄12	9147.558	503	105.19	20.91%	2024/1/4 20:01:00	0	5405	
179		0		南燕东黄13	9147.558	503	0.00	0.00%	2024/8/30 0:00:00	0	7318	
180		0		张头窝东黄14	9147.558	503	0.00	0.00%	2024/1/23 0:00:00	0	7318	
181		0		小甸西黄15	9147.558	503	0.00	0.00%	2024/8/30 0:00:00	0	7318	
182		0		鲁家铺黄16	9147.558	503	228.32	45.39%	2024/12/21 2:50:00	0	3166	
183		0		水流东黄21	9147.558	503	43.66	8.68%	2024/2/2 5:38:00	0	6524	
184		0		黄庄北黄22	9147.558	503	0.00	0.00%	2024/1/25 0:00:00	0	7318	
185	宝坻.黄庄站	0	10kV-42	大塔沽黄31	9147.558	503	8.80	1.75%	2024/5/21 5:17:00	0	7158	
186		0		郭庄子黄32	9147.558	503	135.08	26.85%	2024/3/2 16:22:00	0	4861	
187		0		苑家场黄33	9147.558	503	100.00	19.88%	2024/6/30 5:50:00	0	5499	
188		0		黄庄西黄34	9147.558	503	38.68	7.69%	2024/12/27 18:44:00	0	6615	
189		0	10kV-43	王木庄黄41	9147.558	503	27.50	5.47%	2024/4/13 7:03:00	0	6818	
190		0		西走线黄42	9147.558	503	0.00	0.00%	2024/1/11 0:00:00	0	7318	
191		0		张头窝西黄43	9147.558	503	116.14	23.09%	2024/2/1 22:00:00	0	5206	
192		0		黄庄东黄44	9147.558	503	167.65	33.33%	2024/1/23 7:29:00	0	4269	
193		0		前辛庄黄51	9147.558	503	59.21	11.77%	2024/1/1 20:41:00	0	6241	
194		0		小塔沽黄52	9147.558	503	87.23	17.34%	2024/1/1 19:35:00	0	5732	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
195		0	10kV-44	南燕北黄53	9147.558	503	79.75	15.85%	2024/1/21 8:01:00	0	5868	
196		0		小甸东黄54	9147.558	503	94.51	18.79%	2024/1/22 16:49:00	0	5599	
197		0		王家铺黄55	9147.558	503	0.00	0.00%	2024/8/26 0:00:00	0	7318	
198		0		水流西黄61	9147.558	503	298.52	59.35%	2024/12/5 2:58:00	0	1889	
199		0		黄庄南黄62	9147.558	503	261.65	52.02%	2024/11/15 15:21:00	0	2560	
200		0		貉子沽黄63	9147.558	503	0.00	0.00%	2024/9/16 0:00:00	0	7318	
201	宝坻.开发区站	0	10kV-4	华苑112	7274.4	400	175.68	43.92%	2024/11/18 18:15:00	0	2625	
202		0		三中113	6546.96	360	119.52	33.20%	2024/7/24 10:40:00	0	3064	
203		0		摩托车114	7274.4	400	76.44	19.11%	2024/11/23 14:40:00	0	4429	
204		0		景苑 I 116	5637.66	310	146.04	47.11%	2024/7/23 21:55:00	0	1854	
205		0		纸厂117	7274.4	400	79.44	19.86%	2024/11/22 8:35:00	0	4375	
206		0	10kV-5	县委122	6546.96	360	130.44	36.23%	2024/7/24 12:13:00	0	2865	
207		0		四小123	6546.96	360	258.96	71.93%	2024/7/24 12:20:00	0	528	
208		0		东区124	7274.4	400	128.88	32.22%	2024/7/23 19:53:00	0	3476	
209		0		香港园区125	7274.4	400	184.68	46.17%	2024/9/16 17:19:00	0	2461	
210		0		景苑II126	5637.66	310	96.36	31.08%	2024/7/23 21:09:00	0	2758	
211		0		党校127	6546.96	360	276.31	76.75%	2024/7/24 9:47:00	0	213	
212		0	10kV-4	西区区15	6546.96	360	178.08	49.47%	2024/10/27 20:59:00	0	1999	
213	宝坻.口东站	0	10kV-41	口东园区 I 口1	6546.96	360	222.89	61.91%	2024/1/4 10:48:00	0	1184	
214		0		前齐口12	6546.96	360	174.73	48.54%	2024/10/1 13:00:00	0	2060	
215		0		园区西口13	9147.558	503	351.56	69.89%	2024/8/28 17:05:00	0	925	
216		0		工业东口14	9147.558	503	361.41	71.85%	2024/12/28 16:09:00	0	745	
217		0	10kV-42	口东园区 II 口2	6546.96	360	262.97	73.05%	2024/6/21 11:28:00	0	455	
218		0		东辛口22	9147.558	503	171.91	34.18%	2024/11/26 9:37:00	0	4192	
219		0		园区南口23	9147.558	503	374.77	74.51%	2024/7/24 16:30:00	0	503	
220		0		工业北口24	9147.558	503	126.21	25.09%	2024/12/2 17:12:00	0	5023	
221		0	10kV-43	首瑞口25	9147.558	503	239.24	47.56%	2024/12/6 17:46:00	0	2967	
222		0		福礼口26	9147.558	503	1.05	0.21%	2024/3/7 20:58:00	0	7299	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
223		0	10kV-44	爱康口31	9147.558	503	313.24	62.27%	2024/7/25 17:53:00	0	1621	
224		0		黄辛口32	9147.558	503	163.30	32.47%	2024/11/27 16:33:00	0	4348	
225		0		大张庄口33	9147.558	503	61.87	12.30%	2024/7/20 19:59:00	0	6193	
226		0		潮阳东口34	9147.558	503	0.00	0.00%	2024/1/23 0:00:00	0	7318	
227		0		恒佳口35	9147.558	503	0.00	0.00%	2024/9/5 0:00:00	0	7318	
228		0		翔原口36	9147.558	503	0.00	0.00%	2024/1/3 0:00:00	0	7318	
229	宝坻.莲子营站	0	10kV-41	莲唐一营11	9729.51	535	85.18	15.92%	2024/1/22 0:18:00	0	6235	
230		0		浩润营12	6546.96	360	166.04	46.12%	2024/1/25 10:54:00	0	2218	
231		0		香坻营13	9729.51	535	44.51	8.32%	2024/7/28 21:54:00	0	6974	
232		0		西郝营14	9147.558	503	219.93	43.72%	2024/1/21 17:06:00	0	3318	
233		0	10kV-42	兴华营31	9147.558	503	192.19	38.21%	2024/1/6 11:02:00	0	3823	
234		0		津侨一营32	9729.51	535	2.35	0.44%	2024/2/23 10:59:00	0	7741	
235		0	10kV-43	莲唐二营41	9729.51	535	76.43	14.29%	2024/12/11 0:07:00	0	6394	
236		0		润悦营42	9729.51	535	29.99	5.61%	2024/12/20 22:05:00	0	7238	
237		0		万和营43	8547.42	470	83.80	17.83%	2024/6/25 12:04:00	0	5314	
238		0	10kV-44	小套营51	6546.96	360	225.11	62.53%	2024/12/13 15:42:00	0	1144	
239		0		水岸营52	9729.51	535	164.90	30.82%	2024/7/23 20:31:00	0	4785	
240		0		官庄营53	6546.96	360	118.10	32.81%	2024/12/31 11:53:00	0	3090	
241		0		津侨二营54	9729.51	535	2.32	0.43%	2024/3/2 17:00:00	0	7741	
242	宝坻.林亭口站	0	10kV-4	张庄子林11	7274.4	400	309.72	77.43%	2024/8/17 17:46:00	0	187	
243		0		大靳庄林12	7274.4	400	0.00	0.00%	2024/1/12 0:00:00	0	5820	
244		0		林亭口西林13	7274.4	400	172.53	43.13%	2024/2/29 8:12:00	0	2682	
245		0		科宝林14	7274.4	400	0.86	0.22%	2024/4/29 21:39:00	0	5804	
246		0		龙亭苑林15	7274.4	400	223.15	55.79%	2024/10/25 22:31:00	0	1761	
247		0	10kV-5	众河林21	7274.4	400	45.41	11.35%	2024/12/26 10:48:00	0	4994	
248		0		南五村林22	7274.4	400	241.62	60.41%	2024/1/18 21:15:00	0	1425	
249		0		林亭口林23	6546.96	360	157.73	43.81%	2024/7/24 12:58:00	0	2369	
250		0		季家庄林24	7274.4	400	8.41	2.10%	2024/8/6 11:33:00	0	5667	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
251		0		轻集林25	7274.4	400	0.82	0.21%	2024/7/26 20:58:00	0	5805	
252	宝坻.牛道口站	0	10kV-4	下五庄牛11	9147.558	503	240.47	47.81%	2024/10/30 16:43:00	0	2945	
253		0		塘头牛12	9147.558	503	148.59	29.54%	2024/5/8 18:14:00	0	4616	
254		0		庞庄牛13	9147.558	503	106.64	21.20%	2024/10/26 17:26:00	0	5379	
255		0		三赵牛14	7619.934	419	214.22	51.13%	2024/10/29 17:20:00	0	2200	
256		0		西四庄牛21	9147.558	503	171.80	34.16%	2024/7/29 14:53:00	0	4194	
257	宝坻.牛道口站	0	10kV-5	高家深牛22	6546.96	360	224.06	62.24%	2024/11/6 17:21:00	0	1163	
258		0		高各庄牛23	9147.558	503	233.91	46.50%	2024/6/13 16:56:00	0	3064	
259		0		卢各庄牛24	9147.558	503	198.05	39.37%	2024/11/7 16:48:00	0	3716	
260		0		集利牛25	6546.96	360	150.00	41.67%	2024/6/11 13:23:00	0	2510	
261	宝坻.史各庄站	0	10kV-4	扬水站史11	6546.96	360	236.60	65.72%	2024/11/14 16:35:00	0	935	
262		0		西苑庄史12	6546.96	360	123.22	34.23%	2024/7/24 11:01:00	0	2997	
263		0		通威史13	6546.96	360	231.33	64.26%	2024/7/24 0:21:00	0	1031	
264		0		宜城史14	6546.96	360	235.90	65.53%	2024/7/23 18:15:00	0	947	
265		0		朱孔史15	6546.96	360	239.41	66.50%	2024/7/23 20:17:00	0	884	
266		0	10kV-5	彪家店史16	9147.558	503	102.48	20.37%	2024/5/10 17:32:00	0	5454	
267		0		正大史21	6546.96	360	124.63	34.62%	2024/8/16 14:44:00	0	2971	
268		0		史各庄史22	6546.96	360	167.34	46.48%	2024/10/1 11:56:00	0	2194	
269		0		郭杨史23	6546.96	360	180.88	50.24%	2024/6/13 21:26:00	0	1948	
270		0		庞各庄史24	6546.96	360	281.60	78.22%	2024/7/4 17:41:00	0	116	
271		0		大刘辛史25	9147.558	503	268.42	53.36%	2024/6/13 17:13:00	0	2437	
272	宝坻.双王寺站	0	10kV-4	屯东双11	6546.96	360	108.83	30.23%	2024/7/24 6:37:00	0	3258	
273		0		双唐一双12	9729.51	535	0.00	0.00%	2024/3/13 0:00:00	0	7784	
274		0		郝各庄双13	6546.96	360	261.58	72.66%	2024/10/1 12:22:00	0	480	
275		0		马家店双14	6546.96	360	263.86	73.29%	2024/12/23 16:33:00	0	439	
276		0	10kV-5	屯西双21	6546.96	360	158.48	44.02%	2024/1/23 17:57:00	0	2355	
277		0		南仁孚双22	9147.558	503	400.82	79.69%	2024/7/30 16:41:00	0	29	
278		0		新开口双23	6546.96	360	119.81	33.28%	2024/12/27 10:26:00	0	3059	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
279		0		宝联双24	6546.96	360	167.32	46.48%	2024/1/18 9:46:00	0	2195	
280		0		双唐二双25	9729.51	535	86.73	16.21%	2024/1/22 0:47:00	0	6206	
281	宝坻.隋庄子站	0	10kV-41	东淀隋11	9147.558	503	227.79	45.29%	2024/7/12 10:26:00	0	3175	
282		0		大刘坡隋12	8547.42	470	259.96	55.31%	2024/7/8 13:40:00	0	2110	
283		0		迈克隋13	9729.51	535	303.62	56.75%	2024/5/30 16:04:00	0	2262	
284		0		腾飞隋14	9729.51	535	278.53	52.06%	2024/5/13 17:35:00	0	2718	
285		0	10kV-42	尔王庄隋21	6546.96	360	73.63	20.45%	2024/10/11 17:30:00	0	3899	
286		0		九园东隋22	9147.558	503	237.86	47.29%	2024/8/7 13:41:00	0	2992	
287		0		大白庄东隋23	8547.42	470	57.20	12.17%	2024/7/23 20:49:00	0	5798	
288		0		董塔隋24	6546.96	360	145.24	40.34%	2024/7/24 6:17:00	0	2596	
289		0	10kV-43	石材一隋25	9147.558	503	160.25	31.86%	2024/12/4 9:15:00	0	4404	
290		0		诺宝一隋26	9147.558	503	234.61	46.64%	2024/5/13 17:22:00	0	3051	
291		0		南李隋27	9147.558	503	208.11	41.37%	2024/7/23 13:47:00	0	3533	
292		0		轻纺隋28	8547.42	470	215.77	45.91%	2024/5/28 16:18:00	0	2914	
293		0	10kV-44	九园西隋32	6546.96	360	223.82	62.17%	2024/7/29 10:14:00	0	1167	
294		0		大白庄西隋33	6546.96	360	186.75	51.88%	2024/10/1 16:57:00	0	1841	
295		0		大唐庄隋34	6546.96	360	281.52	78.20%	2024/7/29 13:19:00	0	118	
296		0		石材二隋35	9147.558	503	207.51	41.25%	2024/5/24 15:48:00	0	3544	
297		0		诺宝二隋36	9147.558	503	127.97	25.44%	2024/5/31 16:16:00	0	4991	
298		0		石材隋37	9147.558	503	106.85	21.24%	2024/11/25 10:05:00	0	5375	
299		0		新城隋38	9147.558	503	228.01	45.33%	2024/5/26 16:07:00	0	3171	
300		0	10kV-4	双盛太12	6546.96	360	271.20	75.33%	2024/10/30 10:54:00	0	306	
301		0		昌兴太13	6546.96	360	185.64	51.57%	2024/7/19 21:16:00	0	1862	
302		0		馨园 I 太14	9729.51	535	279.24	52.19%	2024/7/19 21:16:00	0	2705	
303		0		九中 I 太15	9729.51	535	249.24	46.59%	2024/7/23 21:24:00	0	3251	
304		0		润阳一太16	9729.51	535	252.84	47.26%	2024/11/17 21:22:00	0	3185	
305		0		津宝太17	6546.96	360	175.00	48.61%	2024/7/5 14:28:00	0	2055	
306	宝坻.太平庄站	0		宸宝太22	6546.96	360	65.64	18.23%	2024/11/25 14:45:00	0	4044	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
307		0	10kV-5	人防太23	6546.96	360	233.16	64.77%	2024/7/23 21:06:00	0	997	
308		0		馨园Ⅱ太24	9729.51	535	268.80	50.24%	2024/7/23 17:18:00	0	2895	
309		0		九中Ⅱ太25	9729.51	535	176.04	32.90%	2024/7/23 21:13:00	0	4582	
310		0		润阳二太26	9729.51	535	270.24	50.51%	2024/10/27 21:11:00	0	2869	
311		0		中专太27	6546.96	360	141.12	39.20%	2024/3/22 10:30:00	0	2671	
312		0										
313	宝坻.王卜庄站	0	10kV-4	陈山王11	6546.96	360	166.42	46.23%	2024/9/14 10:36:00	0	2211	
314		0		王卜庄西王12	6546.96	360	150.57	41.83%	2024/12/20 17:14:00	0	2499	
315		0		大华王13	6546.96	360	172.96	48.04%	2024/12/17 9:34:00	0	2092	
316		0		方庄子王14	9147.558	503	100.32	19.94%	2024/7/23 20:28:00	0	5494	
317		0		赵二王15	9147.558	503	0.00	0.00%	2024/10/27 0:00:00	0	7318	
318		0		小赵王16	9147.558	503	80.02	15.91%	2024/5/13 16:44:00	0	5863	
319		0		何家庄王17	9147.558	503	208.65	41.48%	2024/1/9 9:59:00	0	3524	
320		0		司各庄王18	9147.558	503	86.26	17.15%	2024/7/20 7:56:00	0	5749	
321		0	10kV-5	砖厂王21	6546.96	360	46.88	13.02%	2024/7/23 18:19:00	0	4385	
322		0		北坛王22	9147.558	503	27.69	5.50%	2024/7/23 18:15:00	0	6814	
323		0		王卜庄东王23	6546.96	360	160.80	44.67%	2024/7/4 13:21:00	0	2313	
324		0		南家庄王24	9147.558	503	104.81	20.84%	2024/7/24 15:47:00	0	5412	
325		0		龙坛王25	9147.558	503	177.29	35.25%	2024/1/22 18:07:00	0	4094	
326		0		庞家庄王26	9147.558	503	380.81	75.71%	2024/1/16 10:31:00	0	393	
327		0		于街王27	6546.96	360	124.32	34.53%	2024/1/13 17:21:00	0	2977	
328		0		西泗王28	9147.558	503	153.94	30.60%	2024/10/1 12:13:00	0	4518	
329		0	10kV-41	轧钢厂铺12	6546.96	360	134.71	37.42%	2024/7/24 11:39:00	0	2788	
330		0		石桥铺13	6546.96	360	152.83	42.45%	2024/8/23 17:21:00	0	2458	
331		0		杨家口铺14	6546.96	360	120.25	33.40%	2024/12/12 14:54:00	0	3051	
332		0		张台铺15	6546.96	360	179.17	49.77%	2024/10/1 12:08:00	0	1979	
333		0		泉州铺16	9147.558	503	267.59	53.20%	2024/11/30 9:08:00	0	2452	
334		0	10kV-42	畜牧局铺22	6546.96	360	287.70	79.92%	2024/7/24 12:30:00	0	5	
		0		棉纺厂铺23	9147.558	503	361.15	71.80%	2024/7/12 10:04:00	0	750	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
335	宝坻.五里铺站	0	10kV-43	霍各庄铺25	6546.96	360	136.55	37.93%	2024/11/10 12:28:00	0	2754	
336		0		口东铺26	9147.558	503	109.56	21.78%	2024/8/12 15:21:00	0	5326	
337		0		金水 I 铺28	8547.42	470	242.99	51.70%	2024/12/29 20:20:00	0	2419	
338		0	10kV-44	林海铺31	9729.51	535	220.26	41.17%	2024/12/20 18:12:00	0	3778	
339		0		北郝铺32	6546.96	360	122.63	34.06%	2024/11/24 23:17:00	0	3007	
340		0		大角甸铺33	9147.558	503	88.68	17.63%	2024/7/23 20:43:00	0	5705	
341		0		监管所铺34	9147.558	503	283.18	56.30%	2024/7/24 12:43:00	0	2168	
342		0		金水 II 铺38	8547.42	470	182.09	38.74%	2024/7/23 21:17:00	0	3526	
343	宝坻.小辛码站	0	10kV-4	欢喜小12	6546.96	360	48.96	13.60%	2024/4/25 14:36:00	0	4347	
344		0		黄庄小13	6546.96	360	180.32	50.09%	2024/7/18 5:17:00	0	1958	
345		0		苑洪桥小14	9147.558	503	122.08	24.27%	2024/1/1 7:22:00	0	5098	
346		0		辛庄南小15	9147.558	503	111.84	22.23%	2024/4/11 15:22:00	0	5284	
347		0	10kV-5	北里沽小21	6546.96	360	139.04	38.62%	2024/5/18 14:36:00	0	2709	
348		0		扬水站小22	6546.96	360	109.60	30.44%	2024/8/31 9:05:00	0	3244	
349		0		小辛码小23	6546.96	360	163.36	45.38%	2024/6/16 13:37:00	0	2267	
350		0		马庄小24	9147.558	503	39.36	7.83%	2024/7/20 20:31:00	0	6602	
351		0		吴辛小25	9147.558	503	140.00	27.83%	2024/4/22 13:35:00	0	4772	
352	宝坻.新安镇站	0	10kV-41	于家口一安11	9147.558	503	33.70	6.70%	2024/2/9 7:50:00	0	6705	
353		0		王善庄一安12	9147.558	503	39.90	7.93%	2024/1/22 7:42:00	0	6592	
354		0		南业安13	9183.93	505	0.00	0.00%	2024/11/7 0:00:00	0	7347	
355		0		王庄安17	9147.558	503	343.40	68.27%	2024/1/23 11:02:00	0	1073	
356		0	10kV-42	木业安18	9147.558	503	384.90	76.52%	2024/7/24 12:54:00	0	318	
357		0		于家口二安21	9147.558	503	56.60	11.25%	2024/1/22 18:03:00	0	6289	
358		0		王善庄二安22	9147.558	503	161.50	32.11%	2024/12/19 15:32:00	0	4381	
359		0	10kV-43	曹口安27	9147.558	503	167.50	33.30%	2024/1/1 16:28:00	0	4272	
360		0		业西安28	9147.558	503	182.80	36.34%	2024/8/18 9:25:00	0	3994	
361		0		园区新11	6546.96	360	228.30	63.42%	2024/1/10 14:45:00	0	1086	
362		0		中粮新12	6546.96	360	75.35	20.93%	2024/12/6 15:26:00	0	3867	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
363	宝坻.新开口站	0	10kV-4	种西新13	6546.96	360	270.25	75.07%	2024/1/19 9:20:00	0	323	
364		0		前寒河新14	7274.4	400	164.50	41.13%	2024/11/27 14:43:00	0	2828	
365		0		新开口东新15	6546.96	360	162.37	45.10%	2024/7/23 20:17:00	0	2285	
366		0	10kV-5	新开口西新21	6546.96	360	196.91	54.70%	2024/7/23 20:30:00	0	1657	
367		0		彭家务新22	6546.96	360	160.99	44.72%	2024/1/16 9:59:00	0	2310	
368		0		石辛庄新23	7274.4	400	126.70	31.68%	2024/10/1 12:17:00	0	3515	
369		0		洛水坨新24	7274.4	400	283.99	71.00%	2024/1/3 6:02:00	0	655	
370		0		新开口南新25	6546.96	360	94.80	26.33%	2024/11/11 15:04:00	0	3514	
371	宝坻.袁罗站	0	10kV-41	大卦庄袁11	9147.558	503	78.65	15.64%	2024/1/22 20:42:00	0	5888	
372		0		刘兰袁12	9147.558	503	61.03	12.13%	2024/3/6 7:05:00	0	6208	
373		0		北王庄袁13	9147.558	503	79.49	15.80%	2024/6/29 9:04:00	0	5872	
374		0		金厂袁14	9147.558	503	127.64	25.38%	2024/1/23 7:27:00	0	4997	
375		0		东鲁沽袁15	9147.558	503	60.18	11.96%	2024/2/9 7:36:00	0	6224	
376		0		八二村袁16	9147.558	503	0.00	0.00%	2024/11/8 0:00:00	0	7318	
377		0		袁罗北袁21	9147.558	503	230.98	45.92%	2024/1/22 7:30:00	0	3117	
378		0		杨庄子袁22	9147.558	503	159.71	31.75%	2024/3/17 7:02:00	0	4414	
379		0		凌沿村袁23	9147.558	503	0.00	0.00%	2024/3/16 0:00:00	0	7318	
380		0		米四庄袁24	9147.558	503	0.00	0.00%	2024/11/8 0:00:00	0	7318	
381		0		大米北袁25	9147.558	503	159.38	31.69%	2024/6/26 13:15:00	0	4420	
382		0	10kV-42	宝芝麻窝袁31	9147.558	503	53.03	10.54%	2024/5/1 12:35:00	0	6354	
383		0		马郭村袁32	9147.558	503	93.66	18.62%	2024/1/4 7:27:00	0	5615	
384		0		岳家楼袁33	9147.558	503	96.55	19.19%	2024/4/16 12:24:00	0	5562	
385		0		王山南袁34	9147.558	503	105.53	20.98%	2024/4/1 15:25:00	0	5399	
386		0		康庄西袁35	9147.558	503	236.62	47.04%	2024/4/28 16:20:00	0	3015	
387		0	10kV-43	大米南袁41	9147.558	503	57.83	11.50%	2024/2/9 7:22:00	0	6266	
388		0		孔家庄袁42	9147.558	503	4.44	0.88%	2024/4/19 15:37:00	0	7237	
389		0		八一村袁43	9147.558	503	0.00	0.00%	2024/3/16 0:00:00	0	7318	
390		0		大钟庄袁44	9147.558	503	87.20	17.34%	2024/5/4 12:44:00	0	5732	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
391	宝坻.岳家庄站	0	10kV-44	二米庄袁45	9147.558	503	141.83	28.20%	2024/6/17 18:31:00	0	4739	
392		0		米东袁51	9147.558	503	0.00	0.00%	2024/3/16 0:00:00	0	7318	
393		0		船窝村袁52	9147.558	503	223.09	44.35%	2024/12/17 11:17:00	0	3261	
394		0		大陈庄袁53	9147.558	503	57.17	11.37%	2024/1/4 13:18:00	0	6278	
395		0		勾家庄袁54	9147.558	503	73.03	14.52%	2024/2/9 7:39:00	0	5990	
396		0		焦王庄袁55	9147.558	503	17.94	3.57%	2024/3/17 18:28:00	0	6992	
397		0		后鲁沽袁56	9147.558	503	0.00	0.00%	2024/10/28 0:00:00	0	7318	
398		0		王山北袁61	9147.558	503	103.90	20.66%	2024/4/1 15:25:00	0	5429	
399		0		康庄东袁62	9147.558	503	236.22	46.96%	2024/4/28 16:20:00	0	3022	
400		0		张五庄袁63	9147.558	503	44.59	8.86%	2024/4/21 16:13:00	0	6507	
401		0		杨木村袁64	9147.558	503	128.64	25.57%	2024/6/15 13:36:00	0	4979	
402		0		厂家窝袁65	9147.558	503	110.66	22.00%	2024/1/22 7:28:00	0	5306	
403	宝坻.岳家庄站	0	10kV-41	天祥 I 岳11	6546.96	360	166.97	46.38%	2024/7/31 8:40:00	0	2201	
404		0		天恒岳12	8547.42	470	261.88	55.72%	2024/11/13 15:06:00	0	2075	
405		0		黑豆窝岳13	6546.96	360	59.06	16.40%	2024/8/14 10:09:00	0	4164	
406		0		天跃一岳14	9147.558	503	292.29	58.11%	2024/11/7 10:32:00	0	2002	
407		0		蝶恋一岳15	9729.51	535	329.73	61.63%	2024/7/23 21:23:00	0	1787	
408		0		鑫海一岳16	9729.51	535	4.57	0.85%	2024/8/10 1:26:00	0	7701	
409		0		赵各庄岳17	6546.96	360	130.24	36.18%	2024/8/6 10:22:00	0	2869	
410		0	10kV-42	天宝 I 岳19	6546.96	360	74.71	20.75%	2024/7/9 16:38:00	0	3879	
411		0		鑫海二岳20	9729.51	535	4.39	0.82%	2024/8/10 1:58:00	0	7704	
412		0		沟头岳21	6546.96	360	219.73	61.04%	2024/8/2 10:31:00	0	1242	
413		0		宝旺岳22	9147.558	503	386.02	76.74%	2024/6/13 1:13:00	0	298	
414		0	10kV-43	天跃二岳23	9147.558	503	291.27	57.91%	2024/8/29 16:20:00	0	2021	
415		0		松江 I 岳24	9729.51	535	381.10	71.23%	2024/7/29 16:17:00	0	853	
416		0		天祥 II 岳25	6546.96	360	256.82	71.34%	2024/8/12 10:51:00	0	567	
417		0		天宝 II 岳27	6546.96	360	143.97	39.99%	2024/7/23 15:45:00	0	2619	
418		0		牛道口岳28	6546.96	360	172.44	47.90%	2024/8/7 14:23:00	0	2101	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
419		0	10kV-44	黄沙务岳29	9147.558	503	254.36	50.57%	2024/7/24 11:08:00	0	2692	
420		0		宝富岳30	9147.558	503	377.41	75.03%	2024/7/3 9:47:00	0	454	
421		0		石佛营岳31	6546.96	360	165.06	45.85%	2024/7/23 21:06:00	0	2236	
422		0		松江Ⅱ岳32	9729.51	535	153.28	28.65%	2024/8/7 10:30:00	0	4996	
423		0		蝶恋二岳33	9729.51	535	354.20	66.21%	2024/7/23 20:51:00	0	1342	
424		0		曙光一关11	9729.51	535	141.79	26.50%	2024/12/27 9:06:00	0	5205	
425	宝坻.中关村站	0	10kV-41	元中一关12	9729.51	535	153.39	28.67%	2024/12/24 15:01:00	0	4994	
426		0		于家观关13	6546.96	360	240.84	66.90%	2024/12/19 17:47:00	0	858	
427		0		宝善一关14	9729.51	535	122.79	22.95%	2024/12/24 16:33:00	0	5551	
428		0		宝康一关15	8547.42	470	27.02	5.75%	2024/12/23 13:38:00	0	6347	
429		0		宝德一关16	9729.51	535	116.60	21.79%	2024/12/24 14:50:00	0	5663	
430		0		梦泽一关21	9729.51	535	256.13	47.87%	2024/12/24 16:06:00	0	3126	
431		0		科景轩一关22	9729.51	535	275.03	51.41%	2024/7/23 17:41:00	0	2782	
432		0		宝志一关23	9729.51	535	139.92	26.15%	2024/3/12 16:49:00	0	5239	
433		0	10kV-42	元中二关31	9729.51	535	0.68	0.13%	2024/12/29 15:59:00	0	7771	
434		0		宝善二关32	9729.51	535	330.66	61.81%	2024/12/24 16:42:00	0	1770	
435		0		科景轩二关33	9729.51	535	248.31	46.41%	2024/12/24 14:36:00	0	3268	
436		0		宝志二关34	9729.51	535	55.00	10.28%	2024/5/13 15:38:00	0	6783	
437		0	10kV-43	曙光二关41	9729.51	535	290.75	54.35%	2024/1/23 16:15:00	0	2496	
438		0		宝康二关42	8547.42	470	118.17	25.14%	2024/12/24 14:44:00	0	4689	
439		0		宝德二关43	9729.51	535	20.10	3.76%	2024/1/7 8:10:00	0	7418	
440		0		梦泽二关44	9729.51	535	283.90	53.07%	2024/7/21 16:25:00	0	2621	
441		0	10kV-41	嵘园Ⅰ216	8547.42	470	15.49	3.30%	2024/7/31 12:05:00	0	6556	
442		0		顺园Ⅰ217	8547.42	470	117.26	24.95%	2024/10/16 17:20:00	0	4705	
443		0		财大Ⅰ218	8547.42	470	278.53	59.26%	2024/7/5 12:41:00	0	1773	
444		0	10kV-42 10kV-43	财大Ⅱ231	8547.42	470	375.02	79.79%	2024/8/30 12:22:00	0	18	
445		0		顺园Ⅱ232	8547.42	470	70.33	14.96%	2024/10/16 17:16:00	0	5559	
446		0		嵘园Ⅱ233	8547.42	470	316.39	67.32%	2024/3/22 22:58:00	0	1084	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	最大负荷发生日期	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
447	宝坻.周良庄站	0	10kV-41	嘉园 I 周11	8547.42	470	159.41	33.92%	2024/3/22 20:43:00	0	3939	
448		0		九园南周12	8547.42	470	127.51	27.13%	2024/10/17 20:54:00	0	4519	
449		0		东皋周13	10311.462	567	2.38	0.42%	2024/1/11 0:00:00	0	8206	
450		0		森林岛 I 周14	8547.42	470	177.38	37.74%	2024/2/27 9:02:00	0	3612	
451		0		康园 I 周15	8547.42	470	162.68	34.61%	2024/10/15 17:45:00	0	3879	
452		0	10kV-42 10kV-43	嘉园 II 周21	8547.42	470	133.36	28.37%	2024/10/16 17:20:00	0	4413	
453		0		香江周22	8547.42	470	241.71	51.43%	2024/7/14 14:47:00	0	2442	
454		0		九园北周23	8547.42	470	100.79	21.44%	2024/10/13 19:04:00	0	5005	
455		0		森林岛 II 周24	8547.42	470	187.38	39.87%	2024/7/23 21:23:00	0	3430	
456		0		安盟周34	8547.42	470	0.93	0.20%	2024/10/28 0:00:00	0	6821	
457	宝坻.马家店站	0	10kV-41	后寒河马11	6546.96	360	152.82	42.45%	2024/11/27 14:43:00	0	2458	
458		0		刘举人马12	6546.96	360	171.92	47.76%	2024/12/3 15:46:00	0	2111	
459		0		天玺园马13	6546.96	360	220.54	61.26%	2024/12/12 9:10:00	0	1227	
460		0		星洋马14	9147.558	503	141.34	28.10%	2024/12/12 9:24:00	0	4748	
461		0		沁园马15	9147.558	503	67.94	13.51%	2024/12/4 15:34:00	0	6082	
462		0	10kV-42 10kV-43	烧角马31	6546.96	360	250.66	69.63%	2024/6/13 16:36:00	0	679	
463		0		西寨马41	6546.96	360	72.10	20.03%	2024/12/4 16:16:00	0	3926	
464		0		大兰马42	9147.558	503	72.48	14.41%	2024/12/11 8:00:00	0	6000	
465		0		后六口马51	6546.96	360	123.26	34.24%	2024/12/10 17:06:00	0	2996	
466		0		璟园马52	9147.558	503	66.27	13.17%	2024/12/4 15:34:00	0	6113	
467	宝坻.温泉城站	0	10kV-41	马营温11	6546.96	360	145.63	40.45%	2024/7/24 14:14:00	0	2589	
468		0		李台温12	9147.558	503	289.78	57.61%	2024/8/9 23:47:00	0	2048	
469		0		田邢庄温13	6546.96	360	67.50	18.75%	2024/7/24 5:38:00	0	4010	
470		0		香榭一温14	8547.42	470	94.29	20.06%	2024/5/22 17:26:00	0	5123	
471		0		橄榄树一温15	8547.42	470	233.55	49.69%	2024/10/14 11:56:00	0	2591	
472		0		邮政一温16	8547.42	470	178.21	37.92%	2024/6/14 11:37:00	0	3597	
473		0		菜家铺温41	6546.96	360	111.67	31.02%	2024/3/24 19:04:00	0	3207	
474		0		后五登温42	6546.96	360	133.34	37.04%	2024/7/27 23:00:00	0	2813	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	最大负荷发生日期	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
475		0	10kV-43	香榭二温43	8547.42	470	155.54	33.09%	2024/12/22 19:48:00	0	4009	
476		0	10kV-44	四里港温51	6546.96	360	95.42	26.51%	2024/7/23 21:46:00	0	3502	
477		0		橄榄树二温52	8547.42	470	211.92	45.09%	2024/10/18 18:03:00	0	2984	
478		0		邮政二温53	8547.42	470	139.52	29.69%	2024/6/14 11:38:00	0	4301	