

滨海供电公司10千伏配电线路可开放容量信息表(2025年第一季度)

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
1	安达	0	10kV-1	831	6928	400	275.59	68.90%	2024/7/19	0	769.25	
2		0		832	6928	400	108.59	27.15%	2024/5/9	0	3661.55	
3		0		833	6928	400	214.26	53.56%	2024/11/6	0	1831.45	
4		0		834	6928	400	231.25	57.81%	2024/9/19	0	1537.15	
5		0	10kV-2	841	6928	400	268.867	67.22%	2024/7/15	0	885.62	
6		0	10kV-3	845	6928	400	132.23	33.06%	2024/7/21	0	3252.23	
7		0		846	6928	400	142.58	35.64%	2024/7/29	0	3072.95	
8		0		848	6928	400	267.5	66.88%	2024/8/1	0	909.30	
9		0	10kV-4	851	6928	400	202.93	50.73%	2024/7/22	0	2027.65	
10		0		852	6928	400	148.63	37.16%	2024/5/14	0	2968.08	
11		0		853	6928	400	285.273	71.32%	2024/7/26	0	601.47	
12		0		854	6928	400	247.85	61.96%	2024/10/29	0	1249.60	
13		0		855	6928	400	265.352	66.34%	2024/11/5	0	946.50	
14	宝山道	0	10kV-41	宝11	8140.4	470	60.85	12.95%	2024/7/29	0	5458.40	
15		0		宝12	8140.4	470	20.40	4.34%	2024/7/21	0	6158.97	
16		0		宝13	8140.4	470	64.02	13.62%	2024/8/5	0	5403.56	
17		0		宝14	8140.4	470	276.82	58.90%	2024/7/23	0	1717.88	
18		0		宝17	8140.4	470	143.51	30.53%	2024/7/23	0	4026.78	
19		0		宝18	8140.4	470	1.06	0.22%	2024/2/11	0	6494.05	
20		0	10kV-42	宝21	8140.4	470	132.25	28.14%	2024/7/1	0	4221.72	
21		0		宝22	9006.4	520	172.00	33.08%	2024/7/23	0	4226.11	
22		0		宝23	9006.4	520	195.56	37.61%	2024/5/28	0	3817.95	
23		0	10kV-43	宝25	8140.4	470	324.65	69.07%	2024/7/23	0	889.38	
24		0	10kV-44	宝31	8140.4	470	116.78	24.85%	2024/7/24	0	4489.76	
25		0		宝32	8140.4	470	80.20	17.06%	2024/8/23	0	5123.34	
26		0		宝33	8140.4	470	228.28	48.57%	2024/7/30	0	2558.60	
27		0		宝34	8140.4	470	204.01	43.41%	2024/1/6	0	2978.94	
28		0		宝35	8140.4	470	170.94	36.37%	2024/7/23	0	3551.59	
29		0		宝36	8140.4	470	135.77	28.89%	2024/7/19	0	4160.80	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
30		0		宝37	8140.4	470	98.84	21.03%	2024/7/23	0	4800.46	
31	茶淀	0	10kV-41	茶11	6928	400	162.31	40.58%	2024/7/23	0	2731.28	
32		0		茶12	6928	400	275.64	68.91%	2024/7/5	0	768.32	
33		0		茶13	6928	400	219.96	54.99%	2024/10/31	0	1732.68	
34		0		茶14	6373.76	368	261.30	71.01%	2024/7/18	0	573.29	
35		0		茶15	6373.76	368	221.84	60.28%	2024/7/23	0	1256.81	
36		0		茶16	6373.76	368	250.08	67.96%	2024/7/2	0	767.66	
37		0		茶17	6928	400	95.27	23.82%	2024/7/23	0	3892.27	
38		0		茶18	5975.4	345	23.44	6.79%	2024/12/12	0	4374.37	
39		0	10kV-42	茶21	6928	400	71.48	17.87%	2024/7/23	0	4304.30	
40		0		茶22	6928	400	42.89	10.72%	2024/7/23	0	4799.53	
41		0		茶23	6928	400	187.85	46.96%	2024/7/23	0	2288.80	
42		0		茶24	6373.76	368	249.96	67.92%	2024/5/19	0	769.68	
43		0	10kV-43	茶25	6373.76	368	259.64	70.55%	2024/11/21	0	602.04	
44		0		茶26	6373.76	368	260.31	70.74%	2024/7/24	0	590.44	
45		0		茶27	6373.76	368	209.65	56.97%	2024/5/19	0	1467.90	
46		0		茶28	6928	400	279.61	69.90%	2024/7/5	0	699.57	
47	厂东路	0	10kV-41	厂13	7499.56	433	0.00	0.00%	2024/1/1	0	5999.65	
48		0		厂14	8140.4	470	45.88	9.76%	2024/1/22	0	5717.70	
49		0		厂15	9006.4	520	98.64	18.97%	2024/3/20	0	5496.76	
50		0	10kV-42	厂21	7499.56	433	190.42	43.98%	2024/11/21	0	2701.66	
51		0		厂22	10392	600	3.52	0.59%	2024/10/27	0	8252.70	
52		0		厂23	7499.56	433	143.28	33.09%	2024/8/21	0	3517.97	
53		0		厂24	17320	1000	305.93	30.59%	2024/5/27	0	8557.24	
54		0	10kV-43	厂34	9006.4	520	0.00	0.00%	2024/1/1	0	7205.12	
55		0		厂35	9006.4	520	46.23	8.89%	2024/5/1	0	6404.42	
56		0	10kV-44	厂41	17320	1000	279.27	27.93%	2024/6/26	0	9019.01	
57		0		厂42	17320	1000	29.59	2.96%	2024/5/2	0	13343.50	
58		0		厂43	6373.76	368	21.62	5.88%	2024/12/14	0	4724.53	
59		0		潮10	6928	400	63.03	15.76%	2024/7/23	0	4450.69	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
60	潮音寺	0	10kV-4	潮12	6928	400	32.80	8.20%	2024/2/4	0	4974.34	
61		0		潮13	6928	400	195.69	48.92%	2024/7/23	0	2153.08	
62		0		潮14	6928	400	106.39	26.60%	2024/7/23	0	3699.69	
63		0		潮15	6928	400	158.19	39.55%	2024/7/29	0	2802.58	
64		0		潮16	6928	400	284.438	71.11%	2024/7/23	0	615.93	
65		0		潮17	6928	400	252.88	63.22%	2024/7/20	0	1162.59	
66		0		潮18	6928	400	0.22	0.06%	2024/1/1	0	5538.59	
67		0		潮19	6928	400	195.45	48.86%	2024/9/9	0	2157.14	
68		0		潮20	6928	400	295.485	73.87%	2024/7/23	0	424.60	
69		0	10kV-5	潮30	6928	400	119.99	30.00%	2024/3/25	0	3464.26	
70		0		潮32	6928	400	146.70	36.68%	2024/4/2	0	3001.49	
71		0		潮33	6928	400	271.63	67.91%	2024/7/23	0	837.84	
72		0		潮34	6928	400	209.75	52.44%	2024/7/23	0	1909.51	
73		0		潮35	6928	400	298.032	74.51%	2024/7/23	0	380.49	
74		0		潮36	6928	400	124.91	31.23%	2024/10/14	0	3379.01	
75		0		潮37	6928	400	264.13	66.03%	2024/5/13	0	967.74	
76		0		潮38	6928	400	213.97	53.49%	2024/7/24	0	1836.44	
77		0		潮39	5975.4	345	167.10	48.43%	2024/8/13	0	1886.23	
78		0		潮40	6928	400	268.032	67.01%	2024/7/23	0	900.09	
79	潮宗桥		10kV-4	宗11	6373.76	368	246.32	66.93%	2024/4/7	0	832.75	
80				宗12	6668.2	385	199.81	51.90%	2024/4/4	0	1873.89	
81				宗14	6373.76	368	74.66	20.29%	2024/7/23	0	3805.97	
82				宗15	6928	400	35.58	8.89%	2024/10/18	0	4926.22	
83				宗16	6373.76	368	15.39	4.18%	2024/7/26	0	4832.42	
84			10kV-5	宗21	6373.76	368	212.12	57.64%	2024/11/25	0	1425.09	
85				宗22	6928	400	227.38	56.84%	2024/4/5	0	1604.25	
86				宗24	6373.76	368	200.94	54.60%	2024/11/27	0	1618.80	
87	崇义路			宗26	6373.76	368	248.472	67.52%	2024/1/8	0	795.47	
88		0	10kV-41	崇11	8573.4	495	143.93	29.08%	2024/7/23	0	4365.90	
89		0		崇31	8573.4	495	315.36	63.71%	2024/7/24	0	1396.75	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
90	大丰路	0	10kV-43	丰31	6928	400	46.52	11.63%	2024/7/23	0	4736.62	
91		0		丰32	6928	400	133.59	33.40%	2024/7/23	0	3228.55	
92		0		丰33	6928	400	51.09	12.77%	2024/7/24	0	4657.45	
93		0		丰34	6928	400	166.76	41.69%	2024/7/23	0	2654.15	
94		0		丰35	6928	400	236.48	59.12%	2024/3/29	0	1446.50	
95		0		丰36	6928	400	88.83	22.21%	2024/6/27	0	4003.90	
96		0	10kV-44	丰41	6928	400	183.87	45.97%	2024/7/23	0	2357.82	
97		0		丰42	6928	400	182.34	45.59%	2024/10/18	0	2384.20	
98		0		丰43	6928	400	121.52	30.38%	2024/7/29	0	3437.62	
99		0		丰44	6928	400	219.14	54.79%	2024/7/23	0	1746.88	
100		0		丰45	6928	400	97.50	24.38%	2024/7/23	0	3853.70	
101		0		丰46	6928	400	2.46	0.62%	2024/12/16	0	5499.78	
102		0	10kV-45	丰51	6928	400	83.09	20.77%	2024/7/23	0	4103.35	
103		0		丰52	6928	400	177.54	44.38%	2024/7/23	0	2467.42	
104		0		丰53	6928	400	94.10	23.53%	2024/3/17	0	3912.55	
105		0		丰54	6928	400	88.83	22.21%	2024/7/23	0	4003.90	
106		0		丰55	6928	400	58.95	14.74%	2024/7/24	0	4521.47	
107		0		丰56	6928	400	2.70	0.67%	2024/12/16	0	5495.72	
108		0	10kV-46	丰61	6928	400	58.48	14.62%	2024/7/23	0	4529.58	
109		0		丰62	6928	400	140.51	35.13%	2024/7/24	0	3108.80	
110		0		丰63	6928	400	81.21	20.30%	2024/7/24	0	4135.83	
111		0		丰65	6928	400	88.83	22.21%	2024/6/27	0	4003.90	
112	大学城	0	10kV-41	大13	6928	400	287.376	71.84%	2024/11/4	0	565.05	
113		0		大15	6928	400	280.88	70.22%	2024/1/26	0	677.49	
114		0		大16	6928	400	286.75	71.69%	2024/7/23	0	575.86	
115		0		大17	6928	400	295.576	73.89%	2024/7/21	0	423.02	
116		0		大18	6928	400	38.68	9.67%	2024/7/30	0	4872.46	
117		0	10kV-42	大21	6928	400	162.87	40.72%	2024/7/24	0	2721.46	
118		0		大22	6668.2	385	49.10	12.75%	2024/7/24	0	4484.11	
119		0		大24	6928	400	299.848	74.96%	2024/7/21	0	349.03	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
120		0	10kV-43	大25	6928	400	242.67	60.67%	2024/7/24	0	1339.32	
121	大众园	0	10kV-41	众11	17320	1000	569.06	56.91%	2024/12/15	0	3999.97	
122		0		众12	15657.28	904	3.22	0.36%	2024/1/1	0	12470.00	
123		0		众13	7499.56	433	231.02	53.35%	2024/1/24	0	1998.36	
124		0		众15	9006.4	520	104.79	20.15%	2024/3/18	0	5390.19	
125		0		众16	7499.56	433	260.57	60.18%	2024/3/26	0	1486.51	
126		0	10kV-42	众22	9266.2	535	121.31	22.67%	2024/1/25	0	5311.85	
127		0		众23	7499.56	433	0.00	0.00%	2024/1/1	0	5999.65	
128		0	10kV-43	众31	17320	1000	549.43	54.94%	2024/8/12	0	4339.94	
129		0		众34	9006.4	520	0.00	0.00%	2024/1/1	0	7205.12	
130		0		众35	10392	600	38.32	6.39%	2024/11/25	0	7649.90	
131		0	10kV-44	众42	17320	1000	618.60	61.86%	2024/8/23	0	3141.78	
132	邓善沽	0	10kV-42	邓21	8140.4	470	204.08	43.42%	2024/7/23	0	2977.62	
133		0		邓22	6373.76	368	252.56	68.63%	2024/12/29	0	724.62	
134		0		邓23	6373.76	368	213.57	58.04%	2024/7/30	0	1399.91	
135		0		邓24	6373.76	368	247.15	67.16%	2024/11/16	0	818.40	
136		0	10kV-43	邓25	8140.4	470	225.00	47.87%	2024/8/24	0	2615.32	
137		0		邓26	8140.4	470	292.32	62.20%	2024/11/15	0	1449.27	
138		0		邓27	8227	475	135.00	28.42%	2024/11/10	0	4243.40	
139		0	10kV-44	邓31	7257.08	419	168.93	40.32%	2024/7/23	0	2879.87	
140		0		邓32	6373.76	368	251.582	68.36%	2024/9/26	0	741.61	
141		0		邓33	6373.76	368	244.34	66.40%	2024/7/30	0	867.11	
142		0		邓34	8140.4	470	340.033	72.35%	2024/11/13	0	622.95	
143		0		邓35	8140.4	470	340.167	72.38%	2024/11/13	0	620.63	
144		0		邓36	8140.4	470	340.18	72.38%	2024/11/14	0	620.40	
145		0		邓37	8227	475	340.224	71.63%	2024/11/14	0	688.92	
146	东尹站	0	10kV-42	尹21	6373.76	368	127.27	34.58%	2024/11/5	0	2894.76	
147		0		尹22	6373.76	368	240.70	65.41%	2024/12/19	0	930.03	
148		0		尹23	6373.76	368	249.297	67.74%	2024/8/25	0	781.18	
149		0		尹35	6373.76	368	270.625	73.54%	2024/10/30	0	411.78	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
150		0	10kV-44	尹36	6373.76	368	213.28	57.96%	2024/7/24	0	1404.98	
151		0		尹37	6373.76	368	172.50	46.88%	2024/7/24	0	2111.31	
152	窦庄子	0	10kV-4	窦11	6373.76	368	88.59	24.07%	2024/12/18	0	3564.56	
153		0		窦16	6928	400	0.00	0.00%	2024/1/1	0	5542.40	
154		0	10kV-5	窦21	6373.76	368	174.49	47.42%	2024/8/14	0	2076.81	
155		0		窦22	6373.76	368	104.88	28.50%	2024/1/5	0	3282.43	
156		0		窦23	6928	400	68.20	17.05%	2024/5/4	0	4361.12	
157		0	10kV-41	福11	6928	400	205.40	51.35%	2024/7/23	0	1984.87	
158		0		福13	6928	400	48.77	12.19%	2024/7/23	0	4697.74	
159		0		福14	6928	400	244.82	61.21%	2024/7/24	0	1302.05	
160	福州道	0		福15	6928	400	142.37	35.59%	2024/7/23	0	3076.59	
161		0		福16	6928	400	69.86	17.47%	2024/7/23	0	4332.36	
162		0		福17	6928	400	89.39	22.35%	2024/7/23	0	3994.13	
163		0		福18	6928	400	63.84	15.96%	2024/8/2	0	4436.69	
164		0	10kV-42	福21	6928	400	110.66	27.67%	2024/7/23	0	3625.70	
165		0		福23	6928	400	293.848	73.46%	2024/11/12	0	452.95	
166		0	10kV-43	福26	6928	400	70.58	17.65%	2024/7/23	0	4319.89	
167		0		福27	6928	400	126.30	31.58%	2024/8/5	0	3354.81	
168		0		福28	6928	400	254.94	63.73%	2024/7/23	0	1126.91	
169		0	10kV-44	福31	6928	400	281.264	70.32%	2024/3/16	0	670.91	
170		0		福32	6928	400	217.17	54.29%	2024/7/23	0	1781.05	
171		0		福34	6928	400	193.97	48.49%	2024/7/23	0	2182.87	
172		0		福35	6928	400	129.61	32.40%	2024/7/23	0	3297.59	
173		0		福38	6928	400	148.43	37.11%	2024/3/17	0	2971.56	
174	付庄	0	10kV-4	付14	6373.76	368	86.40	23.48%	2024/7/23	0	3602.56	
175		0		付15	5196	300	195.60	65.20%	2024/7/23	0	769.01	
176		0		付16	6373.76	368	259.28	70.46%	2024/9/7	0	608.28	
177		0		付17	5196	300	209.84	69.95%	2024/7/18	0	522.37	
178		0		付21	5196	300	110.88	36.96%	2024/4/1	0	2236.36	
179		0		付22	5196	300	78.96	26.32%	2024/10/30	0	2789.21	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
180		0	10kV-5	付23	6373.76	368	161.20	43.80%	2024/10/23	0	2307.02	
181		0		付24	6373.76	368	130.88	35.57%	2024/5/1	0	2832.17	
182		0		付25	6928	400	285.76	71.44%	2024/1/30	0	593.04	
183	港发站	0	10kV-41	发11	6373.76	368	29.18	7.93%	2024/8/19	0	4593.61	
184		0		发12	6373.76	368	259.45	70.50%	2024/6/17	0	605.28	
185		0		发13	6373.76	368	243.63	66.20%	2024/6/30	0	879.28	
186		0		发14	6373.76	368	115.31	31.33%	2024/9/1	0	3101.80	
187		0		发15	6373.76	368	168.40	45.76%	2024/7/24	0	2182.35	
188		0		发16	8278.96	478	272.81	57.07%	2024/7/12	0	1898.06	
189		0		发17	8140.4	470	48.34	10.29%	2024/7/23	0	5675.07	
190		0		发18	8140.4	470	2.29	0.49%	2024/3/17	0	6472.74	
191		0	10kV-44	发31	8140.4	470	227.64	48.43%	2024/1/5	0	2569.65	
192		0		发32	6373.76	368	197.75	53.74%	2024/7/23	0	1673.91	
193		0		发33	6373.76	368	0.00	0.00%	2024/1/1	0	5099.01	
194		0		发34	6373.76	368	305.15	82.92%	2024/7/23	0	0.00	
195		0		发35	6373.76	368	92.81	25.22%	2024/7/21	0	3491.50	
196		0		发36	8278.96	478	255.59	53.47%	2024/7/23	0	2196.42	
197		0		发37	8140.4	470	0.00	0.00%	2024/1/1	0	6512.32	
198	港塘路	0	10kV-5	610	5196	300	132.18	44.06%	2024/7/23	0	1867.49	
199		0		612	5196	300	55.56	18.52%	2024/1/13	0	3194.54	
200		0	10kV-4	615	5196	300	114.84	38.28%	2024/8/3	0	2167.77	
201		0		619	5196	300	97.86	32.62%	2024/11/1	0	2461.95	
202	港塘路	0	10kV-41	湾11	8140.4	470	49.64	10.56%	2024/11/12	0	5652.49	
203		0		湾12	6373.76	368	245.884	66.82%	2024/7/12	0	840.30	
204		0		湾13	8140.4	470	257.57	54.80%	2024/1/19	0	2051.24	
205		0		湾14	6373.76	368	228.35	62.05%	2024/11/1	0	1144.02	
206		0		湾15	6373.76	368	223.01	60.60%	2024/1/3	0	1236.51	
207		0		湾16	8140.4	470	182.02	38.73%	2024/6/21	0	3359.80	
208		0		湾17	8140.4	470	297.40	63.28%	2024/7/19	0	1361.42	
209		0		湾18	8140.4	470	148.30	31.55%	2024/5/1	0	3943.83	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
210	港沟	0	10kV-42	湾21	8140.4	470	7.94	1.69%	2024/4/22	0	6374.73	
211		0		湾22	8140.4	470	169.57	36.08%	2024/5/24	0	3575.33	
212		0		湾23	8140.4	470	258.58	55.02%	2024/7/31	0	2033.78	
213		0		湾24	6373.76	368	126.66	34.42%	2024/11/1	0	2905.26	
214		0		湾25	6373.76	368	253.19	68.80%	2024/7/22	0	713.79	
215		0	10kV-43	湾26	8140.4	470	105.52	22.45%	2024/6/30	0	4684.78	
216		0		湾27	8140.4	470	309.74	65.90%	2024/11/1	0	1147.55	
217		0		湾28	8140.4	470	207.29	44.10%	2024/1/3	0	2922.09	
218		0		高31	6928	400	138.68	34.67%	2024/4/18	0	3140.41	
219	高新园	0		高32	6529.64	377	80.84	21.44%	2024/9/6	0	3823.56	
220		0	10kV-44	高33	6928	400	127.19	31.80%	2024/10/21	0	3339.50	
221		0		高36	6529.64	377	265.259	70.36%	2024/12/6	0	629.43	
222		0		高41	6928	400	213.15	53.29%	2024/9/15	0	1850.68	
223		0		高42	6928	400	14.96	3.74%	2024/1/11	0	5283.29	
224		0	10kV-45	高43	6928	400	24.68	6.17%	2024/4/27	0	5115.03	
225		0		高44	6928	400	54.76	13.69%	2024/11/9	0	4593.96	
226		0		高45	6928	400	244.00	61.00%	2024/10/17	0	1316.30	
227		0		高46	6928	400	73.39	18.35%	2024/12/23	0	4271.23	
228		0	10kV-46	高52	6928	400	72.41	18.10%	2024/12/3	0	4288.24	
229		0		高53	6928	400	136.02	34.00%	2024/12/4	0	3186.57	
230		0		高54	6928	400	103.71	25.93%	2024/3/2	0	3746.18	
231		0	10kV-47	高61	6928	400	280.18	70.04%	2024/8/1	0	689.75	
232		0		高62	6928	400	186.95	46.74%	2024/8/9	0	2304.41	
233		0		高63	6928	400	134.94	33.73%	2024/10/21	0	3205.26	
234		0		高64	6529.64	377	170.89	45.33%	2024/12/5	0	2263.98	
235		0		高65	6928	400	135.78	33.94%	2024/10/21	0	3190.71	
236	高新园	0	10kV-48	工11	6928	400	113.44	28.36%	2024/1/1	0	3577.65	
237		0		工12	6928	400	223.48	55.87%	2024/8/9	0	1671.78	
238		0		工13	6928	400	277.97	69.49%	2024/8/3	0	727.98	
239		0		工14	6928	400	271.52	67.88%	2024/7/30	0	839.62	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
240	工农村	0	10kV-41	工15	6373.76	368	164.88	44.81%	2024/7/24	0	2243.23	
241		0		工16	6928	400	290.08	72.52%	2024/5/15	0	518.25	
242		0		工17	6928	400	235.55	58.89%	2024/7/17	0	1462.73	
243		0		工18	6928	400	109.45	27.36%	2024/7/19	0	3646.67	
244		0	10kV-42	工21	6928	400	112.15	28.04%	2024/5/10	0	3600.00	
245		0		工22	6928	400	173.44	43.36%	2024/7/10	0	2538.45	
246		0		工23	6928	400	279.26	69.81%	2024/1/8	0	705.65	
247		0		工24	6928	400	166.41	41.60%	2024/5/15	0	2660.25	
248		0	10kV-43	工25	6373.76	368	253.633	68.92%	2024/4/7	0	706.08	
249		0		工26	6928	400	279.73	69.93%	2024/8/22	0	697.53	
250		0		工27	6928	400	287.734	71.93%	2024/7/16	0	558.85	
251		0		工28	6928	400	0.00	0.00%	2024/7/1	0	5542.40	
252	光辉	0	10kV-41	光11	8053.8	465	130.28	28.02%	2024/5/31	0	4186.52	
253		0		光12	10166.84	587	202.84	34.55%	2024/11/21	0	4620.35	
254		0		光13	10166.84	587	214.01	36.46%	2024/9/9	0	4426.85	
255		0		光14	6928	400	185.02	46.25%	2024/7/31	0	2337.92	
256		0		光15	7967.2	460	0.00	0.00%	2024/1/1	0	6373.76	
257		0		光21	10166.84	587	63.20	10.77%	2024/7/23	0	7038.78	
258		0		光22	10166.84	587	226.88	38.65%	2024/6/13	0	4203.84	
259		0		光23	7309.04	422	54.37	12.88%	2024/7/23	0	4905.51	
260		0	10kV-43	光41	10166.84	587	58.99	10.05%	2024/3/30	0	7111.73	
261		0		光42	10166.84	587	301.21	51.31%	2024/1/7	0	2916.48	
262		0		光46	9006.4	520	0.00	0.00%	2024/1/1	0	7205.12	
263		0	10kV-44	光51	8053.8	465	111.77	24.04%	2024/7/24	0	4507.22	
264		0		光52	10166.84	587	69.98	11.92%	2024/8/2	0	6921.35	
265		0		光53	6928	400	251.70	62.93%	2024/7/31	0	1182.96	
266		0		光54	6928	400	161.22	40.31%	2024/7/21	0	2750.07	
267		0		光55	7967.2	460	0.00	0.00%	2024/1/1	0	6373.76	
268		0		光61	7309.04	422	51.77	12.27%	2024/12/17	0	4950.61	
269		0		郭11	6373.76	368	251.08	68.23%	2024/3/27	0	750.25	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
270	郭庄子	0	10kV-4	郭12	6373.76	368	186.00	50.54%	2024/3/28	0	1877.51	
271		0		郭13	6373.76	368	191.18	51.95%	2024/3/24	0	1787.81	
272		0		郭14	6373.76	368	85.73	23.30%	2024/3/24	0	3614.13	
273		0		郭15	6928	400	200.85	50.21%	2024/3/24	0	2063.75	
274		0		郭16	6928	400	113.42	28.36%	2024/11/27	0	3577.91	
275		0		郭22	6373.76	368	141.80	38.53%	2024/3/26	0	2642.96	
276		0	10kV-5	郭23	6928	400	145.40	36.35%	2024/3/24	0	3024.16	
277		0		郭25	6373.76	368	190.38	51.73%	2024/1/4	0	1801.56	
278		0		郭26	6373.76	368	237.00	64.40%	2024/3/25	0	994.24	
279		0	10kV-4	783	5888.8	340	224.39	66.00%	2024/7/29	0	824.55	
280	海防路	0	10kV-41	防11	6373.76	368	75.26	20.45%	2024/11/4	0	3795.57	
281		0		防12	6633.56	383	68.75	17.95%	2024/7/10	0	4116.06	
282		0		防13	8140.4	470	75.43	16.05%	2024/1/21	0	5205.84	
283		0	10kV-42	防21	6373.76	368	103.38	28.09%	2024/1/27	0	3308.45	
284		0		防23	8140.4	470	92.13	19.60%	2024/8/23	0	4916.61	
285		0	10kV-41	海11	6928	400	202.03	50.51%	2024/8/1	0	2043.22	
286	海景路	0		海12	6928	400	118.71	29.68%	2024/3/4	0	3486.33	
287		0		海14	6668.2	385	0.00	0.00%	2024/1/1	0	5334.56	
288		0		海15	6928	400	30.00	7.50%	2024/6/17	0	5022.80	
289		0		海16	6928	400	266.875	66.72%	2024/7/23	0	920.13	
290		0	10kV-42	海21	6928	400	194.30	48.57%	2024/7/23	0	2177.18	
291		0		海22	6928	400	295.586	73.90%	2024/7/23	0	422.85	
292		0		海23	6928	400	93.98	23.50%	2024/7/21	0	3914.60	
293		0		海24	6928	400	82.27	20.57%	2024/7/23	0	4117.55	
294		0	10kV-43	海33	6928	400	82.27	20.57%	2024/7/23	0	4117.55	
295		0		海34	6668.2	385	80.04	20.79%	2024/12/10	0	3948.28	
296		0		海35	6928	400	8.32	2.08%	2024/6/11	0	5398.30	
297		0		海36	6928	400	270.35	67.59%	2024/7/23	0	859.90	
298		0	10kV-44	海41	6928	400	213.87	53.47%	2024/7/23	0	1838.22	
299		0		海42	6928	400	249.02	62.26%	2024/7/23	0	1229.32	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
300	海平路	0	10kV-44	海43	6928	400	138.63	34.66%	2024/8/26	0	3141.28	
301		0		海44	6928	400	82.85	20.71%	2024/8/2	0	4107.40	
302		0	10kV-41	平11	7309.04	422	165.38	39.19%	2024/10/29	0	2982.80	
303		0	10kV-42	平31	7309.04	422	236.00	55.92%	2024/8/22	0	1759.76	
304	海洋	0	10kV-2甲	421	6373.76	368	133.14	36.18%	2024/7/30	0	2793.09	
305		0		422	6373.76	368	154.64	42.02%	2024/1/17	0	2420.73	
306		0		423	8140.4	470	151.84	32.31%	2024/7/23	0	3882.43	
307		0		424	8140.4	470	71.89	15.30%	2024/1/10	0	5267.13	
308		0	10kV-2乙	425	8140.4	470	213.15	45.35%	2024/7/24	0	2820.58	
309		0		426	8140.4	470	247.50	52.66%	2024/7/24	0	2225.59	
310		0		427	8140.4	470	73.67	15.67%	2024/1/31	0	5236.37	
311		0		428	8140.4	470	209.67	44.61%	2024/6/3	0	2880.92	
312		0	10kV-3	431	8140.4	470	123.57	26.29%	2024/1/23	0	4372.09	
313		0		432	6373.76	368	222.65	60.50%	2024/8/5	0	1242.71	
314		0		433	8140.4	470	185.50	39.47%	2024/12/22	0	3299.41	
315		0		434	8140.4	470	117.62	25.03%	2024/7/23	0	4475.14	
316		0		435	8140.4	470	170.68	36.31%	2024/1/31	0	3556.19	
317		0		436	8140.4	470	192.51	40.96%	2024/7/23	0	3178.13	
318		0		437	8140.4	470	172.09	36.62%	2024/1/22	0	3531.70	
319		0		438	6373.76	368	183.83	49.95%	2024/5/11	0	1915.14	
320		0	10kV-41	航11	8313.6	480	90.00	18.75%	2024/11/22	0	5092.08	
321		0		航12	6408.4	370	128.87	34.83%	2024/1/23	0	2894.69	
322		0		航13	6373.76	368	12.96	3.52%	2024/1/1	0	4874.47	
323		0		航14	8140.4	470	194.39	41.36%	2024/7/31	0	3145.45	
324		0		航16	8417.52	486	143.28	29.48%	2024/10/30	0	4252.34	
325		0		航17	6373.76	368	244.07	66.32%	2024/7/23	0	871.68	
326		0		航18	6373.76	368	198.00	53.80%	2024/8/24	0	1669.72	
327		0	10kV-42	航21	7534.2	435	150.47	34.59%	2024/9/13	0	3421.24	
328		0		航22	7534.2	435	107.27	24.66%	2024/6/20	0	4169.43	
329		0		航23	8313.6	480	10.09	2.10%	2024/12/27	0	6476.21	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
330	航园	0	10kV-43	航24	8140.4	470	305.99	65.10%	2024/6/19	0	1212.56	
331		0		航25	8417.52	486	108.72	22.37%	2024/6/16	0	4850.97	
332		0		航27	8140.4	470	60.47	12.87%	2024/1/11	0	5465.00	
333		0		航28	8140.4	470	5.76	1.22%	2024/4/1	0	6412.61	
334		0	10kV-44	航31	8140.4	470	181.43	38.60%	2024/8/2	0	3369.99	
335		0		航32	8417.52	486	267.83	55.11%	2024/5/5	0	2095.29	
336		0		航33	8140.4	470	119.51	25.43%	2024/1/9	0	4442.42	
337		0		航34	8140.4	470	128.87	27.42%	2024/11/22	0	4280.29	
338		0		航35	8400.2	485	359.424	74.11%	2024/7/23	0	494.94	
339		0		航36	9006.4	520	244.07	46.94%	2024/10/30	0	2977.79	
340		0		航37	8140.4	470	184.58	39.27%	2024/2/23	0	3315.45	
341		0		航38	8140.4	470	261.34	55.60%	2024/11/7	0	1985.86	
342	和畅路	0	10kV-41	畅11	6928	400	203.01	50.75%	2024/2/23	0	2026.21	
343		0		畅12	6928	400	221.74	55.43%	2024/7/23	0	1701.93	
344		0		畅13	6928	400	280.10	70.03%	2024/7/23	0	691.07	
345		0		畅14	6928	400	155.15	38.79%	2024/7/23	0	2855.17	
346		0		畅15	6928	400	11.31	2.83%	2024/7/25	0	5346.48	
347		0		畅16	6928	400	240.80	60.20%	2024/7/24	0	1371.74	
348		0	10kV-42	畅21	6928	400	167.70	41.92%	2024/7/12	0	2637.91	
349		0		畅22	6928	400	250.78	62.70%	2024/9/22	0	1198.82	
350		0		畅23	6928	400	271.20	67.80%	2024/8/30	0	845.22	
351		0		畅24	6928	400	264.30	66.08%	2024/7/8	0	964.72	
352		0	10kV-43	畅25	6928	400	283.12	70.78%	2024/7/23	0	638.76	
353		0		畅31	6928	400	236.15	59.04%	2024/3/29	0	1452.33	
354		0		畅32	6928	400	204.39	51.10%	2024/4/3	0	2002.37	
355		0		畅33	6928	400	240.15	60.04%	2024/5/8	0	1383.07	
356		0		畅34	6928	400	258.62	64.65%	2024/5/22	0	1063.17	
357		0		畅36	6928	400	280.12	70.03%	2024/5/22	0	690.72	
358		0		畅41	6928	400	195.02	48.75%	2024/5/25	0	2164.72	
359		0		畅42	6928	400	203.33	50.83%	2024/9/3	0	2020.76	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
360		0	10kV-44	畅43	6928	400	285.64	71.41%	2024/7/23	0	595.12	
361		0		畅44	6928	400	163.13	40.78%	2024/7/23	0	2717.02	
362		0		畅45	6928	400	6.15	1.54%	2024/7/25	0	5435.85	
363		0		畅46	6928	400	269.24	67.31%	2024/8/29	0	879.16	
364		0		畅51	6928	400	127.58	31.90%	2024/6/20	0	3332.65	
365		0	10kV-45	畅52	6928	400	244.37	61.09%	2024/5/12	0	1309.95	
366		0		畅53	6928	400	281.20	70.30%	2024/5/13	0	672.02	
367		0		畅54	6928	400	264.30	66.08%	2024/4/8	0	964.72	
368		0		畅55	6928	400	281.40	70.35%	2024/6/3	0	668.55	
369		0		畅56	6928	400	191.44	47.86%	2024/4/17	0	2226.66	
370		0	10kV-46	畅61	6928	400	205.06	51.26%	2024/8/19	0	1990.83	
371		0		畅62	6928	400	283.14	70.79%	2024/7/12	0	638.35	
372		0		畅63	6928	400	296.376	74.09%	2024/7/12	0	409.17	
373		0		畅64	6928	400	245.67	61.42%	2024/5/12	0	1287.41	
374		0		畅65	6928	400	66.18	16.55%	2024/7/23	0	4396.09	
375		0		畅66	6928	400	286.226	71.56%	2024/5/21	0	584.97	
376	后沽	0	10kV-4	后15	6373.76	368	77.50	21.06%	2024/8/4	0	3756.78	
377		0		后16	6373.76	368	62.12	16.88%	2024/9/13	0	4023.02	
378		0		后17	6373.76	368	154.76	42.06%	2024/8/3	0	2418.50	
379		0	10kV-5	后21	6373.76	368	154.04	41.86%	2024/7/24	0	2430.97	
380		0		后22	6373.76	368	74.65	20.29%	2024/7/23	0	3806.04	
381		0		后23	6373.76	368	74.58	20.27%	2024/1/12	0	3807.28	
382		0		后27	5975.4	345	12.22	3.54%	2024/11/13	0	4568.74	
383		0	10kV-41	胡11	6928	400	23.20	5.80%	2024/1/3	0	5140.52	
384		0		胡12	6928	400	28.95	7.24%	2024/1/21	0	5041.07	
385		0		胡13	6928	400	269.77	67.44%	2024/6/26	0	870.05	
386		0		胡15	6928	400	193.01	48.25%	2024/1/2	0	2199.50	
387		0		胡16	6928	400	288.32	72.08%	2024/7/23	0	548.70	
388		0		胡20	6928	400	273.05	68.26%	2024/7/23	0	813.23	
389		0		胡21	6928	400	262.85	65.71%	2024/8/17	0	989.80	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
390	胡家园	0	10kV-42	胡22	6598.92	381	231.91	60.87%	2024/5/23	0	1262.39	
391		0		胡23	6928	400	149.30	37.32%	2024/1/9	0	2956.58	
392		0		胡24	6928	400	270.12	67.53%	2024/5/23	0	863.97	
393		0		胡25	6373.76	368	271.914	73.89%	2024/9/12	0	389.46	
394		0	10kV-43	胡26	6928	400	281.289	70.32%	2024/8/2	0	670.47	
395		0		胡27	6928	400	195.35	48.84%	2024/5/24	0	2158.90	
396		0		胡28	6928	400	206.84	51.71%	2024/5/23	0	1960.00	
397		0		胡31	6373.76	368	249.062	67.68%	2024/12/24	0	785.25	
398		0	10kV-44	胡32	6928	400	53.79	13.45%	2024/11/6	0	4610.77	
399		0		胡33	6928	400	281.758	70.44%	2024/7/23	0	662.35	
400		0		胡34	6512.32	376	249.61	66.39%	2024/7/23	0	886.63	
401		0		胡35	6928	400	173.91	43.48%	2024/5/22	0	2530.35	
402		0		胡36	6373.76	368	225.00	61.14%	2024/7/29	0	1202.01	
403		0		胡37	6928	400	238.71	59.68%	2024/7/23	0	1407.93	
404		0		胡38	6928	400	235.78	58.95%	2024/10/26	0	1458.67	
405		0	10kV-42	琥31	9785.8	565	172.06	30.45%	2024/9/21	0	4848.63	
406		0		琥32	9162.28	529	371.33	70.20%	2024/7/23	0	898.35	
407		0		琥33	8278.96	478	20.14	4.21%	2024/5/16	0	6274.41	
408		0		琥34	9647.24	557	391.67	70.32%	2024/12/31	0	934.10	
409		0		琥35	7794	450	31.30	6.95%	2024/12/12	0	5693.15	
410	琥珀溪	0	10kV-43	琥41	8278.96	478	60.04	12.56%	2024/8/23	0	5583.34	
411		0		琥42	9006.4	520	293.64	56.47%	2024/10/30	0	2119.28	
412		0		琥43	9266.2	535	327.66	61.24%	2024/3/1	0	1737.89	
413		0		琥45	8400.2	485	15.92	3.28%	2024/12/27	0	6444.36	
414		0		琥46	9266.2	535	37.36	6.98%	2024/8/30	0	6765.95	
415		0	10kV-42	琥51	9266.2	535	232.86	43.53%	2024/9/26	0	3379.82	
416		0		琥52	9266.2	535	323.48	60.46%	2024/7/23	0	1810.22	
417		0		琥53	8278.96	478	34.80	7.28%	2024/12/10	0	6020.43	
418		0		琥54	9006.4	520	215.04	41.35%	2024/12/31	0	3480.63	
419		0		琥55	8400.2	485	61.25	12.63%	2024/12/26	0	5659.34	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
420		0	10kV-44	琥61	8278.96	478	59.14	12.37%	2024/12/13	0	5598.93	
421		0		琥62	9006.4	520	183.13	35.22%	2024/10/30	0	4033.27	
422		0		琥63	9266.2	535	0.80	0.15%	2024/1/1	0	7399.03	
423		0		琥64	9006.4	520	54.01	10.39%	2024/12/13	0	6269.63	
424		0		琥65	8400.2	485	17.45	3.60%	2024/9/15	0	6417.96	
425		0		琥66	9266.2	535	115.85	21.65%	2024/7/5	0	5406.47	
426	花园	0	10kV-1	711	6928	400	164.34	41.08%	2024/7/25	0	2696.08	
427		0		712	6928	400	264.132	66.03%	2024/7/11	0	967.63	
428		0		714	6928	400	253.42	63.36%	2024/7/23	0	1153.15	
429		0		716	6928	400	220.95	55.24%	2024/7/24	0	1715.51	
430		0		717	6928	400	49.11	12.28%	2024/5/18	0	4691.75	
431		0	10kV-2甲	721	6928	400	48.65	12.16%	2024/11/18	0	4699.87	
432		0		722	6928	400	30.24	7.56%	2024/1/9	0	5018.61	
433		0		723	6928	400	171.25	42.81%	2024/6/22	0	2576.30	
434		0	10kV-2乙	725	6928	400	267.02	66.75%	2024/7/24	0	917.65	
435		0		727	6928	400	27.08	6.77%	2024/7/24	0	5073.43	
436		0	10kV-3	731	6928	400	224.47	56.12%	2024/8/4	0	1654.60	
437		0		732	6928	400	271.634	67.91%	2024/7/16	0	837.70	
438		0		733	6928	400	168.09	42.02%	2024/7/18	0	2631.12	
439		0		734	6928	400	141.71	35.43%	2024/6/28	0	3087.91	
440		0		735	6928	400	84.63	21.16%	2024/12/31	0	4076.61	
441		0		736	6928	400	184.73	46.18%	2024/7/23	0	2342.82	
442		0		737	6928	400	167.62	41.90%	2024/5/26	0	2639.24	
443		0		738	6928	400	1.99	0.50%	2024/2/29	0	5507.88	
444		0	10kV-41	山11	6373.76	368	119.65	32.51%	2024/12/17	0	3026.70	
445		0		山12	6373.76	368	244.22	66.36%	2024/12/11	0	869.13	
446		0		山13	6928	400	284.65	71.16%	2024/8/26	0	612.30	
447		0		山14	6928	400	193.83	48.46%	2024/6/18	0	2185.30	
448		0		山15	6928	400	218.20	54.55%	2024/7/23	0	1763.12	
449		0		山16	6928	400	214.22	53.55%	2024/7/23	0	1832.13	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
450	华山道	0	10kV-42	山21	6928	400	103.13	25.78%	2024/7/24	0	3756.28	
451		0		山22	6928	400	227.46	56.87%	2024/7/24	0	1602.78	
452		0		山23	6928	400	172.50	43.13%	2024/7/23	0	2554.70	
453		0		山24	6928	400	65.16	16.29%	2024/12/26	0	4413.90	
454		0		山25	6928	400	3.75	0.94%	2024/7/17	0	5477.45	
455		0		山26	6928	400	210.00	52.50%	2024/6/9	0	1905.20	
456		0	10kV-45	山51	6928	400	286.548	71.64%	2024/5/22	0	579.39	
457		0		山52	6928	400	215.74	53.94%	2024/7/23	0	1805.75	
458		0		山53	6373.76	368	216.45	58.82%	2024/1/20	0	1350.18	
459		0		山54	6928	400	250.43	62.61%	2024/7/23	0	1204.95	
460		0		山55	6928	400	216.09	54.02%	2024/7/23	0	1799.65	
461		0		山56	6928	400	3.75	0.94%	2024/7/17	0	5477.45	
462		0	10kV-46	山61	6928	400	37.50	9.38%	2024/8/4	0	4892.90	
463		0		山62	6373.76	368	12.54	3.41%	2024/7/19	0	4881.83	
464		0		山63	6928	400	80.27	20.07%	2024/1/22	0	4152.07	
465		0		山64	6928	400	269.922	67.48%	2024/8/2	0	867.35	
466		0		山65	6928	400	152.70	38.17%	2024/6/9	0	2897.72	
467		0		山66	10392	600	44.18	7.36%	2024/12/19	0	7548.40	
468	化工园	0	10kV-4	952	6928	400	52.54	13.13%	2024/10/18	0	4632.42	
469		0		953	6928	400	175.98	43.99%	2024/12/25	0	2494.48	
470		0		956	6928	400	25.20	6.30%	2024/3/20	0	5106.02	
471		0	10kV-5	961	6373.76	368	164.84	44.79%	2024/7/24	0	2243.91	
472		0		962	6928	400	3.52	0.88%	2024/2/27	0	5481.50	
473		0		963	6928	400	275.00	68.75%	2024/1/11	0	779.40	
474		0		966	6928	400	37.50	9.38%	2024/3/25	0	4892.90	
475		0	10kV-43	惠31	8140.4	470	257.17	54.72%	2024/8/2	0	2058.17	
476		0		惠32	7794	450	1.58	0.35%	2024/12/18	0	6207.80	
477		0		惠34	9526	550	287.75	52.32%	2024/10/17	0	2636.90	
478		0	10kV-44	惠41	7482.24	432	300.94	69.66%	2024/1/10	0	773.55	
479		0		惠42	8763.92	506	110.39	21.82%	2024/10/12	0	5099.16	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
480	惠居站	0	10kV-44	惠43	7828.64	452	340.527	75.34%	2024/10/18	0	364.98	
481		0		惠45	8763.92	506	147.83	29.22%	2024/10/18	0	4450.69	
482		0	10kV-45	惠51	9266.2	535	317.29	59.31%	2024/10/17	0	1917.58	
483		0		惠53	9266.2	535	292.32	54.64%	2024/10/17	0	2349.91	
484		0		惠54	9526	550	245.74	44.68%	2024/10/17	0	3364.55	
485		0	10kV-46	惠61	7828.64	452	199.51	44.14%	2024/7/23	0	2807.36	
486		0		惠62	7828.64	452	326.113	72.15%	2024/10/17	0	614.63	
487		0		惠63	8763.92	506	218.67	43.22%	2024/11/6	0	3223.74	
488		0		惠64	7326.36	423	289.86	68.53%	2024/10/17	0	840.66	
489		0		惠65	9959	575	149.06	25.92%	2024/6/14	0	5385.45	
490	碱渣山	0	10kV-41	碱11	8140.4	470	325.586	69.27%	2024/7/21	0	873.17	
491		0		碱12	8140.4	470	31.09	6.62%	2024/7/21	0	5973.79	
492		0		碱13	8140.4	470	119.83	25.50%	2024/7/23	0	4436.85	
493		0		碱14	7828.64	452	135.53	29.98%	2024/7/19	0	3915.58	
494		0		碱15	8400.2	485	120.76	24.90%	2024/7/21	0	4628.56	
495		0	10kV-43	碱31	8140.4	470	200.08	42.57%	2024/6/13	0	3046.95	
496		0		碱32	6287.16	363	244.86	67.46%	2024/5/26	0	788.70	
497		0		碱33	8140.4	470	199.59	42.47%	2024/6/13	0	3055.46	
498		0		碱34	8140.4	470	62.01	13.19%	2024/7/18	0	5438.32	
499		0		碱35	8140.4	470	328.505	69.89%	2024/7/10	0	822.61	
500		0		碱36	8140.4	470	323.40	68.81%	2024/6/19	0	910.96	
501		0		碱37	8140.4	470	227.74	48.45%	2024/6/18	0	2567.93	
502		0		碱38	8140.4	470	120.85	25.71%	2024/7/31	0	4419.22	
503		0	10kV-44	碱41	8140.4	470	154.02	32.77%	2024/6/16	0	3844.69	
504		0		碱42	6287.16	363	123.05	33.90%	2024/5/26	0	2898.55	
505		0		碱43	8140.4	470	120.03	25.54%	2024/5/29	0	4433.38	
506		0		碱44	8140.4	470	226.91	48.28%	2024/8/3	0	2582.26	
507		0		碱45	8140.4	470	146.81	31.24%	2024/7/24	0	3969.64	
508		0		碱46	8140.4	470	120.01	25.53%	2024/5/29	0	4433.71	
509		0		碱47	8140.4	470	155.74	33.14%	2024/5/26	0	3814.87	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
510	金源路	0	10kV-45	碱48	8140.4	470	143.77	30.59%	2024/7/21	0	4022.24	
511		0		碱51	8140.4	470	272.10	57.89%	2024/5/26	0	1799.60	
512		0		碱52	8140.4	470	204.74	43.56%	2024/5/26	0	2966.24	
513		0		碱53	8140.4	470	190.69	40.57%	2024/7/23	0	3209.53	
514		0		碱54	8140.4	470	217.52	46.28%	2024/8/11	0	2744.86	
515		0		碱55	6287.16	363	236.07	65.03%	2024/3/23	0	940.93	
516		0		碱56	8140.4	470	201.13	42.79%	2024/7/24	0	3028.73	
517		0		碱57	8140.4	470	157.31	33.47%	2024/6/18	0	3787.76	
518		0		碱58	8140.4	470	276.50	58.83%	2024/5/20	0	1723.27	
519		0	10kV-46	碱61	8140.4	470	209.16	44.50%	2024/6/25	0	2889.76	
520		0		碱62	8140.4	470	312.72	66.54%	2024/6/13	0	1096.10	
521		0		碱63	8140.4	470	210.06	44.69%	2024/6/16	0	2874.10	
522		0		碱64	8140.4	470	119.93	25.52%	2024/6/18	0	4435.20	
523		0		碱65	6287.16	363	219.90	60.58%	2024/6/16	0	1221.03	
524		0		碱66	8140.4	470	120.03	25.54%	2024/6/18	0	4433.44	
525		0		碱67	7828.64	452	139.04	30.76%	2024/1/12	0	3854.69	
526		0		碱68	8140.4	470	169.22	36.00%	2024/6/18	0	3581.50	
527	金源路	0	10kV-41	源11	6928	400	92.99	23.25%	2024/6/28	0	3931.85	
528		0		源12	6928	400	186.99	46.75%	2024/6/17	0	2303.79	
529		0		源13	6373.76	368	220.99	60.05%	2024/1/19	0	1271.53	
530		0		源14	6928	400	278.00	69.50%	2024/1/21	0	727.47	
531		0		源15	6928	400	189.99	47.50%	2024/6/17	0	2251.77	
532		0		源16	6373.76	368	145.99	39.67%	2024/8/3	0	2570.53	
533		0		源17	6373.76	368	250.99	68.20%	2024/6/17	0	751.93	
534		0		源18	6928	400	222.99	55.75%	2024/6/17	0	1680.16	
535		0	10kV-42	源21	6928	400	222.00	55.50%	2024/6/17	0	1697.41	
536		0		源22	6928	400	275.00	68.75%	2024/7/24	0	779.49	
537		0		源23	6373.76	368	225.00	61.14%	2024/6/17	0	1202.01	
538		0		源24	6373.76	368	245.00	66.57%	2024/6/19	0	855.69	
539		0		源25	6373.76	368	186.99	50.81%	2024/6/17	0	1860.39	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
540		0	10kV-43	源26	6928	400	102.00	25.50%	2024/7/20	0	3775.81	
541		0		源27	6928	400	264.99	66.25%	2024/7/23	0	952.77	
542		0		源28	6373.76	368	258.994	70.38%	2024/8/23	0	613.23	
543		0	10kV-44	源31	6373.76	368	271.381	73.74%	2024/7/24	0	398.69	
544		0		源32	6373.76	368	77.28	21.00%	2024/7/7	0	3760.47	
545		0										
546	精细园	0	10kV-41	精11	8140.4	470	327.22	69.62%	2024/5/18	0	844.92	
547		0		精12	8140.4	470	126.23	26.86%	2024/8/24	0	4325.96	
548		0		精13	7880.6	455	126.69	27.84%	2024/5/10	0	4110.14	
549		0		精14	9924.36	573	2.15	0.38%	2024/11/20	0	7902.20	
550		0		精15	8278.96	478	81.34	17.02%	2024/11/24	0	5214.31	
551		0	10kV-42	精21	7880.6	455	218.01	47.91%	2024/6/19	0	2528.49	
552		0		精22	7326.36	423	0.00	0.00%	2024/1/1	0	5861.09	
553		0		精23	7880.6	455	89.14	19.59%	2024/4/18	0	4760.52	
554		0		精24	10392	600	50.87	8.48%	2024/5/30	0	7432.58	
555		0	10kV-43	精31	8140.4	470	184.90	39.34%	2024/10/20	0	3309.85	
556		0		精32	8140.4	470	278.13	59.18%	2024/8/26	0	1695.11	
557		0		精33	7880.6	455	73.30	16.11%	2024/12/19	0	5034.91	
558		0		精34	9924.36	573	2.15	0.38%	2024/11/17	0	7902.20	
559		0		精35	8278.96	478	269.25	56.33%	2024/11/22	0	1959.71	
560		0	10kV-44	精41	7880.6	455	233.15	51.24%	2024/9/1	0	2266.29	
561		0		精42	7326.36	423	0.00	0.00%	2024/1/1	0	5861.09	
562		0		精43	7880.6	455	62.14	13.66%	2024/4/10	0	5228.23	
563		0		精44	7880.6	455	114.24	25.11%	2024/3/29	0	4325.91	
564		0		精45	5369.2	310	11.51	3.71%	2024/1/7	0	4095.94	
565		0		精46	9266.2	535	199.07	37.21%	2024/12/3	0	3965.03	
566		0	10kV-42	科21	6373.76	368	59.41	16.15%	2024/9/4	0	4069.96	
567		0		科22	6373.76	368	219.61	59.68%	2024/7/18	0	1295.38	
568		0		科23	6928	400	107.70	26.92%	2024/8/26	0	3677.12	
569		0		科24	6928	400	132.66	33.16%	2024/7/23	0	3244.80	
569		0		科25	6928	400	277.38	69.35%	2024/7/24	0	738.13	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
570	科学园	0	10kV-43	科26	6928	400	156.68	39.17%	2024/7/24	0	2828.70	
571		0		科27	6928	400	110.86	27.71%	2024/7/24	0	3622.32	
572		0	10kV-44	科31	6928	400	44.06	11.02%	2024/1/29	0	4779.25	
573		0		科32	6373.76	368	193.71	52.64%	2024/7/25	0	1743.93	
574		0		科33	6373.76	368	179.30	48.72%	2024/7/23	0	1993.58	
575		0		科34	6928	400	285.977	71.49%	2024/8/22	0	589.28	
576		0		科35	6928	400	44.88	11.22%	2024/8/7	0	4765.03	
577		0		科36	6928	400	170.98	42.74%	2024/7/11	0	2581.08	
578		0		科37	6928	400	214.81	53.70%	2024/12/6	0	1821.98	
579	临津园	0	10kV-4	津11	6373.76	368	246.60	67.01%	2024/7/14	0	827.91	
580		0		津12	7499.56	433	10.81	2.50%	2024/7/26	0	5812.40	
581		0		津13	7499.56	433	300.999	69.51%	2024/1/2	0	786.35	
582		0		津14	7187.8	415	41.40	9.97%	2024/3/7	0	5033.26	
583		0	10kV-5	津21	6373.76	368	251.39	68.31%	2024/12/23	0	744.95	
584		0		津22	7499.56	433	199.80	46.14%	2024/1/2	0	2539.16	
585		0		津23	7499.56	433	297.988	68.82%	2024/1/2	0	838.50	
586		0		津24	7187.8	415	306.997	73.98%	2024/12/12	0	433.05	
587	刘岗	0	10kV-4	刘11	6062	350	187.73	53.64%	2024/12/26	0	1598.05	
588		0		刘13	6373.76	368	216.21	58.75%	2024/1/14	0	1354.23	
589		0		刘14	6373.76	368	194.77	52.93%	2024/11/7	0	1725.66	
590		0	10kV-5	刘22	6373.76	368	2.46	0.67%	2024/11/16	0	5056.38	
591		0		刘23	6373.76	368	123.75	33.63%	2024/8/28	0	2955.66	
592		0		刘24	6062	350	232.38	66.40%	2024/12/26	0	824.73	
593		0		刘25	7794	450	0.35	0.08%	2024/1/1	0	6229.10	
594	美洲路	0	10kV-41	美11	6928	400	151.64	37.91%	2024/7/20	0	2915.98	
595		0		美12	6928	400	98.44	24.61%	2024/6/18	0	3837.45	
596		0		美16	6928	400	94.92	23.73%	2024/7/19	0	3898.35	
597		0		美17	6928	400	82.97	20.74%	2024/1/4	0	4105.38	
598		0		美18	6928	400	61.41	15.35%	2024/1/31	0	4478.85	
599		0		美21	6928	400	70.90	17.72%	2024/12/21	0	4314.45	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
600		0	10kV-42	美22	6928	400	71.60	17.90%	2024/1/2	0	4302.25	
601		0	10kV-43	美23	6928	400	56.72	14.18%	2024/12/19	0	4560.03	
602		0		美25	6928	400	154.81	38.70%	2024/7/20	0	2861.18	
603		0		美26	6928	400	104.06	26.02%	2024/12/27	0	3740.05	
604	南环	0	10kV-41	南11	6928	400	55.90	13.97%	2024/12/21	0	4574.25	
605		0		南12	6928	400	140.86	35.21%	2024/9/9	0	3102.72	
606		0		南13	6928	400	276.33	69.08%	2024/4/11	0	756.40	
607		0		南14	6928	400	209.65	52.41%	2024/12/19	0	1911.30	
608		0		南15	6928	400	134.88	33.72%	2024/9/17	0	3206.23	
609		0		南16	6928	400	148.01	37.00%	2024/12/7	0	2978.90	
610		0		南17	6928	400	200.04	50.01%	2024/7/19	0	2077.72	
611		0		南18	6928	400	0.00	0.00%	2024/1/1	0	5542.40	
612		0	10kV-42	南21	6928	400	0.00	0.00%	2024/1/1	0	5542.40	
613		0		南22	6928	400	0.00	0.00%	2024/1/1	0	5542.40	
614		0		南23	6928	400	146.13	36.53%	2024/11/19	0	3011.38	
615		0		南24	6373.76	368	56.37	15.32%	2024/11/29	0	4122.73	
616		0	10kV-43	南25	6373.76	368	196.52	53.40%	2024/6/11	0	1695.23	
617		0		南26	6928	400	67.38	16.85%	2024/7/3	0	4375.33	
618		0		南27	6928	400	119.65	29.91%	2024/11/4	0	3470.10	
619		0		南28	6928	400	252.89	63.22%	2024/1/13	0	1162.33	
620	宁车沽	0	10kV-4	车11	5196	300	210.70	70.23%	2024/7/26	0	507.55	
621		0		车12	6373.76	368	181.19	49.24%	2024/3/25	0	1960.85	
622		0	10kV-5	车21	5196	300	71.98	23.99%	2024/8/19	0	2910.07	
623		0		车22	5196	300	194.63	64.88%	2024/8/5	0	785.74	
624		0	10kV-42	夏31	7534.2	435	86.75	19.94%	2024/7/20	0	4524.85	
625		0		夏32	8573.4	495	93.12	18.81%	2024/2/22	0	5245.97	
626		0		夏33	9560.64	552	49.92	9.04%	2024/7/1	0	6783.90	
627		0		夏34	7395.64	427	209.45	49.05%	2024/7/31	0	2288.84	
628		0	10kV-43	夏41	9924.36	573	72.36	12.63%	2024/4/30	0	6686.16	
629		0		夏42	8278.96	478	160.10	33.49%	2024/3/20	0	3850.29	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
630	宁夏道	0	10kV-44	夏 ₅₁	8573.4	495	77.42	15.64%	2024/1/23	0	5517.87	
631		0		夏 ₅₂	7534.2	435	107.46	24.70%	2024/7/20	0	4166.15	
632		0		夏 ₅₃	9560.64	552	50.66	9.18%	2024/1/11	0	6771.08	
633		0		夏 ₅₄	7395.64	427	212.07	49.66%	2024/10/8	0	2243.55	
634		0		夏 ₆₁	9006.4	520	52.72	10.14%	2024/7/24	0	6292.06	
635		0		夏 ₆₂	8278.96	478	34.56	7.23%	2024/12/18	0	6024.66	
636		0		夏 ₆₃	6495	375	61.16	16.31%	2024/11/6	0	4136.73	
637	农场	0	10kV-4	农11	5196	300	190.28	63.43%	2024/8/26	0	861.10	
638		0		农12	5196	300	104.94	34.98%	2024/1/29	0	2339.22	
639		0	10kV-5	农21	5196	300	148.45	49.48%	2024/2/17	0	1585.70	
640		0		农22	5196	300	199.814	66.60%	2024/12/3	0	696.02	
641		0		农23	5196	300	194.59	64.86%	2024/8/21	0	786.50	
642		0		农24	5196	300	125.33	41.78%	2024/1/31	0	1986.05	
643		0		农24	5196	300	125.33	41.78%	2024/1/31	0	1986.05	
643	轻纺城	0	10kV-41	纺14	6928	400	164.66	41.17%	2024/8/28	0	2690.47	
644		0		纺15	4347.32	251	61.46	24.49%	2024/12/27	0	2413.39	
645		0		纺16	6928	400	191.52	47.88%	2024/5/15	0	2225.20	
646		0		纺17	6928	400	134.35	33.59%	2024/7/1	0	3215.53	
647		0	10kV-42	纺24	6928	400	38.29	9.57%	2024/8/30	0	4879.20	
648		0		纺25	6928	400	272.66	68.17%	2024/1/10	0	819.88	
649		0		纺26	6928	400	287.536	71.88%	2024/7/2	0	562.28	
650	清河	0	10kV-4	931	4330	250	78.28	31.31%	2024/5/9	0	2108.17	
651		0	10kV-5	932	4156.8	240	78.75	32.81%	2024/11/21	0	1961.49	
652		0	10kV-4	933	3464	200	131.95	65.98%	2024/7/24	0	485.77	
653		0	10kV-5	934	3464	200	128.125	64.06%	2024/7/30	0	552.08	
654		0	10kV-4	935	3464	200	59.06	29.53%	2024/5/13	0	1748.23	
655		0	10kV-5	936	3464	200	107.11	53.55%	2024/1/23	0	916.07	
656		0	10kV-4	937	4156.8	240	164.688	68.62%	2024/6/12	0	473.04	
657		0	10kV-5	938	3464	200	138.906	69.45%	2024/6/12	0	365.35	
658		0		桥11	6373.76	368	118.48	32.19%	2024/7/28	0	3046.99	
659		0		桥13	8140.4	470	178.95	38.07%	2024/7/23	0	3412.99	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
660	三道桥	0	10kV-41	桥15	8140.4	470	180.70	38.45%	2024/7/23	0	3382.54	
661		0		桥16	6373.76	368	55.72	15.14%	2024/7/23	0	4133.89	
662		0		桥17	8140.4	470	211.64	45.03%	2024/7/23	0	2846.70	
663		0	10kV-42	桥22	6373.76	368	108.81	29.57%	2024/7/23	0	3214.44	
664		0		桥24	6373.76	368	194.94	52.97%	2024/6/30	0	1722.63	
665		0		桥25	6373.76	368	266.348	72.38%	2024/12/12	0	485.86	
666		0	10kV-43	桥26	6373.76	368	180.53	49.06%	2024/1/7	0	1972.28	
667		0		桥27	8140.4	470	179.82	38.26%	2024/7/23	0	3397.77	
668		0		桥31	8140.4	470	186.50	39.68%	2024/7/23	0	3282.07	
669		0	10kV-44	桥32	6373.76	368	251.758	68.41%	2024/7/24	0	738.56	
670		0		桥33	8140.4	470	168.05	35.75%	2024/7/23	0	3601.75	
671		0		桥34	6373.76	368	215.68	58.61%	2024/5/22	0	1363.36	
672	沙井子	0	10kV-4	井11	6373.76	368	198.32	53.89%	2024/7/27	0	1664.11	
673		0		井12	6928	400	222.89	55.72%	2024/7/30	0	1681.98	
674		0	10kV-5	井21	6373.76	368	261.50	71.06%	2024/8/23	0	569.76	
675		0		井22	6373.76	368	168.61	45.82%	2024/7/19	0	2178.72	
676		0		井23	6373.76	368	75.92	20.63%	2024/7/25	0	3784.07	
677	胜利村	0	10kV-4	640	6928	400	65.98	16.49%	2024/7/22	0	4399.68	
678		0		641	6373.76	368	344.41	93.59%	2024/6/17	0	0.00	
679		0	10kV-5	642	6373.76	368	263.10	71.49%	2024/7/23	0	542.12	
680		0	10kV-4	643	6373.76	368	241.20	65.54%	2024/7/24	0	921.42	
681		0	10kV-5	644	6373.76	368	223.95	60.85%	2024/10/30	0	1220.28	
682		0	10kV-4	645	6373.76	368	328.24	89.20%	2024/6/17	0	0.00	
683		0	10kV-5	646	6373.76	368	103.48	28.12%	2024/7/24	0	3306.79	
684		0	10kV-4	647	6928	400	273.10	68.28%	2024/7/23	0	812.31	
685		0	10kV-5	648	6928	400	197.70	49.42%	2024/7/24	0	2118.32	
686		0		652	6373.76	368	253.10	68.78%	2024/7/24	0	715.32	
687		0		654	6373.76	368	175.20	47.61%	2024/7/5	0	2064.63	
688	双桥站	0	10kV-4	双11	6373.76	368	8.97	2.44%	2024/4/22	0	4943.73	
689		0	10kV-5	双27	5196	300	211.218	70.41%	2024/4/29	0	498.50	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
690	太平村	0	10kV-4	太11	6373.76	368	175.94	47.81%	2024/7/23	0	2051.80	
691		0		太13	6373.76	368	173.62	47.18%	2024/11/13	0	2091.98	
692		0		太14	6373.76	368	247.04	67.13%	2024/3/25	0	820.28	
693		0	10kV-5	太21	6373.76	368	226.77	61.62%	2024/9/7	0	1171.39	
694		0		太22	6373.76	368	255.23	69.36%	2024/3/14	0	678.39	
695		0		太23	6373.76	368	199.79	54.29%	2024/8/2	0	1638.61	
696		0										
697	塘沽	0	10kV-1	141	8140.4	470	172.92	36.79%	2024/12/20	0	3517.43	
698		0		142	8140.4	470	276.35	58.80%	2024/7/23	0	1725.90	
699		0		143	8140.4	470	271.19	57.70%	2024/1/2	0	1815.27	
700		0		144	8140.4	470	131.16	27.91%	2024/7/23	0	4240.70	
701		0		145	8140.4	470	161.04	34.26%	2024/7/23	0	3723.19	
702		0		146	8140.4	470	159.00	33.83%	2024/7/23	0	3758.53	
703		0		147	6373.76	368	262.00	71.20%	2024/3/16	0	561.17	
704		0		148	8140.4	470	276.95	58.93%	2024/7/23	0	1715.51	
705		0	10kV-2甲	151	8140.4	470	330.00	70.21%	2024/7/23	0	796.72	
706		0		152	8140.4	470	195.95	41.69%	2024/5/21	0	3118.40	
707		0		153	6373.76	368	261.00	70.92%	2024/7/24	0	578.49	
708		0		154	6373.76	368	80.64	21.91%	2024/7/30	0	3702.36	
709		0	10kV-2乙	155	8140.4	470	39.84	8.48%	2024/2/21	0	5822.31	
710		0		156	8140.4	470	183.47	39.04%	2024/8/1	0	3334.55	
711		0		157	8140.4	470	197.63	42.05%	2024/7/28	0	3089.30	
712		0		158	6373.76	368	258.95	70.37%	2024/6/24	0	613.96	
713		0	10kV-3	161	6373.76	368	261.00	70.92%	2024/7/23	0	578.49	
714		0		162	8140.4	470	322.31	68.58%	2024/1/23	0	929.91	
715		0		163	8140.4	470	192.47	40.95%	2024/1/13	0	3178.67	
716		0		164	8140.4	470	247.67	52.70%	2024/7/23	0	2222.64	
717		0		165	8140.4	470	219.47	46.70%	2024/7/23	0	2711.05	
718		0		166	8140.4	470	307.55	65.44%	2024/7/23	0	1185.54	
719		0		167	8140.4	470	126.36	26.88%	2024/7/24	0	4323.83	
		0		168	6373.76	368	226.79	61.63%	2024/6/22	0	1170.95	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
720	腾深	0	10kV-43	深31	11604.4	670	242.91	36.25%	2024/11/7	0	5076.37	
721		0		深32	10651.8	615	164.96	26.82%	2024/9/11	0	5664.38	
722		0		深34	6200.56	358	174.62	48.78%	2024/1/23	0	1936.03	
723		0	10kV-44	深41	4416.6	255	10.50	4.12%	2024/1/1	0	3351.37	
724		0		深45	9266.2	535	133.20	24.90%	2024/12/20	0	5105.97	
725		0		深46	9006.4	520	141.60	27.23%	2024/6/14	0	4752.64	
726		0	10kV-45	深51	11604.4	670	249.54	37.24%	2024/11/6	0	4961.54	
727		0		深52	10651.8	615	112.48	18.29%	2024/10/1	0	6573.23	
728		0		深54	9266.2	535	211.29	39.49%	2024/8/22	0	3753.35	
729		0	10kV-46	深61	4416.6	255	14.77	5.79%	2024/1/12	0	3277.50	
730		0		深64	7309.04	422	3.87	0.92%	2024/9/25	0	5780.17	
731		0		深66	9006.4	520	176.00	33.85%	2024/11/7	0	4156.80	
732	体育场		10kV-41	体11	7828.64	452	174.07	38.51%	2024/7/21	0	3248.09	
733				体12	9093	525	37.63	7.17%	2024/10/23	0	6622.72	
734				体13	9093	525	372.75	71.00%	2024/7/24	0	818.42	
735				体14	7828.64	452	24.26	5.37%	2024/3/12	0	5842.66	
736			10kV-44	体31	7828.64	452	128.18	28.36%	2024/7/30	0	4042.90	
737				体32	9093	525	369.28	70.34%	2024/7/24	0	878.56	
738				体33	9093	525	171.43	32.65%	2024/7/24	0	4305.25	
739				体34	7828.64	452	5.45	1.21%	2024/7/30	0	6168.50	
740	填海站	0	10kV-41	填11	6928	400	54.84	13.71%	2024/5/17	0	4592.50	
741		0		填12	9266.2	535	39.64	7.41%	2024/12/2	0	6726.41	
742		0		填13	7499.56	433	131.60	30.39%	2024/8/26	0	3720.30	
743		0		填17	7153.16	413	0.15	0.04%	2024/1/18	0	5720.00	
744		0		填18	7724.72	446	44.44	9.96%	2024/12/21	0	5410.02	
745		0	10kV-42	填21	7499.56	433	48.75	11.26%	2024/12/4	0	5155.30	
746		0		填22	9266.2	535	26.54	4.96%	2024/1/18	0	6953.24	
747		0		填23	7499.56	433	113.85	26.29%	2024/7/5	0	4027.80	
748		0		填27	7724.72	446	46.06	10.33%	2024/1/2	0	5382.10	
749		0		填28	7724.72	446	35.98	8.07%	2024/1/8	0	5556.65	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
750	同进	0	10kV-41	同11	8278.96	478	137.17	28.70%	2024/1/13	0	4247.38	
751		0		同12	8278.96	478	249.90	52.28%	2024/7/31	0	2294.93	
752		0		同13	9093	525	56.04	10.67%	2024/10/29	0	6303.75	
753		0		同14	8278.96	478	9.61	2.01%	2024/9/13	0	6456.74	
754		0		同15	6495	375	171.07	45.62%	2024/6/6	0	2233.00	
755		0	10kV-42	同31	8278.96	478	158.50	33.16%	2024/12/20	0	3877.95	
756		0		同32	8278.96	478	193.97	40.58%	2024/8/13	0	3263.61	
757		0		同33	9093	525	176.42	33.60%	2024/1/10	0	4218.75	
758		0		同34	8278.96	478	51.23	10.72%	2024/10/29	0	5735.90	
759		0		同35	6495	375	237.04	63.21%	2024/12/16	0	1090.55	
760		0		同36	8227	475	180.66	38.03%	2024/9/7	0	3452.57	
761	团结路	0	10kV-41	团11	6373.76	368	173.67	47.19%	2024/12/19	0	2091.01	
762		0		团12	6373.76	368	252.988	68.75%	2024/7/31	0	717.26	
763		0		团14	6373.76	368	29.18	7.93%	2024/10/19	0	4593.61	
764		0		团15	8140.4	470	140.80	29.96%	2024/1/4	0	4073.65	
765		0		团16	6373.76	368	1.06	0.29%	2024/1/1	0	5080.74	
766		0		团17	8278.96	478	241.70	50.56%	2024/10/10	0	2436.94	
767		0		团18	8140.4	470	159.43	33.92%	2024/1/23	0	3750.92	
768		0	10kV-42	团21	6373.76	368	162.42	44.14%	2024/1/6	0	2285.86	
769		0		团22	8140.4	470	253.13	53.86%	2024/1/18	0	2128.20	
770		0		团23	6373.76	368	0.53	0.14%	2024/2/22	0	5089.88	
771		0		团24	8278.96	478	150.65	31.52%	2024/5/16	0	4014.00	
772		0	10kV-43	团25	8140.4	470	87.01	18.51%	2024/4/26	0	5005.27	
773		0		团26	6373.76	368	105.29	28.61%	2024/5/16	0	3275.33	
774		0		团27	6373.76	368	111.27	30.24%	2024/3/20	0	3171.81	
775		0		团28	6373.76	368	91.58	24.89%	2024/1/10	0	3512.81	
776		0	10kV-4	王11	6373.76	368	51.24	13.92%	2024/2/26	0	4211.53	
777		0		王12	6373.76	368	57.14	15.53%	2024/7/30	0	4109.27	
778		0		王14	6373.76	368	91.11	24.76%	2024/7/23	0	3520.95	
779		0		王15	6928	400	82.33	20.58%	2024/4/19	0	4116.48	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
780	王庄镇	0	10kV-5	王21	6373.76	368	84.57	22.98%	2024/7/23	0	3634.29	
781		0		王22	6235.2	360	119.78	33.27%	2024/11/7	0	2913.50	
782		0		王24	6373.76	368	125.29	34.05%	2024/8/1	0	2929.02	
783		0		王25	6373.76	368	214.06	58.17%	2024/8/3	0	1391.42	
784		0		王26	6373.76	368	91.66	24.91%	2024/1/25	0	3511.53	
785		0										
786	西沽	0	10kV-41	西11	6928	400	99.14	24.79%	2024/1/2	0	3825.28	
787		0		西12	6928	400	187.27	46.82%	2024/7/23	0	2298.95	
788		0		西13	6928	400	80.74	20.19%	2024/7/30	0	4143.95	
789		0		西14	6928	400	160.78	40.20%	2024/12/15	0	2757.67	
790		0		西15	6928	400	88.01	22.00%	2024/4/7	0	4018.10	
791		0		西16	6928	400	238.13	59.53%	2024/7/28	0	1418.08	
792		0	10kV-42	西21	6928	400	123.28	30.82%	2024/11/22	0	3407.17	
793		0		西22	6928	400	31.17	7.79%	2024/12/28	0	5002.50	
794		0		西23	6373.76	368	255.47	69.42%	2024/7/2	0	674.28	
795		0		西24	6928	400	251.72	62.93%	2024/9/8	0	1182.63	
796		0		西25	6928	400	116.72	29.18%	2024/11/18	0	3520.83	
797		0		西26	6928	400	126.68	31.67%	2024/7/20	0	3348.30	
798		0	10kV-43	西31	6928	400	90.94	22.73%	2024/1/22	0	3967.35	
799		0		西32	6928	400	242.81	60.70%	2024/8/2	0	1336.90	
800		0		西33	6928	400	122.70	30.67%	2024/4/7	0	3417.32	
801		0		西34	6928	400	215.63	53.91%	2024/8/2	0	1807.78	
802		0		西35	6928	400	237.66	59.41%	2024/7/23	0	1426.20	
803		0		西36	6928	400	128.20	32.05%	2024/3/30	0	3321.92	
804		0	10kV-44	西41	6928	400	127.50	31.88%	2024/7/23	0	3334.10	
805		0		西42	6928	400	108.75	27.19%	2024/11/25	0	3658.85	
806		0		西43	6928	400	143.91	35.98%	2024/3/30	0	3049.95	
807		0		西44	6928	400	127.62	31.90%	2024/9/19	0	3332.07	
808		0	10kV-5	582	6928	400	183.98	46.00%	2024/6/22	0	2355.80	
809		0		583	6373.76	368	86.72	23.56%	2024/8/2	0	3597.03	
		0		584	6373.76	368	181.41	49.30%	2024/7/23	0	1957.06	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
810	新北路	0		585	6373.76	368	253.281	68.83%	2024/7/29	0	712.18	
811		0		586	6373.76	368	164.53	44.71%	2024/11/13	0	2249.33	
812		0	10kV-4	588	6373.76	368	13.13	3.57%	2024/12/26	0	4871.68	
813		0		589	6373.76	368	247.656	67.30%	2024/11/13	0	809.61	
814		0		590	6373.76	368	240.47	65.34%	2024/12/21	0	934.08	
815		0		591	6928	400	55.55	13.89%	2024/1/23	0	4580.33	
816		0		592	6373.76	368	254.688	69.21%	2024/7/30	0	687.81	
817		0		593	6373.76	368	197.58	53.69%	2024/7/24	0	1676.96	
818	新村	0	10kV-41	村11	8140.4	470	172.22	36.64%	2024/6/22	0	3529.40	
819		0		村13	8140.4	470	297.06	63.20%	2024/6/22	0	1367.24	
820		0		村14	8140.4	470	203.08	43.21%	2024/5/22	0	2995.04	
821		0		村15	8140.4	470	116.06	24.69%	2024/8/2	0	4502.09	
822		0		村16	8140.4	470	38.39	8.17%	2024/1/8	0	5847.44	
823		0		村17	6373.76	368	271.35	73.74%	2024/7/23	0	399.26	
824		0	10kV-42	村21	8140.4	470	228.06	48.52%	2024/7/24	0	2562.32	
825		0		村22	8140.4	470	118.42	25.19%	2024/7/23	0	4461.35	
826		0	10kV-43	村25	8140.4	470	132.43	28.18%	2024/8/4	0	4218.60	
827		0		村26	8140.4	470	163.20	34.72%	2024/8/2	0	3685.70	
828		0		村27	8140.4	470	161.38	34.34%	2024/3/14	0	3717.29	
829		0		村28	8140.4	470	138.95	29.56%	2024/8/2	0	4105.74	
830		0	10kV-44	村31	8140.4	470	96.78	20.59%	2024/7/23	0	4836.09	
831		0		村32	8140.4	470	44.60	9.49%	2024/7/29	0	5739.78	
832		0		村33	6373.76	368	140.11	38.07%	2024/7/30	0	2672.27	
833		0		村34	8140.4	470	311.86	66.35%	2024/7/24	0	1110.97	
834		0		村35	8140.4	470	195.25	41.54%	2024/6/20	0	3130.56	
835		0		村36	8140.4	470	142.14	30.24%	2024/3/13	0	4050.46	
836		0		村38	8140.4	470	9.08	1.93%	2024/1/4	0	6354.99	
837		0	10kV-41	港11	8140.4	470	174.02	37.03%	2024/6/11	0	3498.24	
838		0		港12	8140.4	470	61.70	13.13%	2024/1/21	0	5443.69	
839		0		港13	8140.4	470	89.65	19.07%	2024/7/23	0	4959.62	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
840	新港	0	10kV-41	港14	8140.4	470	169.63	36.09%	2024/7/23	0	3574.35	
841		0		港17	8140.4	470	117.60	25.02%	2024/3/1	0	4475.52	
842		0		港18	8140.4	470	136.06	28.95%	2024/7/6	0	4155.85	
843		0	10kV-42	港21	8140.4	470	272.64	58.01%	2024/7/24	0	1790.25	
844		0		港24	8140.4	470	219.73	46.75%	2024/7/21	0	2706.65	
845		0	10kV-43	港25	8140.4	470	323.09	68.74%	2024/7/24	0	916.47	
846		0		港26	8140.4	470	177.72	37.81%	2024/7/23	0	3434.30	
847		0		港27	8140.4	470	305.51	65.00%	2024/7/23	0	1220.92	
848		0		港28	8140.4	470	193.36	41.14%	2024/12/19	0	3163.34	
849	新河	0	10kV-41	河11	6373.76	368	193.89	52.69%	2024/7/23	0	1740.89	
850		0		河12	8140.4	470	76.99	16.38%	2024/3/18	0	5178.82	
851		0		河13	6373.76	368	148.71	40.41%	2024/7/23	0	2523.33	
852		0		河14	6373.76	368	176.48	47.96%	2024/7/23	0	2042.31	
853		0		河15	8140.4	470	209.71	44.62%	2024/7/23	0	2880.19	
854		0		河16	8140.4	470	36.74	7.82%	2024/3/26	0	5876.02	
855		0		河17	8140.4	470	258.93	55.09%	2024/7/23	0	2027.72	
856		0	10kV-42	河21	7309.04	422	223.95	53.07%	2024/12/13	0	1968.50	
857		0		河23	8140.4	470	59.41	12.64%	2024/8/5	0	5483.27	
858		0		河24	8140.4	470	248.56	52.88%	2024/5/23	0	2207.35	
859		0	10kV-43	河25	6373.76	368	191.78	52.11%	2024/7/19	0	1777.43	
860		0		河26	8140.4	470	108.81	23.15%	2024/4/10	0	4627.75	
861		0		河27	6373.76	368	193.01	52.45%	2024/7/23	0	1756.11	
862		0	10kV-44	河31	8140.4	470	260.68	55.46%	2024/7/23	0	1997.27	
863		0		河32	8140.4	470	0.00	0.00%	2024/1/1	0	6512.32	
864		0		河33	8140.4	470	271.23	57.71%	2024/7/23	0	1814.62	
865		0		河34	7309.04	422	18.11	4.29%	2024/8/3	0	5533.65	
866		0		河36	8140.4	470	178.24	37.92%	2024/7/23	0	3425.17	
867		0		河37	8140.4	470	117.95	25.10%	2024/12/13	0	4469.44	
868		0		461	9266.2	535	108.72	20.32%	2024/8/16	0	5529.96	
869		0		462	9266.2	535	234.85	43.90%	2024/8/9	0	3345.43	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
870	新民路	0	10kV-41	471	6373.76	368	192.48	52.30%	2024/7/21	0	1765.25	
871		0		472	6928	400	44.80	11.20%	2024/8/30	0	4766.46	
872		0		473	9266.2	535	263.96	49.34%	2024/7/21	0	2841.17	
873		0		474	9266.2	535	89.87	16.80%	2024/8/23	0	5856.41	
874		0		481	8140.4	470	220.64	46.94%	2024/4/21	0	2690.84	
875		0	10kV-42	482	6373.76	368	197.76	53.74%	2024/8/10	0	1673.80	
876		0		483	6373.76	368	238.72	64.87%	2024/7/26	0	964.38	
877		0		484	6373.76	368	239.20	65.00%	2024/5/12	0	956.06	
878		0		485	8140.4	470	219.68	46.74%	2024/12/6	0	2707.46	
879		0	10kV-43	486	8140.4	470	221.92	47.22%	2024/7/15	0	2668.67	
880		0		487	6373.76	368	201.60	54.78%	2024/5/19	0	1607.30	
881		0		488	7326.36	423	261.60	61.84%	2024/12/25	0	1330.18	
882		0		491	6373.76	368	305.12	82.91%	2024/8/30	0	0.00	
883		0	10kV-44	492	10392	600	148.48	24.75%	2024/8/13	0	5741.93	
884		0		493	6373.76	368	259.50	70.52%	2024/7/18	0	604.47	
885		0		494	9543.32	551	21.44	3.89%	2024/9/13	0	7263.32	
886		0		495	8140.4	470	234.72	49.94%	2024/1/17	0	2446.97	
887		0		496	8140.4	470	195.68	41.63%	2024/7/23	0	3123.14	
888		0		497	8140.4	470	198.88	42.31%	2024/8/5	0	3067.72	
889		0		498	7326.36	423	264.32	62.49%	2024/10/17	0	1283.07	
890		0	10kV-41	圣13	8781.24	507	379.501	74.85%	2024/7/19	0	452.03	
891	新圣路	0	10kV-42	圣21	6373.76	368	195.57	53.14%	2024/1/29	0	1711.70	
892		0		圣23	6633.56	383	163.44	42.67%	2024/9/9	0	2476.03	
893		0		圣24	8140.4	470	251.02	53.41%	2024/8/30	0	2164.72	
894		0	10kV-43	圣25	6373.76	368	208.69	56.71%	2024/5/12	0	1484.43	
895		0		圣26	6633.56	383	105.71	27.60%	2024/7/29	0	3476.04	
896		0		圣27	8729.28	504	276.15	54.79%	2024/6/27	0	2200.52	
897		0		圣28	6633.56	383	67.66	17.67%	2024/7/22	0	4134.99	
898		0		圣31	6373.76	368	84.68	23.01%	2024/7/30	0	3632.39	
899		0		圣32	8140.4	470	170.88	36.36%	2024/7/29	0	3552.75	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	最大负荷发生日期	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
900		0	10kV-44	圣33	8140.4	470	286.82	61.03%	2024/7/8	0	1544.61	
901		0		圣34	9006.4	520	303.30	58.33%	2024/12/25	0	1952.00	
902		0		圣35	8781.24	507	165.47	32.64%	2024/7/17	0	4159.07	
903		0		圣36	8140.4	470	146.86	31.25%	2024/9/19	0	3968.69	
904		0		圣37	9006.4	520	186.26	35.82%	2024/7/31	0	3979.18	
905		0		圣38	6633.56	383	209.14	54.61%	2024/10/17	0	1684.53	
906	兴塘	0	10kV-41	兴11	6928	400	265.43	66.36%	2024/7/24	0	945.15	
907		0		兴12	6373.76	368	180.59	49.07%	2024/1/22	0	1971.26	
908		0		兴13	6928	400	230.39	57.60%	2024/1/19	0	1552.03	
909		0		兴14	6928	400	298.047	74.51%	2024/7/23	0	380.23	
910		0		兴15	6928	400	4.92	1.23%	2024/11/28	0	5457.15	
911		0	10kV-42	兴21	6928	400	56.37	14.09%	2024/12/19	0	4566.12	
912		0		兴22	6928	400	249.84	62.46%	2024/7/24	0	1215.10	
913		0		兴23	6928	400	207.77	51.94%	2024/11/12	0	1943.77	
914		0		兴24	6928	400	269.336	67.33%	2024/8/5	0	877.50	
915		0		兴25	6928	400	20.39	5.10%	2024/12/13	0	5189.23	
916		0	10kV-43	兴32	6928	400	272.70	68.17%	2024/1/3	0	819.32	
917		0		兴33	6928	400	16.29	4.07%	2024/9/9	0	5260.27	
918		0		兴34	6928	400	187.73	46.93%	2024/7/23	0	2290.85	
919		0		兴35	6373.76	368	95.63	25.99%	2024/10/4	0	3442.78	
920		0		兴36	6928	400	281.13	70.28%	2024/7/24	0	673.18	
921		0	10kV-44	兴41	6928	400	4.81	1.20%	2024/7/26	0	5459.18	
922		0		兴42	6928	400	87.66	21.91%	2024/6/30	0	4024.20	
923		0		兴43	6928	400	250.31	62.58%	2024/7/19	0	1207.00	
924		0		兴44	6928	400	181.06	45.26%	2024/1/19	0	2406.53	
925		0		兴45	6373.76	368	169.45	46.05%	2024/4/25	0	2164.08	
926		0		兴46	6928	400	99.14	24.79%	2024/9/25	0	3825.28	
927		0	10kV-4	杨11	6928	400	270.617	67.65%	2024/11/25	0	855.31	
928		0		杨12	6373.76	368	165.94	45.09%	2024/7/15	0	2224.94	
929		0		杨13	6373.76	368	67.64	18.38%	2024/11/29	0	3927.50	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
930	杨柳庄	0	10kV-5	杨14	6373.76	368	134.00	36.41%	2024/5/10	0	2778.11	
931		0		杨15	6373.76	368	215.07	58.44%	2024/11/25	0	1373.98	
932		0		杨21	6928	400	184.89	46.22%	2024/11/25	0	2340.04	
933		0		杨22	6928	400	267.38	66.85%	2024/11/25	0	911.38	
934		0		杨23	6373.76	368	228.02	61.96%	2024/7/5	0	1149.72	
935		0		杨24	6373.76	368	126.41	34.35%	2024/3/18	0	2909.67	
936		0		杨25	6373.76	368	127.27	34.58%	2024/11/5	0	2894.76	
937	营城	0	10kV-42	营21	7967.2	460	319.82	69.53%	2024/1/16	0	834.41	
938		0		营22	7967.2	460	208.88	45.41%	2024/8/30	0	2755.98	
939		0		营23	7967.2	460	298.20	64.83%	2024/7/31	0	1208.97	
940		0		营24	6373.76	368	220.48	59.91%	2024/1/1	0	1280.24	
941		0	10kV-43	营25	6373.76	368	272.912	74.16%	2024/7/9	0	372.17	
942		0		营26	6754.8	390	238.07	61.04%	2024/12/23	0	1280.54	
943		0		营27	7794	450	53.45	11.88%	2024/8/23	0	5309.45	
944		0		营28	9266.2	535	0.00	0.00%	2024/1/1	0	7412.96	
945		0	10kV-44	营31	9266.2	535	238.42	44.56%	2024/4/30	0	3283.58	
946		0		营32	6373.76	368	186.02	50.55%	2024/1/1	0	1877.11	
947		0		营33	6373.76	368	273.846	74.41%	2024/7/24	0	356.00	
948		0		营34	7967.2	460	10.20	2.22%	2024/1/29	0	6197.13	
949		0		营36	6754.8	390	224.18	57.48%	2024/11/28	0	1521.11	
950		0		营37	7794	450	10.90	2.42%	2024/9/11	0	6046.39	
951		0		营38	9006.4	520	0.00	0.00%	2024/1/1	0	7205.12	
952	永兴路	0	10kV-41	永13	7499.56	433	303.13	70.01%	2024/5/8	0	749.40	
953		0		永14	7447.6	430	240.49	55.93%	2024/9/10	0	1792.76	
954		0		永22	7759.36	448	335.056	74.79%	2024/5/7	0	404.32	
955		0	10kV-42	永33	7499.56	433	303.89	70.18%	2024/12/27	0	736.31	
956		0	10kV-41	乐11	10392	600	49.06	8.18%	2024/1/1	0	7463.85	
957		0		乐12	6928	400	276.706	69.18%	2024/7/23	0	749.85	
958		0		乐13	6928	400	57.83	14.46%	2024/8/10	0	4540.75	
959		0		乐14	6928	400	263.85	65.96%	2024/7/12	0	972.52	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
960	游乐港	0		乐15	6928	400	260.75	65.19%	2024/7/23	0	1026.30	
961		0		乐16	6928	400	142.25	35.56%	2024/12/19	0	3078.63	
962		0	10kV-42	乐21	10392	600	49.06	8.18%	2024/1/1	0	7463.85	
963		0		乐22	6928	400	273.867	68.47%	2024/7/23	0	799.02	
964		0		乐23	6928	400	225.75	56.44%	2024/8/15	0	1632.46	
965		0		乐24	6928	400	226.36	56.59%	2024/8/15	0	1621.83	
966		0		乐25	6928	400	99.41	24.85%	2024/12/20	0	3820.55	
967		0		乐26	6928	400	48.53	12.13%	2024/7/26	0	4701.86	
968		0	10kV-43	乐31	6928	400	262.75	65.69%	2024/7/12	0	991.57	
969	友谊路	0	10kV-4	561	6928	400	93.57	23.39%	2024/7/23	0	3921.82	
970		0		562	6373.76	368	174.91	47.53%	2024/7/24	0	2069.62	
971		0		563	6373.76	368	251.516	68.35%	2024/6/24	0	742.75	
972		0		564	6373.76	368	190.76	51.84%	2024/8/10	0	1795.13	
973		0	10kV-5	565	6373.76	368	199.39	54.18%	2024/6/20	0	1645.59	
974		0		566	6928	400	182.46	45.61%	2024/6/20	0	2382.24	
975		0		567	6928	400	196.15	49.04%	2024/7/24	0	2145.17	
976		0		568	6928	400	197.22	49.30%	2024/8/24	0	2126.64	
977	于家堡	0	10kV-41	于11	6928	400	160.14	40.03%	2024/12/10	0	2768.83	
978		0		于12	6928	400	131.76	32.94%	2024/5/23	0	3260.26	
979		0		于13	6928	400	149.66	37.42%	2024/5/22	0	2950.24	
980		0		于14	6928	400	264.29	66.07%	2024/7/21	0	964.95	
981		0	10kV-42	于21	6928	400	45.51	11.38%	2024/12/31	0	4754.11	
982		0		于22	6928	400	36.05	9.01%	2024/1/22	0	4918.01	
983		0		于23	6928	400	41.00	10.25%	2024/7/30	0	4832.26	
984		0		于24	6928	400	69.13	17.28%	2024/12/13	0	4345.14	
985		0		于25	6928	400	59.50	14.88%	2024/1/23	0	4511.83	
986		0		于26	6928	400	53.12	13.28%	2024/8/21	0	4622.45	
987		0	10kV-43	于31	6928	400	40.58	10.14%	2024/1/25	0	4839.62	
988		0		于32	6928	400	58.62	14.66%	2024/1/3	0	4527.05	
989		0		于33	6928	400	49.73	12.43%	2024/11/21	0	4681.06	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
990		0		于34	6928	400	58.32	14.58%	2024/12/23	0	4532.38	
991		0		于35	6928	400	19.03	4.76%	2024/2/1	0	5212.84	
992		0	10kV-44	于41	6928	400	125.77	31.44%	2024/12/10	0	3364.05	
993		0		于42	6928	400	270.303	67.58%	2024/7/24	0	860.75	
994		0		于43	6928	400	60.03	15.01%	2024/7/23	0	4502.70	
995		0		于44	6928	400	60.03	15.01%	2024/7/23	0	4502.70	
996		0										
997	渔港	0	10kV-41	鲤11	8140.4	470	116.87	24.87%	2024/7/30	0	4488.08	
998		0		鲤12	6373.76	368	179.17	48.69%	2024/8/23	0	1995.87	
999		0		鲤13	8140.4	470	129.60	27.57%	2024/9/1	0	4267.73	
1000		0		鲤14	7326.36	423	137.75	32.56%	2024/8/2	0	3475.31	
1001		0		鲤15	7880.6	455	193.80	42.59%	2024/7/25	0	2947.88	
1002		0		鲤16	7326.36	423	19.45	4.60%	2024/12/24	0	5524.28	
1003		0		鲤17	7326.36	423	11.27	2.66%	2024/11/5	0	5665.86	
1004		0	10kV-42	鲤21	8140.4	470	231.11	49.17%	2024/8/2	0	2509.53	
1005		0		鲤22	6373.76	368	145.55	39.55%	2024/7/12	0	2578.13	
1006		0	10kV-44	鲤31	8140.4	470	109.56	23.31%	2024/8/2	0	4614.81	
1007		0		鲤32	6373.76	368	103.07	28.01%	2024/1/24	0	3313.77	
1008		0		鲤33	7326.36	423	39.84	9.42%	2024/8/2	0	5171.13	
1009		0		鲤36	7326.36	423	20.87	4.93%	2024/12/8	0	5499.55	
1010		0		鲤37	7326.36	423	8.53	2.02%	2024/11/5	0	5713.44	
1011	玉辰	0	10kV-42	辰31	9266.2	535	261.78	48.93%	2024/5/1	0	2878.88	
1012		0		辰32	9266.2	535	335.27	62.67%	2024/5/1	0	1606.08	
1013		0		辰33	9266.2	535	400.891	74.93%	2024/8/10	0	469.53	
1014		0		辰34	7361	425	202.75	47.70%	2024/1/27	0	2377.26	
1015		0		辰35	7915.24	457	130.45	28.55%	2024/5/9	0	4072.78	
1016		0		辰36	9006.4	520	119.88	23.05%	2024/12/19	0	5128.89	
1017		0	10kV-43	辰41	9266.2	535	2.71	0.51%	2024/1/2	0	7365.97	
1018		0		辰42	9266.2	535	2.74	0.51%	2024/3/1	0	7365.54	
1019		0		辰44	7915.24	457	124.71	27.29%	2024/5/9	0	4172.16	
		0		辰46	9924.36	573	128.93	22.50%	2024/7/5	0	5706.39	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
1020	漳州道	0	10kV-44	辰51	9266.2	535	371.451	69.43%	2024/7/24	0	979.43	
1021		0		辰52	9266.2	535	329.63	61.61%	2024/9/27	0	1703.77	
1022		0		辰53	9266.2	535	267.70	50.04%	2024/8/2	0	2776.36	
1023		0		辰54	7361	425	47.64	11.21%	2024/8/2	0	5063.73	
1024		0		辰55	7915.24	457	107.37	23.49%	2024/5/9	0	4472.54	
1025		0		辰56	9006.4	520	1.08	0.21%	2024/12/19	0	7186.38	
1026		0		辰63	9266.2	535	2.73	0.51%	2024/3/13	0	7365.61	
1027		0		辰64	7915.24	457	121.67	26.62%	2024/7/12	0	4224.94	
1028		0		辰66	9924.36	573	46.86	8.18%	2024/10/30	0	7127.84	
1029		0	10kV-41	漳11	8140.4	470	216.56	46.08%	2024/7/23	0	2761.47	
1030		0		漳12	8140.4	470	191.07	40.65%	2024/11/5	0	3202.92	
1031		0		漳13	8140.4	470	228.87	48.70%	2024/8/8	0	2548.22	
1032		0		漳14	8140.4	470	216.39	46.04%	2024/11/4	0	2764.50	
1033		0		漳15	8140.4	470	173.85	36.99%	2024/8/19	0	3501.27	
1034		0		漳16	8140.4	470	196.70	41.85%	2024/2/23	0	3105.49	
1035		0		漳17	8140.4	470	202.15	43.01%	2024/9/12	0	3011.12	
1036		0		漳18	6928	400	187.56	46.89%	2024/6/13	0	2293.88	
1037		0	10kV-43	漳21	8140.4	470	253.65	53.97%	2024/8/8	0	2119.07	
1038		0		漳22	8140.4	470	158.38	33.70%	2024/7/23	0	3769.20	
1039		0		漳23	8140.4	470	122.17	25.99%	2024/7/24	0	4396.37	
1040		0		漳24	8140.4	470	200.57	42.67%	2024/12/26	0	3038.52	
1041		0		漳25	8140.4	470	185.80	39.53%	2024/7/23	0	3294.25	
1042		0		漳26	6928	400	180.53	45.13%	2024/6/13	0	2415.67	
1043		0		漳27	8140.4	470	102.83	21.88%	2024/2/23	0	4731.27	
1044		0		漳28	6529.64	377	222.54	59.03%	2024/7/23	0	1369.34	
1045		0	10kV-41	中11	6373.76	368	178.42	48.48%	2024/7/14	0	2008.81	
1046		0		中15	6373.76	368	217.09	58.99%	2024/7/23	0	1339.01	
1047		0		中17	6373.76	368	217.97	59.23%	2024/7/15	0	1323.78	
1048		0	10kV-42	中21	6373.76	368	182.52	49.60%	2024/7/21	0	1937.76	
1049		0		中22	6373.76	368	260.664	70.83%	2024/1/24	0	584.31	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	最大负荷发生日期	线路最大负荷日后 需预留容量 (kVA)	可开放容量 (kVA)	备注
1050	中塘	0	10kV-43	中24	7880.6	455	229.98	50.55%	2024/8/28	0	2321.23	
1051		0		中26	6373.76	368	250.996	68.21%	2024/7/8	0	751.76	
1052		0	10kV-44	中31	7880.6	455	136.52	30.01%	2024/5/8	0	3939.90	
1053		0		中32	6373.76	368	234.08	63.61%	2024/7/15	0	1044.71	
1054		0		中34	6373.76	368	184.28	50.08%	2024/11/4	0	1907.33	
1055		0		中36	6373.76	368	260.664	70.83%	2024/7/30	0	584.31	
1056		0										
1057	珠江道	0	10kV-41	珠11	6928	400	68.39	17.10%	2024/8/9	0	4357.82	
1058		0		珠12	6928	400	86.92	21.73%	2024/6/18	0	4036.88	
1059		0		珠13	6928	400	137.23	34.31%	2024/6/21	0	3165.63	
1060		0		珠14	7620.8	440	329.146	74.81%	2024/7/30	0	395.83	
1061		0		珠15	9266.2	535	275.79	51.55%	2024/7/12	0	2636.35	
1062		0	10kV-42	珠21	6928	400	205.33	51.33%	2024/11/1	0	1986.14	
1063		0		珠22	6928	400	112.15	28.04%	2024/5/1	0	3600.00	
1064		0		珠23	6928	400	59.78	14.95%	2024/9/30	0	4507.01	
1065		0		珠24	9006.4	520	227.11	43.67%	2024/9/25	0	3271.59	
1066		0	10kV-45	珠51	6928	400	95.77	23.94%	2024/12/11	0	3883.65	
1067		0		珠52	6928	400	146.66	36.67%	2024/8/22	0	3002.25	
1068		0		珠53	6928	400	114.38	28.59%	2024/12/24	0	3561.43	
1069		0		珠54	9006.4	520	214.41	41.23%	2024/4/15	0	3491.56	
1070		0	10kV-46	珠61	6928	400	119.87	29.97%	2024/8/22	0	3466.29	
1071		0		珠62	6928	400	131.03	32.76%	2024/8/9	0	3272.96	
1072		0		珠63	6928	400	48.49	12.12%	2024/1/24	0	4702.62	
1072		0		珠64	9266.2	535	285.98	53.45%	2024/9/21	0	2459.77	