

宝坻供电公司10千伏配电线路可开放容量信息表（2025年第二季度）

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
1	宝坻. 八门城 站	0	10kV-4	小甸八13	7274.4	400	132.97	33.24%	0	3239	
2		0		西十村八14	7274.4	400	198.41	49.60%	0	2106	
3		0		八门城八15	6546.96	360	213.10	59.20%	0	1297	
4		0	10kV-5	箭杆河八21	6546.96	360	128.87	35.80%	0	2756	
5		0		袁罗八22	7274.4	400	10.24	2.56%	0	5365	
6		0		康庄八23	7274.4	400	159.24	39.81%	0	2784	
7	宝坻. 北申庄 站	0	10kV-41	八间房申11	9147.558	503	87.52	17.40%	0	5454	
8		0		南业东申12	9147.558	503	177.22	35.23%	0	3900	
9		0		北辛庄申13	9147.558	503	179.30	35.65%	0	3864	
10		0		张兰庄申14	9147.558	503	50.82	10.10%	0	6089	
11		0		潭东申15	9147.558	503	68.04	13.53%	0	5791	
12		0		艾家口申16	9147.558	503	92.41	18.37%	0	5369	
13		0		李家口申21	9147.558	503	20.40	4.06%	0	6616	
14		0		马厂申22	9147.558	503	5.57	1.11%	0	6873	
15		0		西庄沽申23	9147.558	503	55.70	11.07%	0	6005	
16		0	10kV-42	小陈申31	9147.558	503	205.98	40.95%	0	3402	
17		0		南庄申32	9147.558	503	60.19	11.97%	0	5927	
18		0		老艾口申33	9147.558	503	85.82	17.06%	0	5483	
19		0		苗家庄申34	9147.558	503	72.25	14.36%	0	5718	
20		0	10kV-43	埝北村申41	9147.558	503	243.49	48.41%	0	2752	
21		0		车辆村申42	9147.558	503	156.90	31.19%	0	4252	
22		0		潭西申43	9147.558	503	0.00	0.00%	0	6970	
23		0		小苑庄申44	9147.558	503	33.22	6.60%	0	6394	
24		0		大赵庄申45	9147.558	503	80.11	15.93%	0	5582	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
25		0	10kV-44	张家庄申51	9147.558	503	82.74	16.45%	0	5537	
26		0		张松申52	9147.558	503	241.90	48.09%	0	2780	
27		0		工部申53	9147.558	503	180.46	35.88%	0	3844	
28		0		佟家庄申54	9147.558	503	67.15	13.35%	0	5806	
29		0		窑上村申55	9147.558	503	68.33	13.58%	0	5786	
30		0		伍麻村申56	9147.558	503	60.13	11.95%	0	5928	
31		0		边家庄申61	9147.558	503	92.05	18.30%	0	5375	
32		0		北芮村申62	9147.558	503	110.59	21.99%	0	5054	
33	宝坻.菜园站	0	10kV-4	韩庄园13	6546.96	360	71.54	19.87%	0	3749	
34		0		高四台园14	9147.558	503	283.36	56.33%	0	2062	
35		0		区东园15	6546.96	360	277.56	77.10%	0	181	
36		0		庞家湾园16	6546.96	360	113.56	31.54%	0	3021	
37		0	10kV-5	林场园23	9147.558	503	121.82	24.22%	0	4860	
38		0		吴家牌园24	9147.558	503	291.80	58.01%	0	1916	
39		0		华尖园25	9147.558	503	186.16	37.01%	0	3745	
40		0		区西园26	9147.558	503	171.21	34.04%	0	4004	
41	宝坻.城东站	0	10kV-41	钰华东11	8547.42	470	203.25	43.25%	0	2992	
42		0		区委二东12	8547.42	470	321.05	68.31%	0	952	
43		0		顺驰东13	8547.42	470	291.96	62.12%	0	1456	
44		0		泰富东14	8547.42	470	236.48	50.32%	0	2416	
45		0		金玉一东15	8547.42	470	131.08	27.89%	0	4242	
46		0		怡锦一东16	9729.51	535	14.33	2.68%	0	7165	
47		0		玉六园东17	9729.51	535	119.21	22.28%	0	5348	
48		0	10kV-42	双站路东23	9729.51	535	56.88	10.63%	0	6428	
49		0		怡锦二东27	9729.51	535	0.79	0.15%	0	7399	
50		0		龙熙东31	6546.96	360	247.74	68.82%	0	697	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
51		0	10kV-44	玺悦Ⅱ东32	9729.51	535	4.48	0.84%	0	7335	
52		0		金玉二东33	8547.42	470	63.12	13.43%	0	5419	
53				玺悦Ⅰ东34	9729.51	535	4.48	0.84%	0	7335	
54		0		苑北东35	8547.42	470	101.27	21.55%	0	4758	
55		0		广电二东36	8547.42	470	324.92	69.13%	0	885	
56		0		祥和东37	8547.42	470	305.23	64.94%	0	1226	
57	宝坻.城关站	0	10kV-4	宝鑫ⅠⅠ11	7274.4	400	269.97	67.49%	0	867	
58		0	10kV-4	城关乡112	6546.96	360	286.51	79.59%	0	26	
59		0	10kV-4	海滨115	6546.96	360	81.80	22.72%	0	3571	
60		0	10kV-5	宝鑫ⅠⅠ122	7274.4	400	70.54	17.63%	0	4321	
61		0	10kV-5	城关镇ⅠⅠ124	6546.96	360	265.00	73.61%	0	398	
62		0	10kV-5	城关镇Ⅰ125	6546.96	360	281.61	78.22%	0	111	
63		0	10kV-4	工贸城13	6546.96	360	275.77	76.60%	0	212	
64		0	10kV-4	瑞祥城14	7274.4	400	236.37	59.09%	0	1448	
65		0	10kV-5	霍各庄城21	6546.96	360	0.00	0.00%	0	4988	
66		0	10kV-5	铸件城23	6546.96	360	272.70	75.75%	0	265	
67	宝坻.城南站	0	10kV-41	帝景南11	8547.42	470	191.57	40.76%	0	3194	
68		0		潮阳花园南12	8547.42	470	129.70	27.59%	0	4266	
69		0		嘉兴园南13	8547.42	470	196.67	41.84%	0	3106	
70		0		金和园南14	8547.42	470	138.24	29.41%	0	4118	
71		0		宝境南15	8547.42	470	127.81	27.19%	0	4299	
72		0		万兆南16	8547.42	470	284.88	60.61%	0	1578	
73		0		吾悦一南17	8547.42	470	92.12	19.60%	0	4917	
74		0		原筑一南18	8547.42	470	147.01	31.28%	0	3966	
75		0		体育馆南23	8547.42	470	167.76	35.69%	0	3607	
76		0		观潮园南24	8547.42	470	85.94	18.29%	0	5024	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
77		0	10kV-42 10kV-43	润和南25	8547.42	470	113.35	24.12%	0	4549	
78		0		泰达南26	8547.42	470	124.19	26.42%	0	4361	
79		0		北岸南27	8547.42	470	165.22	35.15%	0	3651	
80		0		馨和南28	8547.42	470	286.79	61.02%	0	1545	
81		0		翰墨园南29	6546.96	360	49.93	13.87%	0	4123	
82		0		吾悦二南30	8547.42	470	142.56	30.33%	0	4043	
83		0		原筑二南31	8547.42	470	143.17	30.46%	0	4033	
84	宝坻.城西站	0	10kV-4	三岔口116	9147.558	503	96.96	19.28%	0	5290	
85		0		天宝甲西13	6546.96	360	228.23	63.40%	0	1035	
86		0		高家庄西14	9147.558	503	49.92	9.92%	0	6105	
87		0		宝中道西15	9729.51	535	147.04	27.48%	0	4866	
88		0		中关村一西17	9729.51	535	93.04	17.39%	0	5802	
89		0	10kV-5	四中西23	8547.42	470	290.40	61.79%	0	1483	
90		0		中关村南西24	9729.51	535	69.68	13.02%	0	6206	
91		0		牛道口东西25	6546.96	360	256.32	71.20%	0	549	
92		0		星源西26	9147.558	503	376.72	74.89%	0	445	
93		0		天宝乙西27	6546.96	360	0.72	0.20%	0	4976	
94	宝坻.大白庄 站	0	10kV-41	小刘坡白11	6546.96	360	215.12	59.75%	0	1262	
95		0		晋铝白12	9147.558	503	326.41	64.89%	0	1316	
96		0		无纺白13	8547.42	470	232.10	49.38%	0	2492	
97		0		小杨庄白14	8547.42	470	273.32	58.15%	0	1778	
98		0		贝特瑞白15	9147.558	503	109.62	21.79%	0	5071	
99		0		盟固利白16	9729.51	535	365.61	68.34%	0	1081	
100		0		孙校白17	9147.558	503	202.20	40.20%	0	3468	
101		0		园二路白18	9147.558	503	390.11	77.56%	0	213	
102		0		首高白21	9147.558	503	393.54	78.24%	0	153	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
103		0	10kV-42	九贸白22	9147.558	503	268.56	53.39%	0	2318	
104		0		嘉诺缘白23	8547.42	470	375.98	80.00%	0	0	
105		0		八道沽白24	6546.96	360	151.15	41.99%	0	2370	
106		0		勇猛白25	8547.42	470	234.18	49.83%	0	2456	
107		0		天普白26	9729.51	535	17.16	3.21%	0	7116	
108		0		东皋一白27	9729.51	535	380.73	71.16%	0	819	
109		0		彭元白28	9147.558	503	224.35	44.60%	0	3084	
110	宝坻.大口电 站	0	10kV-4	程马庄屯11	9147.558	503	128.14	25.48%	0	4750	
111		0		大薄甸屯12	9147.558	503	0.00	0.00%	0	6970	
112		0		大五登屯13	6546.96	360	162.42	45.12%	0	2175	
113		0		大口屯镇屯14	6546.96	360	223.95	62.21%	0	1109	
114		0		屯开发屯15	9147.558	503	184.39	36.66%	0	3776	
115		0	10kV-5	天骄屯21	9147.558	503	281.78	56.02%	0	2089	
116		0		大口屯东屯22	9147.558	503	140.10	27.85%	0	4543	
117		0		尹家铺屯23	6546.96	360	159.61	44.34%	0	2224	
118		0		镇东屯24	9147.558	503	0.00	0.00%	0	6970	
119	宝坻.大钟庄 站	0	10kV-4	新安镇214	7274.4	400	129.15	32.29%	0	3305	
120		0		盛松I钟11	7274.4	400	79.60	19.90%	0	4164	
121		0		宝芝钟12	7274.4	400	282.42	70.61%	0	651	
122		0		何仇钟13	7274.4	400	91.31	22.83%	0	3961	
123		0	10kV-5	盛松II钟21	7274.4	400	26.20	6.55%	0	5089	
124		0		工业园区钟22	6546.96	360	163.92	45.53%	0	2149	
125		0		冯庄水钟23	7274.4	400	261.92	65.48%	0	1006	
126		0		钟芝钟24	7274.4	400	19.38	4.85%	0	5207	
127		0	10kV-4	老鸦口老12	7274.4	400	61.55	15.39%	0	4476	
128		0		精密老13	6546.96	360	178.41	49.56%	0	1898	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
129	宝坻. 东老口 站	0		珠江老14	6546.96	360	126.95	35.26%	0	2789	
130		0		农场老15	6546.96	360	152.03	42.23%	0	2355	
131		0	10kV-5	牛家牌老21	6546.96	360	177.55	49.32%	0	1913	
132		0		孙庄老22	6546.96	360	72.19	20.05%	0	3738	
133		0		前坨老23	6546.96	360	213.29	59.25%	0	1294	
134		0		东滨老24	6546.96	360	14.48	4.02%	0	4737	
135		0									
136	宝坻. 尔王庄 站	0	10kV-41	李家河尔11	6546.96	360	140.35	38.99%	0	2557	
137		0		郑贵庄尔12	9147.558	503	54.11	10.76%	0	6032	
138		0		尔辛庄尔13	6546.96	360	52.69	14.64%	0	4076	
139		0		东安子尔15	6546.96	360	134.88	37.47%	0	2652	
140		0	10kV-42	黄花淀尔21	6546.96	360	86.54	24.04%	0	3489	
141		0	10kV-43	小宝庄尔23	6546.96	360	287.73	79.93%	0	5	
142		0		潘套尔25	6546.96	360	115.58	32.11%	0	2986	
143		0		小董庄尔26	6546.96	360	66.88	18.58%	0	3830	
144	宝坻. 海濱站	0	10kV-41	大吴路海11	9729.51	535	57.00	10.65%	0	6426	
145		0		张古海12	6546.96	360	230.56	64.04%	0	995	
146		0		前五里海13	9147.558	503	64.92	12.91%	0	5845	
147		0		剑桥Ⅱ海14	8547.42	470	258.35	54.97%	0	2038	
148		0		翡翠Ⅱ海15	9729.51	535	111.87	20.91%	0	5475	
149		0		东城海16	9147.558	503	107.87	21.44%	0	5101	
150		0	10kV-42	区医院海21	8547.42	470	70.27	14.95%	0	5295	
151		0		白龙港海22	6546.96	360	223.83	62.17%	0	1111	
152		0		小刘庄海23	6546.96	360	230.21	63.95%	0	1001	
153		0		剑桥Ⅰ海24	8547.42	470	375.19	79.83%	0	14	
154		0		翡翠Ⅰ海25	8547.42	470	152.72	32.49%	0	3867	
		0		西城海26	9147.558	503	222.22	44.18%	0	3121	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
155	宝坻. 黑狼口 站	0	10kV-4	黑狼口黑11	6546.96	360	235.32	65.37%	0	912	
156		0		老庄子黑12	9147.558	503	200.08	39.78%	0	3504	
157		0		农场黑13	9147.558	503	126.29	25.11%	0	4782	
158		0		塑料一黑14	9147.558	503	272.97	54.27%	0	2242	
159		0	10kV-5	塑料二黑21	9147.558	503	108.17	21.51%	0	5096	
160		0		久大黑22	6546.96	360	183.71	51.03%	0	1806	
161		0		糙甸乡黑23	6546.96	360	192.54	53.48%	0	1653	
162		0		发达纸厂黑24	6546.96	360	50.06	13.90%	0	4121	
163	宝坻. 欢喜庄 站	0	10kV-42	陈塘欢19	9147.558	503	138.28	27.49%	0	4575	
164		0		高康马欢20	9147.558	503	132.34	26.31%	0	4677	
165		0		水流庄欢21	9147.558	503	297.16	59.08%	0	1823	
166		0	10kV-43	五道沽欢23	9147.558	503	4.93	0.98%	0	6884	
167		0		李宦庄欢24	9147.558	503	137.05	27.25%	0	4596	
168		0		曹家沽欢25	9147.558	503	69.29285	13.78%	0	5769	
169		0		周家庄欢26	9147.558	503	23.03	4.58%	0	6571	
170		0	10kV-44	后辛欢27	9147.558	503	163.44	32.49%	0	4139	
171		0		回庄欢28	9147.558	503	154.69	30.75%	0	4290	
172		0		工业园欢29	9147.558	503	181.60	36.10%	0	3824	
173		0		尹庄欢30	9147.558	503	1.05	0.21%	0	6951	
174		0		清白沽欢31	9147.558	503	98.61	19.61%	0	5262	
175		0		南辛码欢33	9147.558	503	143.27	28.48%	0	4488	
176		0		葫芦窝欢34	9147.558	503	257.90	51.27%	0	2503	
177		0	10kV-41	杜家台黄11	9147.558	503	177.26	35.24%	0	3899	
178		0		东走线黄12	9147.558	503	9.28	1.84%	0	6809	
179		0		南燕东黄13	9147.558	503	0.00	0.00%	0	6970	
180		0		张头窝东黄14	9147.558	503	0.00	0.00%	0	6970	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
181	宝坻. 黄庄站	0		小甸西黄15	9147.558	503	0.00	0.00%	0	6970	
182		0		鲁家铺黄16	9147.558	503	228.88	45.50%	0	3005	
183		0		水流东黄21	9147.558	503	36.52	7.26%	0	6337	
184		0		黄庄北黄22	9147.558	503	0.00	0.00%	0	6970	
185		0	10kV-42	大塔沽黄31	9147.558	503	8.80	1.75%	0	6817	
186		0		郭庄子黄32	9147.558	503	2.98	0.59%	0	6918	
187		0		苑家场黄33	9147.558	503	100.00	19.88%	0	5238	
188		0		黄庄西黄34	9147.558	503	38.68	7.69%	0	6300	
189		0	10kV-43	王木庄黄41	9147.558	503	27.50	5.47%	0	6493	
190		0		西走线黄42	9147.558	503	0.00	0.00%	0	6970	
191		0		张头窝西黄43	9147.558	503	22.99	4.57%	0	6571	
192		0		黄庄东黄44	9147.558	503	152.75	30.37%	0	4324	
193		0	10kV-44	前辛庄黄51	9147.558	503	5.12	1.02%	0	6881	
194		0		小塔沽黄52	9147.558	503	12.01	2.39%	0	6762	
195		0		南燕北黄53	9147.558	503	0.00	0.00%	0	6970	
196		0		小甸东黄54	9147.558	503	24.05	4.78%	0	6553	
197		0		王家铺黄55	9147.558	503	0.00	0.00%	0	6970	
198		0		水流西黄61	9147.558	503	298.52	59.35%	0	1799	
199		0		黄庄南黄62	9147.558	503	261.65	52.02%	0	2438	
200		0		貉子沽黄63	9147.558	503	0.00	0.00%	0	6970	
201	宝坻. 开发区站	0	10kV-4	华苑112	7274.4	400	175.68	43.92%	0	2500	
202		0		三中113	6546.96	360	119.52	33.20%	0	2918	
203		0		摩托车114	7274.4	400	76.44	19.11%	0	4218	
204		0		景苑 I 116	5637.66	310	146.04	47.11%	0	1766	
205		0		纸厂117	7274.4	400	79.44	19.86%	0	4166	
206		0		县委122	6546.96	360	130.44	36.23%	0	2729	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
207		0	10kV-5	四小123	6546.96	360	258.96	71.93%	0	503	
208		0		东区124	7274.4	400	128.88	32.22%	0	3310	
209		0		香港园区125	7274.4	400	184.68	46.17%	0	2344	
210		0		景苑III126	5637.66	310	96.36	31.08%	0	2626	
211		0		党校127	6546.96	360	276.31	76.75%	0	202	
212		0	10kV-4	西区区15	6546.96	360	178.08	49.47%	0	1904	
213	宝坻.口东站	0	10kV-41	口东园区 I 口1	6546.96	360	191.95	53.32%	0	1664	
214		0		前齐口12	6546.96	360	174.90	48.58%	0	1959	
215		0		园区西口13	9147.558	503	351.56	69.89%	0	881	
216		0		工业东口14	9147.558	503	361.41	71.85%	0	710	
217		0	10kV-42	口东园区 II 口2	6546.96	360	262.97	73.05%	0	434	
218		0		东辛口22	9147.558	503	171.91	34.18%	0	3992	
219		0		园区南口23	9147.558	503	374.77	74.51%	0	479	
220		0		工业北口24	9147.558	503	126.21	25.09%	0	4784	
221		0	10kV-43	首瑞口25	9147.558	503	239.24	47.56%	0	2826	
222		0		福礼口26	9147.558	503	0.00	0.00%	0	6970	
223		0	10kV-44	爱康口31	9147.558	503	313.24	62.27%	0	1544	
224		0		黄辛口32	9147.558	503	163.30	32.47%	0	4141	
225		0		大张庄口33	9147.558	503	61.87	12.30%	0	5898	
226		0		潮阳东口34	9147.558	503	0.00	0.00%	0	6970	
227		0		恒佳口35	9147.558	503	135.70	26.98%	0	4619	
228		0		翔原口36	9147.558	503	319.75	63.57%	0	1432	
229		0	10kV-41	莲唐一营11	9729.51	535	80.61	15.07%	0	6017	
230		0		浩润营12	6546.96	360	166.04	46.12%	0	2112	
231		0		香坻营13	9729.51	535	46.22	8.64%	0	6612	
232		0		西郝营14	9147.558	503	184.32	36.64%	0	3777	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
233	宝坻. 莲子营 站	0	10kV-42	兴华营31	9147.558	503	181.44	36.07%	0	3827	
234		0		津侨一营32	9729.51	535	2.33	0.43%	0	7373	
235		0	10kV-43	莲唐二营41	9729.51	535	76.43	14.29%	0	6089	
236		0		润悦营42	9729.51	535	35.24	6.59%	0	6803	
237		0		万和营43	8547.42	470	83.80	17.83%	0	5061	
238		0	10kV-44	小套营51	6546.96	360	225.11	62.53%	0	1089	
239		0		水岸营52	9729.51	535	164.90	30.82%	0	4557	
240		0		官庄营53	6546.96	360	141.26	39.24%	0	2542	
241		0		津侨二营54	9729.51	535	2.29	0.43%	0	7373	
242	宝坻. 林亭口 站	0	10kV-4	张庄子林11	7274.4	400	309.72	77.43%	0	178	
243		0		大靳庄林12	7274.4	400	0.00	0.00%	0	5542	
244		0		林亭口西林13	7274.4	400	282.57	70.64%	0	648	
245		0		科宝林14	7274.4	400	0.86	0.21%	0	5528	
246		0		龙亭苑林15	7274.4	400	240.05	60.01%	0	1385	
247		0	10kV-5	众河林21	7274.4	400	45.41	11.35%	0	4756	
248		0		南五村林22	7274.4	400	240.12	60.03%	0	1383	
249		0		林亭口林23	6546.96	360	157.73	43.81%	0	2256	
250		0		季家庄林24	7274.4	400	8.41	2.10%	0	5397	
251		0		轻集林25	7274.4	400	0.82	0.20%	0	5528	
252	宝坻. 牛道口 站	0	10kV-4	下五庄牛11	9147.558	503	240.47	47.81%	0	2805	
253		0		塘头牛12	9147.558	503	169.45	33.69%	0	4035	
254		0		庞庄牛13	9147.558	503	106.64	21.20%	0	5123	
255		0		三赵牛14	7619.934	419	214.22	51.13%	0	2095	
256		0	10kV-5	西四庄牛21	9147.558	503	171.80	34.15%	0	3994	
257		0		高家深牛22	6546.96	360	224.06	62.24%	0	1107	
258		0		高各庄牛23	9147.558	503	233.91	46.50%	0	2918	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
259		0		卢各庄牛24	9147.558	503	198.05	39.37%	0	3539	
260		0		集利牛25	6546.96	360	150.00	41.67%	0	2390	
261	宝坻.史各庄 站	0	10kV-4	扬水站史11	6546.96	360	236.60	65.72%	0	890	
262		0		西苑庄史12	6546.96	360	123.22	34.23%	0	2854	
263		0		通威史13	6546.96	360	231.33	64.26%	0	982	
264		0		宜城史14	6546.96	360	235.90	65.53%	0	902	
265		0		朱孔史15	6546.96	360	239.41	66.50%	0	842	
266		0		彪家店史16	9147.558	503	102.48	20.37%	0	5195	
267		0	10kV-5	正大史21	6546.96	360	124.63	34.62%	0	2830	
268		0		史各庄史22	6546.96	360	208.12	57.81%	0	1383	
269		0		郭杨史23	6546.96	360	180.88	50.24%	0	1855	
270		0		庞各庄史24	6546.96	360	281.60	78.22%	0	111	
271		0		大刘辛史25	9147.558	503	268.42	53.36%	0	2321	
272	宝坻.双王寺 站	0	10kV-4	屯东双11	6546.96	360	108.83	30.23%	0	3103	
273		0		双唐一双12	9729.51	535	0.00	0.00%	0	7413	
274		0		郝各庄双13	6546.96	360	261.58	72.66%	0	458	
275		0		马家店双14	6546.96	360	263.86	73.29%	0	418	
276		0	10kV-5	屯西双21	6546.96	360	146.12	40.59%	0	2457	
277		0		南仁孚双22	9147.558	503	400.82	79.69%	0	27	
278		0		新开口双23	6546.96	360	164.42	45.67%	0	2140	
279		0		宝联双24	6546.96	360	158.55	44.04%	0	2242	
280		0		双唐二双25	9729.51	535	92.26	17.24%	0	5815	
281		0	10kV-41	东淀隋11	9147.558	503	227.79	45.29%	0	3024	
282		0		大刘坡隋12	8547.42	470	259.96	55.31%	0	2010	
283		0		迈克隋13	9729.51	535	303.62	56.75%	0	2154	
284		0		腾飞隋14	9729.51	535	278.53	52.06%	0	2589	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
285	宝坻. 隋庄子 站	0	10kV-42	尔王庄隋21	6546.96	360	73.63	20.45%	0	3713	
286		0		九园东隋22	9147.558	503	237.86	47.29%	0	2850	
287		0		大白庄东隋23	8547.42	470	57.20	12.17%	0	5522	
288		0		董塔隋24	6546.96	360	145.24	40.34%	0	2473	
289		0	10kV-43	石材一隋25	9147.558	503	160.25	31.86%	0	4194	
290		0		诺宝一隋26	9147.558	503	234.61	46.64%	0	2906	
291		0		南李隋27	9147.558	503	208.11	41.37%	0	3365	
292		0		轻纺隋28	8547.42	470	215.77	45.91%	0	2775	
293		0	10kV-44	九园西隋32	6546.96	360	223.82	62.17%	0	1112	
294		0		大白庄西隋33	6546.96	360	186.75	51.87%	0	1754	
295		0		大唐庄隋34	6546.96	360	281.52	78.20%	0	112	
296		0		石材二隋35	9147.558	503	207.51	41.26%	0	3375	
297		0		诺宝二隋36	9147.558	503	127.97	25.44%	0	4753	
298		0		石材隋37	9147.558	503	106.85	21.24%	0	5119	
299		0		新城隋38	9147.558	503	228.01	45.33%	0	3020	
300	宝坻. 太平庄 站	0	10kV-4	双盛太12	6546.96	360	271.20	75.33%	0	291	
301		0		昌兴太13	6546.96	360	185.64	51.57%	0	1773	
302		0		馨园 I 太14	9729.51	535	279.24	52.19%	0	2577	
303		0		九中 I 太15	9729.51	535	318.60	59.55%	0	1895	
304		0		润阳一太16	9729.51	535	252.84	47.26%	0	3034	
305		0		津宝太17	6546.96	360	175.00	48.61%	0	1957	
306		0	10kV-5	宸宝太22	6546.96	360	65.64	18.23%	0	3851	
307		0		人防太23	6546.96	360	233.16	64.77%	0	950	
308		0		馨园 II 太24	9729.51	535	268.80	50.24%	0	2757	
309		0		九中 II 太25	9729.51	535	176.04	32.90%	0	4364	
310		0		润阳二太26	9729.51	535	270.24	50.51%	0	2732	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
311		0		中专太27	6546.96	360	104.16	28.93%	0	3184	
312	宝坻.王卜庄 站	0	10kV-4	陈山王11	6546.96	360	166.42	46.23%	0	2106	
313		0		王卜庄西王12	6546.96	360	150.57	41.83%	0	2380	
314		0		大华王13	6546.96	360	172.96	48.04%	0	1993	
315		0		方庄子王14	9147.558	503	105.45	20.96%	0	5143	
316		0		赵二王15	9147.558	503	0.00	0.00%	0	6970	
317		0		小赵王16	9147.558	503	80.02	15.91%	0	5584	
318		0		何家庄王17	9147.558	503	154.26	30.67%	0	4298	
319		0		司各庄王18	9147.558	503	125.93	25.04%	0	4788	
320		0	10kV-5	砖厂王21	6546.96	360	54.73	15.20%	0	4040	
321		0		北坛王22	9147.558	503	27.69	5.50%	0	6490	
322		0		王卜庄东王23	6546.96	360	176.18	48.94%	0	1937	
323		0		南家庄王24	9147.558	503	104.81	20.84%	0	5154	
324		0		龙坛王25	9147.558	503	196.66	39.10%	0	3563	
325		0		庞家庄王26	9147.558	503	345.30	68.65%	0	989	
326		0		于街王27	6546.96	360	116.82	32.45%	0	2965	
327		0		西泗王28	9147.558	503	154.26	30.67%	0	4298	
328	宝坻.五里铺 站	0	10kV-41	轧钢厂铺12	6546.96	360	134.71	37.42%	0	2655	
329		0		石桥铺13	6546.96	360	152.83	42.45%	0	2341	
330		0		杨家口铺14	6546.96	360	120.25	33.40%	0	2905	
331		0		张台铺15	6546.96	360	227.66	63.24%	0	1045	
332		0		泉州铺16	9147.558	503	267.59	53.20%	0	2335	
333		0	10kV-42	畜牧局铺22	6546.96	360	287.70	79.92%	0	5	
334		0		棉纺厂铺23	9147.558	503	361.15	71.80%	0	714	
335		0	10kV-43	霍各庄铺25	6546.96	360	136.55	37.93%	0	2623	
336		0		口东铺26	9147.558	503	109.56	21.78%	0	5072	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
337		0	10kV-44	金水Ⅰ铺28	8547.42	470	242.99	51.70%	0	2304	
338		0		林海铺31	9729.51	535	220.26	41.17%	0	3598	
339		0		北郝铺32	6546.96	360	132.26	36.74%	0	2697	
340		0		大角甸铺33	9147.558	503	88.68	17.63%	0	5434	
341		0		监管所铺34	9147.558	503	283.18	56.30%	0	2065	
342		0		金水Ⅱ铺38	8547.42	470	182.09	38.74%	0	3358	
343	宝坻.小辛码站	0	10kV-4	欢喜小12	6546.96	360	48.96	13.60%	0	4140	
344		0		黄庄小13	6546.96	360	180.32	50.09%	0	1865	
345		0		苑洪桥小14	9147.558	503	123.84	24.62%	0	4825	
346		0		辛庄南小15	9147.558	503	111.84	22.23%	0	5032	
347		0	10kV-5	北里沽小21	6546.96	360	139.04	38.62%	0	2580	
348		0		扬水站小22	6546.96	360	109.60	30.44%	0	3090	
349		0		小辛码小23	6546.96	360	163.36	45.38%	0	2159	
350		0		马庄小24	9147.558	503	39.36	7.83%	0	6288	
351		0		吴辛小25	9147.558	503	140.00	27.83%	0	4545	
352		0	10kV-41	于家口一安11	9147.558	503	38.40	7.63%	0	6304	
353	宝坻.新安镇站	0		王善庄一安12	9147.558	503	44.80	8.91%	0	6194	
354		0		南业安13	9183.93	505	0.00	0.00%	0	6997	
355		0		王庄安17	9147.558	503	313.20	62.27%	0	1545	
356		0		木业安18	9147.558	503	384.90	76.52%	0	303	
357		0	10kV-42	于家口二安21	9147.558	503	69.60	13.84%	0	5764	
358		0		王善庄二安22	9147.558	503	161.50	32.11%	0	4172	
359		0	10kV-43	曹口安27	9147.558	503	163.80	32.56%	0	4133	
360		0		业西安28	9147.558	503	182.80	36.34%	0	3803	
361		0		园区新11	6546.96	360	223.85	62.18%	0	1111	
362		0		中粮新12	6546.96	360	75.35	20.93%	0	3683	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
363	宝坻. 新开口 站	0	10kV-4	种西新13	6546.96	360	247.24	68.68%	0	706	
364		0		前寒河新14	7274.4	400	164.50	41.13%	0	2693	
365		0		新开口东新15	6546.96	360	162.37	45.10%	0	2176	
366		0	10kV-5	新开口西新21	6546.96	360	196.91	54.70%	0	1578	
367		0		彭家务新22	6546.96	360	144.84	40.23%	0	2479	
368		0		石辛庄新23	7274.4	400	126.70	31.67%	0	3348	
369		0		洛水坨新24	7274.4	400	283.99	71.00%	0	624	
370		0		新开口南新25	6546.96	360	94.80	26.33%	0	3346	
371	宝坻. 袁罗站	0	10kV-41	大卦庄袁11	9147.558	503	92.76	18.44%	0	5363	
372		0		刘兰袁12	9147.558	503	57.78	11.49%	0	5969	
373		0		北王庄袁13	9147.558	503	79.49	15.80%	0	5593	
374		0		金厂袁14	9147.558	503	151.27	30.07%	0	4350	
375		0		东鲁沽袁15	9147.558	503	67.22	13.36%	0	5805	
376		0		八二村袁16	9147.558	503	0.00	0.00%	0	6970	
377		0		袁罗北袁21	9147.558	503	228.26	45.38%	0	3016	
378		0		杨庄子袁22	9147.558	503	129.05	25.66%	0	4734	
379		0		凌沿村袁23	9147.558	503	0.00	0.00%	0	6970	
380		0		米四庄袁24	9147.558	503	0.00	0.00%	0	6970	
381		0		大米北袁25	9147.558	503	159.38	31.69%	0	4209	
382		0	10kV-42	宝芝麻窝袁31	9147.558	503	75.40	14.99%	0	5664	
383		0		马郭村袁32	9147.558	503	95.83	19.05%	0	5310	
384		0		岳家楼袁33	9147.558	503	96.55	19.20%	0	5297	
385		0		王山南袁34	9147.558	503	105.53	20.98%	0	5142	
386		0		康庄西袁35	9147.558	503	236.62	47.04%	0	2871	
387		0		大米南袁41	9147.558	503	66.41	13.20%	0	5819	
388		0		孔家庄袁42	9147.558	503	4.44	0.88%	0	6893	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
389	宝坻.岳家庄 站	0	10kV-43	八一村袁43	9147.558	503	0.00	0.00%	0	6970	
390		0		大钟庄袁44	9147.558	503	89.26	17.74%	0	5424	
391		0		二米庄袁45	9147.558	503	141.83	28.20%	0	4513	
392		0	10kV-44	米东袁51	9147.558	503	0.00	0.00%	0	6970	
393		0		船窝村袁52	9147.558	503	223.09	44.35%	0	3106	
394		0		大陈庄袁53	9147.558	503	5.17	1.03%	0	6880	
395		0		勾家庄袁54	9147.558	503	84.22	16.74%	0	5511	
396		0		焦王庄袁55	9147.558	503	20.18	4.01%	0	6620	
397		0		后鲁沽袁56	9147.558	503	0.00	0.00%	0	6970	
398		0		王山北袁61	9147.558	503	103.90	20.66%	0	5170	
399		0		康庄东袁62	9147.558	503	236.22	46.96%	0	2878	
400		0		张五庄袁63	9147.558	503	44.59	8.87%	0	6197	
401		0		杨木村袁64	9147.558	503	128.64	25.57%	0	4742	
402		0		厂家窝袁65	9147.558	503	121.99	24.25%	0	4857	
403		0	10kV-41	天祥 I 岳11	6546.96	360	166.97	46.38%	0	2096	
404		0		天恒岳12	8547.42	470	261.88	55.72%	0	1977	
405		0		黑豆窝岳13	6546.96	360	59.06	16.40%	0	3965	
406		0		天跃一岳14	9147.558	503	292.29	58.11%	0	1907	
407		0		蝶恋一岳15	9729.51	535	329.73	61.63%	0	1702	
408		0		鑫海一岳16	9729.51	535	4.57	0.85%	0	7334	
409		0		赵各庄岳17	6546.96	360	130.24	36.18%	0	2732	
410		0	10kV-42	天宝 I 岳19	6546.96	360	74.71	20.75%	0	3694	
411		0		鑫海二岳20	9729.51	535	4.39	0.82%	0	7337	
412		0		沟头岳21	6546.96	360	219.73	61.04%	0	1182	
413		0		宝旺岳22	9147.558	503	386.02	76.74%	0	284	
414		0		天跃二岳23	9147.558	503	291.27	57.91%	0	1925	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
415		0	10kV-43	松江Ⅰ岳24	9729.51	535	381.10	71.23%	0	812	
416		0		天祥Ⅱ岳25	6546.96	360	256.82	71.34%	0	540	
417		0	10kV-44	天宝Ⅱ岳27	6546.96	360	143.97	39.99%	0	2495	
418		0		牛道口岳28	6546.96	360	172.44	47.90%	0	2001	
419		0		黄沙务岳29	9147.558	503	254.36	50.57%	0	2564	
420		0		宝富岳30	9147.558	503	377.41	75.03%	0	433	
421		0		石佛营岳31	6546.96	360	165.06	45.85%	0	2129	
422		0		松江Ⅱ岳32	9729.51	535	153.28	28.65%	0	4758	
423		0		蝶恋二岳33	9729.51	535	354.20	66.21%	0	1278	
424		0	10kV-41	曙光一关11	9729.51	535	141.79	26.50%	0	4957	
425		0		元中一关12	9729.51	535	153.39	28.67%	0	4756	
426		0		于家观关13	6546.96	360	240.84	66.90%	0	817	
427		0		宝善一关14	9729.51	535	122.79	22.95%	0	5286	
428		0		宝康一关15	8547.42	470	27.02	5.75%	0	6044	
429		0		宝德一关16	9729.51	535	116.60	21.80%	0	5393	
430		0		梦泽一关21	9729.51	535	256.13	47.88%	0	2977	
431		0		科景轩一关22	9729.51	535	275.03	51.41%	0	2649	
432	宝坻. 中关村站	0		宝志一关23	9729.51	535	58.29	10.90%	0	6403	
433		0	10kV-42	元中二关31	9729.51	535	0.68	0.13%	0	7401	
434		0		宝善二关32	9729.51	535	330.66	61.81%	0	1686	
435		0		科景轩二关33	9729.51	535	248.31	46.41%	0	3112	
436		0		宝志二关34	9729.51	535	55.00	10.28%	0	6460	
437		0	10kV-43	曙光二关41	9729.51	535	255.67	47.79%	0	2985	
438		0		宝康二关42	8547.42	470	118.17	25.14%	0	4466	
439		0		宝德二关43	9729.51	535	13.14	2.46%	0	7185	
440		0		梦泽二关44	9729.51	535	283.90	53.06%	0	2496	

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许 容量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容 量 (kVA)	备注
441	宝坻. 周良庄 站	0	10kV-41	嵘园 I 216	8547.42	470	15.49	3.29%	0	6244	
442		0		顺园 I 217	8547.42	470	117.26	24.95%	0	4481	
443		0		财大 I 218	8547.42	470	278.53	59.26%	0	1688	
444		0	10kV-42	财大 II 231	8547.42	470	375.02	79.79%	0	17	
445		0		顺园 II 232	8547.42	470	70.33	14.96%	0	5294	
446		0	10kV-43	嵘园 II 233	8547.42	470	236.22	50.26%	0	2421	
447		0	10kV-41	嘉园 I 周11	8547.42	470	151.07	32.14%	0	3896	
448		0		九园南周12	8547.42	470	127.51	27.13%	0	4304	
449		0		东皋周13	10311.462	567	2.33	0.41%	0	7816	
450		0		森林岛 I 周14	8547.42	470	161.02	34.26%	0	3723	
451		0		康园 I 周15	8547.42	470	162.68	34.61%	0	3695	
452		0	10kV-42 10kV-43	嘉园 II 周21	8547.42	470	133.36	28.37%	0	4202	
453		0		香江周22	8547.42	470	241.71	51.43%	0	2326	
454		0		九园北周23	8547.42	470	112.23	23.88%	0	4568	
455		0		森林岛 II 周24	8547.42	470	187.38	39.87%	0	3267	
456		0		安盟周34	8547.42	470	0.93	0.20%	0	6496	
457	宝坻. 马家店 站	0	10kV-41	后寒河马11	6546.96	360	152.82	42.45%	0	2341	
458		0		刘举人马12	6546.96	360	171.92	47.75%	0	2011	
459		0		天玺园马13	6546.96	360	220.54	61.26%	0	1168	
460		0		星洋马14	9147.558	503	141.34	28.10%	0	4521	
461		0		沁园马15	9147.558	503	67.94	13.51%	0	5793	
462		0	10kV-42 10kV-43	烧角马31	6546.96	360	250.66	69.63%	0	647	
463		0		西寨马41	6546.96	360	72.10	20.03%	0	3739	
464		0		大兰马42	9147.558	503	72.48	14.41%	0	5714	
465		0		后六口马51	6546.96	360	123.26	34.24%	0	2853	
466		0		璟园马52	9147.558	503	66.27	13.17%	0	5822	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负 载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
467	宝坻. 温泉城 站	0	10kV-41	马营温11	6546.96	360	145.63	40.45%	0	2466	
468		0		李台温12	9147.558	503	289.78	57.61%	0	1951	
469		0		田邢庄温13	6546.96	360	67.50	18.75%	0	3819	
470		0		香榭一温14	8547.42	470	94.29	20.06%	0	4879	
471		0		橄榄树一温15	8547.42	470	233.55	49.69%	0	2467	
472		0		邮政一温16	8547.42	470	178.21	37.92%	0	3426	
473		0	10kV-43	菜家铺温41	6546.96	360	98.97	27.49%	0	3274	
474		0		后五登温42	6546.96	360	172.46	47.91%	0	2001	
475		0		香榭二温43	8547.42	470	158.90	33.81%	0	3760	
476		0	10kV-44	四里港温51	6546.96	360	95.42	26.51%	0	3335	
477		0		橄榄树二温52	8547.42	470	211.92	45.09%	0	2842	
478		0		邮政二温53	8547.42	470	139.52	29.68%	0	4096	