

滨海供电公司10千伏配电线路可开放容量信息表(2025年第二季度)

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷 日后需预留容量（kVA）	可开放容量（kVA）	备注
1	安达	0	10kV-1	831	6928	400	275.59	68.90%	0	769.25	
2		0		832	6928	400	108.59	27.15%	0	3661.55	
3		0		833	6928	400	214.26	53.56%	0	1831.45	
4		0		834	6928	400	231.25	57.81%	0	1537.15	
5		0	10kV-2	841	6928	400	268.87	67.22%	0	885.62	
6		0	10kV-3	845	6928	400	132.23	33.06%	0	3252.23	
7		0		846	6928	400	142.58	35.64%	0	3072.95	
8		0		848	6928	400	287.50	71.88%	0	562.90	
9		0	10kV-4	851	6928	400	228.13	57.03%	0	1591.28	
10		0		852	6928	400	148.63	37.16%	0	2968.08	
11		0		853	6928	400	285.27	71.32%	0	601.47	
12		0		854	6928	400	247.85	61.96%	0	1249.60	
13		0		855	6928	400	285.35	71.34%	0	600.10	
14	宝山道	0	10kV-41	宝11	8140.4	470	60.85	12.95%	0	5458.40	
15		0		宝12	8140.4	470	20.40	4.34%	0	6158.97	
16		0		宝13	8140.4	470	64.02	13.62%	0	5403.56	
17		0		宝14	8140.4	470	276.82	58.90%	0	1717.88	
18		0		宝17	8140.4	470	143.51	30.53%	0	4026.78	
19		0		宝18	8140.4	470	1.06	0.22%	0	6494.05	
20		0	10kV-42	宝21	8140.4	470	132.25	28.14%	0	4221.72	
21		0		宝22	9006.4	520	172.00	33.08%	0	4226.11	
22		0		宝23	9006.4	520	195.56	37.61%	0	3817.95	
23		0	10kV-43	宝25	8140.4	470	324.65	69.07%	0	889.38	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
24		0	10kV-44	宝31	8140.4	470	116.78	24.85%	0	4489.76	
25		0		宝32	8140.4	470	80.20	17.06%	0	5123.34	
26		0		宝33	8140.4	470	228.28	48.57%	0	2558.60	
27		0		宝34	8140.4	470	129.79	27.61%	0	4264.36	
28		0		宝35	8140.4	470	170.94	36.37%	0	3551.59	
29		0		宝36	8140.4	470	135.77	28.89%	0	4160.80	
30		0		宝37	8140.4	470	98.84	21.03%	0	4800.46	
31	茶淀	0	10kV-41	茶11	6928	400	162.31	40.58%	0	2731.28	
32		0		茶12	6928	400	275.64	68.91%	0	768.32	
33		0		茶13	6928	400	219.96	54.99%	0	1732.68	
34		0		茶14	6373.76	368	283.59	77.06%	0	187.16	
35		0		茶15	6373.76	368	221.84	60.28%	0	1256.81	
36		0		茶16	6373.76	368	250.08	67.96%	0	767.66	
37		0		茶17	6928	400	95.27	23.82%	0	3892.27	
38		0		茶18	5975.4	345	23.44	6.79%	0	4374.37	
39		0	10kV-42	茶21	6928	400	71.48	17.87%	0	4304.30	
40		0		茶22	6928	400	42.89	10.72%	0	4799.53	
41		0		茶23	6928	400	285.82	71.46%	0	592.00	
42		0		茶24	6373.76	368	257.70	70.03%	0	635.73	
43		0	10kV-43	茶25	6373.76	368	273.52	74.33%	0	361.71	
44		0		茶26	6373.76	368	275.74	74.93%	0	323.16	
45		0		茶27	6373.76	368	209.65	56.97%	0	1467.90	
46		0		茶28	6928	400	279.61	69.90%	0	699.57	
47		0		厂13	7499.56	433	0.00	0.00%	0	5999.65	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
48	厂东路	0	10kV-41	厂14	8140.4	470	44.30	9.42%	0	5745.10	
49		0		厂15	9006.4	520	45.18	8.69%	0	6422.67	
50		0	10kV-42	厂21	7499.56	433	190.42	43.98%	0	2701.66	
51		0		厂22	10392	600	3.69	0.62%	0	8249.67	
52		0		厂23	7499.56	433	143.28	33.09%	0	3517.97	
53		0		厂24	17320	1000	305.93	30.59%	0	8557.24	
54		0	10kV-43	厂34	9006.4	520	0.00	0.00%	0	7205.12	
55		0		厂35	9006.4	520	46.23	8.89%	0	6404.42	
56		0	10kV-44	厂41	17320	1000	279.27	27.93%	0	9019.01	
57		0		厂42	17320	1000	29.59	2.96%	0	13343.50	
58		0		厂43	6373.76	368	23.73	6.45%	0	4688.00	
59	潮音寺	0	10kV-4	潮10	6928	400	63.03	15.76%	0	4450.69	
60		0		潮12	6928	400	29.05	7.26%	0	5039.29	
61		0		潮13	6928	400	195.69	48.92%	0	2153.08	
62		0		潮14	6928	400	106.39	26.60%	0	3699.69	
63		0		潮15	6928	400	158.19	39.55%	0	2802.58	
64		0		潮16	6928	400	304.44	76.11%	0	269.53	
65		0		潮17	6928	400	252.88	63.22%	0	1162.59	
66		0		潮18	6928	400	0.22	0.06%	0	5538.59	
67		0		潮19	6928	400	195.45	48.86%	0	2157.14	
68		0		潮20	6928	400	295.49	73.87%	0	424.60	
69		0		潮30	6928	400	84.36	21.09%	0	4081.28	
70		0		潮32	6928	400	146.70	36.68%	0	3001.49	
71		0		潮33	6928	400	271.63	67.91%	0	837.84	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
72		0	10kV-5	潮34	6928	400	209.75	52.44%	0	1909.51	
73		0		潮35	6928	400	318.03	79.51%	0	34.09	
74		0		潮36	6928	400	124.91	31.23%	0	3379.01	
75		0		潮37	6928	400	264.13	66.03%	0	967.74	
76		0		潮38	6928	400	213.97	53.49%	0	1836.44	
77		0		潮39	5975.4	345	167.10	48.43%	0	1886.23	
78		0		潮40	6928	400	288.03	72.01%	0	553.69	
79	潮宗桥	0	10kV-4	宗11	6373.76	368	266.32	72.37%	0	486.35	
80		0		宗12	6668.2	385	231.97	60.25%	0	1316.87	
81		0		宗14	6373.76	368	74.66	20.29%	0	3805.97	
82		0		宗15	6928	400	35.58	8.89%	0	4926.22	
83		0	10kV-5	宗16	6373.76	368	15.39	4.18%	0	4832.42	
84		0		宗21	6373.76	368	226.49	61.55%	0	1176.24	
85		0		宗22	6928	400	227.38	56.84%	0	1604.25	
86		0		宗24	6373.76	368	185.03	50.28%	0	1894.25	
87	崇义路	0	10kV-41	宗26	6373.76	368	282.14	76.67%	0	212.41	
88		0		崇11	8573.4	495	143.93	29.08%	0	4365.90	
89		0	10kV-43	崇31	8573.4	495	315.36	63.71%	0	1396.75	
90		0		丰31	6928	400	57.42	14.36%	0	4547.85	
91		0		丰32	6928	400	133.59	33.40%	0	3228.55	
92		0		丰33	6928	400	51.09	12.77%	0	4657.45	
93		0		丰34	6928	400	166.76	41.69%	0	2654.15	
94		0		丰35	6928	400	202.03	50.51%	0	2043.22	
95		0		丰36	6928	400	88.83	22.21%	0	4003.90	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
96	大丰路	0	10kV-44	丰41	6928	400	183.87	45.97%	0	2357.82	
97		0		丰42	6928	400	182.34	45.59%	0	2384.20	
98		0		丰43	6928	400	121.52	30.38%	0	3437.62	
99		0		丰44	6928	400	219.14	54.79%	0	1746.88	
100		0		丰45	6928	400	97.50	24.38%	0	3853.70	
101		0		丰46	6928	400	2.46	0.62%	0	5499.78	
102		0	10kV-45	丰51	6928	400	83.09	20.77%	0	4103.35	
103		0		丰52	6928	400	177.54	44.38%	0	2467.42	
104		0		丰53	6928	400	57.77	14.44%	0	4541.77	
105		0		丰54	6928	400	88.83	22.21%	0	4003.90	
106		0		丰55	6928	400	58.95	14.74%	0	4521.47	
107		0		丰56	6928	400	2.70	0.67%	0	5495.72	
108		0	10kV-46	丰61	6928	400	114.02	28.51%	0	3567.52	
109		0		丰62	6928	400	140.51	35.13%	0	3108.80	
110		0		丰63	6928	400	81.21	20.30%	0	4135.83	
111		0		丰65	6928	400	88.83	22.21%	0	4003.90	
112	大学城	0	10kV-41	大13	6928	400	307.38	76.84%	0	218.65	
113		0		大15	6928	400	235.45	58.86%	0	1464.44	
114		0		大16	6928	400	286.75	71.69%	0	575.86	
115		0		大17	6928	400	295.58	73.89%	0	423.02	
116		0		大18	6928	400	38.68	9.67%	0	4872.46	
117		0	10kV-42	大21	6928	400	162.87	40.72%	0	2721.46	
118		0		大22	6668.2	385	49.10	12.75%	0	4484.11	
119		0		大24	6928	400	299.85	74.96%	0	349.03	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
120	大众园	0	10kV-43	大25	6928	400	242.67	60.67%	0	1339.32	
121		0	10kV-41	众11	17320	1000	571.69	57.17%	0	3954.29	
122		0		众12	15657.28	904	3.22	0.36%	0	12470.00	
123		0		众13	7499.56	433	235.06	54.29%	0	1928.36	
124		0		众15	9006.4	520	0.00	0.00%	0	7205.12	
125		0		众16	7499.56	433	197.45	45.60%	0	2579.88	
126		0	10kV-42	众22	9266.2	535	118.67	22.18%	0	5357.53	
127		0		众23	7499.56	433	0.00	0.00%	0	5999.65	
128		0	10kV-43	众31	17320	1000	549.43	54.94%	0	4339.94	
129		0		众34	9006.4	520	0.00	0.00%	0	7205.12	
130		0		众35	10392	600	39.38	6.56%	0	7631.63	
131		0	10kV-44	众42	17320	1000	618.60	61.86%	0	3141.78	
132	邓善沽	0	10kV-42	邓21	8140.4	470	204.08	43.42%	0	2977.62	
133		0		邓22	6373.76	368	252.56	68.63%	0	724.62	
134		0		邓23	6373.76	368	213.57	58.04%	0	1399.91	
135		0		邓24	6373.76	368	247.15	67.16%	0	818.40	
136		0	10kV-43	邓25	8140.4	470	225.00	47.87%	0	2615.32	
137		0		邓26	8140.4	470	292.32	62.20%	0	1449.27	
138		0		邓27	8227	475	151.34	31.86%	0	3960.43	
139		0	10kV-44	邓31	7257.08	419	168.93	40.32%	0	2879.87	
140		0		邓32	6373.76	368	271.58	73.80%	0	395.21	
141		0		邓33	6373.76	368	244.34	66.40%	0	867.11	
142		0		邓34	8140.4	470	360.03	76.60%	0	276.55	
143		0		邓35	8140.4	470	360.17	76.63%	0	274.23	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
144		0		邓36	8140.4	470	360.18	76.63%	0	274.00	
145		0		邓37	8227	475	360.22	75.84%	0	342.52	
146	东尹站	0	10kV-42	尹21	6373.76	368	127.27	34.58%	0	2894.76	
147		0		尹22	6373.76	368	240.70	65.41%	0	930.03	
148		0		尹23	6373.76	368	269.30	73.18%	0	434.78	
149		0	10kV-44	尹35	6373.76	368	290.63	78.97%	0	65.38	
150		0		尹36	6373.76	368	213.28	57.96%	0	1404.98	
151		0		尹37	6373.76	368	172.50	46.88%	0	2111.31	
152	窦庄子	0	10kV-4	窦11	6373.76	368	88.59	24.07%	0	3564.56	
153		0		窦16	6928	400	0.00	0.00%	0	5542.40	
154		0	10kV-5	窦21	6373.76	368	174.49	47.42%	0	2076.81	
155		0		窦22	6373.76	368	99.49	27.04%	0	3375.81	
156		0		窦23	6928	400	69.84	17.46%	0	4332.70	
157	福州道	0	10kV-41	福11	6928	400	205.40	51.35%	0	1984.87	
158		0		福13	6928	400	48.77	12.19%	0	4697.74	
159		0		福14	6928	400	244.82	61.21%	0	1302.05	
160		0		福15	6928	400	142.37	35.59%	0	3076.59	
161		0		福16	6928	400	69.86	17.47%	0	4332.36	
162		0		福17	6928	400	89.39	22.35%	0	3994.13	
163		0		福18	6928	400	63.84	15.96%	0	4436.69	
164		0	10kV-42	福21	6928	400	110.66	27.67%	0	3625.70	
165		0		福23	6928	400	313.85	78.46%	0	106.55	
166		0	10kV-43	福26	6928	400	70.58	17.65%	0	4319.89	
167		0		福27	6928	400	126.30	31.58%	0	3354.81	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
168		0	10kV-44	福28	6928	400	254.94	63.73%	0	1126.91	
169		0		福31	6928	400	139.61	34.90%	0	3124.39	
170		0		福32	6928	400	217.17	54.29%	0	1781.05	
171		0		福34	6928	400	193.97	48.49%	0	2182.87	
172		0		福35	6928	400	129.61	32.40%	0	3297.59	
173		0		福38	6928	400	155.27	38.82%	0	2853.09	
174	付庄	0	10kV-4	付14	6373.76	368	86.40	23.48%	0	3602.56	
175		0		付15	5196	300	195.60	65.20%	0	769.01	
176		0		付16	6373.76	368	279.28	75.89%	0	261.88	
177		0		付17	5196	300	209.84	69.95%	0	522.37	
178		0	10kV-5	付21	5196	300	110.88	36.96%	0	2236.36	
179		0		付22	5196	300	78.96	26.32%	0	2789.21	
180		0		付23	6373.76	368	161.20	43.80%	0	2307.02	
181		0		付24	6373.76	368	130.88	35.57%	0	2832.17	
182		0		付25	6928	400	277.52	69.38%	0	735.75	
183		0	10kV-41	发11	6373.76	368	29.18	7.93%	0	4593.61	
184	港发站	0		发12	6373.76	368	259.45	70.50%	0	605.28	
185		0		发13	6373.76	368	243.63	66.20%	0	879.28	
186		0		发14	6373.76	368	115.31	31.33%	0	3101.80	
187		0		发15	6373.76	368	168.40	45.76%	0	2182.35	
188		0		发16	8278.96	478	272.81	57.07%	0	1898.06	
189		0		发17	8140.4	470	92.46	19.67%	0	4910.90	
190		0		发18	8140.4	470	2.11	0.45%	0	6475.79	
191		0		发31	8140.4	470	235.72	50.15%	0	2429.60	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
192		0	10kV-44	发32	6373.76	368	197.75	53.74%	0	1673.91	
193		0		发33	6373.76	368	0.00	0.00%	0	5099.01	
194		0		发34	6373.76	368	305.15	82.92%	0	0.00	
195		0		发35	6373.76	368	92.81	25.22%	0	3491.50	
196		0		发36	8278.96	478	255.59	53.47%	0	2196.42	
197		0		发37	8140.4	470	0.00	0.00%	0	6512.32	
198	港塘路	0	10kV-5	610	5196	300	132.18	44.06%	0	1867.49	
199		0		612	5196	300	45.18	15.06%	0	3374.35	
200		0	10kV-4	615	5196	300	114.84	38.28%	0	2167.77	
201		0		619	5196	300	97.86	32.62%	0	2461.95	
202	港湾	0	10kV-41	湾11	8140.4	470	49.64	10.56%	0	5652.49	
203		0		湾12	6373.76	368	245.88	66.82%	0	840.30	
204		0		湾13	8140.4	470	209.69	44.61%	0	2880.52	
205		0		湾14	6373.76	368	228.35	62.05%	0	1144.02	
206		0		湾15	6373.76	368	163.90	44.54%	0	2260.33	
207		0		湾16	8140.4	470	182.02	38.73%	0	3359.80	
208		0		湾17	8140.4	470	303.44	64.56%	0	1256.67	
209		0		湾18	8140.4	470	148.30	31.55%	0	3943.83	
210		0	10kV-42	湾21	8140.4	470	8.82	1.88%	0	6359.56	
211		0		湾22	8140.4	470	169.57	36.08%	0	3575.33	
212		0		湾23	8140.4	470	258.58	55.02%	0	2033.78	
213		0		湾24	6373.76	368	126.66	34.42%	0	2905.26	
214		0		湾25	6373.76	368	253.19	68.80%	0	713.79	
215		0		湾26	8140.4	470	113.69	24.19%	0	4543.24	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
216		0	10kV-43	湾27	8140.4	470	309.74	65.90%	0	1147.55	
217		0		湾28	8140.4	470	65.94	14.03%	0	5370.24	
218	高新园	0		高31	6928	400	138.68	34.67%	0	3140.41	
219		0		高32	6529.64	377	97.83	25.95%	0	3529.26	
220		0		高33	6928	400	127.19	31.80%	0	3339.50	
221		0		高36	6529.64	377	285.26	75.67%	0	283.03	
222		0	10kV-44	高41	6928	400	213.15	53.29%	0	1850.68	
223		0		高42	6928	400	15.71	3.93%	0	5270.35	
224		0		高43	6928	400	24.68	6.17%	0	5115.03	
225		0		高44	6928	400	54.76	13.69%	0	4593.96	
226		0		高45	6928	400	244.00	61.00%	0	1316.30	
227		0		高46	6928	400	73.39	18.35%	0	4271.23	
228		0	10kV-45	高52	6928	400	72.41	18.10%	0	4288.24	
229		0		高53	6928	400	136.02	34.00%	0	3186.57	
230		0		高54	6928	400	103.57	25.89%	0	3748.62	
231		0	10kV-46	高61	6928	400	280.18	70.04%	0	689.75	
232		0		高62	6928	400	189.59	47.40%	0	2258.65	
233		0		高63	6928	400	134.94	33.73%	0	3205.26	
234		0		高64	6529.64	377	170.89	45.33%	0	2263.98	
235		0		高65	6928	400	135.78	33.94%	0	3190.71	
236		0	10kV-41	工11	6928	400	106.41	26.60%	0	3699.45	
237		0		工12	6928	400	223.48	55.87%	0	1671.78	
238		0		工13	6928	400	277.97	69.49%	0	727.98	
239		0		工14	6928	400	271.52	67.88%	0	839.62	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
240	工农村	0		工15	6373.76	368	164.88	44.81%	0	2243.23	
241		0		工16	6928	400	310.08	77.52%	0	171.85	
242		0		工17	6928	400	235.55	58.89%	0	1462.73	
243		0		工18	6928	400	109.45	27.36%	0	3646.67	
244		0	10kV-42	工21	6928	400	112.15	28.04%	0	3600.00	
245		0		工22	6928	400	173.44	43.36%	0	2538.45	
246		0		工23	6928	400	250.90	62.72%	0	1196.85	
247		0		工24	6928	400	166.41	41.60%	0	2660.25	
248		0	10kV-43	工25	6373.76	368	273.63	74.36%	0	359.68	
249		0		工26	6928	400	279.73	69.93%	0	697.53	
250		0		工27	6928	400	287.73	71.93%	0	558.85	
251		0		工28	6928	400	0.00	0.00%	0	5542.40	
252	光辉	0	10kV-41	光11	8053.8	465	130.28	28.02%	0	4186.52	
253		0		光12	10166.84	587	202.84	34.55%	0	4620.35	
254		0		光13	10166.84	587	218.44	37.21%	0	4350.16	
255		0		光14	6928	400	185.02	46.25%	0	2337.92	
256		0		光15	7967.2	460	0.00	0.00%	0	6373.76	
257		0		光21	10166.84	587	63.20	10.77%	0	7038.78	
258		0		光22	10166.84	587	226.88	38.65%	0	4203.84	
259		0		光23	7309.04	422	54.43	12.90%	0	4904.47	
260		0	10kV-43	光41	10166.84	587	93.60	15.95%	0	6512.32	
261		0		光42	10166.84	587	184.50	31.43%	0	4937.93	
262		0		光46	9006.4	520	0.00	0.00%	0	7205.12	
263		0		光51	8053.8	465	111.77	24.04%	0	4507.22	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
264		0	10kV-44	光52	10166.84	587	69.98	11.92%	0	6921.35	
265		0		光53	6928	400	251.70	62.93%	0	1182.96	
266		0		光54	6928	400	161.22	40.31%	0	2750.07	
267		0		光55	7967.2	460	0.00	0.00%	0	6373.76	
268		0		光61	7309.04	422	55.58	13.17%	0	4884.52	
269		0									
270	郭庄子	0	10kV-4	郭11	6373.76	368	177.09	48.12%	0	2031.79	
271		0		郭12	6373.76	368	82.76	22.49%	0	3665.57	
272		0		郭13	6373.76	368	141.60	38.48%	0	2646.55	
273		0		郭14	6373.76	368	97.57	26.51%	0	3409.03	
274		0		郭15	6928	400	202.71	50.68%	0	2031.46	
275		0		郭16	6928	400	77.07	19.27%	0	4207.63	
276		0	10kV-5	郭22	6373.76	368	126.54	34.39%	0	2907.28	
277		0		郭23	6928	400	137.01	34.25%	0	3169.47	
278		0		郭25	6373.76	368	185.79	50.49%	0	1881.09	
279		0		郭26	6373.76	368	207.10	56.28%	0	1512.12	
280	海滨浴场	0	10kV-4	783	5888.8	340	224.39	66.00%	0	824.55	
281	海防路	0	10kV-41	防11	6373.76	368	76.14	20.69%	0	3780.35	
282		0		防12	6633.56	383	68.75	17.95%	0	4116.06	
283		0		防13	8140.4	470	72.80	15.49%	0	5251.51	
284		0	10kV-42	防21	6373.76	368	77.72	21.12%	0	3752.95	
285		0		防23	8140.4	470	92.13	19.60%	0	4916.61	
286		0	10kV-41	海11	6928	400	208.01	52.00%	0	1939.70	
287		0		海12	6928	400	108.52	27.13%	0	3662.90	
				海14	6668.2	385	0.00	0.00%	0	5334.56	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
288	海景路	0		海15	6928	400	30.00	7.50%	0	5022.80	
289		0		海16	6928	400	286.88	71.72%	0	573.73	
290		0	10kV-42	海21	6928	400	194.30	48.57%	0	2177.18	
291		0		海22	6928	400	315.59	78.90%	0	76.45	
292		0		海23	6928	400	93.98	23.50%	0	3914.60	
293		0		海24	6928	400	82.27	20.57%	0	4117.55	
294		0	10kV-43	海33	6928	400	82.27	20.57%	0	4117.55	
295		0		海34	6668.2	385	80.04	20.79%	0	3948.28	
296		0		海35	6928	400	8.32	2.08%	0	5398.30	
297		0		海36	6928	400	270.35	67.59%	0	859.90	
298		0	10kV-44	海41	6928	400	213.87	53.47%	0	1838.22	
299		0		海42	6928	400	249.02	62.26%	0	1229.32	
300		0		海43	6928	400	138.63	34.66%	0	3141.28	
301		0		海44	6928	400	82.85	20.71%	0	4107.40	
302	海平路	0	10kV-41	平11	7309.04	422	165.38	39.19%	0	2982.80	
303		0	10kV-42	平31	7309.04	422	236.00	55.92%	0	1759.76	
304	海洋	0	10kV-2甲	421	6373.76	368	133.14	36.18%	0	2793.09	
305		0		422	6373.76	368	139.09	37.80%	0	2690.04	
306		0		423	8140.4	470	151.84	32.31%	0	3882.43	
307		0		424	8140.4	470	67.32	14.32%	0	5346.27	
308		0	10kV-2乙	425	8140.4	470	213.15	45.35%	0	2820.58	
309		0		426	8140.4	470	247.50	52.66%	0	2225.59	
310		0		427	8140.4	470	66.44	14.14%	0	5361.63	
311		0		428	8140.4	470	209.67	44.61%	0	2880.92	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
312		0	10kV-3	431	8140.4	470	103.25	21.97%	0	4723.96	
313		0		432	6373.76	368	222.65	60.50%	0	1242.71	
314		0		433	8140.4	470	213.54	45.43%	0	2813.74	
315		0		434	8140.4	470	117.62	25.03%	0	4475.14	
316		0		435	8140.4	470	168.94	35.94%	0	3586.37	
317		0		436	8140.4	470	192.51	40.96%	0	3178.13	
318		0		437	8140.4	470	150.69	32.06%	0	3902.37	
319		0		438	6373.76	368	187.11	50.85%	0	1858.19	
320	航园	0	10kV-41	航11	8313.6	480	59.77	12.45%	0	5615.73	
321		0		航12	6408.4	370	118.81	32.11%	0	3069.00	
322		0		航13	6373.76	368	10.81	2.94%	0	4911.76	
323		0		航14	8140.4	470	194.39	41.36%	0	3145.45	
324		0		航16	8417.52	486	143.28	29.48%	0	4252.34	
325		0		航17	6373.76	368	244.07	66.32%	0	871.68	
326		0		航18	6373.76	368	198.00	53.80%	0	1669.72	
327		0	10kV-42	航21	7534.2	435	150.47	34.59%	0	3421.24	
328		0		航22	7534.2	435	107.27	24.66%	0	4169.43	
329		0		航23	8313.6	480	14.39	3.00%	0	6401.61	
330		0		航24	8140.4	470	305.99	65.10%	0	1212.56	
331		0	10kV-43	航25	8417.52	486	108.72	22.37%	0	4850.97	
332		0		航27	8140.4	470	55.44	11.80%	0	5552.15	
333		0		航28	8140.4	470	5.76	1.22%	0	6412.61	
334		0		航31	8140.4	470	181.43	38.60%	0	3369.99	
335		0		航32	8417.52	486	267.83	55.11%	0	2095.29	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷 日后需预留容量（kVA）	可开放容量（kVA）	备注
336		0	10kV-44	航33	8140.4	470	55.44	11.80%	0	5552.15	
337		0		航34	8140.4	470	78.49	16.70%	0	5152.94	
338		0		航35	8400.2	485	379.42	78.23%	0	148.54	
339		0		航36	9006.4	520	244.07	46.94%	0	2977.79	
340		0		航37	8140.4	470	172.99	36.81%	0	3516.15	
341		0		航38	8140.4	470	261.34	55.60%	0	1985.86	
342	和畅路	0	10kV-41	畅11	6928	400	201.24	50.31%	0	2056.99	
343		0		畅12	6928	400	221.74	55.43%	0	1701.93	
344		0		畅13	6928	400	306.96	76.74%	0	225.85	
345		0		畅14	6928	400	155.15	38.79%	0	2855.17	
346		0		畅15	6928	400	11.31	2.83%	0	5346.48	
347		0		畅16	6928	400	240.80	60.20%	0	1371.74	
348		0	10kV-42	畅21	6928	400	167.70	41.92%	0	2637.91	
349		0		畅22	6928	400	254.61	63.65%	0	1132.59	
350		0		畅23	6928	400	305.66	76.42%	0	248.30	
351		0		畅24	6928	400	264.30	66.08%	0	964.72	
352		0		畅25	6928	400	283.12	70.78%	0	638.76	
353		0	10kV-43	畅31	6928	400	205.20	51.30%	0	1988.42	
354		0		畅32	6928	400	204.39	51.10%	0	2002.37	
355		0		畅33	6928	400	240.15	60.04%	0	1383.07	
356		0		畅34	6928	400	258.62	64.65%	0	1063.17	
357		0		畅36	6928	400	280.12	70.03%	0	690.72	
358		0		畅41	6928	400	195.02	48.75%	0	2164.72	
359		0		畅42	6928	400	203.33	50.83%	0	2020.76	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
360		0	10kV-44	畅43	6928	400	285.64	71.41%	0	595.12	
361		0		畅44	6928	400	163.13	40.78%	0	2717.02	
362		0		畅45	6928	400	6.15	1.54%	0	5435.85	
363		0		畅46	6928	400	269.24	67.31%	0	879.16	
364		0	10kV-45	畅51	6928	400	127.58	31.90%	0	3332.65	
365		0		畅52	6928	400	244.37	61.09%	0	1309.95	
366		0		畅53	6928	400	295.81	73.95%	0	419.01	
367		0		畅54	6928	400	310.96	77.74%	0	156.62	
368		0		畅55	6928	400	310.94	77.74%	0	156.85	
369		0		畅56	6928	400	191.44	47.86%	0	2226.66	
370		0	10kV-46	畅61	6928	400	205.06	51.26%	0	1990.83	
371		0		畅62	6928	400	303.14	75.79%	0	291.95	
372		0		畅63	6928	400	296.38	74.09%	0	409.17	
373		0		畅64	6928	400	245.67	61.42%	0	1287.41	
374		0		畅65	6928	400	66.18	16.55%	0	4396.09	
375		0		畅66	6928	400	306.23	76.56%	0	238.57	
376	后沽	0	10kV-4	后15	6373.76	368	77.50	21.06%	0	3756.78	
377		0		后16	6373.76	368	62.12	16.88%	0	4023.02	
378		0		后17	6373.76	368	154.76	42.06%	0	2418.50	
379		0	10kV-5	后21	6373.76	368	154.04	41.86%	0	2430.97	
380		0		后22	6373.76	368	74.65	20.29%	0	3806.04	
381		0		后23	6373.76	368	77.23	20.99%	0	3761.35	
382		0		后27	5975.4	345	12.22	3.54%	0	4568.74	
383		0		胡11	6928	400	14.41	3.60%	0	5292.75	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
384	胡家园	0	10kV-41	胡12	6928	400	21.68	5.42%	0	5166.90	
385		0		胡13	6928	400	269.77	67.44%	0	870.05	
386		0		胡15	6928	400	190.43	47.61%	0	2244.15	
387		0		胡16	6928	400	308.32	77.08%	0	202.30	
388		0	10kV-42	胡20	6928	400	273.05	68.26%	0	813.23	
389		0		胡21	6928	400	262.85	65.71%	0	989.80	
390		0		胡22	6598.92	381	231.91	60.87%	0	1262.39	
391		0		胡23	6928	400	133.48	33.37%	0	3230.58	
392		0		胡24	6928	400	270.12	67.53%	0	863.97	
393		0	10kV-43	胡25	6373.76	368	271.91	73.89%	0	389.46	
394		0		胡26	6928	400	301.29	75.32%	0	324.07	
395		0		胡27	6928	400	195.35	48.84%	0	2158.90	
396		0		胡28	6928	400	206.84	51.71%	0	1960.00	
397		0	10kV-44	胡31	6373.76	368	249.06	67.68%	0	785.25	
398		0		胡32	6928	400	53.79	13.45%	0	4610.77	
399		0		胡33	6928	400	301.76	75.44%	0	315.95	
400		0		胡34	6512.32	376	249.61	66.39%	0	886.63	
401		0		胡35	6928	400	173.91	43.48%	0	2530.35	
402		0		胡36	6373.76	368	270.00	73.37%	0	422.61	
403		0		胡37	6928	400	238.71	59.68%	0	1407.93	
404		0		胡38	6928	400	235.78	58.95%	0	1458.67	
405		0	10kV-42	琥31	9785.8	565	172.06	30.45%	0	4848.63	
406		0		琥32	9162.28	529	391.33	73.98%	0	551.95	
407		0		琥33	8278.96	478	20.14	4.21%	0	6274.41	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
408	琥珀溪	0		琥34	9647.24	557	391.67	70.32%	0	934.10	
409		0		琥35	7794	450	31.30	6.95%	0	5693.15	
410		0	10kV-43	琥41	8278.96	478	60.04	12.56%	0	5583.34	
411		0		琥42	9006.4	520	179.76	34.57%	0	4091.68	
412		0		琥43	9266.2	535	321.06	60.01%	0	1852.20	
413		0		琥45	8400.2	485	22.57	4.65%	0	6329.21	
414		0		琥46	9266.2	535	68.59	12.82%	0	6224.95	
415		0	10kV-44	琥51	9266.2	535	232.86	43.53%	0	3379.82	
416		0		琥52	9266.2	535	323.48	60.46%	0	1810.22	
417		0		琥53	8278.96	478	34.80	7.28%	0	6020.43	
418		0		琥54	9006.4	520	215.04	41.35%	0	3480.63	
419		0		琥55	8400.2	485	77.06	15.89%	0	5385.41	
420		0		琥61	8278.96	478	59.14	12.37%	0	5598.93	
421		0		琥62	9006.4	520	53.11	10.21%	0	6285.22	
422		0		琥63	9266.2	535	0.80	0.15%	0	7399.03	
423		0		琥64	9006.4	520	136.45	26.24%	0	4841.77	
424		0		琥65	8400.2	485	19.52	4.03%	0	6382.00	
425		0		琥66	9266.2	535	115.85	21.65%	0	5406.47	
426		0	10kV-1	711	6928	400	164.34	41.08%	0	2696.08	
427		0		712	6928	400	284.13	71.03%	0	621.23	
428		0		714	6928	400	253.42	63.36%	0	1153.15	
429		0		716	6928	400	220.95	55.24%	0	1715.51	
430		0		717	6928	400	49.11	12.28%	0	4691.75	
431		0		721	6928	400	48.65	12.16%	0	4699.87	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
432	花园	0	10kV-2甲	722	6928	400	30.13	7.53%	0	5020.64	
433		0		723	6928	400	171.25	42.81%	0	2576.30	
434		0	10kV-2乙	725	6928	400	267.02	66.75%	0	917.65	
435		0		727	6928	400	27.08	6.77%	0	5073.43	
436		0	10kV-3	731	6928	400	224.47	56.12%	0	1654.60	
437		0		732	6928	400	291.63	72.91%	0	491.30	
438		0		733	6928	400	168.09	42.02%	0	2631.12	
439		0		734	6928	400	141.71	35.43%	0	3087.91	
440		0		735	6928	400	92.02	23.00%	0	3948.70	
441		0		736	6928	400	184.73	46.18%	0	2342.82	
442		0		737	6928	400	167.62	41.90%	0	2639.24	
443		0		738	6928	400	1.52	0.38%	0	5516.00	
444	华山道	0	10kV-41	山11	6373.76	368	119.65	32.51%	0	3026.70	
445		0		山12	6373.76	368	244.22	66.36%	0	869.13	
446		0		山13	6928	400	284.65	71.16%	0	612.30	
447		0		山14	6928	400	193.83	48.46%	0	2185.30	
448		0		山15	6928	400	218.20	54.55%	0	1763.12	
449		0		山16	6928	400	214.22	53.55%	0	1832.13	
450		0	10kV-42	山21	6928	400	103.13	25.78%	0	3756.28	
451		0		山22	6928	400	227.46	56.87%	0	1602.78	
452		0		山23	6928	400	172.50	43.13%	0	2554.70	
453		0		山24	6928	400	71.60	17.90%	0	4302.25	
454		0		山25	6928	400	68.44	17.11%	0	4357.05	
455		0		山26	6928	400	210.00	52.50%	0	1905.20	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷 日后需预留容量（kVA）	可开放容量（kVA）	备注
456		0	10kV-45	山51	6928	400	306.55	76.64%	0	232.99	
457		0		山52	6928	400	215.74	53.94%	0	1805.75	
458		0		山53	6373.76	368	213.98	58.15%	0	1392.81	
459		0		山54	6928	400	250.43	62.61%	0	1204.95	
460		0		山55	6928	400	216.09	54.02%	0	1799.65	
461		0		山56	6928	400	68.44	17.11%	0	4357.05	
462		0	10kV-46	山61	6928	400	37.50	9.38%	0	4892.90	
463		0		山62	6373.76	368	12.54	3.41%	0	4881.83	
464		0		山63	6928	400	82.03	20.51%	0	4121.62	
465		0		山64	6928	400	289.92	72.48%	0	520.95	
466		0		山65	6928	400	152.70	38.17%	0	2897.72	
467		0		山66	10392	600	44.18	7.36%	0	7548.40	
468	化工园	0	10kV-4	952	6928	400	52.54	13.13%	0	4632.42	
469		0		953	6928	400	175.98	43.99%	0	2494.48	
470		0		956	6928	400	24.22	6.05%	0	5122.93	
471		0	10kV-5	961	6373.76	368	164.84	44.79%	0	2243.91	
472		0		962	6928	400	3.52	0.88%	0	5481.50	
473		0		963	6928	400	261.72	65.43%	0	1009.43	
474		0		966	6928	400	8.59	2.15%	0	5393.55	
475		0	10kV-43	惠31	8140.4	470	257.17	54.72%	0	2058.17	
476		0		惠32	7794	450	1.76	0.39%	0	6204.75	
477		0		惠34	9526	550	287.75	52.32%	0	2636.90	
478		0	10kV-44	惠41	7482.24	432	300.94	69.66%	0	773.55	
479		0		惠42	8763.92	506	110.39	21.82%	0	5099.16	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
480	惠居站	0	10kV-45	惠43	7828.64	452	360.53	79.76%	0	18.58	
481		0		惠45	8763.92	506	147.83	29.22%	0	4450.69	
482		0		惠51	9266.2	535	317.29	59.31%	0	1917.58	
483		0	10kV-46	惠53	9266.2	535	292.32	54.64%	0	2349.91	
484		0		惠54	9526	550	245.74	44.68%	0	3364.55	
485		0		惠61	7828.64	452	199.51	44.14%	0	2807.36	
486		0	10kV-46	惠62	7828.64	452	346.11	76.57%	0	268.23	
487		0		惠63	8763.92	506	218.67	43.22%	0	3223.74	
488		0		惠64	7326.36	423	289.86	68.53%	0	840.66	
489		0		惠65	9959	575	149.06	25.92%	0	5385.45	
490		0	10kV-41	碱11	8140.4	470	345.59	73.53%	0	526.77	
491		0		碱12	8140.4	470	31.09	6.62%	0	5973.79	
492		0		碱13	8140.4	470	119.83	25.50%	0	4436.85	
493		0		碱14	7828.64	452	135.53	29.98%	0	3915.58	
494		0		碱15	8400.2	485	120.76	24.90%	0	4628.56	
495		0	10kV-43	碱31	8140.4	470	200.08	42.57%	0	3046.95	
496		0		碱32	6287.16	363	244.86	67.46%	0	788.70	
497		0		碱33	8140.4	470	199.59	42.47%	0	3055.46	
498		0		碱34	8140.4	470	62.01	13.19%	0	5438.32	
499		0		碱35	8140.4	470	348.51	74.15%	0	476.21	
500		0		碱36	8140.4	470	323.40	68.81%	0	910.96	
501		0		碱37	8140.4	470	227.74	48.45%	0	2567.93	
502		0		碱38	8140.4	470	121.41	25.83%	0	4409.46	
503		0		碱41	8140.4	470	154.02	32.77%	0	3844.69	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
504	碱渣山	0	10kV-44	碱42	6287.16	363	123.05	33.90%	0	2898.55	
505		0		碱43	8140.4	470	120.03	25.54%	0	4433.38	
506		0		碱44	8140.4	470	241.38	51.36%	0	2331.67	
507		0		碱45	8140.4	470	146.81	31.24%	0	3969.64	
508		0		碱46	8140.4	470	120.01	25.53%	0	4433.71	
509		0		碱47	8140.4	470	155.74	33.14%	0	3814.87	
510		0		碱48	8140.4	470	143.77	30.59%	0	4022.24	
511		0	10kV-45	碱51	8140.4	470	272.10	57.89%	0	1799.60	
512		0		碱52	8140.4	470	204.74	43.56%	0	2966.24	
513		0		碱53	8140.4	470	190.69	40.57%	0	3209.53	
514		0		碱54	8140.4	470	217.52	46.28%	0	2744.86	
515		0		碱55	6287.16	363	181.11	49.89%	0	1892.92	
516		0		碱56	8140.4	470	201.13	42.79%	0	3028.73	
517		0		碱57	8140.4	470	157.31	33.47%	0	3787.76	
518		0		碱58	8140.4	470	276.50	58.83%	0	1723.27	
519		0	10kV-46	碱61	8140.4	470	209.16	44.50%	0	2889.76	
520		0		碱62	8140.4	470	312.72	66.54%	0	1096.10	
521		0		碱63	8140.4	470	210.06	44.69%	0	2874.10	
522		0		碱64	8140.4	470	119.93	25.52%	0	4435.20	
523		0		碱65	6287.16	363	219.90	60.58%	0	1221.03	
524		0		碱66	8140.4	470	120.03	25.54%	0	4433.44	
525		0		碱67	7828.64	452	120.05	26.56%	0	4183.72	
526		0		碱68	8140.4	470	169.22	36.00%	0	3581.50	
527		0		源11	6928	400	92.99	23.25%	0	3931.85	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
528	金源路	0	10kV-41	源12	6928	400	186.99	46.75%	0	2303.79	
529		0		源13	6373.76	368	207.99	56.52%	0	1496.57	
530		0		源14	6928	400	222.99	55.75%	0	1680.16	
531		0		源15	6928	400	189.99	47.50%	0	2251.77	
532		0		源16	6373.76	368	145.99	39.67%	0	2570.53	
533		0		源17	6373.76	368	250.99	68.20%	0	751.93	
534		0		源18	6928	400	222.99	55.75%	0	1680.16	
535		0	10kV-42	源21	6928	400	222.00	55.50%	0	1697.41	
536		0		源22	6928	400	275.00	68.75%	0	779.49	
537		0		源23	6373.76	368	225.00	61.14%	0	1202.01	
538		0		源24	6373.76	368	245.00	66.57%	0	855.69	
539		0	10kV-43	源25	6373.76	368	186.99	50.81%	0	1860.39	
540		0		源26	6928	400	102.00	25.50%	0	3775.81	
541		0		源27	6928	400	264.99	66.25%	0	952.77	
542		0		源28	6373.76	368	278.99	75.81%	0	266.83	
543		0	10kV-44	源31	6373.76	368	271.38	73.74%	0	398.69	
544		0		源32	6373.76	368	221.79	60.27%	0	1257.54	
545		0		源34	6928	400	1.18	0.30%	0	5521.89	
546		0		源35	6928	400	1.16	0.29%	0	5522.31	
547		0	10kV-41	精11	8140.4	470	327.22	69.62%	0	844.92	
548		0		精12	8140.4	470	126.23	26.86%	0	4325.96	
549		0		精13	7880.6	455	126.69	27.84%	0	4110.14	
550		0		精14	9924.36	573	2.15	0.38%	0	7902.20	
551		0		精15	8278.96	478	229.31	47.97%	0	2651.57	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
552	精细园	0	10kV-42	精21	7880.6	455	218.01	47.91%	0	2528.49	
553		0		精22	7326.36	423	0.00	0.00%	0	5861.09	
554		0		精23	7880.6	455	89.14	19.59%	0	4760.52	
555		0		精24	10392	600	50.87	8.48%	0	7432.58	
556		0	10kV-43	精31	8140.4	470	184.90	39.34%	0	3309.85	
557		0		精32	8140.4	470	278.13	59.18%	0	1695.11	
558		0		精33	7880.6	455	73.30	16.11%	0	5034.91	
559		0		精34	9924.36	573	2.15	0.38%	0	7902.20	
560		0		精35	8278.96	478	239.39	50.08%	0	2476.90	
561		0		精36	9006.4	520	20.39	3.92%	0	6851.95	
562		0	10kV-44	精41	7880.6	455	233.15	51.24%	0	2266.29	
563		0		精42	7326.36	423	0.00	0.00%	0	5861.09	
564		0		精43	7880.6	455	62.14	13.66%	0	5228.23	
565		0		精44	7880.6	455	104.02	22.86%	0	4502.87	
566		0		精45	5369.2	310	6.59	2.13%	0	4181.19	
567		0		精46	9266.2	535	199.07	37.21%	0	3965.03	
568	科学园	0	10kV-42	科21	6373.76	368	59.41	16.15%	0	4069.96	
569		0		科22	6373.76	368	219.61	59.68%	0	1295.38	
570		0		科23	6928	400	188.79	47.20%	0	2272.57	
571		0		科24	6928	400	132.66	33.16%	0	3244.80	
572		0	10kV-43	科25	6928	400	277.38	69.35%	0	738.13	
573		0		科26	6928	400	156.68	39.17%	0	2828.70	
574		0		科27	6928	400	110.86	27.71%	0	3622.32	
575		0		科31	6928	400	40.20	10.05%	0	4846.22	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
576		0	10kV-44	科32	6373.76	368	193.71	52.64%	0	1743.93	
577		0		科33	6373.76	368	179.30	48.72%	0	1993.58	
578		0		科34	6928	400	305.98	76.49%	0	242.88	
579		0		科35	6928	400	44.88	11.22%	0	4765.03	
580		0		科36	6928	400	178.83	44.71%	0	2445.10	
581		0		科37	6928	400	214.81	53.70%	0	1821.98	
582	临津园	0	10kV-4	津11	6373.76	368	246.60	67.01%	0	827.91	
583		0		津12	7499.56	433	10.81	2.50%	0	5812.40	
584		0		津13	7499.56	433	313.20	72.33%	0	575.06	
585		0		津14	7187.8	415	38.41	9.25%	0	5085.01	
586		0	10kV-5	津21	6373.76	368	251.39	68.31%	0	744.95	
587		0		津22	7499.56	433	179.39	41.43%	0	2892.70	
588		0		津23	7499.56	433	293.99	67.90%	0	907.67	
589		0		津24	7187.8	415	327.00	78.79%	0	86.65	
590		0		津24	7187.8	415	327.00	78.79%	0	86.65	
590	刘岗	0	10kV-4	刘11	6062	350	187.73	53.64%	0	1598.05	
591		0		刘13	6373.76	368	167.70	45.57%	0	2194.53	
592		0		刘14	6373.76	368	194.77	52.93%	0	1725.66	
593		0	10kV-5	刘22	6373.76	368	2.46	0.67%	0	5056.38	
594		0		刘23	6373.76	368	123.75	33.63%	0	2955.66	
595		0		刘24	6062	350	240.82	68.81%	0	678.60	
596		0		刘25	7794	450	0.35	0.08%	0	6229.10	
597		0	10kV-41	美11	6928	400	151.64	37.91%	0	2915.98	
598		0		美12	6928	400	98.44	24.61%	0	3837.45	
599		0		美16	6928	400	94.92	23.73%	0	3898.35	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
600	美洲路	0		美17	6928	400	76.52	19.13%	0	4217.02	
601		0		美18	6928	400	43.95	10.99%	0	4781.27	
602		0		美21	6928	400	75.70	18.93%	0	4231.22	
603		0	10kV-42	美22	6928	400	60.00	15.00%	0	4503.20	
604		0		美23	6928	400	63.16	15.79%	0	4448.40	
605		0		美25	6928	400	154.81	38.70%	0	2861.18	
606		0	10kV-43	美26	6928	400	114.96	28.74%	0	3551.28	
607		0									
608	南环	0	10kV-41	南11	6928	400	103.48	25.87%	0	3750.18	
609		0		南12	6928	400	140.86	35.21%	0	3102.72	
610		0		南13	6928	400	276.33	69.08%	0	756.40	
611		0		南14	6928	400	209.65	52.41%	0	1911.30	
612		0		南15	6928	400	134.88	33.72%	0	3206.23	
613		0		南16	6928	400	152.34	38.09%	0	2903.80	
614		0		南17	6928	400	216.80	54.20%	0	1787.48	
615		0		南18	6928	400	0.00	0.00%	0	5542.40	
616		0	10kV-42	南21	6928	400	0.00	0.00%	0	5542.40	
617		0		南22	6928	400	0.00	0.00%	0	5542.40	
618		0		南23	6928	400	148.24	37.06%	0	2974.85	
619		0		南24	6373.76	368	55.66	15.13%	0	4134.91	
620		0	10kV-43	南25	6373.76	368	196.52	53.40%	0	1695.23	
621		0		南26	6928	400	116.37	29.09%	0	3526.92	
622		0		南27	6928	400	130.66	32.67%	0	3279.30	
623		0		南28	6928	400	84.73	21.18%	0	4074.93	
623		0	10kV-4	车11	5196	300	210.70	70.23%	0	507.55	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
624	宁车沽	0	10kV-5	车12	6373.76	368	132.23	35.93%	0	2808.77	
625		0		车21	5196	300	71.98	23.99%	0	2910.07	
626		0		车22	5196	300	194.63	64.88%	0	785.74	
627	宁夏道	0	10kV-42	夏31	7534.2	435	86.75	19.94%	0	4524.85	
628		0		夏32	8573.4	495	70.75	14.29%	0	5633.28	
629		0		夏33	9560.64	552	49.92	9.04%	0	6783.90	
630		0		夏34	7395.64	427	209.45	49.05%	0	2288.84	
631		0	10kV-43	夏41	9924.36	573	72.36	12.63%	0	6686.16	
632		0		夏42	8278.96	478	125.03	26.16%	0	4457.72	
633		0	10kV-44	夏51	8573.4	495	69.37	14.01%	0	5657.20	
634		0		夏52	7534.2	435	107.46	24.70%	0	4166.15	
635		0		夏53	9560.64	552	47.82	8.66%	0	6820.25	
636		0		夏54	7395.64	427	212.07	49.66%	0	2243.55	
637		0		夏61	9006.4	520	52.72	10.14%	0	6292.06	
638		0		夏62	8278.96	478	47.92	10.03%	0	5793.12	
639		0		夏63	6495	375	63.01	16.80%	0	4104.61	
640	农场	0	10kV-4	农11	5196	300	190.28	63.43%	0	861.10	
641		0		农12	5196	300	89.12	29.71%	0	2613.22	
642		0	10kV-5	农21	5196	300	190.28	63.43%	0	861.10	
643		0		农22	5196	300	219.81	73.27%	0	349.62	
644		0		农23	5196	300	194.59	64.86%	0	786.50	
645		0		农24	5196	300	40.61	13.54%	0	3453.52	
646		0	10kV-41	纺14	6928	400	164.66	41.17%	0	2690.47	
647		0		纺15	4347.32	251	61.46	24.49%	0	2413.39	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
648	轻纺城	0	10kV-42	纺16	6928	400	191.52	47.88%	0	2225.20	
649		0		纺17	6928	400	134.35	33.59%	0	3215.53	
650		0		纺24	6928	400	38.29	9.57%	0	4879.20	
651		0		纺25	6928	400	185.27	46.32%	0	2333.45	
652		0		纺26	6928	400	307.54	76.88%	0	215.88	
653	清河	0	10kV-4	931	4330	250	78.28	31.31%	0	2108.17	
654		0	10kV-5	932	4156.8	240	78.75	32.81%	0	1961.49	
655		0	10kV-4	933	3464	200	131.95	65.98%	0	485.77	
656		0	10kV-5	934	3464	200	148.13	74.06%	0	205.68	
657		0	10kV-4	935	3464	200	59.06	29.53%	0	1748.23	
658		0	10kV-5	936	3464	200	90.23	45.12%	0	1208.35	
659		0	10kV-4	937	4156.8	240	184.69	76.95%	0	126.64	
660		0	10kV-5	938	3464	200	158.91	79.45%	0	18.95	
661	三道桥	0	10kV-41	桥11	6373.76	368	118.48	32.19%	0	3046.99	
662		0		桥13	8140.4	470	178.95	38.07%	0	3412.99	
663		0		桥15	8140.4	470	180.70	38.45%	0	3382.54	
664		0		桥16	6373.76	368	55.72	15.14%	0	4133.89	
665		0		桥17	8140.4	470	211.64	45.03%	0	2846.70	
666		0	10kV-42	桥22	6373.76	368	108.81	29.57%	0	3214.44	
667		0		桥24	6373.76	368	194.94	52.97%	0	1722.63	
668		0	10kV-43	桥25	6373.76	368	286.35	77.81%	0	139.46	
669		0		桥26	6373.76	368	286.17	77.76%	0	142.51	
670		0		桥27	8140.4	470	179.82	38.26%	0	3397.77	
671		0		桥31	8140.4	470	186.50	39.68%	0	3282.07	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
672		0	10kV-44	桥32	6373.76	368	271.76	73.85%	0	392.16	
673		0		桥33	8140.4	470	168.05	35.75%	0	3601.75	
674		0		桥34	6373.76	368	215.86	58.66%	0	1360.33	
675	沙井子	0	10kV-4	井11	6373.76	368	198.32	53.89%	0	1664.11	
676		0		井12	6928	400	222.89	55.72%	0	1681.98	
677		0	10kV-5	井21	6373.76	368	261.50	71.06%	0	569.76	
678		0		井22	6373.76	368	168.61	45.82%	0	2178.72	
679		0		井23	6373.76	368	75.92	20.63%	0	3784.07	
680	胜利村	0	10kV-4	640	6928	400	65.98	16.49%	0	4399.68	
681		0		641	6373.76	368	344.41	93.59%	0	0.00	
682		0	10kV-5	642	6373.76	368	263.10	71.49%	0	542.12	
683		0	10kV-4	643	6373.76	368	241.20	65.54%	0	921.42	
684		0	10kV-5	644	6373.76	368	223.95	60.85%	0	1220.28	
685		0	10kV-4	645	6373.76	368	328.24	89.20%	0	0.00	
686		0	10kV-5	646	6373.76	368	103.48	28.12%	0	3306.79	
687		0	10kV-4	647	6928	400	273.10	68.28%	0	812.31	
688		0	10kV-5	648	6928	400	197.70	49.42%	0	2118.32	
689		0		652	6373.76	368	253.10	68.78%	0	715.32	
690		0		654	6373.76	368	175.20	47.61%	0	2064.63	
691	双桥站	0	10kV-4	双11	6373.76	368	8.97	2.44%	0	4943.73	
692		0	10kV-5	双27	5196	300	211.22	70.41%	0	498.50	
693	太平村	0	10kV-4	太11	6373.76	368	175.94	47.81%	0	2051.80	
694		0		太13	6373.76	368	173.62	47.18%	0	2091.98	
695		0		太14	6373.76	368	158.54	43.08%	0	2353.03	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
696		0	10kV-5	太21	6373.76	368	226.77	61.62%	0	1171.39	
697		0		太22	6373.76	368	234.42	63.70%	0	1038.92	
698		0		太23	6373.76	368	199.79	54.29%	0	1638.61	
699	塘沽	0	10kV-1	141	8140.4	470	172.92	36.79%	0	3517.43	
700		0		142	8140.4	470	276.35	58.80%	0	1725.90	
701		0		143	8140.4	470	252.71	53.77%	0	2135.35	
702		0		144	8140.4	470	131.16	27.91%	0	4240.70	
703		0		145	8140.4	470	161.04	34.26%	0	3723.19	
704		0		146	8140.4	470	159.00	33.83%	0	3758.53	
705		0		147	6373.76	368	240.71	65.41%	0	929.86	
706		0		148	8140.4	470	276.95	58.93%	0	1715.51	
707		0	10kV-2甲	151	8140.4	470	357.11	75.98%	0	327.19	
708		0		152	8140.4	470	220.31	46.88%	0	2696.50	
709		0		153	6373.76	368	269.15	73.14%	0	437.30	
710		0		154	6373.76	368	80.64	21.91%	0	3702.36	
711		0	10kV-2乙	155	8140.4	470	38.64	8.22%	0	5843.09	
712		0		156	8140.4	470	183.47	39.04%	0	3334.55	
713		0		157	8140.4	470	197.63	42.05%	0	3089.30	
714		0		158	6373.76	368	258.95	70.37%	0	613.96	
715		0	10kV-3	161	6373.76	368	261.00	70.92%	0	578.49	
716		0		162	8140.4	470	324.11	68.96%	0	898.73	
717		0		163	8140.4	470	229.91	48.92%	0	2530.23	
718		0		164	8140.4	470	247.67	52.70%	0	2222.64	
719		0		165	8140.4	470	219.47	46.70%	0	2711.05	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
720		0		166	8140.4	470	307.55	65.44%	0	1185.54	
721		0		167	8140.4	470	126.36	26.88%	0	4323.83	
722		0		168	6373.76	368	226.79	61.63%	0	1170.95	
723	腾深	0	10kV-43	深31	11604.4	670	242.91	36.25%	0	5076.37	
724		0		深32	10651.8	615	164.96	26.82%	0	5664.38	
725		0		深34	6200.56	358	129.75	36.24%	0	2713.21	
726		0	10kV-44	深41	4416.6	255	12.23	4.80%	0	3321.47	
727		0		深45	9266.2	535	133.20	24.90%	0	5105.97	
728		0		深46	9006.4	520	141.60	27.23%	0	4752.64	
729		0	10kV-45	深51	11604.4	670	249.54	37.24%	0	4961.54	
730		0		深52	10651.8	615	151.26	24.60%	0	5901.60	
731		0		深54	9266.2	535	211.29	39.49%	0	3753.35	
732		0	10kV-46	深61	4416.6	255	15.46	6.06%	0	3265.50	
733		0		深64	7309.04	422	3.97	0.94%	0	5778.52	
734		0		深66	9006.4	520	176.00	33.85%	0	4156.80	
735	体育场		10kV-41	体11	7828.64	452	174.07	38.51%	0	3248.09	
736				体12	9093	525	37.63	7.17%	0	6622.72	
737				体13	9093	525	372.75	71.00%	0	818.42	
738				体14	7828.64	452	5.80	1.28%	0	6162.42	
739			10kV-44	体31	7828.64	452	128.18	28.36%	0	4042.90	
740				体32	9093	525	389.28	74.15%	0	532.16	
741				体33	9093	525	171.43	32.65%	0	4305.25	
742				体34	7828.64	452	5.45	1.21%	0	6168.50	
743		0		填11	6928	400	84.90	21.23%	0	4071.90	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
744	填海站	0	10kV-41	填12	9266.2	535	39.64	7.41%	0	6726.41	
745		0		填13	7499.56	433	131.60	30.39%	0	3720.30	
746		0		填17	7153.16	413	0.15	0.04%	0	5720.00	
747		0		填18	7724.72	446	44.44	9.96%	0	5410.02	
748		0	10kV-42	填21	7499.56	433	55.17	12.74%	0	5044.17	
749		0		填22	9266.2	535	12.31	2.30%	0	7199.84	
750		0		填23	7499.56	433	113.85	26.29%	0	4027.80	
751		0		填27	7724.72	446	28.30	6.35%	0	5689.60	
752		0		填28	7724.72	446	21.74	4.87%	0	5803.27	
753		0		填28	7724.72	446	21.74	4.87%	0	5803.27	
753	同进	0	10kV-41	同11	8278.96	478	106.80	22.34%	0	4773.43	
754		0		同12	8278.96	478	249.90	52.28%	0	2294.93	
755		0		同13	9093	525	56.04	10.67%	0	6303.75	
756		0		同14	8278.96	478	9.61	2.01%	0	6456.74	
757		0		同15	6495	375	171.07	45.62%	0	2233.00	
758		0	10kV-42	同31	8278.96	478	223.26	46.71%	0	2756.36	
759		0		同32	8278.96	478	193.97	40.58%	0	3263.61	
760		0		同33	9093	525	148.73	28.33%	0	4698.33	
761		0		同34	8278.96	478	51.23	10.72%	0	5735.90	
762		0		同35	6495	375	237.04	63.21%	0	1090.55	
763		0		同36	8227	475	180.66	38.03%	0	3452.57	
764		0		同36	8227	475	180.66	38.03%	0	3452.57	
764		0	10kV-41	团11	6373.76	368	179.82	48.87%	0	1984.46	
765		0		团12	6373.76	368	272.99	74.18%	0	370.86	
766		0		团14	6373.76	368	52.91	14.38%	0	4182.61	
767		0		团15	8140.4	470	73.65	15.67%	0	5236.67	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
768	团结路	0		团16	6373.76	368	1.06	0.29%	0	5080.74	
769		0		团17	8278.96	478	241.70	50.56%	0	2436.94	
770		0		团18	8140.4	470	174.90	37.21%	0	3483.02	
771		0		团21	6373.76	368	162.42	44.14%	0	2285.86	
772		0	10kV-42	团22	8140.4	470	253.13	53.86%	0	2128.20	
773		0		团23	6373.76	368	0.53	0.14%	0	5089.88	
774		0		团24	8278.96	478	150.65	31.52%	0	4014.00	
775		0		团25	8140.4	470	87.01	18.51%	0	5005.27	
776		0	10kV-43	团26	6373.76	368	105.29	28.61%	0	3275.33	
777		0		团27	6373.76	368	111.27	30.24%	0	3171.81	
778		0		团28	6373.76	368	91.58	24.89%	0	3512.81	
779	王庄镇	0	10kV-4	王11	6373.76	368	46.33	12.59%	0	4296.61	
780		0		王12	6373.76	368	59.45	16.15%	0	4069.37	
781		0		王14	6373.76	368	91.11	24.76%	0	3520.95	
782		0		王15	6928	400	82.33	20.58%	0	4116.48	
783		0	10kV-5	王21	6373.76	368	84.57	22.98%	0	3634.29	
784		0		王22	6235.2	360	119.78	33.27%	0	2913.50	
785		0		王24	6373.76	368	125.29	34.05%	0	2929.02	
786		0		王25	6373.76	368	214.06	58.17%	0	1391.42	
787		0		王26	6373.76	368	85.22	23.16%	0	3622.93	
788		0	10kV-41	西11	6928	400	97.85	24.46%	0	3847.60	
789		0		西12	6928	400	187.27	46.82%	0	2298.95	
790		0		西13	6928	400	80.74	20.19%	0	4143.95	
791		0		西14	6928	400	182.34	45.59%	0	2384.20	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
792	西沽	0		西15	6928	400	88.01	22.00%	0	4018.10	
793		0		西16	6928	400	238.13	59.53%	0	1418.08	
794		0	10kV-42	西21	6928	400	113.32	28.33%	0	3579.70	
795		0		西22	6928	400	31.76	7.94%	0	4992.35	
796		0		西23	6373.76	368	255.47	69.42%	0	674.28	
797		0		西24	6928	400	251.72	62.93%	0	1182.63	
798		0		西25	6928	400	116.72	29.18%	0	3520.83	
799		0		西26	6928	400	126.68	31.67%	0	3348.30	
800		0	10kV-43	西31	6928	400	78.75	19.69%	0	4178.45	
801		0		西32	6928	400	242.81	60.70%	0	1336.90	
802		0		西33	6928	400	122.70	30.67%	0	3417.32	
803		0		西34	6928	400	215.63	53.91%	0	1807.78	
804		0		西35	6928	400	237.66	59.41%	0	1426.20	
805		0		西36	6928	400	47.70	11.92%	0	4716.32	
806		0	10kV-44	西41	6928	400	127.50	31.88%	0	3334.10	
807		0		西42	6928	400	53.79	13.45%	0	4610.77	
808		0		西43	6928	400	41.72	10.43%	0	4819.83	
809		0		西44	6928	400	127.62	31.90%	0	3332.07	
810	新北路	0	10kV-5	582	6928	400	183.98	46.00%	0	2355.80	
811		0		583	6373.76	368	86.72	23.56%	0	3597.03	
812		0		584	6373.76	368	181.41	49.30%	0	1957.06	
813		0		585	6373.76	368	277.50	75.41%	0	292.71	
814		0		586	6373.76	368	164.53	44.71%	0	2249.33	
815		0		588	6373.76	368	21.56	5.86%	0	4725.55	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
816		0	10kV-4	589	6373.76	368	267.66	72.73%	0	463.21	
817		0		590	6373.76	368	240.47	65.34%	0	934.08	
818		0		591	6928	400	52.03	13.01%	0	4641.22	
819		0		592	6373.76	368	254.69	69.21%	0	687.81	
820		0		593	6373.76	368	197.58	53.69%	0	1676.96	
821		0									
822	新村	0	10kV-41	村11	8140.4	470	172.22	36.64%	0	3529.40	
823		0		村13	8140.4	470	297.06	63.20%	0	1367.24	
824		0		村14	8140.4	470	203.08	43.21%	0	2995.04	
825		0		村15	8140.4	470	116.06	24.69%	0	4502.09	
826		0		村16	8140.4	470	36.26	7.72%	0	5884.23	
827		0		村17	6373.76	368	291.35	79.17%	0	52.86	
828		0	10kV-42	村21	8140.4	470	228.06	48.52%	0	2562.32	
829		0		村22	8140.4	470	118.42	25.19%	0	4461.35	
830		0	10kV-43	村25	8140.4	470	132.43	28.18%	0	4218.60	
831		0		村26	8140.4	470	163.20	34.72%	0	3685.70	
832		0		村27	8140.4	470	73.45	15.63%	0	5240.13	
833		0	10kV-44	村28	8140.4	470	138.95	29.56%	0	4105.74	
834		0		村31	8140.4	470	96.78	20.59%	0	4836.09	
835		0		村32	8140.4	470	44.60	9.49%	0	5739.78	
836		0		村33	6373.76	368	140.11	38.07%	0	2672.27	
837		0		村34	8140.4	470	311.86	66.35%	0	1110.97	
838		0		村35	8140.4	470	210.30	44.74%	0	2869.92	
839		0		村36	8140.4	470	120.92	25.73%	0	4417.92	
				村38	8140.4	470	9.08	1.93%	0	6354.99	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷 日后需预留容量（kVA）	可开放容量（kVA）	备注
840	新港	0	10kV-41	港11	8140.4	470	214.63	45.67%	0	2794.95	
841		0		港12	8140.4	470	53.97	11.48%	0	5577.65	
842		0		港13	8140.4	470	89.65	19.07%	0	4959.62	
843		0		港14	8140.4	470	169.63	36.09%	0	3574.35	
844		0		港17	8140.4	470	101.60	21.62%	0	4752.57	
845		0		港18	8140.4	470	136.06	28.95%	0	4155.85	
846		0	10kV-42	港21	8140.4	470	272.64	58.01%	0	1790.25	
847		0		港24	8140.4	470	219.73	46.75%	0	2706.65	
848		0	10kV-43	港25	8140.4	470	323.09	68.74%	0	916.47	
849		0		港26	8140.4	470	177.72	37.81%	0	3434.30	
850		0		港27	8140.4	470	305.51	65.00%	0	1220.92	
851		0		港28	8140.4	470	193.36	41.14%	0	3163.34	
852	新河	0	10kV-41	河11	6373.76	368	193.89	52.69%	0	1740.89	
853		0		河12	8140.4	470	86.66	18.44%	0	5011.37	
854		0		河13	6373.76	368	171.74	46.67%	0	2124.51	
855		0		河14	6373.76	368	176.48	47.96%	0	2042.31	
856		0		河15	8140.4	470	209.71	44.62%	0	2880.19	
857		0		河16	8140.4	470	35.68	7.59%	0	5894.27	
858		0		河17	8140.4	470	258.93	55.09%	0	2027.72	
859		0	10kV-42	河21	7309.04	422	223.95	53.07%	0	1968.50	
860		0		河23	8140.4	470	59.41	12.64%	0	5483.27	
861		0		河24	8140.4	470	248.56	52.88%	0	2207.35	
862		0	10kV-43	河25	6373.76	368	191.78	52.11%	0	1777.43	
863		0		河26	8140.4	470	108.81	23.15%	0	4627.75	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
864		0	10kV-44	河27	6373.76	368	193.01	52.45%	0	1756.11	
865		0		河31	8140.4	470	260.68	55.46%	0	1997.27	
866		0		河32	8140.4	470	0.00	0.00%	0	6512.32	
867		0		河33	8140.4	470	271.23	57.71%	0	1814.62	
868		0		河34	7309.04	422	18.11	4.29%	0	5533.65	
869		0		河36	8140.4	470	178.24	37.92%	0	3425.17	
870		0		河37	8140.4	470	117.95	25.10%	0	4469.44	
871	新民路	0		461	9266.2	535	110.42	20.64%	0	5500.52	
872		0		462	9266.2	535	234.85	43.90%	0	3345.43	
873		0	10kV-41	471	6373.76	368	192.48	52.30%	0	1765.25	
874		0		472	6928	400	44.80	11.20%	0	4766.46	
875		0		473	9266.2	535	263.96	49.34%	0	2841.17	
876		0		474	9266.2	535	89.87	16.80%	0	5856.41	
877		0	10kV-42	481	8140.4	470	220.64	46.94%	0	2690.84	
878		0		482	6373.76	368	197.76	53.74%	0	1673.80	
879		0		483	6373.76	368	238.72	64.87%	0	964.38	
880		0		484	6373.76	368	239.20	65.00%	0	956.06	
881		0	10kV-43	485	8140.4	470	301.92	64.24%	0	1283.07	
882		0		486	8140.4	470	221.92	47.22%	0	2668.67	
883		0		487	6373.76	368	201.60	54.78%	0	1607.30	
884		0		488	7326.36	423	261.60	61.84%	0	1330.18	
885		0		491	6373.76	368	305.12	82.91%	0	0.00	
886		0		492	10392	600	148.48	24.75%	0	5741.93	
887		0		493	6373.76	368	259.50	70.52%	0	604.47	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
888		0	10kV-44	494	9543.32	551	22.56	4.09%	0	7243.92	
889		0		495	8140.4	470	300.96	64.03%	0	1299.69	
890		0		496	8140.4	470	195.68	41.63%	0	3123.14	
891		0		497	8140.4	470	198.88	42.31%	0	3067.72	
892		0		498	7326.36	423	264.32	62.49%	0	1283.07	
893		0	10kV-41	圣13	8781.24	507	379.50	74.85%	0	452.03	
894	新圣路	0	10kV-42	圣21	6373.76	368	189.64	51.53%	0	1814.51	
895		0		圣23	6633.56	383	163.44	42.67%	0	2476.03	
896		0		圣24	8140.4	470	251.02	53.41%	0	2164.72	
897		0		圣25	6373.76	368	293.45	79.74%	0	16.42	
898		0	10kV-43	圣26	6633.56	383	105.71	27.60%	0	3476.04	
899		0		圣27	8729.28	504	276.15	54.79%	0	2200.52	
900		0		圣28	6633.56	383	67.66	17.67%	0	4134.99	
901		0		圣31	6373.76	368	84.68	23.01%	0	3632.39	
902		0	10kV-44	圣32	8140.4	470	170.88	36.36%	0	3552.75	
903		0		圣33	8140.4	470	286.82	61.03%	0	1544.61	
904		0		圣34	9006.4	520	303.30	58.33%	0	1952.00	
905		0		圣35	8781.24	507	165.47	32.64%	0	4159.07	
906		0		圣36	8140.4	470	146.86	31.25%	0	3968.69	
907		0		圣37	9006.4	520	186.26	35.82%	0	3979.18	
908		0		圣38	6633.56	383	209.14	54.61%	0	1684.53	
909		0	10kV-41	兴11	6928	400	265.43	66.36%	0	945.15	
910		0		兴12	6373.76	368	165.47	44.96%	0	2233.08	
911		0		兴13	6928	400	190.08	47.52%	0	2250.25	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
912	兴塘	0		兴14	6928	400	298.05	74.51%	0	380.23	
913		0		兴15	6928	400	4.92	1.23%	0	5457.15	
914		0	10kV-42	兴21	6928	400	56.37	14.09%	0	4566.12	
915		0		兴22	6928	400	249.84	62.46%	0	1215.10	
916		0		兴23	6928	400	207.77	51.94%	0	1943.77	
917		0		兴24	6928	400	289.34	72.33%	0	531.10	
918		0		兴25	6928	400	20.39	5.10%	0	5189.23	
919		0	10kV-43	兴32	6928	400	245.39	61.35%	0	1292.23	
920		0		兴33	6928	400	16.29	4.07%	0	5260.27	
921		0		兴34	6928	400	245.86	61.46%	0	1284.12	
922		0		兴35	6373.76	368	95.74	26.02%	0	3440.76	
923		0		兴36	6928	400	281.13	70.28%	0	673.18	
924		0	10kV-44	兴41	6928	400	4.92	1.23%	0	5457.15	
925		0		兴42	6928	400	87.66	21.91%	0	4024.20	
926		0		兴43	6928	400	250.31	62.58%	0	1207.00	
927		0		兴44	6928	400	180.35	45.09%	0	2418.70	
928		0		兴45	6373.76	368	169.45	46.05%	0	2164.08	
929		0		兴46	6928	400	99.14	24.79%	0	3825.28	
930	杨柳庄	0	10kV-4	杨11	6928	400	72.23	18.06%	0	4291.36	
931		0		杨12	6373.76	368	231.02	62.78%	0	1097.69	
932		0		杨13	6373.76	368	64.22	17.45%	0	3986.70	
933		0		杨14	6373.76	368	134.00	36.41%	0	2778.11	
934		0		杨15	6373.76	368	92.67	25.18%	0	3493.93	
935		0		杨21	6928	400	192.53	48.13%	0	2207.87	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
936		0	10kV-5	杨22	6928	400	70.47	17.62%	0	4321.86	
937		0		杨23	6373.76	368	256.64	69.74%	0	653.97	
938		0		杨24	6373.76	368	125.71	34.16%	0	2921.64	
939		0		杨25	6373.76	368	127.27	34.58%	0	2894.76	
940	营城	0	10kV-42	营21	7967.2	460	277.98	60.43%	0	1559.18	
941		0		营22	7967.2	460	208.88	45.41%	0	2755.98	
942		0		营23	7967.2	460	298.20	64.83%	0	1208.97	
943		0		营24	6373.76	368	124.66	33.87%	0	2939.91	
944		0	10kV-43	营25	6373.76	368	272.91	74.16%	0	372.17	
945		0		营26	6754.8	390	240.88	61.76%	0	1231.82	
946		0		营27	7794	450	53.45	11.88%	0	5309.45	
947		0		营28	9266.2	535	0.00	0.00%	0	7412.96	
948		0	10kV-44	营31	9266.2	535	238.42	44.56%	0	3283.58	
949		0		营32	6373.76	368	116.75	31.72%	0	3076.95	
950		0		营33	6373.76	368	273.85	74.41%	0	356.00	
951		0		营34	7967.2	460	74.73	16.24%	0	5079.52	
952		0		营36	6754.8	390	245.98	63.07%	0	1143.50	
953		0		营37	7794	450	10.90	2.42%	0	6046.39	
954		0		营38	9006.4	520	0.00	0.00%	0	7205.12	
955		0	10kV-41	永13	7499.56	433	303.13	70.01%	0	749.40	
956	永兴路	0		永14	7447.6	430	240.49	55.93%	0	1792.76	
957		0		永22	7759.36	448	355.06	79.25%	0	57.92	
958		0	10kV-42	永33	7499.56	433	319.06	73.68%	0	473.60	
959		0		乐11	10392	600	6.16	1.03%	0	8206.87	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
960	游乐港	0	10kV-41	乐12	6928	400	296.71	74.18%	0	403.45	
961		0		乐13	6928	400	58.94	14.74%	0	4521.56	
962		0		乐14	6928	400	263.85	65.96%	0	972.52	
963		0		乐15	6928	400	260.75	65.19%	0	1026.30	
964		0		乐16	6928	400	142.25	35.56%	0	3078.63	
965		0	10kV-42	乐21	10392	600	6.53	1.09%	0	8200.59	
966		0		乐22	6928	400	273.87	68.47%	0	799.02	
967		0		乐23	6928	400	225.75	56.44%	0	1632.46	
968		0		乐24	6928	400	226.36	56.59%	0	1621.83	
969		0		乐25	6928	400	99.41	24.85%	0	3820.55	
970		0		乐26	6928	400	48.53	12.13%	0	4701.86	
971		0	10kV-43	乐31	6928	400	262.75	65.69%	0	991.57	
972	友谊路	0	10kV-4	561	6928	400	93.57	23.39%	0	3921.82	
973		0		562	6373.76	368	191.91	52.15%	0	1775.11	
974		0		563	6373.76	368	271.52	73.78%	0	396.35	
975		0		564	6373.76	368	190.76	51.84%	0	1795.13	
976		0	10kV-5	565	6373.76	368	199.39	54.18%	0	1645.59	
977		0		566	6928	400	182.46	45.61%	0	2382.24	
978		0		567	6928	400	196.15	49.04%	0	2145.17	
979		0		568	6928	400	197.22	49.30%	0	2126.64	
980		0	10kV-41	于11	6928	400	160.14	40.03%	0	2768.83	
981		0		于12	6928	400	131.76	32.94%	0	3260.26	
982		0		于13	6928	400	149.66	37.42%	0	2950.24	
983		0		于14	6928	400	264.29	66.07%	0	964.95	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
984	于家堡	0	10kV-42	于21	6928	400	45.51	11.38%	0	4754.11	
985		0		于22	6928	400	33.38	8.35%	0	4964.19	
986		0		于23	6928	400	41.00	10.25%	0	4832.26	
987		0		于24	6928	400	102.58	25.65%	0	3765.66	
988		0		于25	6928	400	57.58	14.40%	0	4545.06	
989		0		于26	6928	400	53.12	13.28%	0	4622.45	
990		0	10kV-43	于31	6928	400	37.95	9.49%	0	4885.04	
991		0		于32	6928	400	49.73	12.43%	0	4681.06	
992		0		于33	6928	400	49.73	12.43%	0	4681.06	
993		0		于34	6928	400	58.37	14.59%	0	4531.36	
994		0		于35	6928	400	17.42	4.35%	0	5240.74	
995		0	10kV-44	于41	6928	400	125.77	31.44%	0	3364.05	
996		0		于42	6928	400	290.30	72.58%	0	514.35	
997		0		于43	6928	400	60.03	15.01%	0	4502.70	
998		0		于44	6928	400	60.03	15.01%	0	4502.70	
999	渔港	0	10kV-41	鲤11	8140.4	470	116.87	24.87%	0	4488.08	
1000		0		鲤12	6373.76	368	179.17	48.69%	0	1995.87	
1001		0		鲤13	8140.4	470	188.75	40.16%	0	3243.26	
1002		0		鲤14	7326.36	423	137.75	32.56%	0	3475.31	
1003		0		鲤15	7880.6	455	193.80	42.59%	0	2947.88	
1004		0		鲤16	7326.36	423	60.12	14.21%	0	4819.86	
1005		0		鲤17	7326.36	423	47.77	11.29%	0	5033.73	
1006		0	10kV-42	鲤21	8140.4	470	231.11	49.17%	0	2509.53	
1007		0		鲤22	6373.76	368	145.55	39.55%	0	2578.13	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1008		0	10kV-44	鲤31	8140.4	470	117.00	24.89%	0	4485.81	
1009		0		鲤32	6373.76	368	100.79	27.39%	0	3353.34	
1010		0		鲤33	7326.36	423	39.84	9.42%	0	5171.13	
1011		0		鲤36	7326.36	423	36.37	8.60%	0	5231.25	
1012		0		鲤37	7326.36	423	36.37	8.60%	0	5231.25	
1013		0									
1014	玉辰	0	10kV-42	辰31	9266.2	535	261.78	48.93%	0	2878.88	
1015		0		辰32	9266.2	535	335.27	62.67%	0	1606.08	
1016		0		辰33	9266.2	535	420.89	78.67%	0	123.13	
1017		0		辰34	7361	425	30.83	7.25%	0	5354.79	
1018		0		辰35	7915.24	457	130.45	28.55%	0	4072.78	
1019		0		辰36	9006.4	520	119.88	23.05%	0	5128.89	
1020		0	10kV-43	辰41	9266.2	535	2.67	0.50%	0	7366.78	
1021		0		辰42	9266.2	535	2.72	0.51%	0	7365.94	
1022		0		辰44	7915.24	457	124.71	27.29%	0	4172.16	
1023		0		辰46	9924.36	573	128.93	22.50%	0	5706.39	
1024		0	10kV-44	辰51	9266.2	535	371.45	69.43%	0	979.43	
1025		0		辰52	9266.2	535	329.63	61.61%	0	1703.77	
1026		0		辰53	9266.2	535	267.70	50.04%	0	2776.36	
1027		0		辰54	7361	425	47.64	11.21%	0	5063.73	
1028		0		辰55	7915.24	457	107.37	23.49%	0	4472.54	
1029		0		辰56	9006.4	520	180.90	34.79%	0	4072.02	
1030		0		辰63	9266.2	535	2.73	0.51%	0	7365.68	
1031		0		辰64	7915.24	457	121.67	26.62%	0	4224.94	
		0		辰66	9924.36	573	46.86	8.18%	0	7127.84	

序号	变电站名称	主变最大负荷 日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷 日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1032	漳州道	0	10kV-41	漳11	8140.4	470	216.56	46.08%	0	2761.47	
1033		0		漳12	8140.4	470	207.42	44.13%	0	2919.77	
1034		0		漳13	8140.4	470	228.87	48.70%	0	2548.22	
1035		0		漳14	8140.4	470	216.39	46.04%	0	2764.50	
1036		0		漳15	8140.4	470	173.85	36.99%	0	3501.27	
1037		0		漳16	8140.4	470	239.24	50.90%	0	2368.72	
1038		0		漳17	8140.4	470	202.15	43.01%	0	3011.12	
1039		0		漳18	6928	400	187.56	46.89%	0	2293.88	
1040		0	10kV-43	漳21	8140.4	470	253.65	53.97%	0	2119.07	
1041		0		漳22	8140.4	470	158.38	33.70%	0	3769.20	
1042		0		漳23	8140.4	470	122.17	25.99%	0	4396.37	
1043		0		漳24	8140.4	470	201.97	42.97%	0	3014.15	
1044		0		漳25	8140.4	470	185.80	39.53%	0	3294.25	
1045		0		漳26	6928	400	180.53	45.13%	0	2415.67	
1046		0		漳27	8140.4	470	106.52	22.66%	0	4667.34	
1047		0		漳28	6529.64	377	222.54	59.03%	0	1369.34	
1048	中塘	0	10kV-41	中11	6373.76	368	178.42	48.48%	0	2008.81	
1049		0		中15	6373.76	368	217.09	58.99%	0	1339.01	
1050		0		中17	6373.76	368	217.97	59.23%	0	1323.78	
1051		0	10kV-42	中21	6373.76	368	182.52	49.60%	0	1937.76	
1052		0		中22	6373.76	368	289.16	78.58%	0	90.76	
1053		0	10kV-43	中24	7880.6	455	229.98	50.55%	0	2321.23	
1054		0		中26	6373.76	368	251.00	68.21%	0	751.76	
1055		0		中31	7880.6	455	136.52	30.01%	0	3939.90	

序号	变电站名称	主变最大负荷 日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷 日后需预留容量（kVA）	可开放容量（kVA）	备注
1056		0	10kV-44	中32	6373.76	368	234.08	63.61%	0	1044.71	
1057		0		中34	6373.76	368	184.28	50.08%	0	1907.33	
1058		0		中36	6373.76	368	292.97	79.61%	0	24.78	
1059	珠江道	0	10kV-41	珠11	6928	400	68.39	17.10%	0	4357.82	
1060		0		珠12	6928	400	86.92	21.73%	0	4036.88	
1061		0		珠13	6928	400	144.58	36.15%	0	3038.27	
1062		0		珠14	7620.8	440	329.15	74.81%	0	395.83	
1063		0		珠15	9266.2	535	275.79	51.55%	0	2636.35	
1064		0	10kV-42	珠21	6928	400	205.33	51.33%	0	1986.14	
1065		0		珠22	6928	400	112.15	28.04%	0	3600.00	
1066		0		珠23	6928	400	59.78	14.95%	0	4507.01	
1067		0		珠24	9006.4	520	227.11	43.67%	0	3271.59	
1068		0	10kV-45	珠51	6928	400	98.61	24.65%	0	3834.42	
1069		0		珠52	6928	400	146.66	36.67%	0	3002.25	
1070		0		珠53	6928	400	114.38	28.59%	0	3561.43	
1071		0		珠54	9006.4	520	214.41	41.23%	0	3491.56	
1072		0	10kV-46	珠61	6928	400	119.87	29.97%	0	3466.29	
1073		0		珠62	6928	400	131.03	32.76%	0	3272.96	
1074		0		珠63	6928	400	39.86	9.96%	0	4852.06	
1075		0		珠64	9266.2	535	285.98	53.45%	0	2459.77	