

宝坻供电公司10千伏配电线路可开放容量信息表（2025年第三季度）

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
1	宝坻. 八门城站	0	10kV-4	小甸八13	7274.4	400	132.97	33.24%	0	3401	
2		0		西十村八14	7274.4	400	198.41	49.60%	0	2211	
3		0		八门城八15	6546.96	360	213.10	59.20%	0	1362	
4		0	10kV-5	箭杆河八21	6546.96	360	128.87	35.80%	0	2894	
5		0		袁罗八22	7274.4	400	10.24	2.56%	0	5633	
6		0		康庄八23	7274.4	400	159.24	39.81%	0	2924	
7	宝坻. 北申庄站	0	10kV-41	八间房申11	9147.558	503	87.52	17.40%	0	5726	
8		0		南业东申12	9147.558	503	177.22	35.23%	0	4095	
9		0		北辛庄申13	9147.558	503	179.30	35.65%	0	4057	
10		0		张兰庄申14	9147.558	503	50.82	10.10%	0	6394	
11		0		潭东申15	9147.558	503	74.48	14.81%	0	5963	
12		0		艾家口申16	9147.558	503	0.00	0.00%	0	7318	
13		0		李家口申21	9147.558	503	20.40	4.06%	0	6947	
14		0		马厂申22	9147.558	503	14.22	2.83%	0	7059	
15		0		西庄沽申23	9147.558	503	71.21	14.16%	0	6023	
16		0	10kV-42	小陈申31	9147.558	503	205.98	40.95%	0	3572	
17		0		南庄申32	9147.558	503	60.19	11.97%	0	6223	
18		0		老艾口申33	9147.558	503	35.34	7.03%	0	6675	
19		0		苗家庄申34	9147.558	503	72.25	14.36%	0	6004	
20		0	10kV-43	埝北村申41	9147.558	503	243.49	48.41%	0	2890	
21		0		车辋村申42	9147.558	503	156.90	31.19%	0	4465	
22		0		潭西申43	9147.558	503	0.00	0.00%	0	7318	
23		0		小苑庄申44	9147.558	503	33.22	6.60%	0	6714	
24		0		大赵庄申45	9147.558	503	80.11	15.93%	0	5861	
25		0	10kV-44	张家庄申51	9147.558	503	82.74	16.45%	0	5813	
26		0		张松申52	9147.558	503	241.90	48.09%	0	2919	
27		0		工部申53	9147.558	503	180.46	35.88%	0	4036	
28		0		佟家庄申54	9147.558	503	67.15	13.35%	0	6097	
29		0		窑上村申55	9147.558	503	76.32	15.17%	0	5930	
30		0		伍麻庄申56	9147.558	503	54.59	10.85%	0	6325	
31		0		边家庄申61	9147.558	503	45.84	9.11%	0	6484	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
32	宝坻. 菜园站	0	10kV-4	北芮庄申62	9147.558	503	110.59	21.99%	0	5307	
33		0		韩庄园13	6546.96	360	66.27	18.41%	0	4032	
34		0		高四台园14	9147.558	503	283.36	56.33%	0	2165	
35		0		区东园15	6546.96	360	277.56	77.10%	0	190	
36		0		庞家湾园16	6546.96	360	113.56	31.54%	0	3172	
37		0	10kV-5	林场园23	9147.558	503	143.09	28.45%	0	4716	
38		0		吴家牌园24	9147.558	503	287.58	57.17%	0	2088	
39		0		华尖园25	9147.558	503	182.29	36.24%	0	4003	
40		0		区西园26	9147.558	503	178.60	35.51%	0	4070	
41	宝坻. 城东站	0	10kV-41	钰华东11	8547.42	470	203.25	43.25%	0	3142	
42		0		区委二东12	8547.42	470	277.36	59.01%	0	1794	
43		0		顺驰东13	8547.42	470	291.96	62.12%	0	1528	
44		0		泰富东14	8547.42	470	192.79	41.02%	0	3332	
45		0		金玉一东15	8547.42	470	112.44	23.92%	0	4793	
46		0		怡锦一东16	9729.51	535	14.33	2.68%	0	7523	
47		0		玉六园东17	9729.51	535	119.21	22.28%	0	5616	
48		0	10kV-42	双站路东23	9729.51	535	56.88	10.63%	0	6749	
49		0		怡锦二东27	9729.51	535	0.62	0.12%	0	7772	
50		0	10kV-44	龙熙东31	6546.96	360	247.74	68.82%	0	732	
51		0		玺悦II东32	9729.51	535	2.37	0.44%	0	7740	
52		0		金玉二东33	8547.42	470	63.12	13.43%	0	5690	
53		0		玺悦I东34	9729.51	535	4.04	0.76%	0	7710	
54		0		苑北东35	8547.42	470	101.27	21.55%	0	4996	
55		0		广电二东36	8547.42	470	312.09	66.40%	0	1162	
56		0		祥和东37	8547.42	470	251.96	53.61%	0	2256	
57	宝坻. 城关站	0	10kV-4	宝鑫I111	7274.4	400	269.97	67.49%	0	910	
58		0	10kV-4	城关乡112	6546.96	360	279.44	77.62%	0	156	
59		0	10kV-4	海滨115	6546.96	360	78.31	21.75%	0	3813	
60		0	10kV-5	宝鑫II122	7274.4	400	70.54	17.63%	0	4537	
61		0	10kV-5	城关镇II124	6546.96	360	265.00	73.61%	0	418	
62		0	10kV-5	城关镇I125	6546.96	360	281.61	78.22%	0	116	
63		0	10kV-4	工贸城13	6546.96	360	275.77	76.60%	0	222	
64		0	10kV-4	瑞祥城14	7274.4	400	236.37	59.09%	0	1521	
65		0	10kV-5	霍各庄城21	6546.96	360	0.00	0.00%	0	5238	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
66	宝坻.城南站	0	10kV-5	铸件城23	6546.96	360	272.70	75.75%	0	278	
67		0	10kV-41	帝景南11	8547.42	470	191.57	40.76%	0	3354	
68		0		潮阳花园南12	8547.42	470	90.07	19.16%	0	5200	
69		0		嘉兴园南13	8547.42	470	196.67	41.84%	0	3261	
70		0		金和园南14	8547.42	470	138.24	29.41%	0	4324	
71		0		宝境南15	8547.42	470	127.81	27.19%	0	4514	
72		0		万兆南16	8547.42	470	284.88	60.61%	0	1657	
73		0		吾悦一南17	8547.42	470	70.15	14.93%	0	5562	
74		0		原筑一南18	8547.42	470	147.01	31.28%	0	4164	
75		0	10kV-42 10kV-43	体育馆南23	8547.42	470	167.76	35.69%	0	3787	
76		0		观潮园南24	8547.42	470	85.68	18.23%	0	5280	
77		0		润和南25	8547.42	470	113.35	24.12%	0	4777	
78		0		泰达南26	8547.42	470	119.62	25.45%	0	4663	
79		0		北岸南27	8547.42	470	108.23	23.03%	0	4870	
80		0		馨和南28	8547.42	470	286.79	61.02%	0	1622	
81		0		翰墨园南29	6546.96	360	49.93	13.87%	0	4330	
82		0		吾悦二南30	8547.42	470	142.56	30.33%	0	4245	
83		0		原筑二南31	8547.42	470	143.17	30.46%	0	4234	
84	宝坻.城西站	0	10kV-4	三岔口116	9147.558	503	96.96	19.28%	0	5555	
85		0		天宝甲西13	6546.96	360	284.56	79.04%	0	63	
86		0		高家庄西14	9147.558	503	49.92	9.92%	0	6410	
87		0		宝中道西15	9729.51	535	147.04	27.48%	0	5110	
88		0		中关村一西17	9729.51	535	93.04	17.39%	0	6092	
89		0	10kV-5	四中西23	8547.42	470	290.40	61.79%	0	1557	
90		0		中关村南西24	9729.51	535	69.68	13.02%	0	6516	
91		0		牛道口东西25	6546.96	360	256.32	71.20%	0	576	
92		0		星源西26	9147.558	503	376.72	74.89%	0	467	
93		0		天宝乙西27	6546.96	360	0.72	0.20%	0	5224	
94		0	10kV-41	小刘坡白11	6546.96	360	91.94	25.54%	0	3566	
95		0		晋铝白12	9147.558	503	326.41	64.89%	0	1382	
96		0		无纺白13	8547.42	470	265.02	56.39%	0	2018	
97		0		小杨庄白14	8547.42	470	272.03	57.88%	0	1891	
98		0		贝特瑞白15	9147.558	503	105.14	20.90%	0	5406	
99		0		盟固利白16	9729.51	535	2.79	0.52%	0	7733	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
100	宝坻. 大白庄站	0		孙校白17	9147.558	503	199.25	39.61%	0	3694	
101		0		园二路白18	9147.558	503	348.87	69.36%	0	974	
102		0	10kV-42	首高白21	9147.558	503	401.41	79.80%	0	18	
103		0		九贸白22	9147.558	503	174.64	34.72%	0	4142	
104		0		嘉诺缘白23	8547.42	470	134.45	28.61%	0	4393	
105		0		八道沽白24	6546.96	360	131.40	36.50%	0	2848	
106		0		勇猛白25	8547.42	470	112.61	23.96%	0	4790	
107		0		天普白26	9729.51	535	17.73	3.31%	0	7461	
108		0		东皋一白27	9729.51	535	392.51	73.37%	0	645	
109		0		彭元白28	9147.558	503	127.38	25.32%	0	5002	
110	宝坻. 大口屯站	0	10kV-4	程马庄屯11	9147.558	503	154.16	30.65%	0	4514	
111		0		大薄甸屯12	9147.558	503	0.00	0.00%	0	7318	
112		0		大五登屯13	6546.96	360	162.77	45.21%	0	2277	
113		0		大口屯镇屯14	6546.96	360	223.95	62.21%	0	1165	
114		0		屯开发屯15	9147.558	503	108.46	21.56%	0	5346	
115		0	10kV-5	天骄屯21	9147.558	503	283.18	56.30%	0	2168	
116		0		大口屯东屯22	9147.558	503	140.10	27.85%	0	4770	
117		0		尹家铺屯23	6546.96	360	159.61	44.34%	0	2335	
118		0		镇东屯24	9147.558	503	0.00	0.00%	0	7318	
119	宝坻. 大钟庄站	0	10kV-4	新安镇214	7274.4	400	129.15	32.29%	0	3471	
120		0		盛松I钟11	7274.4	400	172.53	43.13%	0	2682	
121		0		宝芝钟12	7274.4	400	282.42	70.61%	0	683	
122		0		何饥钟13	7274.4	400	190.12	47.53%	0	2362	
123		0	10kV-5	盛松II钟21	7274.4	400	53.70	13.42%	0	4843	
124		0		工业园区钟22	6546.96	360	163.92	45.53%	0	2257	
125		0		冯庄水钟23	7274.4	400	317.43	79.36%	0	47	
126		0		钟芝钟24	7274.4	400	36.40	9.10%	0	5158	
127	宝坻. 东老口站	0	10kV-4	老鸦口老12	7274.4	400	59.45	14.86%	0	4738	
128		0		精密老13	6546.96	360	178.41	49.56%	0	1993	
129		0		珠江老14	6546.96	360	126.95	35.26%	0	2929	
130		0		农场老15	6546.96	360	152.03	42.23%	0	2473	
131		0	10kV-5	牛家牌老21	6546.96	360	207.55	57.65%	0	1463	
132		0		孙庄老22	6546.96	360	72.19	20.05%	0	3925	
133		0		前坨老23	6546.96	360	213.29	59.25%	0	1359	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
134	宝坻. 尔王庄站	0	10kV-41	东滨老24	6546.96	360	14.48	4.02%	0	4974	
135		0		李家河尔11	6546.96	360	140.35	38.99%	0	2685	
136		0		郑贵庄尔12	9147.558	503	50.91	10.12%	0	6392	
137		0		尔辛庄尔13	6546.96	360	52.69	14.64%	0	4279	
138		0		东安子尔15	6546.96	360	134.88	37.47%	0	2785	
139		0	10kV-42	黄花淀尔21	6546.96	360	166.99	46.39%	0	2201	
140		0		小宝庄尔23	6546.96	360	281.73	78.26%	0	114	
141		0	10kV-43	潘套尔25	6546.96	360	101.87	28.30%	0	3385	
142		0		小董庄尔26	6546.96	360	66.88	18.58%	0	4021	
143	宝坻. 海滨站	0	10kV-41	大吴路海11	9729.51	535	40.77	7.62%	0	7042	
144		0		张古海12	6546.96	360	148.87	41.35%	0	2530	
145		0		前五里海13	9147.558	503	64.92	12.91%	0	6137	
146		0		剑桥Ⅱ海14	8547.42	470	258.35	54.97%	0	2140	
147		0		翡翠Ⅱ海15	9729.51	535	111.87	20.91%	0	5749	
148		0		东城海16	9147.558	503	107.87	21.44%	0	5356	
149		0		龙第二海17	8547.42	470	96.77	20.59%	0	5078	
150		0	10kV-42	区医院海21	8547.42	470	63.62	13.54%	0	5681	
151		0		白龙港海22	6546.96	360	155.85	43.29%	0	2403	
152		0		小刘庄海23	6546.96	360	176.37	48.99%	0	2030	
153		0		剑桥Ⅰ海24	8547.42	470	105.67	22.48%	0	4916	
154		0		翡翠Ⅰ海25	8547.42	470	152.72	32.49%	0	4060	
155		0		西城海26	9147.558	503	222.22	44.18%	0	3277	
156		0		龙第一海31	8547.42	470	38.98	8.29%	0	6129	
157	宝坻. 黑狼口站	0	10kV-4	黑狼口黑11	6546.96	360	183.26	50.90%	0	1905	
158		0		老庄子黑12	9147.558	503	161.07	32.02%	0	4389	
159		0		农场黑13	9147.558	503	126.29	25.11%	0	5021	
160		0		塑料一黑14	9147.558	503	137.27	27.29%	0	4822	
161		0	10kV-5	塑料二黑21	9147.558	503	108.17	21.51%	0	5351	
162		0		久大黑22	6546.96	360	130.33	36.20%	0	2867	
163		0		糙甸乡黑23	6546.96	360	163.68	45.47%	0	2261	
164		0		发达纸厂黑24	6546.96	360	203.33	56.48%	0	1540	
165		0	10kV-42	陈塘欢19	9147.558	503	57.19	11.37%	0	6278	
166		0		高康马欢20	9147.558	503	132.34	26.31%	0	4911	
167		0		水流庄欢21	9147.558	503	297.16	59.08%	0	1914	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
168	宝坻. 欢喜庄站	0	10kV-43	五道沽欢23	9147.558	503	4.93	0.98%	0	7228	
169		0		李宦庄欢24	9147.558	503	100.28	19.94%	0	5494	
170		0		曹家沽欢25	9147.558	503	138.54	27.54%	0	4799	
171		0		周家庄欢26	9147.558	503	0.07	0.01%	0	7317	
172		0	10kV-44	后辛欢27	9147.558	503	88.87	17.67%	0	5702	
173		0		回庄欢28	9147.558	503	154.69	30.75%	0	4505	
174		0		工业园欢29	9147.558	503	181.60	36.10%	0	4016	
175		0		尹庄欢30	9147.558	503	0.00	0.00%	0	7318	
176		0		清白沽欢31	9147.558	503	1.09	0.22%	0	7298	
177		0		南辛码欢33	9147.558	503	122.41	24.34%	0	5092	
178		0		葫芦窝欢34	9147.558	503	257.90	51.27%	0	2628	
179	宝坻. 黄庄站	0	10kV-41	杜家台黄11	9147.558	503	93.68	18.63%	0	5614	
180		0		东走线黄12	9147.558	503	9.28	1.84%	0	7149	
181		0		南燕东黄13	9147.558	503	0.00	0.00%	0	7318	
182		0		张头窝东黄14	9147.558	503	0.00	0.00%	0	7318	
183		0		小甸西黄15	9147.558	503	0.00	0.00%	0	7318	
184		0		鲁家铺黄16	9147.558	503	228.32	45.39%	0	3166	
185		0		水流东黄21	9147.558	503	36.52	7.26%	0	6654	
186		0		黄庄北黄22	9147.558	503	0.00	0.00%	0	7318	
187		0	10kV-42	大塔沽黄31	9147.558	503	7.38	1.47%	0	7184	
188		0		郭庄子黄32	9147.558	503	0.00	0.00%	0	7318	
189		0		苑家场黄33	9147.558	503	99.04	19.69%	0	5517	
190		0		黄庄西黄34	9147.558	503	41.11	8.17%	0	6570	
191		0	10kV-43	王木庄黄41	9147.558	503	23.42	4.66%	0	6892	
192		0		西走线黄42	9147.558	503	0.00	0.00%	0	7318	
193		0		张头窝西黄43	9147.558	503	0.00	0.00%	0	7318	
194		0		黄庄东黄44	9147.558	503	152.75	30.37%	0	4540	
195		0	10kV-44	前辛庄黄51	9147.558	503	5.38	1.07%	0	7220	
196		0		小塔沽黄52	9147.558	503	12.01	2.39%	0	7100	
197		0		南燕北黄53	9147.558	503	0.00	0.00%	0	7318	
198		0		小甸东黄54	9147.558	503	17.22	3.42%	0	7005	
199		0		王家铺黄55	9147.558	503	0.00	0.00%	0	7318	
200		0		水流西黄61	9147.558	503	298.52	59.35%	0	1889	
201		0		黄庄南黄62	9147.558	503	241.79	48.07%	0	2921	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
202	宝坻. 开发区站	0	10kV-4	貉子沽黄63	9147.558	503	0.00	0.00%	0	7318	
203		0		华苑112	7274.4	400	102.24	25.56%	0	3960	
204		0		三中113	6546.96	360	119.52	33.20%	0	3064	
205		0		摩托车114	7274.4	400	45.12	11.28%	0	4999	
206		0		景苑I116	5637.66	310	146.04	47.11%	0	1854	
207		0		纸厂117	7274.4	400	40.92	10.23%	0	5075	
208		0	10kV-5	县委122	6546.96	360	130.44	36.23%	0	2865	
209		0		四小123	6546.96	360	258.96	71.93%	0	528	
210		0		东区124	7274.4	400	128.88	32.22%	0	3476	
211		0		香港园区125	7274.4	400	72.24	18.06%	0	4506	
212		0		景苑II126	5637.66	310	96.36	31.08%	0	2758	
213		0		党校127	6546.96	360	287.52	79.87%	0	9	
214		0	10kV-4	西区区15	6546.96	360	137.28	38.13%	0	2741	
215	宝坻. 口东站	0	10kV-41	口东园区I口1	6546.96	360	187.91	52.20%	0	1820	
216		0		前齐口12	6546.96	360	199.51	55.42%	0	1609	
217		0		园区西口13	9147.558	503	319.41	63.50%	0	1509	
218		0		工业东口14	9147.558	503	361.41	71.85%	0	746	
219		0	10kV-42	口东园区II口2	6546.96	360	256.29	71.19%	0	577	
220		0		东辛口22	9147.558	503	144.67	28.76%	0	4687	
221		0		园区南口23	9147.558	503	323.28	64.27%	0	1439	
222		0		工业北口24	9147.558	503	126.21	25.09%	0	5023	
223		0	10kV-43	首瑞口25	9147.558	503	239.24	47.56%	0	2967	
224		0		福礼口26	9147.558	503	0.00	0.00%	0	7318	
225		0	10kV-44	爱康口31	9147.558	503	362.11	71.99%	0	733	
226		0		黄辛口32	9147.558	503	45.53	9.05%	0	6490	
227		0		大张庄口33	9147.558	503	78.22	15.55%	0	5895	
228		0		潮阳东口34	9147.558	503	0.00	0.00%	0	7318	
229		0		恒佳口35	9147.558	503	113.55	22.58%	0	5253	
230		0		翔原口36	9147.558	503	325.72	64.76%	0	1394	
231		0	10kV-41	莲唐一营11	9729.51	535	80.61	15.07%	0	6318	
232		0		浩润营12	6546.96	360	256.16	71.16%	0	579	
233		0		香坻营13	9729.51	535	46.22	8.64%	0	6943	
234		0		西郝营14	9147.558	503	196.19	39.00%	0	3750	
235		0	10kV-42	兴华营31	9147.558	503	156.65	31.14%	0	4469	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
236	宝坻. 莲子营站	0	10kV-42	津侨一营32	9729.51	535	2.29	0.43%	0	7742	
237		0	10kV-43	莲唐二营41	9729.51	535	76.43	14.29%	0	6394	
238		0		润悦营42	9729.51	535	35.24	6.59%	0	7143	
239		0		万和营43	8547.42	470	83.51	17.77%	0	5319	
240		0	10kV-44	小套营51	6546.96	360	225.11	62.53%	0	1144	
241		0		水岸营52	9729.51	535	164.90	30.82%	0	4785	
242		0		官庄营53	6546.96	360	161.16	44.77%	0	2307	
243		0		津侨二营54	9729.51	535	2.28	0.43%	0	7742	
244	宝坻. 林亭口站	0	10kV-4	张庄子林11	7274.4	400	309.72	77.43%	0	187	
245		0		大靳庄林12	7274.4	400	0.00	0.00%	0	5820	
246		0		林亭口西林13	7274.4	400	159.06	39.77%	0	2927	
247		0		科宝林14	7274.4	400	0.80	0.20%	0	5805	
248		0		龙亭苑林15	7274.4	400	212.10	53.02%	0	1962	
249		0	10kV-5	众河林21	7274.4	400	45.41	11.35%	0	4994	
250		0		南五村林22	7274.4	400	240.12	60.03%	0	1453	
251		0		林亭口林23	6546.96	360	157.73	43.81%	0	2369	
252		0		季家庄林24	7274.4	400	8.41	2.10%	0	5667	
253	宝坻. 牛道口站	0	10kV-4	轻集林25	7274.4	400	0.82	0.20%	0	5805	
254		0		下五庄牛11	9147.558	503	217.50	43.24%	0	3363	
255		0		塘头牛12	9147.558	503	186.09	37.00%	0	3934	
256		0		庞庄牛13	9147.558	503	104.53	20.78%	0	5417	
257		0		三赵牛14	7619.934	419	169.45	40.44%	0	3014	
258		0	10kV-5	西四庄牛21	9147.558	503	171.80	34.15%	0	4194	
259		0		高家深牛22	6546.96	360	162.19	45.05%	0	2288	
260		0		高各庄牛23	9147.558	503	194.77	38.72%	0	3776	
261		0		卢各庄牛24	9147.558	503	63.05	12.53%	0	6171	
262	宝坻. 史各庄站	0	10kV-4	集利牛25	6546.96	360	170.16	47.27%	0	2143	
263		0		扬水站史11	6546.96	360	220.43	61.23%	0	1229	
264		0		西苑庄史12	6546.96	360	179.30	49.80%	0	1977	
265		0		通威史13	6546.96	360	231.33	64.26%	0	1031	
266		0		官城史14	6546.96	360	236.95	65.82%	0	928	
267		0		朱孔史15	6546.96	360	239.41	66.50%	0	884	
268		0		彪家店史16	9147.558	503	0.00	0.00%	0	7318	
269		0		正大史21	6546.96	360	124.63	34.62%	0	2971	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
270		0	10kV-5	史各庄史22	6546.96	360	239.06	66.41%	0	890	
271		0		郭杨史23	6546.96	360	44.30	12.30%	0	4432	
272		0		庞各庄史24	6546.96	360	281.60	78.22%	0	116	
273		0		大刘辛史25	9147.558	503	296.02	58.85%	0	1935	
274	宝坻. 双王寺站	0	10kV-4	屯东双11	6546.96	360	108.83	30.23%	0	3258	
275		0		双唐一双12	9729.51	535	0.00	0.00%	0	7784	
276		0		郝各庄双13	6546.96	360	280.57	77.94%	0	135	
277		0		马家店双14	6546.96	360	263.86	73.29%	0	439	
278		0	10kV-5	屯西双21	6546.96	360	146.12	40.59%	0	2580	
279		0		南仁孚双22	9147.558	503	401.32	79.79%	0	20	
280		0		新开口双23	6546.96	360	119.88	33.30%	0	3057	
281		0		宝联双24	6546.96	360	158.55	44.04%	0	2354	
282		0		双唐二双25	9729.51	535	92.26	17.24%	0	6106	
283		0	10kV-41	东淀隋11	9147.558	503	227.79	45.29%	0	3175	
284		0		大刘坡隋12	8547.42	470	259.96	55.31%	0	2110	
285		0		迈克隋13	9729.51	535	242.80	45.38%	0	3368	
286		0		腾飞隋14	9729.51	535	166.53	31.13%	0	4755	
287	宝坻. 隋庄子站	0	10kV-42	尔王庄隋21	6546.96	360	51.20	14.22%	0	4306	
288		0		九园东隋22	9147.558	503	272.27	54.13%	0	2367	
289		0		大白庄东隋23	8547.42	470	57.20	12.17%	0	5798	
290		0		董塔隋24	6546.96	360	145.24	40.34%	0	2596	
291		0	10kV-43	石材一隋25	9147.558	503	160.25	31.86%	0	4404	
292		0		诺宝一隋26	9147.558	503	93.56	18.60%	0	5617	
293		0		南李隋27	9147.558	503	208.11	41.37%	0	3533	
294		0		轻纺隋28	8547.42	470	44.50	9.47%	0	6029	
295		0	10kV-44	九园西隋32	6546.96	360	223.82	62.17%	0	1167	
296		0		大白庄西隋33	6546.96	360	115.14	31.98%	0	3144	
297		0		大唐庄隋34	6546.96	360	281.52	78.20%	0	118	
298		0		石材二隋35	9147.558	503	194.79	38.73%	0	3776	
299		0		诺宝二隋36	9147.558	503	59.61	11.85%	0	6234	
300		0		石材隋37	9147.558	503	103.27	20.53%	0	5440	
301		0		新城隋38	9147.558	503	46.30	9.20%	0	6476	
302		0		双盛太12	6546.96	360	229.44	63.73%	0	1065	
303		0		昌兴太13	6546.96	360	185.64	51.57%	0	1862	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母线	线路名称	线路允许 容量 （kVA）	允许电流 （A）	历史最大 电流 （A）	最高负载率 （%）	线路最大 负荷日后 需预留容 量（kVA）	可开放容 量（kVA）	备注
304	宝坻.太平 庄站	0	10kV-4	馨园Ⅰ太14	9729.51	535	279.24	52.19%	0	2705	
305		0		九中Ⅰ太15	9729.51	535	260.76	48.74%	0	3041	
306		0		润阳一太16	9729.51	535	75.60	14.13%	0	6409	
307		0		津宝太17	6546.96	360	173.04	48.07%	0	2091	
308		0	10kV-5	宸宝太22	6546.96	360	97.68	27.13%	0	3461	
309		0		人防太23	6546.96	360	233.16	64.77%	0	997	
310		0		馨园Ⅱ太24	9729.51	535	268.80	50.24%	0	2895	
311		0		九中Ⅱ太25	9729.51	535	176.04	32.90%	0	4582	
312		0		润阳二太26	9729.51	535	78.48	14.67%	0	6356	
313		0		中专太27	6546.96	360	82.92	23.03%	0	3730	
314		0	10kV-4	陈山王11	6546.96	360	103.05	28.62%	0	3364	
315		0		王卜庄西王12	6546.96	360	150.57	41.83%	0	2499	
316		0		大华王13	6546.96	360	172.96	48.04%	0	2092	
317		0		方庄子王14	9147.558	503	105.45	20.96%	0	5400	
318		0		赵二王15	9147.558	503	0.00	0.00%	0	7318	
319		0		小赵王16	9147.558	503	40.96	8.14%	0	6573	
320		0		何家庄王17	9147.558	503	154.26	30.67%	0	4513	
321		0		司各庄王18	9147.558	503	86.26	17.15%	0	5749	
322	宝坻.王卜 庄站	0	10kV-5	砖厂王21	6546.96	360	67.68	18.80%	0	4007	
323		0		北坛王22	9147.558	503	71.84	14.28%	0	6011	
324		0		王卜庄东王23	6546.96	360	176.18	48.94%	0	2034	
325		0		南家庄王24	9147.558	503	104.81	20.84%	0	5412	
326		0		龙坛王25	9147.558	503	235.69	46.86%	0	3032	
327		0		庞家庄王26	9147.558	503	345.30	68.65%	0	1038	
328		0		于街王27	6546.96	360	133.75	37.15%	0	2805	
329		0		西泗王28	9147.558	503	185.12	36.80%	0	3952	
330	宝坻.五里 铺站	0	10kV-41	轧钢厂铺12	6546.96	360	134.71	37.42%	0	2788	
331		0		石桥铺13	6546.96	360	152.83	42.45%	0	2458	
332		0		杨家口铺14	6546.96	360	120.25	33.40%	0	3051	
333		0		张台铺15	6546.96	360	143.99	40.00%	0	2619	
334		0		泉州铺16	9147.558	503	97.99	19.48%	0	5536	
335		0	10kV-42	畜牧局铺22	6546.96	360	286.70	79.64%	0	24	
336		0		棉纺厂铺23	9147.558	503	361.15	71.80%	0	750	
337		0		霍各庄铺25	6546.96	360	71.37	19.82%	0	3940	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
338	珊站	0	10kV-43	口东铺26	9147.558	503	109.56	21.78%	0	5326	
339		0		金水 I 铺28	8547.42	470	242.99	51.70%	0	2419	
340		0	10kV-44	林海铺31	9729.51	535	220.26	41.17%	0	3778	
341		0		北郝铺32	6546.96	360	258.46	71.79%	0	537	
342		0		大角甸铺33	9147.558	503	192.83	38.34%	0	3811	
343		0		监管所铺34	9147.558	503	283.18	56.30%	0	2168	
344		0		金水 II 铺38	8547.42	470	182.09	38.74%	0	3526	
345		0									
346	宝坻. 小辛码站	0	10kV-4	欢喜小12	6546.96	360	44.00	12.22%	0	4437	
347		0		黄庄小13	6546.96	360	180.32	50.09%	0	1958	
348		0		苑洪桥小14	9147.558	503	123.84	24.62%	0	5066	
349		0		辛庄南小15	9147.558	503	0.16	0.03%	0	7315	
350		0	10kV-5	北里沽小21	6546.96	360	99.68	27.69%	0	3425	
351		0		扬水站小22	6546.96	360	109.60	30.44%	0	3244	
352		0		小辛码小23	6546.96	360	205.44	57.07%	0	1501	
353		0		马庄小24	9147.558	503	39.36	7.83%	0	6602	
354		0		吴辛小25	9147.558	503	60.00	11.93%	0	6227	
355		0									
356	宝坻. 新安镇站	0	10kV-41	于家口一安11	9147.558	503	38.40	7.63%	0	6620	
357		0		王善庄一安12	9147.558	503	44.40	8.83%	0	6511	
358		0		南业安13	9183.93	505	0.00	0.00%	0	7347	
359		0		王庄安17	9147.558	503	322.90	64.19%	0	1446	
360		0		木业安18	9147.558	503	402.15	79.95%	0	5	
361		0	10kV-42	于家口二安21	9147.558	503	69.60	13.84%	0	6052	
362		0		王善庄二安22	9147.558	503	161.50	32.11%	0	4381	
363		0	10kV-43	曹口安27	9147.558	503	161.00	32.01%	0	4390	
364		0		业西安28	9147.558	503	182.80	36.34%	0	3994	
365	宝坻. 新开口站	0	10kV-4	园区新11	6546.96	360	223.85	62.18%	0	1167	
366		0		中粮新12	6546.96	360	75.35	20.93%	0	3867	
367		0		种西新13	6546.96	360	247.24	68.68%	0	741	
368		0		前寒河新14	7274.4	400	121.84	30.46%	0	3604	
369		0		新开口东新15	6546.96	360	166.98	46.38%	0	2201	
370		0	10kV-5	新开口西新21	6546.96	360	196.91	54.70%	0	1657	
371		0		彭家务新22	6546.96	360	144.84	40.23%	0	2603	
				石辛庄新23	7274.4	400	102.86	25.71%	0	3949	
				洛水坨新24	7274.4	400	247.25	61.81%	0	1323	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
372	宝坻. 袁罗站	0	10kV-41	新开口南新25	6546.96	360	33.29	9.25%	0	4632	
373		0		大卦庄袁11	9147.558	503	92.76	18.44%	0	5631	
374		0		刘兰袁12	9147.558	503	24.22	4.81%	0	6878	
375		0		北王庄袁13	9147.558	503	85.32	16.96%	0	5766	
376		0		金厂袁14	9147.558	503	151.27	30.07%	0	4567	
377		0		东鲁沽袁15	9147.558	503	67.22	13.36%	0	6096	
378		0		八二村袁16	9147.558	503	0.00	0.00%	0	7318	
379		0		袁罗北袁21	9147.558	503	222.12	44.16%	0	3279	
380		0		杨庄子袁22	9147.558	503	69.24	13.77%	0	6059	
381		0		凌沿村袁23	9147.558	503	0.00	0.00%	0	7318	
382		0		米四庄袁24	9147.558	503	0.00	0.00%	0	7318	
383		0		大米北袁25	9147.558	503	0.00	0.00%	0	7318	
384		0	10kV-42	宝芝麻窝袁31	9147.558	503	50.52	10.04%	0	6399	
385		0		马郭村袁32	9147.558	503	95.83	19.05%	0	5575	
386		0		岳家楼袁33	9147.558	503	68.57	13.63%	0	6071	
387		0		王山南袁34	9147.558	503	65.94	13.11%	0	6119	
388		0		康庄西袁35	9147.558	503	116.95	23.25%	0	5191	
389		0	10kV-43	大米南袁41	9147.558	503	66.41	13.20%	0	6110	
390		0		孔家庄袁42	9147.558	503	3.98	0.79%	0	7246	
391		0		八一村袁43	9147.558	503	0.00	0.00%	0	7318	
392		0		大钟庄袁44	9147.558	503	89.26	17.74%	0	5695	
393		0		二米庄袁45	9147.558	503	86.81	17.26%	0	5739	
394		0	10kV-44	米东袁51	9147.558	503	0.00	0.00%	0	7318	
395		0		船窝村袁52	9147.558	503	223.09	44.35%	0	3261	
396		0		大陈庄袁53	9147.558	503	0.00	0.00%	0	7318	
397		0		勾家庄袁54	9147.558	503	84.22	16.74%	0	5786	
398		0		焦王庄袁55	9147.558	503	25.61	5.09%	0	6852	
399		0		后鲁沽袁56	9147.558	503	0.00	0.00%	0	7318	
400		0		王山北袁61	9147.558	503	0.00	0.00%	0	7318	
401		0		康庄东袁62	9147.558	503	56.56	11.24%	0	6290	
402		0		张五庄袁63	9147.558	503	43.37	8.62%	0	6529	
403		0		杨木村袁64	9147.558	503	74.14	14.74%	0	5970	
404		0		厂家窝袁65	9147.558	503	119.14	23.69%	0	5151	
405		0		天祥 I 岳11	6546.96	360	257.70	71.58%	0	551	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
406	宝坻. 岳家庄站	0	10kV-41	天恒岳12	8547.42	470	130.59	27.79%	0	4463	
407		0		黑豆窝岳13	6546.96	360	59.06	16.40%	0	4164	
408		0		天跃一岳14	9147.558	503	160.52	31.91%	0	4399	
409		0		蝶恋一岳15	9729.51	535	361.05	67.49%	0	1218	
410		0		鑫海一岳16	9729.51	535	222.41	41.57%	0	3739	
411		0		赵各庄岳17	6546.96	360	194.55	54.04%	0	1699	
412		0	10kV-42	天宝Ⅰ岳19	6546.96	360	74.71	20.75%	0	3879	
413		0		鑫海二岳20	9729.51	535	244.05	45.62%	0	3345	
414		0		沟头岳21	6546.96	360	219.73	61.04%	0	1242	
415		0		宝旺岳22	9147.558	503	170.55	33.91%	0	4216	
416		0	10kV-43	天跃二岳23	9147.558	503	350.56	69.69%	0	943	
417		0		松江Ⅰ岳24	9729.51	535	381.10	71.23%	0	853	
418		0		天祥Ⅱ岳25	6546.96	360	256.82	71.34%	0	567	
419		0	10kV-44	天宝Ⅱ岳27	6546.96	360	143.97	39.99%	0	2619	
420		0		牛道口岳28	6546.96	360	191.40	53.17%	0	1757	
421		0		黄沙务岳29	9147.558	503	321.03	63.82%	0	1480	
422		0		宝富岳30	9147.558	503	377.41	75.03%	0	454	
423		0		石佛营岳31	6546.96	360	177.12	49.20%	0	2017	
424		0		松江Ⅱ岳32	9729.51	535	153.28	28.65%	0	4996	
425		0		蝶恋二岳33	9729.51	535	354.20	66.21%	0	1342	
426	宝坻. 中关村站	0	10kV-41	曙光一关11	9729.51	535	141.79	26.50%	0	5205	
427		0		元中一关12	9729.51	535	153.39	28.67%	0	4994	
428		0		于家观关13	6546.96	360	240.84	66.90%	0	858	
429		0		宝善一关14	9729.51	535	122.79	22.95%	0	5551	
430		0		宝康一关15	8547.42	470	27.02	5.75%	0	6347	
431		0		宝德一关16	9729.51	535	116.60	21.80%	0	5663	
432		0		梦泽一关21	9729.51	535	256.13	47.88%	0	3126	
433		0		科景轩一关22	9729.51	535	275.03	51.41%	0	2782	
434		0		宝志一关23	9729.51	535	58.29	10.90%	0	6723	
435		0	10kV-42 10kV-43	元中二关31	9729.51	535	0.68	0.13%	0	7771	
436		0		宝善二关32	9729.51	535	330.66	61.81%	0	1770	
437		0		科景轩二关33	9729.51	535	248.31	46.41%	0	3268	
438		0		宝志二关34	9729.51	535	40.50	7.57%	0	7047	
439		0		曙光二关41	9729.51	535	255.67	47.79%	0	3134	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
440	宝坻. 周良庄站	0		宝康二关42	8547.42	470	118.17	25.14%	0	4689	
441		0		宝德二关43	9729.51	535	13.14	2.46%	0	7545	
442		0		梦泽二关44	9729.51	535	283.90	53.06%	0	2621	
443		0	10kV-41	嵘园 I 216	8547.42	470	19.37	4.12%	0	6486	
444		0		顺园 I 217	8547.42	470	43.30	9.21%	0	6051	
445		0		财大 I 218	8547.42	470	357.36	76.03%	0	339	
446		0	10kV-42	财大 II 231	8547.42	470	371.02	78.94%	0	91	
447		0		顺园 II 232	8547.42	470	32.58	6.93%	0	6245	
448		0	10kV-43	嵘园 II 233	8547.42	470	35.89	7.64%	0	6185	
449		0		嘉园 I 周11	8547.42	470	27.60	5.87%	0	6336	
450		0	10kV-41	九园南周12	8547.42	470	109.28	23.25%	0	4851	
451		0		东皋周13	10311.462	567	104.00	18.34%	0	6358	
452		0		森林岛 I 周14	8547.42	470	161.02	34.26%	0	3910	
453		0	10kV-42 10kV-43	康园 I 周15	8547.42	470	24.76	5.27%	0	6388	
454		0		嘉园 II 周21	8547.42	470	38.48	8.19%	0	6138	
455		0		香江周22	8547.42	470	241.71	51.43%	0	2442	
456		0		九园北周23	8547.42	470	130.46	27.76%	0	4465	
457		0		森林岛 II 周24	8547.42	470	228.55	48.63%	0	2681	
458		0		安盟周34	8547.42	470	0.88	0.19%	0	6822	
459	宝坻. 马家店站	0	10kV-41	后寒河马11	6546.96	360	64.90	18.03%	0	4057	
460		0		刘举人马12	6546.96	360	171.92	47.75%	0	2111	
461		0		天玺园马13	6546.96	360	220.54	61.26%	0	1227	
462		0		星洋马14	9147.558	503	141.34	28.10%	0	4748	
463		0		沁园马15	9147.558	503	67.94	13.51%	0	6082	
464		0	10kV-42 10kV-43	烧角马31	6546.96	360	206.21	57.28%	0	1487	
465		0		西寨马41	6546.96	360	72.29	20.08%	0	3923	
466		0		大兰马42	9147.558	503	72.48	14.41%	0	6000	
467		0		后六口马51	6546.96	360	123.26	34.24%	0	2996	
468		0		璟园马52	9147.558	503	66.27	13.17%	0	6113	
469		0	10kV-41	马营温11	6546.96	360	146.11	40.59%	0	2580	
470		0		李台温12	9147.558	503	289.78	57.61%	0	2048	
471		0		田邢庄温13	6546.96	360	67.50	18.75%	0	4010	
472		0		香榭一温14	8547.42	470	71.54	15.22%	0	5537	
473		0		橄榄树一温15	8547.42	470	175.99	37.44%	0	3637	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
474	宝坻.温泉城站	0		邮政一温16	8547.42	470	112.15	23.86%	0	4798	
475		0	10kV-43 10kV-44	菜家铺温41	6546.96	360	98.26	27.29%	0	3451	
476		0		后五登温42	6546.96	360	202.67	56.30%	0	1552	
477		0		香榭二温43	8547.42	470	158.23	33.67%	0	3960	
478		0		四里港温51	6546.96	360	95.42	26.51%	0	3502	
479		0		橄榄树二温52	8547.42	470	275.65	58.65%	0	1825	
480		0		邮政二温53	8547.42	470	43.55	9.27%	0	6046	