

城西供电公司10千伏配电线路可开放容量信息表(第三季度)

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
1	安华里	0	10kV-41	华11	5542	400	42.75	10.69%	0	3841	
2	安华里	0	10kV-41	华12	5542	400	62.39	15.60%	0	3569	
3	安华里	0	10kV-41	华13	5542	400	71.40	17.85%	0	3444	
4	安华里	0	10kV-41	华14	5542	400	42.48	10.62%	0	3845	
5	安华里	0	10kV-41	华15	5542	400	131.96	32.99%	0	2605	
6	安华里	0	10kV-41	华16	5542	400	166.88	41.72%	0	2121	
7	安华里	0	10kV-41	华17	5542	400	313.22	78.30%	0	94	
8	安华里	0	10kV-41	华18	5542	400	284.42	71.11%	0	493	
9	安华里	0	10kV-421	华20	5542	400	25.37	6.34%	0	4082	
10	安华里	0	10kV-421	华21	5542	400	86.02	21.50%	0	3242	
11	安华里	0	10kV-421	华22	5542	400	32.16	8.04%	0	3988	
12	安华里	0	10kV-421	华23	5542	400	57.73	14.43%	0	3634	
13	安华里	0	10kV-421	华24	5542	400	76.15	19.04%	0	3379	
14	安华里	0	10kV-422	华25	5542	400	183.56	45.89%	0	1890	
15	安华里	0	10kV-422	华26	5542	400	309.46	77.36%	0	146	
16	安华里	0	10kV-422	华27	5542	400	33.22	8.31%	0	3973	
17	安华里	0	10kV-422	华28	5542	400	252.76	63.19%	0	932	
18	安华里	0	10kV-43	华31	5542	400	23.72	5.93%	0	4105	
19	安华里	0	10kV-43	华32	5542	400	95.23	23.81%	0	3114	
20	安华里	0	10kV-43	华33	5542	400	165.36	41.34%	0	2143	
21	安华里	0	10kV-43	华34	5542	400	221.22	55.30%	0	1369	
22	安华里	0	10kV-43	华35	5542	400	130.38	32.59%	0	2627	
23	安华里	0	10kV-43	华36	5542	400	66.70	16.67%	0	3510	
24	安华里	0	10kV-43	华37	5542	400	295.04	73.76%	0	346	
25	安华里	0	10kV-43	华38	5542	400	54.34	13.58%	0	3681	
26	白塔寺	0	10kV-4	白11	5542	400	133.25	33.31%	0	2587	
27	白塔寺	0	10kV-5	白12	5542	400	90.50	22.63%	0	3180	
28	白塔寺	0	10kV-4	白13	5542	400	284.39	71.10%	0	493	
29	白塔寺	0	10kV-5	白14	5542	400	196.89	49.22%	0	1706	
30	白塔寺	0	10kV-4	白15	5542	400	268.25	67.06%	0	717	
31	白塔寺	0	10kV-5	白16	5542	400	29.44	7.36%	0	4026	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
32	白塔寺	0	10kV-4	白17	5542	400	303.85	75.96%	0	224	
33	白塔寺	0	10kV-5	白18	5542	400	285.75	71.44%	0	474	
34	保山道	0	10kV-41	保11	5542	400	154.42	38.60%	0	2294	
35	保山道	0	10kV-41	保13	5542	400	154.76	38.69%	0	2289	
36	保山道	0	10kV-41	保14	5542	400	311.49	77.87%	0	118	
37	保山道	0	10kV-41	保15	5542	400	297.63	74.41%	0	310	
38	保山道	0	10kV-41	保16	5542	400	253.05	63.26%	0	928	
39	保山道	0	10kV-41	保18	5542	400	34.43	8.61%	0	3957	
40	保山道	0	10kV-42	保21	5542	400	262.87	65.72%	0	792	
41	保山道	0	10kV-42	保22	5542	400	190.45	47.61%	0	1795	
42	保山道	0	10kV-43	保31	5542	400	203.71	50.93%	0	1611	
43	保山道	0	10kV-43	保32	5542	400	263.81	65.95%	0	778	
44	保山道	0	10kV-43	保33	5542	400	140.44	35.11%	0	2488	
45	保山道	0	10kV-43	保34	5542	400	313.64	78.41%	0	88	
46	保山道	0	10kV-44	保40	5542	400	41.08	10.27%	0	3864	
47	保山道	0	10kV-44	保41	5542	400	250.99	62.75%	0	956	
48	保山道	0	10kV-44	保42	5542	400	122.28	30.57%	0	2739	
49	保山道	0	10kV-44	保43	5542	400	238.27	59.57%	0	1132	
50	保山道	0	10kV-44	保45	5542	400	161.30	40.33%	0	2199	
51	保山道	0	10kV-44	保46	5542	400	104.87	26.22%	0	2981	
52	宝通道	0	10kV-41	通11	5542	400	211.69	52.92%	0	1501	
53	宝通道	0	10kV-41	通12	5542	400	91.61	22.90%	0	3164	
54	宝通道	0	10kV-41	通13	5542	400	164.75	41.19%	0	2151	
55	宝通道	0	10kV-41	通15	5542	400	145.92	36.48%	0	2412	
56	宝通道	0	10kV-41	通17	5542	400	169.85	42.46%	0	2080	
57	宝通道	0	10kV-41	通18	5542	400	298.20	74.55%	0	302	
58	宝通道	0	10kV-43	通34	5542	400	293.63	73.41%	0	365	
59	宝通道	0	10kV-44	通41	5542	400	117.27	29.32%	0	2809	
60	宝通道	0	10kV-44	通43	5542	400	325.36	81.34%	0	0	
61	宝通道	0	10kV-44	通44	5542	400	199.21	49.80%	0	1674	
62	宝通道	0	10kV-44	通45	5542	400	166.16	41.54%	0	2131	
63	宝通道	0	10kV-44	通46	5542	400	162.64	40.66%	0	2180	
64	宝通道	0	10kV-44	通47	5542	400	145.57	36.39%	0	2417	
65	宝通道	0	10kV-44	通48	5542	400	140.47	35.12%	0	2487	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
66	边村	0	10kV-5	552	5542	400	199.90	49.98%	0	1664	
67	边村	0	10kV-4	553	5542	400	345.77	86.44%	0	0	
68	边村	0	10kV-5	554	5542	400	319.70	79.93%	0	4	
69	边村	0	10kV-4	555	5542	400	309.81	77.45%	0	141	
70	边村	0	10kV-5	556	5542	400	306.41	76.60%	0	188	
71	边村	0	10kV-4	557	5542	400	132.10	33.02%	0	2603	
72	边村	0	10kV-5	558	5542	400	131.83	32.96%	0	2607	
73	边村	0	10kV-4	559	5542	400	270.08	67.52%	0	692	
74	边村	0	10kV-4	561	5542	400	299.83	74.96%	0	279	
75	边村	0	10kV-5	562	5542	400	299.77	74.94%	0	280	
76	边村	0	10kV-5	564	5542	400	133.62	33.40%	0	2582	
77	滨渠道	0	10kV-41	滨07	5542	400	103.03	25.76%	0	3006	
78	滨渠道	0	10kV-41	滨11	5542	400	184.09	46.02%	0	1883	
79	滨渠道	0	10kV-41	滨12	5542	400	142.07	35.52%	0	2465	
80	滨渠道	0	10kV-41	滨13	5542	400	137.49	34.37%	0	2529	
81	滨渠道	0	10kV-41	滨14	5542	400	89.67	22.42%	0	3191	
82	滨渠道	0	10kV-42	滨15	5542	400	193.76	48.44%	0	1749	
83	滨渠道	0	10kV-42	滨16	5542	400	205.36	51.34%	0	1588	
84	滨渠道	0	10kV-42	滨17	5542	400	210.46	52.62%	0	1518	
85	滨渠道	0	10kV-43	滨18	5542	400	273.05	68.26%	0	650	
86	滨渠道	0	10kV-43	滨19	5542	400	197.27	49.32%	0	1700	
87	滨渠道	0	10kV-43	滨21	5542	400	245.93	61.48%	0	1026	
88	滨渠道	0	10kV-44	滨22	5542	400	191.65	47.91%	0	1778	
89	滨渠道	0	10kV-44	滨23	5542	400	191.82	47.96%	0	1776	
90	滨渠道	0	10kV-44	滨24	5542	400	85.10	21.27%	0	3255	
91	滨渠道	0	10kV-44	滨25	5542	400	76.84	19.21%	0	3369	
92	滨渠道	0	10kV-44	滨26	5542	400	184.44	46.11%	0	1878	
93	滨渠道	0	10kV-44	滨27	5542	400	273.93	68.48%	0	638	
94	储珍道	0	10kV-42	储24	5542	400	210.82	52.71%	0	1513	
95	储珍道	0	10kV-42	储25	5542	400	311.05	77.76%	0	124	
96	储珍道	0	10kV-44	储37	5542	400	219.20	54.80%	0	1397	
97	储珍道	0	10kV-44	储38	5542	400	225.40	56.35%	0	1311	
98	储珍道	0	10kV-44	储39	5542	400	301.99	75.50%	0	250	
99	储珍道	0	10kV-44	储41	5542	400	242.36	60.59%	0	1076	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
100	大胡同	0	10kV-41	同11	5542	400	70.92	17.73%	0	3451	
101	大胡同	0	10kV-41	同13	5542	400	124.20	31.05%	0	2713	
102	大胡同	0	10kV-41	同14	5542	400	50.52	12.63%	0	3734	
103	大胡同	0	10kV-41	同15	5542	400	184.56	46.14%	0	1877	
104	大胡同	0	10kV-41	同16	5542	400	31.20	7.80%	0	4001	
105	大胡同	0	10kV-41	同17	5542	400	174.48	43.62%	0	2016	
106	大胡同	0	10kV-42	同21	5542	400	205.80	51.45%	0	1582	
107	大胡同	0	10kV-43	同31	5542	400	107.16	26.79%	0	2949	
108	大胡同	0	10kV-43	同33	5542	400	185.88	46.47%	0	1858	
109	大胡同	0	10kV-44	同41	5542	400	160.92	40.23%	0	2204	
110	大胡同	0	10kV-44	同43	5542	400	154.32	38.58%	0	2295	
111	大胡同	0	10kV-44	同44	5542	400	67.92	16.98%	0	3493	
112	大胡同	0	10kV-44	同45	5542	400	233.88	58.47%	0	1193	
113	大胡同	0	10kV-44	同47	5542	400	143.52	35.88%	0	2445	
114	大寺	0	10kV-41	大09	5542	400	341.21	85.30%	0	0	
115	大寺	0	10kV-41	大11	5542	400	177.65	44.41%	0	1972	
116	大寺	0	10kV-41	大12	5542	400	316.51	79.13%	0	48	
117	大寺	0	10kV-41	大13	5542	400	306.20	76.55%	0	191	
118	大寺	0	10kV-41	大14	5542	400	197.10	49.28%	0	1703	
119	大寺	0	10kV-42	大15	5542	400	309.95	77.49%	0	139	
120	大寺	0	10kV-42	大16	5542	400	289.80	72.45%	0	418	
121	大寺	0	10kV-42	大17	5542	400	318.86	79.71%	0	16	
122	大寺	0	10kV-43	大18	5542	400	196.75	49.19%	0	1708	
123	大寺	0	10kV-43	大19	5542	400	219.84	54.96%	0	1388	
124	大寺	0	10kV-43	大21	5542	400	277.49	69.37%	0	589	
125	大寺	0	10kV-44	大41	5542	400	19.34	4.83%	0	4166	
126	大寺	0	10kV-44	大42	5542	400	213.76	53.44%	0	1472	
127	大寺	0	10kV-44	大43	5542	400	328.50	82.12%	0	0	
128	大寺	0	10kV-44	大44	5542	400	36.74	9.19%	0	3925	
129	大寺	0	10kV-44	大45	5542	400	135.36	33.84%	0	2558	
130	大寺	0	10kV-44	大46	5542	400	300.49	75.12%	0	270	
131	大学道	0	10kV-41	学11	5542	400	263.11	65.78%	0	788	
132	大学道	0	10kV-41	学12	5542	400	39.37	9.84%	0	3888	
133	大学道	0	10kV-41	学13	5542	400	170.84	42.71%	0	2067	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
134	大学道	0	10kV-41	学14	5542	400	122.68	30.67%	0	2734	
135	大学道	0	10kV-41	学15	5542	400	43.41	10.85%	0	3832	
136	大学道	0	10kV-41	学16	5542	400	248.00	62.00%	0	998	
137	大学道	0	10kV-41	学17	5542	400	59.58	14.90%	0	3608	
138	大学道	0	10kV-41	学18	5542	400	169.96	42.49%	0	2079	
139	大学道	0	10kV-42	学22	5542	400	244.31	61.08%	0	1049	
140	大学道	0	10kV-42	学23	5542	400	186.48	46.62%	0	1850	
141	大学道	0	10kV-42	学24	5542	400	313.56	78.39%	0	89	
142	大学道	0	10kV-43	学31	5542	400	179.80	44.95%	0	1942	
143	大学道	0	10kV-43	学32	5542	400	53.43	13.36%	0	3693	
144	大学道	0	10kV-43	学33	5542	400	91.75	22.94%	0	3162	
145	大学道	0	10kV-43	学34	5542	400	156.60	39.15%	0	2264	
146	大学道	0	10kV-44	学41	5542	400	217.77	54.44%	0	1416	
147	大学道	0	10kV-44	学42	5542	400	53.61	13.40%	0	3691	
148	大学道	0	10kV-44	学43	5542	400	193.86	48.47%	0	1748	
149	大学道	0	10kV-44	学44	5542	400	289.13	72.28%	0	428	
150	大学道	0	10kV-44	学45	5542	400	249.58	62.39%	0	976	
151	大学道	0	10kV-44	学46	5542	400	105.63	26.41%	0	2970	
152	大学道	0	10kV-44	学47	5542	400	299.32	74.83%	0	287	
153	大学道	0	10kV-44	学48	5542	400	156.95	39.24%	0	2259	
154	第六埠	0	10kV-42	埠21	5542	400	171.45	42.86%	0	2058	
155	第六埠	0	10kV-42	埠22	5542	400	245.98	61.50%	0	1026	
156	第六埠	0	10kV-42	埠23	5542	400	200.10	50.03%	0	1661	
157	第六埠	0	10kV-42	埠24	5542	400	262.22	65.56%	0	800	
158	第六埠	0	10kV-43	埠25	5542	400	299.32	74.83%	0	287	
159	第六埠	0	10kV-43	埠28	5542	400	299.95	74.99%	0	278	
160	第六埠	0	10kV-44	埠31	5542	400	214.20	53.55%	0	1466	
161	第六埠	0	10kV-44	埠32	5542	400	126.26	31.56%	0	2684	
162	第六埠	0	10kV-44	埠33	5542	400	259.51	64.88%	0	838	
163	第六埠	0	10kV-44	埠35	5542	400	212.90	53.22%	0	1484	
164	第六埠	0	10kV-44	埠36	5542	400	118.22	29.56%	0	2796	
165	第六埠	0	10kV-44	埠37	5542	400	234.66	58.67%	0	1182	
166	第六埠	0	10kV-44	埠38	5542	400	280.06	70.01%	0	553	
167	丁字沽	0	10kV-41	丁11	5542	400	239.00	59.75%	0	1122	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
168	丁字沽	0	10kV-41	丁13	5542	400	190.00	47.50%	0	1801	
169	丁字沽	0	10kV-41	丁14	5542	400	246.00	61.50%	0	1025	
170	丁字沽	0	10kV-41	丁15	5542	400	254.00	63.50%	0	914	
171	丁字沽	0	10kV-41	丁16	5542	400	240.00	60.00%	0	1108	
172	丁字沽	0	10kV-42	丁21	5542	400	238.00	59.50%	0	1136	
173	丁字沽	0	10kV-42	丁22	5542	400	218.00	54.50%	0	1413	
174	丁字沽	0	10kV-43	丁31	5542	400	284.00	71.00%	0	499	
175	丁字沽	0	10kV-43	丁32	5542	400	236.00	59.00%	0	1164	
176	丁字沽	0	10kV-43	丁33	5542	400	166.00	41.50%	0	2134	
177	丁字沽	0	10kV-44	丁43	5542	400	226.00	56.50%	0	1302	
178	丁字沽	0	10kV-44	丁44	5542	400	241.00	60.25%	0	1095	
179	丁字沽	0	10kV-44	丁45	5542	400	265.00	66.25%	0	762	
180	丁字沽	0	10kV-44	丁46	5542	400	224.00	56.00%	0	1330	
181	东门	0	10kV-41	东11	5542	400	195.87	48.97%	0	1720	
182	东门	0	10kV-41	东12	5542	400	303.54	75.89%	0	228	
183	东门	0	10kV-41	东13	5542	400	244.98	61.25%	0	1039	
184	东门	0	10kV-41	东14	5542	400	210.75	52.69%	0	1514	
185	东门	0	10kV-41	东15	5542	400	181.10	45.27%	0	1924	
186	东门	0	10kV-41	东16	5542	400	120.38	30.10%	0	2766	
187	东门	0	10kV-41	东17	5542	400	207.82	51.96%	0	1554	
188	东门	0	10kV-41	东18	5542	400	174.53	43.63%	0	2015	
189	东门	0	10kV-42	东21	5542	400	299.32	74.83%	0	286	
190	东门	0	10kV-42	东22	5542	400	0.59	0.15%	0	4425	
191	东门	0	10kV-42	东23	5542	400	256.75	64.19%	0	876	
192	东门	0	10kV-42	东24	5542	400	311.11	77.78%	0	123	
193	东门	0	10kV-43	东31	5542	400	289.29	72.32%	0	425	
194	东门	0	10kV-43	东32	5542	400	158.12	39.53%	0	2243	
195	东门	0	10kV-43	东33	5542	400	0.70	0.18%	0	4424	
196	东门	0	10kV-43	东34	5542	400	315.70	78.93%	0	60	
197	东门	0	10kV-44	东41	5542	400	227.75	56.94%	0	1278	
198	东门	0	10kV-44	东42	5542	400	43.49	10.87%	0	3831	
199	东门	0	10kV-44	东43	5542	400	120.50	30.12%	0	2764	
200	东门	0	10kV-44	东44	5542	400	113.11	28.28%	0	2866	
201	东门	0	10kV-44	东45	5542	400	191.88	47.97%	0	1775	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
202	东门	0	10kV-44	东46	5542	400	255.65	63.91%	0	892	
203	东门	0	10kV-44	东47	5542	400	196.92	49.23%	0	1705	
204	东门	0	10kV-44	东48	5542	400	187.90	46.97%	0	1830	
205	东桑园	0	10kV-4	东11	5542	400	195.87	48.97%	0	1720	
206	东桑园	0	10kV-5	东12	5542	400	303.54	75.89%	0	228	
207	东桑园	0	10kV-4	东13	5542	400	244.98	61.25%	0	1039	
208	东桑园	0	10kV-5	东14	5542	400	210.75	52.69%	0	1514	
209	东桑园	0	10kV-4	东15	5542	400	181.10	45.27%	0	1924	
210	东桑园	0	10kV-5	东16	5542	400	120.38	30.10%	0	2766	
211	东桑园	0	10kV-4	东17	5542	400	207.82	51.96%	0	1554	
212	东桑园	0	10kV-5	东18	5542	400	174.53	43.63%	0	2015	
213	东桑园	0	10kV-4	东19	5542	400	190.91	47.73%	0	1789	
214	东桑园	0	10kV-4	东21	5542	400	299.32	74.83%	0	286	
215	东桑园	0	10kV-5	东22	5542	400	0.59	0.15%	0	4425	
216	东桑园	0	10kV-5	东24	5542	400	251.11	62.78%	0	954	
217	二马路	0	10kV-41	马11	5542	400	99.61	24.90%	0	3054	
218	二马路	0	10kV-41	马12	5542	400	103.59	25.90%	0	2998	
219	二马路	0	10kV-41	马13	5542	400	161.37	40.34%	0	2198	
220	二马路	0	10kV-41	马14	5542	400	37.50	9.38%	0	3914	
221	二马路	0	10kV-41	马15	5542	400	37.15	9.29%	0	3919	
222	二马路	0	10kV-41	马16	5542	400	257.58	64.39%	0	865	
223	二马路	0	10kV-41	马17	5542	400	173.44	43.36%	0	2031	
224	二马路	0	10kV-41	马18	5542	400	99.84	24.96%	0	3050	
225	二马路	0	10kV-42	马21	5542	400	37.73	9.43%	0	3911	
226	二马路	0	10kV-43	马32	5542	400	126.91	31.73%	0	2675	
227	二马路	0	10kV-43	马34	5542	400	72.07	18.02%	0	3435	
228	二马路	0	10kV-44	马41	5542	400	264.09	66.02%	0	775	
229	二马路	0	10kV-44	马42	5542	400	32.58	8.14%	0	3982	
230	二马路	0	10kV-44	马43	5542	400	276.80	69.20%	0	599	
231	二马路	0	10kV-44	马44	5542	400	62.93	15.73%	0	3562	
232	二马路	0	10kV-44	马45	5542	400	49.80	12.45%	0	3744	
233	二马路	0	10kV-44	马46	5542	400	70.55	17.64%	0	3456	
234	二马路	0	10kV-44	马47	5542	400	174.96	43.74%	0	2010	
235	二马路	0	10kV-44	马48	5542	400	50.39	12.60%	0	3735	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
236	丰泽道	0	10kV-41	丰12	5542	400	128.40	32.10%	0	2655	
237	丰泽道	0	10kV-41	丰13	5542	400	225.84	56.46%	0	1305	
238	丰泽道	0	10kV-41	丰14	5542	400	314.88	78.72%	0	71	
239	丰泽道	0	10kV-41	丰15	5542	400	72.24	18.06%	0	3433	
240	丰泽道	0	10kV-41	丰16	5542	400	281.16	70.29%	0	538	
241	丰泽道	0	10kV-44	丰41	5542	400	217.92	54.48%	0	1414	
242	丰泽道	0	10kV-44	丰42	5542	400	245.40	61.35%	0	1034	
243	丰泽道	0	10kV-44	丰43	5542	400	207.00	51.75%	0	1566	
244	丰泽道	0	10kV-44	丰44	5542	400	245.64	61.41%	0	1030	
245	丰泽道	0	10kV-44	丰47	5542	400	186.96	46.74%	0	1843	
246	丰泽道	0	10kV-44	丰48	5542	400	239.64	59.91%	0	1113	
247	复康路	0	10kV-41	复11	5542	400	218.66	54.66%	0	1404	
248	复康路	0	10kV-41	复12	5542	400	82.88	20.72%	0	3285	
249	复康路	0	10kV-41	复13	5542	400	245.25	61.31%	0	1036	
250	复康路	0	10kV-41	复14	5542	400	253.35	63.34%	0	923	
251	复康路	0	10kV-41	复15	5542	400	208.72	52.18%	0	1542	
252	复康路	0	10kV-41	复16	5542	400	178.06	44.52%	0	1967	
253	复康路	0	10kV-44	复41	5542	400	124.89	31.22%	0	2703	
254	复康路	0	10kV-44	复42	5542	400	206.97	51.74%	0	1566	
255	复康路	0	10kV-44	复43	5542	400	264.40	66.10%	0	770	
256	复康路	0	10kV-44	复44	5542	400	308.82	77.21%	0	155	
257	复康路	0	10kV-44	复45	5542	400	66.95	16.74%	0	3506	
258	复康路	0	10kV-44	复46	5542	400	313.96	78.49%	0	84	
259	复康路	0	10kV-44	复47	5542	400	256.02	64.00%	0	887	
260	高教区	0	10kV-41	高15	5542	400	319.08	79.77%	0	13	
261	高教区	0	10kV-41	高16	5542	400	293.64	73.41%	0	365	
262	高教区	0	10kV-41	高17	5542	400	215.76	53.94%	0	1444	
263	高教区	0	10kV-41	高18	5542	400	236.40	59.10%	0	1158	
264	高教区	0	10kV-42	高21	5542	400	264.48	66.12%	0	769	
265	高教区	0	10kV-42	高22	5542	400	236.76	59.19%	0	1153	
266	高教区	0	10kV-42	高23	5542	400	291.12	72.78%	0	400	
267	高教区	0	10kV-42	高24	5542	400	266.69	66.67%	0	739	
268	高教区	0	10kV-43	高25	5542	400	274.37	68.59%	0	632	
269	高教区	0	10kV-43	高26	5542	400	273.12	68.28%	0	650	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
270	高教区	0	10kV-43	高27	5542	400	170.76	42.69%	0	2068	
271	高教区	0	10kV-43	高28	5542	400	152.04	38.01%	0	2327	
272	高教区	0	10kV-44	高31	5542	400	313.44	78.36%	0	91	
273	高教区	0	10kV-44	高33	5542	400	221.28	55.32%	0	1368	
274	高教区	0	10kV-44	高34	5542	400	240.84	60.21%	0	1097	
275	光荣道	0	10kV-41	荣11	5542	400	213.07	53.27%	0	1482	
276	光荣道	0	10kV-41	荣12	5542	400	200.06	50.02%	0	1662	
277	光荣道	0	10kV-41	荣13	5542	400	72.78	18.20%	0	3425	
278	光荣道	0	10kV-41	荣14	5542	400	151.36	37.84%	0	2336	
279	光荣道	0	10kV-41	荣15	5542	400	195.14	48.78%	0	1730	
280	光荣道	0	10kV-41	荣16	5542	400	84.38	21.10%	0	3264	
281	光荣道	0	10kV-41	荣17	5542	400	59.07	14.77%	0	3615	
282	光荣道	0	10kV-41	荣18	5542	400	61.53	15.38%	0	3581	
283	光荣道	0	10kV-42	荣21	5542	400	257.02	64.25%	0	873	
284	光荣道	0	10kV-42	荣22	5542	400	103.02	25.75%	0	3006	
285	光荣道	0	10kV-42	荣23	5542	400	173.16	43.29%	0	2034	
286	光荣道	0	10kV-42	荣24	5542	400	125.35	31.34%	0	2697	
287	光荣道	0	10kV-43	荣31	5542	400	91.42	22.85%	0	3167	
288	光荣道	0	10kV-43	荣33	5542	400	154.35	38.59%	0	2295	
289	光荣道	0	10kV-43	荣34	5542	400	121.30	30.33%	0	2753	
290	光荣道	0	10kV-44	荣42	5542	400	173.69	43.42%	0	2027	
291	光荣道	0	10kV-44	荣43	5542	400	267.36	66.84%	0	729	
292	光荣道	0	10kV-44	荣44	5542	400	36.04	9.01%	0	3934	
293	光荣道	0	10kV-44	荣45	5542	400	124.47	31.12%	0	2709	
294	光荣道	0	10kV-44	荣46	5542	400	98.98	24.74%	0	3062	
295	光荣道	0	10kV-44	荣47	5542	400	64.87	16.22%	0	3535	
296	光荣道	0	10kV-44	荣48	5542	400	39.03	9.76%	0	3893	
297	海泰	0	10kV-41	泰11	5542	400	106.46	26.61%	0	2959	
298	海泰	0	10kV-41	泰12	5542	400	295.72	73.93%	0	336	
299	海泰	0	10kV-41	泰13	5542	400	218.93	54.73%	0	1400	
300	海泰	0	10kV-41	泰14	5542	400	19.87	4.97%	0	4158	
301	海泰	0	10kV-41	泰15	5542	400	259.62	64.91%	0	837	
302	海泰	0	10kV-41	泰16	5542	400	289.78	72.45%	0	419	
303	海泰	0	10kV-42	泰21	5542	400	173.71	43.43%	0	2027	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
304	海泰	0	10kV-42	泰22	5542	400	219.06	54.77%	0	1398	
305	海泰	0	10kV-42	泰23	5542	400	104.03	26.01%	0	2992	
306	海泰	0	10kV-42	泰24	5542	400	253.38	63.34%	0	923	
307	海泰	0	10kV-42	泰25	5542	400	145.25	36.31%	0	2421	
308	海泰	0	10kV-42	泰26	5542	400	288.77	72.19%	0	433	
309	海泰	0	10kV-43	泰31	5542	400	276.23	69.06%	0	606	
310	海泰	0	10kV-44	泰41	5542	400	31.10	7.77%	0	4003	
311	海泰	0	10kV-44	泰42	5542	400	205.65	51.41%	0	1584	
312	海泰	0	10kV-45	泰51	5542	400	107.83	26.96%	0	2940	
313	海泰	0	10kV-45	泰52	5542	400	308.70	77.18%	0	157	
314	海泰	0	10kV-45	泰53	5542	400	122.73	30.68%	0	2733	
315	海泰	0	10kV-45	泰54	5542	400	242.56	60.64%	0	1073	
316	海泰	0	10kV-45	泰55	5542	400	252.67	63.17%	0	933	
317	海泰	0	10kV-45	泰56	5542	400	291.50	72.88%	0	395	
318	海泰	0	10kV-46	泰61	5542	400	265.06	66.26%	0	761	
319	海泰	0	10kV-46	泰62	5542	400	55.83	13.96%	0	3660	
320	海泰	0	10kV-46	泰63	5542	400	314.62	78.65%	0	75	
321	海泰	0	10kV-46	泰64	5542	400	65.36	16.34%	0	3528	
322	海泰	0	10kV-46	泰65	5542	400	225.38	56.35%	0	1311	
323	海泰	0	10kV-46	泰66	5542	400	83.19	20.80%	0	3281	
324	红泥河	0	10kV-42	红21	5542	400	227.58	56.89%	0	1280	
325	红泥河	0	10kV-42	红22	5542	400	244.53	61.13%	0	1046	
326	红泥河	0	10kV-42	红23	5542	400	261.92	65.48%	0	805	
327	红泥河	0	10kV-42	红24	5542	400	237.42	59.36%	0	1144	
328	红泥河	0	10kV-43	红31	5542	400	284.16	71.04%	0	497	
329	红泥河	0	10kV-43	红32	5542	400	226.17	56.54%	0	1300	
330	红泥河	0	10kV-43	红33	5542	400	226.63	56.66%	0	1294	
331	红泥河	0	10kV-43	红34	5542	400	184.22	46.05%	0	1881	
332	红泥河	0	10kV-44	红41	5542	400	286.63	71.66%	0	462	
333	红泥河	0	10kV-44	红42	5542	400	312.47	78.12%	0	104	
334	红泥河	0	10kV-44	红43	5542	400	296.84	74.21%	0	321	
335	红泥河	0	10kV-44	红44	5542	400	263.32	65.83%	0	785	
336	红泥河	0	10kV-44	红45	5542	400	294.02	73.51%	0	360	
337	红泥河	0	10kV-44	红46	5542	400	216.33	54.08%	0	1436	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
338	红泥河	0	10kV-44	红47	5542	400	262.62	65.65%	0	795	
339	红泥河	0	10kV-44	红48	5542	400	306.45	76.61%	0	188	
340	环翠路	0	10kV-41	翠11	5542	400	155.21	38.80%	0	2283	
341	环翠路	0	10kV-41	翠12	5542	400	50.10	12.52%	0	3739	
342	环翠路	0	10kV-41	翠13	5542	400	28.13	7.03%	0	4044	
343	环翠路	0	10kV-41	翠15	5542	400	215.16	53.79%	0	1453	
344	环翠路	0	10kV-41	翠16	5542	400	131.13	32.78%	0	2617	
345	环翠路	0	10kV-41	翠17	5542	400	40.08	10.02%	0	3878	
346	环翠路	0	10kV-41	翠18	5542	400	158.91	39.73%	0	2232	
347	环翠路	0	10kV-43	翠32	5542	400	219.90	54.98%	0	1387	
348	环翠路	0	10kV-43	翠33	5542	400	176.48	44.12%	0	1988	
349	环翠路	0	10kV-44	翠41	5542	400	59.59	14.90%	0	3608	
350	环翠路	0	10kV-44	翠42	5542	400	179.82	44.96%	0	1942	
351	环翠路	0	10kV-44	翠45	5542	400	203.91	50.98%	0	1608	
352	环翠路	0	10kV-44	翠46	5542	400	194.24	48.56%	0	1742	
353	环翠路	0	10kV-44	翠47	5542	400	245.21	61.30%	0	1036	
354	环翠路	0	10kV-44	翠48	5542	400	214.98	53.75%	0	1455	
355	惠友道	0	10kV-41	友11	5542	400	244.32	61.08%	0	1049	
356	惠友道	0	10kV-41	友12	5542	400	314.80	78.70%	0	72	
357	惠友道	0	10kV-41	友13	5542	400	158.00	39.50%	0	2245	
358	惠友道	0	10kV-41	友14	5542	400	150.32	37.58%	0	2351	
359	惠友道	0	10kV-41	友15	5542	400	29.52	7.38%	0	4025	
360	惠友道	0	10kV-41	友16	5542	400	196.00	49.00%	0	1718	
361	惠友道	0	10kV-42	友21	5542	400	289.15	72.29%	0	427	
362	惠友道	0	10kV-42	友22	5542	400	302.24	75.56%	0	246	
363	惠友道	0	10kV-42	友23	5542	400	130.64	32.66%	0	2624	
364	惠友道	0	10kV-42	友24	5542	400	313.20	78.30%	0	94	
365	惠友道	0	10kV-42	友25	5542	400	151.04	37.76%	0	2341	
366	惠友道	0	10kV-42	友26	5542	400	144.64	36.16%	0	2430	
367	惠友道	0	10kV-45	友51	5542	400	268.64	67.16%	0	712	
368	惠友道	0	10kV-45	友52	5542	400	297.52	74.38%	0	311	
369	惠友道	0	10kV-45	友53	5542	400	183.68	45.92%	0	1889	
370	惠友道	0	10kV-45	友54	5542	400	131.06	32.76%	0	2618	
371	惠友道	0	10kV-45	友55	5542	400	14.80	3.70%	0	4229	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
372	惠友道	0	10kV-45	友56	5542	400	287.60	71.90%	0	449	
373	惠友道	0	10kV-46	友61	5542	400	276.56	69.14%	0	602	
374	惠友道	0	10kV-46	友62	5542	400	274.64	68.66%	0	628	
375	惠友道	0	10kV-46	友63	5542	400	179.76	44.94%	0	1943	
376	惠友道	0	10kV-46	友64	5542	400	83.04	20.76%	0	3283	
377	惠友道	0	10kV-46	友65	5542	400	167.68	41.92%	0	2110	
378	惠友道	0	10kV-46	友66	5542	400	217.74	54.43%	0	1417	
379	精武	0	10kV-41	精11	5542	400	182.24	45.56%	0	1909	
380	精武	0	10kV-41	精12	5542	400	261.56	65.39%	0	810	
381	精武	0	10kV-41	精13	5542	400	150.51	37.63%	0	2348	
382	精武	0	10kV-41	精14	5542	400	271.26	67.82%	0	675	
383	精武	0	10kV-41	精15	5542	400	260.42	65.10%	0	826	
384	精武	0	10kV-41	精16	5542	400	184.32	46.08%	0	1880	
385	精武	0	10kV-41	精17	5542	400	295.41	73.85%	0	341	
386	精武	0	10kV-41	精18	5542	400	159.82	39.95%	0	2219	
387	精武	0	10kV-42	精21	5542	400	92.53	23.13%	0	3152	
388	精武	0	10kV-42	精22	5542	400	277.79	69.45%	0	585	
389	精武	0	10kV-42	精23	5542	400	210.08	52.52%	0	1523	
390	精武	0	10kV-42	精24	5542	400	300.79	75.20%	0	266	
391	精武	0	10kV-43	精25	5542	400	242.22	60.55%	0	1078	
392	精武	0	10kV-43	精26	5542	400	291.94	72.99%	0	389	
393	精武	0	10kV-43	精27	5542	400	305.77	76.44%	0	197	
394	精武	0	10kV-43	精28	5542	400	196.55	49.14%	0	1710	
395	精武	0	10kV-44	精41	5542	400	252.84	63.21%	0	931	
396	老君堂	0	10kV-43	君31	5542	400	274.92	68.73%	0	625	
397	老君堂	0	10kV-43	君32	5542	400	241.94	60.48%	0	1082	
398	老君堂	0	10kV-43	君34	5542	400	146.06	36.52%	0	2410	
399	老君堂	0	10kV-43	君35	5542	400	78.10	19.53%	0	3351	
400	老君堂	0	10kV-43	君36	5542	400	137.92	34.48%	0	2523	
401	老君堂	0	10kV-44	君41	5542	400	108.12	27.03%	0	2936	
402	老君堂	0	10kV-44	君42	5542	400	136.66	34.16%	0	2540	
403	老君堂	0	10kV-44	君44	5542	400	226.50	56.62%	0	1295	
404	老君堂	0	10kV-44	君45	5542	400	261.94	65.49%	0	804	
405	老君堂	0	10kV-44	君46	5542	400	188.98	47.25%	0	1815	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
406	老君堂	0	10kV-45	君51	5542	400	211.75	52.94%	0	1500	
407	老君堂	0	10kV-45	君53	5542	400	271.05	67.76%	0	678	
408	老君堂	0	10kV-45	君54	5542	400	229.28	57.32%	0	1257	
409	老君堂	0	10kV-45	君56	5542	400	291.55	72.89%	0	394	
410	老君堂	0	10kV-46	君62	5542	400	257.50	64.38%	0	866	
411	老君堂	0	10kV-46	君63	5542	400	263.68	65.92%	0	780	
412	老君堂	0	10kV-46	君66	5542	400	228.67	57.17%	0	1265	
413	梨园头	0	10kV-41	梨11	5542	400	174.14	43.53%	0	2021	
414	梨园头	0	10kV-41	梨12	5542	400	204.02	51.00%	0	1607	
415	梨园头	0	10kV-41	梨13	5542	400	211.24	52.81%	0	1507	
416	梨园头	0	10kV-41	梨14	5542	400	216.27	54.07%	0	1437	
417	梨园头	0	10kV-41	梨15	5542	400	314.70	78.67%	0	73	
418	梨园头	0	10kV-41	梨16	5542	400	143.89	35.97%	0	2440	
419	梨园头	0	10kV-41	梨17	5542	400	149.93	37.48%	0	2356	
420	梨园头	0	10kV-42	梨21	5542	400	302.50	75.62%	0	243	
421	梨园头	0	10kV-42	梨22	5542	400	252.02	63.00%	0	942	
422	梨园头	0	10kV-42	梨23	5542	400	193.59	48.40%	0	1751	
423	梨园头	0	10kV-42	梨24	5542	400	308.50	77.12%	0	159	
424	梨园头	0	10kV-43	梨31	5542	400	229.39	57.35%	0	1255	
425	梨园头	0	10kV-43	梨32	5542	400	300.37	75.09%	0	272	
426	梨园头	0	10kV-43	梨33	5542	400	294.45	73.61%	0	354	
427	梨园头	0	10kV-43	梨34	5542	400	267.86	66.96%	0	722	
428	凌庄子	0	10kV-41	凌11	5542	400	82.44	20.61%	0	3291	
429	凌庄子	0	10kV-41	凌12	5542	400	120.06	30.02%	0	2770	
430	凌庄子	0	10kV-41	凌13	5542	400	161.55	40.39%	0	2195	
431	凌庄子	0	10kV-41	凌15	5542	400	192.31	48.08%	0	1769	
432	凌庄子	0	10kV-41	凌16	5542	400	262.97	65.74%	0	790	
433	凌庄子	0	10kV-41	凌17	5542	400	127.97	31.99%	0	2661	
434	凌庄子	0	10kV-41	凌18	5542	400	89.30	22.32%	0	3196	
435	凌庄子	0	10kV-42	凌21	5542	400	133.07	33.27%	0	2590	
436	凌庄子	0	10kV-42	凌22	5542	400	100.37	25.09%	0	3043	
437	凌庄子	0	10kV-42	凌23	5542	400	245.22	61.30%	0	1036	
438	凌庄子	0	10kV-42	凌24	5542	400	243.11	60.78%	0	1065	
439	凌庄子	0	10kV-43	凌25	5542	400	66.97	16.74%	0	3506	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
440	凌庄子	0	10kV-43	凌26	5542	400	24.96	6.24%	0	4088	
441	凌庄子	0	10kV-43	凌28	5542	400	90.35	22.59%	0	3182	
442	凌庄子	0	10kV-44	凌31	5542	400	91.76	22.94%	0	3162	
443	凌庄子	0	10kV-44	凌32	5542	400	118.13	29.53%	0	2797	
444	凌庄子	0	10kV-44	凌33	5542	400	168.75	42.19%	0	2096	
445	凌庄子	0	10kV-44	凌34	5542	400	251.20	62.80%	0	953	
446	凌庄子	0	10kV-44	凌36	5542	400	280.20	70.05%	0	551	
447	凌庄子	0	10kV-44	凌37	5542	400	132.89	33.22%	0	2592	
448	凌庄子	0	10kV-44	凌38	5542	400	82.97	20.74%	0	3284	
449	刘庄	0	10kV-41	刘11	5542	400	122.06	30.51%	0	2742	
450	刘庄	0	10kV-41	刘12	5542	400	265.01	66.25%	0	762	
451	刘庄	0	10kV-41	刘13	5542	400	229.79	57.45%	0	1250	
452	刘庄	0	10kV-41	刘14	5542	400	221.51	55.38%	0	1365	
453	刘庄	0	10kV-41	刘15	5542	400	121.53	30.38%	0	2750	
454	刘庄	0	10kV-41	刘17	5542	400	230.10	57.53%	0	1246	
455	刘庄	0	10kV-41	刘21	5542	400	93.41	23.35%	0	3139	
456	刘庄	0	10kV-41	刘22	5542	400	23.10	5.78%	0	4114	
457	刘庄	0	10kV-41	刘23	5542	400	253.41	63.35%	0	923	
458	刘庄	0	10kV-42	刘24	5542	400	168.72	42.18%	0	2096	
459	刘庄	0	10kV-42	刘25	5542	400	227.25	56.81%	0	1285	
460	刘庄	0	10kV-42	刘26	5542	400	363.14	90.79%	0	0	
461	刘庄	0	10kV-43	刘31	5542	400	111.89	27.97%	0	2883	
462	刘庄	0	10kV-43	刘32	5542	400	259.64	64.91%	0	836	
463	刘庄	0	10kV-43	刘33	5542	400	270.52	67.63%	0	685	
464	刘庄	0	10kV-43	刘35	5542	400	53.25	13.31%	0	3696	
465	刘庄	0	10kV-43	刘36	5542	400	233.11	58.28%	0	1204	
466	柳霞路	0	10kV-41	霞11	5542	400	212.52	53.13%	0	1489	
467	柳霞路	0	10kV-41	霞12	5542	400	130.25	32.56%	0	2629	
468	柳霞路	0	10kV-41	霞13	5542	400	213.05	53.26%	0	1482	
469	柳霞路	0	10kV-41	霞14	5542	400	179.47	44.87%	0	1947	
470	柳霞路	0	10kV-41	霞15	5542	400	164.53	41.13%	0	2154	
471	柳霞路	0	10kV-41	霞16	5542	400	46.76	11.69%	0	3786	
472	柳霞路	0	10kV-41	霞17	5542	400	40.96	10.24%	0	3866	
473	柳霞路	0	10kV-42	霞21	5542	400	238.18	59.55%	0	1134	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
474	柳霞路	0	10kV-42	霞22	5542	400	106.17	26.54%	0	2963	
475	柳霞路	0	10kV-42	霞23	5542	400	45.53	11.38%	0	3803	
476	柳霞路	0	10kV-43	霞25	5542	400	125.68	31.42%	0	2692	
477	柳霞路	0	10kV-44	霞31	5542	400	158.38	39.59%	0	2239	
478	柳霞路	0	10kV-44	霞32	5542	400	203.38	50.84%	0	1616	
479	柳霞路	0	10kV-44	霞33	5542	400	34.80	8.70%	0	3951	
480	柳霞路	0	10kV-44	霞34	5542	400	141.68	35.42%	0	2471	
481	柳霞路	0	10kV-44	霞35	5542	400	112.15	28.04%	0	2880	
482	柳霞路	0	10kV-44	霞36	5542	400	103.71	25.93%	0	2997	
483	芦北口	0	10kV-41	芦11	5542	400	214.04	53.51%	0	1468	
484	芦北口	0	10kV-41	芦12	5542	400	174.30	43.58%	0	2019	
485	芦北口	0	10kV-41	芦13	5542	400	44.19	11.05%	0	3821	
486	芦北口	0	10kV-41	芦14	5542	400	167.97	41.99%	0	2106	
487	芦北口	0	10kV-41	芦15	5542	400	231.97	57.99%	0	1220	
488	芦北口	0	10kV-41	芦16	5542	400	111.36	27.84%	0	2891	
489	芦北口	0	10kV-41	芦17	5542	400	302.77	75.69%	0	239	
490	芦北口	0	10kV-41	芦18	5542	400	315.43	78.86%	0	63	
491	芦北口	0	10kV-42	芦21	5542	400	49.35	12.34%	0	3750	
492	芦北口	0	10kV-42	芦22	5542	400	260.78	65.20%	0	820	
493	芦北口	0	10kV-42	芦24	5542	400	281.67	70.42%	0	531	
494	芦北口	0	10kV-43	芦31	5542	400	270.07	67.52%	0	692	
495	芦北口	0	10kV-43	芦32	5542	400	284.00	71.00%	0	499	
496	芦北口	0	10kV-43	芦33	5542	400	282.26	70.56%	0	523	
497	芦北口	0	10kV-43	芦34	5542	400	258.58	64.64%	0	851	
498	密云路	0	10kV-41	密11	5542	400	138.00	34.50%	0	2522	
499	密云路	0	10kV-41	密12	5542	400	197.40	49.35%	0	1699	
500	密云路	0	10kV-41	密13	5542	400	158.16	39.54%	0	2242	
501	密云路	0	10kV-41	密14	5542	400	310.44	77.61%	0	132	
502	密云路	0	10kV-41	密15	5542	400	131.52	32.88%	0	2611	
503	密云路	0	10kV-41	密16	5542	400	239.76	59.94%	0	1112	
504	密云路	0	10kV-41	密17	5542	400	105.60	26.40%	0	2971	
505	密云路	0	10kV-42	密20	5542	400	55.44	13.86%	0	3665	
506	密云路	0	10kV-42	密23	5542	400	181.80	45.45%	0	1915	
507	密云路	0	10kV-43	密31	5542	400	312.72	78.18%	0	101	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
508	密云路	0	10kV-43	密32	5542	400	294.82	73.70%	0	349	
509	密云路	0	10kV-43	密33	5542	400	45.48	11.37%	0	3803	
510	密云路	0	10kV-44	密41	5542	400	113.28	28.32%	0	2864	
511	密云路	0	10kV-44	密42	5542	400	217.92	54.48%	0	1414	
512	密云路	0	10kV-44	密43	5542	400	79.80	19.95%	0	3328	
513	密云路	0	10kV-44	密44	5542	400	162.36	40.59%	0	2184	
514	密云路	0	10kV-44	密45	5542	400	273.12	68.28%	0	650	
515	密云路	0	10kV-44	密46	5542	400	237.48	59.37%	0	1143	
516	南开	0	10kV-5	90	5542	400	319.20	79.80%	0	11	
517	南开	0	10kV-4	91	5542	400	204.00	51.00%	0	1607	
518	南开	0	10kV-5	92	5542	400	221.00	55.25%	0	1372	
519	南开	0	10kV-4	93	5542	400	155.81	38.95%	0	2275	
520	南开	0	10kV-5	94	5542	400	250.00	62.50%	0	970	
521	南开	0	10kV-4	95	5542	400	266.00	66.50%	0	748	
522	南开	0	10kV-5	96	5542	400	146.00	36.50%	0	2411	
523	南开	0	10kV-4	97	5542	400	201.53	50.38%	0	1641	
524	南开	0	10kV-5	98	5542	400	95.00	23.75%	0	3117	
525	南开	0	10kV-5	99	5542	400	118.56	29.64%	0	2791	
526	南口	0	10kV-41	南11	5542	400	309.96	77.49%	0	139	
527	南口	0	10kV-41	南12	5542	400	267.77	66.94%	0	724	
528	南口	0	10kV-41	南13	5542	400	255.55	63.89%	0	893	
529	南口	0	10kV-41	南14	5542	400	259.57	64.89%	0	837	
530	南口	0	10kV-41	南15	5542	400	236.72	59.18%	0	1154	
531	南口	0	10kV-41	南16	5542	400	139.45	34.86%	0	2501	
532	南口	0	10kV-41	南17	5542	400	275.10	68.77%	0	622	
533	南口	0	10kV-41	南18	5542	400	242.87	60.72%	0	1069	
534	南口	0	10kV-42	南21	5542	400	221.19	55.30%	0	1369	
535	南口	0	10kV-42	南22	5542	400	280.31	70.08%	0	550	
536	南口	0	10kV-42	南23	5542	400	311.02	77.75%	0	124	
537	南口	0	10kV-42	南24	5542	400	215.33	53.83%	0	1450	
538	南口	0	10kV-43	南25	5542	400	128.03	32.01%	0	2660	
539	南口	0	10kV-43	南26	5542	400	103.71	25.93%	0	2997	
540	南口	0	10kV-43	南27	5542	400	223.24	55.81%	0	1341	
541	南口	0	10kV-43	南28	5542	400	231.15	57.79%	0	1231	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
542	南口	0	10kV-44	南32	5542	400	292.50	73.13%	0	381	
543	南口	0	10kV-44	南33	5542	400	228.52	57.13%	0	1268	
544	南口	0	10kV-44	南34	5542	400	132.54	33.13%	0	2597	
545	南口	0	10kV-44	南35	5542	400	244.34	61.08%	0	1048	
546	南口	0	10kV-44	南37	5542	400	273.94	68.48%	0	638	
547	南口	0	10kV-44	南38	5542	400	199.34	49.83%	0	1672	
548	南门西	0	10kV-41	南11	5542	400	309.96	77.49%	0	139	
549	南门西	0	10kV-41	南12	5542	400	267.77	66.94%	0	724	
550	南门西	0	10kV-41	南13	5542	400	285.55	71.39%	0	477	
551	南门西	0	10kV-41	南14	5542	400	259.57	64.89%	0	837	
552	南门西	0	10kV-41	南15	5542	400	236.72	59.18%	0	1154	
553	南门西	0	10kV-41	南16	5542	400	139.45	34.86%	0	2501	
554	南门西	0	10kV-41	南17	5542	400	275.10	68.77%	0	622	
555	南门西	0	10kV-42	南21	5542	400	221.19	55.30%	0	1369	
556	南门西	0	10kV-42	南22	5542	400	280.31	70.08%	0	550	
557	南门西	0	10kV-42	南23	5542	400	311.02	77.75%	0	124	
558	南门西	0	10kV-42	南24	5542	400	215.33	53.83%	0	1450	
559	南门西	0	10kV-43	南31	5542	400	0.00	0.00%	0	4434	
560	南门西	0	10kV-43	南32	5542	400	292.50	73.13%	0	381	
561	南门西	0	10kV-43	南33	5542	400	228.52	57.13%	0	1268	
562	南门西	0	10kV-43	南34	5542	400	132.54	33.13%	0	2597	
563	南门西	0	10kV-44	南40	5542	400	117.25	29.31%	0	2809	
564	南门西	0	10kV-44	南41	5542	400	114.79	28.70%	0	2843	
565	南门西	0	10kV-44	南42	5542	400	197.05	49.26%	0	1703	
566	南门西	0	10kV-44	南43	5542	400	161.72	40.43%	0	2193	
567	南门西	0	10kV-44	南44	5542	400	184.57	46.14%	0	1876	
568	南门西	0	10kV-44	南45	5542	400	85.08	21.27%	0	3255	
569	南门西	0	10kV-44	南46	5542	400	35.86	8.96%	0	3937	
570	南门西	0	10kV-44	南47	5542	400	92.64	23.16%	0	3150	
571	年丰路	0	10kV-41	年11	5542	400	100.63	25.16%	0	3039	
572	年丰路	0	10kV-41	年12	5542	400	14.09	3.52%	0	4238	
573	年丰路	0	10kV-41	年13	5542	400	271.33	67.83%	0	674	
574	年丰路	0	10kV-41	年15	5542	400	314.35	78.59%	0	78	
575	年丰路	0	10kV-41	年16	5542	400	70.07	17.52%	0	3463	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
576	年丰路	0	10kV-42	年24	5542	400	289.05	72.26%	0	429	
577	年丰路	0	10kV-43	年32	5542	400	152.47	38.12%	0	2321	
578	年丰路	0	10kV-43	年33	5542	400	16.26	4.07%	0	4208	
579	年丰路	0	10kV-43	年34	5542	400	272.36	68.09%	0	660	
580	年丰路	0	10kV-43	年35	5542	400	235.18	58.80%	0	1175	
581	年丰路	0	10kV-43	年36	5542	400	177.02	44.26%	0	1981	
582	勤俭道临时	0	10kV-5	820	5542	400	153.82	38.46%	0	2302	
583	勤俭道临时	0	10kV-4	821	5542	400	70.05	17.51%	0	3463	
584	勤俭道临时	0	10kV-5	822	5542	400	253.09	63.27%	0	927	
585	勤俭道临时	0	10kV-5	824	5542	400	0.00	0.00%	0	4434	
586	勤俭道临时	0	10kV-4	825	5542	400	260.76	65.19%	0	821	
587	勤俭道临时	0	10kV-5	826	5542	400	83.78	20.94%	0	3273	
588	勤俭道临时	0	10kV-5	828	5542	400	127.60	31.90%	0	2666	
589	勤俭道临时	0	10kV-4	829	5542	400	59.84	14.96%	0	3605	
590	勤俭道临时	0	10kV-4	831	5542	400	246.75	61.69%	0	1015	
591	勤俭道临时	0	10kV-5	832	5542	400	300.78	75.20%	0	266	
592	勤俭道临时	0	10kV-4	833	5542	400	139.04	34.76%	0	2507	
593	勤俭道临时	0	10kV-5	834	5542	400	136.75	34.19%	0	2539	
594	勤俭道临时	0	10kV-5	836	5542	400	51.39	12.85%	0	3722	
595	青泊洼	0	10kV-41	泊11	5542	400	251.78	62.94%	0	945	
596	青泊洼	0	10kV-41	泊12	5542	400	289.40	72.35%	0	424	
597	青泊洼	0	10kV-41	泊13	5542	400	259.37	64.84%	0	840	
598	青泊洼	0	10kV-42	泊21	5542	400	237.01	59.25%	0	1150	
599	青泊洼	0	10kV-42	泊22	5542	400	124.48	31.12%	0	2709	
600	青泊洼	0	10kV-42	泊23	5542	400	218.19	54.55%	0	1411	
601	青泊洼	0	10kV-44	泊41	5542	400	289.23	72.31%	0	426	
602	青泊洼	0	10kV-44	泊42	5542	400	170.37	42.59%	0	2073	
603	青泊洼	0	10kV-44	泊43	5542	400	185.49	46.37%	0	1864	
604	邵公庄	0	10kV-42	邵24	5542	400	69.50	17.37%	0	3471	
605	邵公庄	0	10kV-42	邵25	5542	400	172.59	43.15%	0	2042	
606	邵公庄	0	10kV-42	邵26	5542	400	318.13	79.53%	0	26	
607	邵公庄	0	10kV-42	邵27	5542	400	154.07	38.52%	0	2299	
608	邵公庄	0	10kV-42	邵28	5542	400	307.69	76.92%	0	171	
609	邵公庄	0	10kV-42	邵29	5542	400	290.89	72.72%	0	403	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
610	邵公庄	0	10kV-43	邵31	5542	400	31.58	7.90%	0	3996	
611	邵公庄	0	10kV-43	邵32	5542	400	279.77	69.94%	0	557	
612	邵公庄	0	10kV-43	邵33	5542	400	88.90	22.23%	0	3202	
613	邵公庄	0	10kV-44	邵37	5542	400	286.34	71.58%	0	466	
614	邵公庄	0	10kV-44	邵38	5542	400	277.68	69.42%	0	586	
615	邵公庄	0	10kV-44	邵39	5542	400	170.95	42.74%	0	2065	
616	邵公庄	0	10kV-44	邵40	5542	400	91.18	22.79%	0	3170	
617	邵公庄	0	10kV-44	邵41	5542	400	112.36	28.09%	0	2877	
618	邵公庄	0	10kV-44	邵42	5542	400	156.01	39.00%	0	2272	
619	邵公庄	0	10kV-44	邵43	5542	400	295.63	73.91%	0	338	
620	邵公庄	0	10kV-44	邵44	5542	400	247.73	61.93%	0	1001	
621	邵公庄	0	10kV-44	邵45	5542	400	259.88	64.97%	0	833	
622	泰康路	0	10kV-42	康25	5542	400	262.83	65.71%	0	792	
623	泰康路	0	10kV-42	康26	5542	400	282.82	70.71%	0	515	
624	泰康路	0	10kV-44	康47	5542	400	244.89	61.22%	0	1041	
625	泰康路	0	10kV-44	康48	5542	400	302.53	75.63%	0	242	
626	天和路	0	10kV-41	天11	5542	400	163.15	40.79%	0	2173	
627	天和路	0	10kV-41	天13	5542	400	188.84	47.21%	0	1817	
628	天和路	0	10kV-41	天14	5542	400	223.02	55.76%	0	1344	
629	天和路	0	10kV-41	天15	5542	400	199.10	49.78%	0	1675	
630	天和路	0	10kV-41	天16	5542	400	277.27	69.32%	0	592	
631	天和路	0	10kV-41	天17	5542	400	137.08	34.27%	0	2534	
632	天和路	0	10kV-42	天21	5542	400	202.97	50.74%	0	1621	
633	天和路	0	10kV-42	天22	5542	400	120.34	30.08%	0	2766	
634	天和路	0	10kV-42	天24	5542	400	233.02	58.25%	0	1205	
635	天和路	0	10kV-43	天25	5542	400	225.19	56.30%	0	1314	
636	天和路	0	10kV-43	天26	5542	400	257.80	64.45%	0	862	
637	天和路	0	10kV-43	天27	5542	400	69.25	17.31%	0	3474	
638	天和路	0	10kV-43	天28	5542	400	140.41	35.10%	0	2488	
639	天和路	0	10kV-44	天31	5542	400	116.14	29.03%	0	2825	
640	天和路	0	10kV-44	天32	5542	400	284.11	71.03%	0	497	
641	天和路	0	10kV-44	天34	5542	400	193.08	48.27%	0	1758	
642	天和路	0	10kV-44	天35	5542	400	270.70	67.67%	0	683	
643	天和路	0	10kV-44	天36	5542	400	97.58	24.40%	0	3082	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
644	天和路	0	10kV-44	天37	5542	400	146.03	36.51%	0	2410	
645	天和路	0	10kV-44	天38	5542	400	207.68	51.92%	0	1556	
646	天华	0	10kV-4	731	5542	400	235.26	58.82%	0	1174	
647	天华	0	10kV-5	732	5542	400	187.45	46.86%	0	1837	
648	天华	0	10kV-4	733	5542	400	256.61	64.15%	0	878	
649	天华	0	10kV-5	734	5542	400	192.02	48.00%	0	1773	
650	天华	0	10kV-4	735	5542	400	297.56	74.39%	0	311	
651	天华	0	10kV-5	736	5542	400	318.86	79.71%	0	16	
652	天华	0	10kV-4	737	5542	400	121.92	30.48%	0	2744	
653	天华	0	10kV-5	738	5542	400	250.28	62.57%	0	966	
654	天华	0	10kV-4	739	5542	400	242.55	60.64%	0	1073	
655	天华	0	10kV-4	741	5542	400	213.47	53.37%	0	1476	
656	天华	0	10kV-5	742	5542	400	182.41	45.60%	0	1906	
657	天华	0	10kV-4	743	5542	400	52.17	13.04%	0	3711	
658	天华	0	10kV-5	744	5542	400	177.25	44.31%	0	1978	
659	天华	0	10kV-5	746	5542	400	210.07	52.52%	0	1523	
660	万码	0	10kV-42	万21	5542	400	166.32	41.58%	0	2129	
661	万码	0	10kV-42	万22	5542	400	174.97	43.74%	0	2009	
662	万码	0	10kV-42	万23	5542	400	46.25	11.56%	0	3793	
663	万码	0	10kV-42	万24	5542	400	81.06	20.26%	0	3311	
664	万码	0	10kV-43	万31	5542	400	269.11	67.28%	0	705	
665	万码	0	10kV-43	万32	5542	400	258.83	64.71%	0	848	
666	万码	0	10kV-43	万33	5542	400	178.70	44.68%	0	1958	
667	万码	0	10kV-43	万34	5542	400	175.90	43.98%	0	1996	
668	万码	0	10kV-44	万41	5542	400	218.42	54.60%	0	1407	
669	万码	0	10kV-44	万42	5542	400	276.40	69.10%	0	604	
670	万码	0	10kV-44	万43	5542	400	163.99	41.00%	0	2162	
671	万码	0	10kV-44	万44	5542	400	262.10	65.52%	0	802	
672	万码	0	10kV-44	万45	5542	400	228.91	57.23%	0	1262	
673	万码	0	10kV-44	万46	5542	400	175.43	43.86%	0	2003	
674	万码	0	10kV-44	万47	5542	400	197.16	49.29%	0	1702	
675	万码	0	10kV-44	万48	5542	400	281.25	70.31%	0	537	
676	汪庄子	0	10kV-41	汪11	5542	400	319.11	79.78%	0	12	
677	汪庄子	0	10kV-41	汪12	5542	400	312.67	78.17%	0	102	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
678	汪庄子	0	10kV-41	汪13	5542	400	282.48	70.62%	0	520	
679	汪庄子	0	10kV-41	汪14	5542	400	154.69	38.67%	0	2290	
680	汪庄子	0	10kV-41	汪15	5542	400	333.95	83.49%	0	0	
681	汪庄子	0	10kV-41	汪16	5542	400	205.91	51.48%	0	1581	
682	汪庄子	0	10kV-41	汪17	5542	400	237.08	59.27%	0	1149	
683	汪庄子	0	10kV-41	汪18	5542	400	34.81	8.70%	0	3951	
684	汪庄子	0	10kV-42	汪21	5542	400	160.79	40.20%	0	2206	
685	汪庄子	0	10kV-42	汪22	5542	400	206.61	51.65%	0	1571	
686	汪庄子	0	10kV-42	汪23	5542	400	284.78	71.19%	0	488	
687	汪庄子	0	10kV-42	汪24	5542	400	37.50	9.38%	0	3914	
688	汪庄子	0	10kV-43	汪31	5542	400	93.28	23.32%	0	3141	
689	汪庄子	0	10kV-43	汪32	5542	400	253.25	63.31%	0	925	
690	汪庄子	0	10kV-43	汪33	5542	400	310.79	77.70%	0	128	
691	汪庄子	0	10kV-43	汪34	5542	400	276.80	69.20%	0	599	
692	王顶堤	0	10kV-4	181	5542	400	45.70	11.43%	0	3800	
693	王顶堤	0	10kV-5	182	5542	400	138.34	34.58%	0	2517	
694	王顶堤	0	10kV-4	183	5542	400	254.94	63.73%	0	901	
695	王顶堤	0	10kV-5	184	5542	400	138.34	34.58%	0	2517	
696	王顶堤	0	10kV-4	185	5542	400	303.93	75.98%	0	223	
697	王顶堤	0	10kV-5	186	5542	400	176.13	44.03%	0	1993	
698	王顶堤	0	10kV-4	187	5542	400	0.00	0.00%	0	4434	
699	王顶堤	0	10kV-5	188	5542	400	181.93	45.48%	0	1913	
700	王顶堤	0	10kV-4	189	5542	400	297.42	74.36%	0	313	
701	王顶堤	0	10kV-5	190	5542	400	53.79	13.45%	0	3688	
702	王顶堤	0	10kV-4	191	5542	400	241.87	60.47%	0	1082	
703	王顶堤	0	10kV-5	192	5542	400	276.05	69.01%	0	609	
704	王顶堤	0	10kV-5	194	5542	400	272.23	68.06%	0	662	
705	王顶堤	0	10kV-5	196	5542	400	124.80	31.20%	0	2704	
706	微电子	0	10kV-41	511	5542	400	246.19	61.55%	0	1023	
707	微电子	0	10kV-41	512	5542	400	274.76	68.69%	0	627	
708	微电子	0	10kV-41	513	5542	400	185.05	46.26%	0	1870	
709	微电子	0	10kV-41	514	5542	400	264.28	66.07%	0	772	
710	微电子	0	10kV-41	515	5542	400	220.19	55.05%	0	1383	
711	微电子	0	10kV-41	516	5542	400	139.68	34.92%	0	2498	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
712	微电子	0	10kV-41	517	5542	400	313.10	78.28%	0	96	
713	微电子	0	10kV-41	518	5542	400	273.53	68.38%	0	644	
714	微电子	0	10kV-42	521	5542	400	223.66	55.91%	0	1335	
715	微电子	0	10kV-42	522	5542	400	215.40	53.85%	0	1449	
716	微电子	0	10kV-42	523	5542	400	196.82	49.20%	0	1707	
717	微电子	0	10kV-42	524	5542	400	71.82	17.95%	0	3439	
718	微电子	0	10kV-43	525	5542	400	141.18	35.29%	0	2478	
719	微电子	0	10kV-43	526	5542	400	231.94	57.99%	0	1220	
720	微电子	0	10kV-43	527	5542	400	295.29	73.82%	0	342	
721	微电子	0	10kV-43	528	5542	400	265.87	66.47%	0	750	
722	微电子	0	10kV-44	微31	5542	400	312.14	78.03%	0	109	
723	微电子	0	10kV-44	微32	5542	400	197.78	49.45%	0	1693	
724	微电子	0	10kV-44	微33	5542	400	239.56	59.89%	0	1114	
725	微电子	0	10kV-44	微34	5542	400	179.46	44.86%	0	1947	
726	微电子	0	10kV-44	微35	5542	400	226.25	56.56%	0	1299	
727	微电子	0	10kV-44	微36	5542	400	89.22	22.31%	0	3197	
728	微电子	0	10kV-44	微37	5542	400	176.59	44.15%	0	1987	
729	微电子	0	10kV-44	微38	5542	400	242.74	60.69%	0	1070	
730	吴嘴	0	10kV-41	吴11	5542	400	120.60	30.15%	0	2763	
731	吴嘴	0	10kV-41	吴12	5542	400	60.12	15.03%	0	3601	
732	吴嘴	0	10kV-41	吴13	5542	400	78.17	19.54%	0	3351	
733	吴嘴	0	10kV-41	吴14	5542	400	200.75	50.19%	0	1652	
734	吴嘴	0	10kV-41	吴15	5542	400	162.78	40.69%	0	2178	
735	吴嘴	0	10kV-41	吴16	5542	400	131.61	32.90%	0	2610	
736	吴嘴	0	10kV-41	吴17	5542	400	135.12	33.78%	0	2561	
737	吴嘴	0	10kV-41	吴18	5542	400	19.68	4.92%	0	4161	
738	吴嘴	0	10kV-42	吴21	5542	400	153.52	38.38%	0	2307	
739	吴嘴	0	10kV-42	吴22	5542	400	93.75	23.44%	0	3135	
740	吴嘴	0	10kV-42	吴23	5542	400	226.53	56.63%	0	1295	
741	吴嘴	0	10kV-42	吴24	5542	400	114.62	28.65%	0	2846	
742	吴嘴	0	10kV-43	吴31	5542	400	85.78	21.45%	0	3245	
743	吴嘴	0	10kV-43	吴32	5542	400	173.69	43.42%	0	2027	
744	吴嘴	0	10kV-43	吴34	5542	400	278.80	69.70%	0	571	
745	吴嘴	0	10kV-44	吴41	5542	400	60.47	15.12%	0	3596	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
746	吴嘴	0	10kV-44	吴43	5542	400	22.38	5.59%	0	4124	
747	吴嘴	0	10kV-44	吴44	5542	400	127.74	31.94%	0	2664	
748	吴嘴	0	10kV-44	吴45	5542	400	78.28	19.57%	0	3349	
749	吴嘴	0	10kV-44	吴46	5542	400	23.32	5.83%	0	4111	
750	吴嘴	0	10kV-44	吴47	5542	400	278.07	69.52%	0	581	
751	吴嘴	0	10kV-44	吴48	5542	400	202.04	50.51%	0	1634	
752	西广开	0	10kV-41	广11	5542	400	254.97	63.74%	0	901	
753	西广开	0	10kV-41	广12	5542	400	216.40	54.10%	0	1435	
754	西广开	0	10kV-41	广13	5542	400	154.38	38.60%	0	2295	
755	西广开	0	10kV-41	广14	5542	400	227.65	56.91%	0	1280	
756	西广开	0	10kV-41	广15	5542	400	73.38	18.35%	0	3417	
757	西广开	0	10kV-41	广16	5542	400	92.37	23.09%	0	3154	
758	西广开	0	10kV-41	广17	5542	400	169.75	42.44%	0	2082	
759	西广开	0	10kV-41	广18	5542	400	225.30	56.33%	0	1312	
760	西广开	0	10kV-42	广21	5542	400	118.75	29.69%	0	2788	
761	西广开	0	10kV-42	广22	5542	400	259.89	64.97%	0	833	
762	西广开	0	10kV-42	广23	5542	400	264.34	66.09%	0	771	
763	西广开	0	10kV-43	广31	5542	400	185.81	46.45%	0	1859	
764	西广开	0	10kV-43	广32	5542	400	247.94	61.98%	0	998	
765	西广开	0	10kV-43	广33	5542	400	313.35	78.34%	0	92	
766	西广开	0	10kV-43	广34	5542	400	84.63	21.16%	0	3261	
767	西广开	0	10kV-44	广41	5542	400	138.44	34.61%	0	2515	
768	西广开	0	10kV-44	广43	5542	400	110.78	27.70%	0	2899	
769	西广开	0	10kV-44	广44	5542	400	315.69	78.92%	0	60	
770	西广开	0	10kV-44	广45	5542	400	164.23	41.06%	0	2158	
771	西广开	0	10kV-44	广46	5542	400	179.24	44.81%	0	1950	
772	西广开	0	10kV-44	广47	5542	400	305.73	76.43%	0	198	
773	西广开	0	10kV-44	广48	5542	400	99.63	24.91%	0	3053	
774	西湖村	0	10kV-41	湖11	5542	400	194.11	48.53%	0	1744	
775	西湖村	0	10kV-41	湖12	5542	400	204.19	51.05%	0	1605	
776	西湖村	0	10kV-41	湖13	5542	400	270.89	67.72%	0	680	
777	西湖村	0	10kV-41	湖14	5542	400	317.66	79.41%	0	32	
778	西湖村	0	10kV-41	湖15	5542	400	120.38	30.10%	0	2766	
779	西湖村	0	10kV-41	湖16	5542	400	8.91	2.23%	0	4310	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
780	西湖村	0	10kV-41	湖17	5542	400	129.41	32.35%	0	2641	
781	西湖村	0	10kV-41	湖18	5542	400	281.44	70.36%	0	534	
782	西湖村	0	10kV-42	湖21	5542	400	205.25	51.31%	0	1590	
783	西湖村	0	10kV-42	湖22	5542	400	0.70	0.18%	0	4424	
784	西湖村	0	10kV-42	湖23	5542	400	31.30	7.82%	0	4000	
785	西湖村	0	10kV-42	湖24	5542	400	182.51	45.63%	0	1905	
786	西湖村	0	10kV-43	湖31	5542	400	159.53	39.88%	0	2223	
787	西湖村	0	10kV-43	湖32	5542	400	259.87	64.97%	0	833	
788	西湖村	0	10kV-43	湖33	5542	400	193.99	48.50%	0	1746	
789	西湖村	0	10kV-43	湖34	5542	400	152.38	38.10%	0	2322	
790	西湖村	0	10kV-44	湖41	5542	400	214.86	53.71%	0	1457	
791	西湖村	0	10kV-44	湖42	5542	400	172.19	43.05%	0	2048	
792	西湖村	0	10kV-44	湖43	5542	400	122.73	30.68%	0	2733	
793	西湖村	0	10kV-44	湖44	5542	400	195.75	48.94%	0	1721	
794	西湖村	0	10kV-44	湖45	5542	400	281.20	70.30%	0	538	
795	西湖村	0	10kV-44	湖46	5542	400	89.08	22.27%	0	3199	
796	西湖村	0	10kV-44	湖47	5542	400	229.39	57.35%	0	1255	
797	西湖村	0	10kV-44	湖48	5542	400	289.05	72.26%	0	429	
798	西南角	0	10kV-4	961	5542	400	155.21	38.80%	0	2283	
799	西南角	0	10kV-5	962	5542	400	170.86	42.71%	0	2066	
800	西南角	0	10kV-5	964	5542	400	63.11	15.78%	0	3559	
801	西南角	0	10kV-4	965	5542	400	101.25	25.31%	0	3031	
802	西南角	0	10kV-5	966	5542	400	154.86	38.72%	0	2288	
803	西南角	0	10kV-4	967	5542	400	59.41	14.85%	0	3610	
804	西南角	0	10kV-5	968	5542	400	217.97	54.49%	0	1414	
805	西南角	0	10kV-4	969	5542	400	141.15	35.29%	0	2478	
806	西南角	0	10kV-5	970	5542	400	89.12	22.28%	0	3199	
807	西南角	0	10kV-4	971	5542	400	302.77	75.69%	0	239	
808	西南角	0	10kV-4	973	5542	400	95.80	23.95%	0	3106	
809	西南角	0	10kV-5	974	5542	400	262.44	65.61%	0	797	
810	西青	0	10kV-43	青31	5542	400	273.58	68.40%	0	643	
811	西青	0	10kV-43	青32	5542	400	310.29	77.57%	0	134	
812	西青	0	10kV-43	青33	5542	400	285.77	71.44%	0	474	
813	西青	0	10kV-43	青34	5542	400	154.84	38.71%	0	2288	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
814	西青	0	10kV-43	青36	5542	400	127.06	31.77%	0	2673	
815	西青	0	10kV-44	青42	5542	400	107.37	26.84%	0	2946	
816	西青	0	10kV-44	青43	5542	400	228.10	57.03%	0	1273	
817	西青	0	10kV-44	青44	5542	400	274.75	68.69%	0	627	
818	西青	0	10kV-44	青45	5542	400	315.90	78.97%	0	57	
819	西青	0	10kV-45	青52	5542	400	304.06	76.01%	0	221	
820	西青	0	10kV-45	青53	5542	400	311.42	77.85%	0	119	
821	西青	0	10kV-45	青54	5542	400	93.19	23.30%	0	3142	
822	西青	0	10kV-45	青55	5542	400	212.04	53.01%	0	1496	
823	西青	0	10kV-45	青56	5542	400	201.85	50.46%	0	1637	
824	西青	0	10kV-46	青61	5542	400	245.68	61.42%	0	1030	
825	西青	0	10kV-46	青62	5542	400	130.58	32.64%	0	2624	
826	西青	0	10kV-46	青63	5542	400	252.48	63.12%	0	935	
827	西青	0	10kV-46	青64	5542	400	83.93	20.98%	0	3271	
828	西青	0	10kV-46	青65	5542	400	142.18	35.55%	0	2464	
829	西青	0	10kV-46	青66	5542	400	245.33	61.33%	0	1035	
830	西营门	0	10kV-41	营10	5542	400	9.24	2.31%	0	4306	
831	西营门	0	10kV-41	营11	5542	400	220.32	55.08%	0	1381	
832	西营门	0	10kV-41	营12	5542	400	272.88	68.22%	0	653	
833	西营门	0	10kV-41	营13	5542	400	271.80	67.95%	0	668	
834	西营门	0	10kV-41	营14	5542	400	238.69	59.67%	0	1127	
835	西营门	0	10kV-41	营17	5542	400	120.91	30.23%	0	2758	
836	西营门	0	10kV-42	营21	5542	400	277.38	69.34%	0	591	
837	西营门	0	10kV-42	营22	5542	400	8.04	2.01%	0	4322	
838	西营门	0	10kV-42	营24	5542	400	121.80	30.45%	0	2746	
839	西营门	0	10kV-43	营31	5542	400	264.42	66.11%	0	770	
840	西营门	0	10kV-43	营32	5542	400	285.47	71.37%	0	478	
841	西营门	0	10kV-44	营41	5542	400	161.50	40.37%	0	2196	
842	西营门	0	10kV-44	营42	5542	400	218.42	54.61%	0	1407	
843	西营门	0	10kV-44	营43	5542	400	201.84	50.46%	0	1637	
844	西营门	0	10kV-44	营44	5542	400	35.68	8.92%	0	3939	
845	西站西	0	10kV-41	西11	5542	400	277.21	69.30%	0	593	
846	西站西	0	10kV-41	西12	5542	400	167.34	41.84%	0	2115	
847	西站西	0	10kV-41	西13	5542	400	148.01	37.00%	0	2383	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
848	西站西	0	10kV-41	西14	5542	400	70.31	17.58%	0	3459	
849	西站西	0	10kV-41	西15	5542	400	142.91	35.73%	0	2454	
850	西站西	0	10kV-41	西16	5542	400	178.95	44.74%	0	1954	
851	西站西	0	10kV-41	西17	5542	400	128.32	32.08%	0	2656	
852	西站西	0	10kV-41	西18	5542	400	175.43	43.86%	0	2003	
853	西站西	0	10kV-42	西21	5542	400	184.92	46.23%	0	1872	
854	西站西	0	10kV-42	西22	5542	400	282.13	70.53%	0	525	
855	西站西	0	10kV-42	西23	5542	400	213.57	53.39%	0	1475	
856	西站西	0	10kV-43	西31	5542	400	201.09	50.27%	0	1647	
857	西站西	0	10kV-43	西32	5542	400	134.82	33.71%	0	2566	
858	西站西	0	10kV-43	西33	5542	400	112.68	28.17%	0	2872	
859	西站西	0	10kV-43	西34	5542	400	129.73	32.43%	0	2636	
860	西站西	0	10kV-44	西41	5542	400	129.37	32.34%	0	2641	
861	西站西	0	10kV-44	西42	5542	400	201.27	50.32%	0	1645	
862	西站西	0	10kV-44	西43	5542	400	307.27	76.82%	0	176	
863	西站西	0	10kV-44	西44	5542	400	279.53	69.88%	0	561	
864	西站西	0	10kV-44	西45	5542	400	181.58	45.40%	0	1918	
865	西站西	0	10kV-44	西46	5542	400	148.36	37.09%	0	2378	
866	西站西	0	10kV-44	西47	5542	400	288.70	72.18%	0	434	
867	西站西	0	10kV-44	西48	5542	400	191.60	47.90%	0	1779	
868	湘潭道	0	10kV-43	湘31	5542	400	293.63	73.41%	0	365	
869	湘潭道	0	10kV-43	湘32	5542	400	33.04	8.26%	0	3976	
870	湘潭道	0	10kV-43	湘33	5542	400	265.95	66.49%	0	749	
871	湘潭道	0	10kV-43	湘34	5542	400	217.52	54.38%	0	1420	
872	湘潭道	0	10kV-43	湘36	5542	400	55.24	13.81%	0	3668	
873	湘潭道	0	10kV-45	湘52	5542	400	119.81	29.95%	0	2774	
874	湘潭道	0	10kV-46	湘61	5542	400	81.26	20.32%	0	3308	
875	湘潭道	0	10kV-46	湘62	5542	400	37.14	9.29%	0	3919	
876	新科道	0	10kV-42	科21	5542	400	311.60	77.90%	0	116	
877	新科道	0	10kV-42	科22	5542	400	269.88	67.47%	0	694	
878	新科道	0	10kV-42	科23	5542	400	272.72	68.18%	0	655	
879	新科道	0	10kV-42	科24	5542	400	144.02	36.01%	0	2438	
880	新科道	0	10kV-43	科31	5542	400	266.22	66.56%	0	745	
881	新科道	0	10kV-43	科32	5542	400	316.99	79.25%	0	42	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
882	新科道	0	10kV-43	科33	5542	400	286.17	71.54%	0	469	
883	新科道	0	10kV-43	科34	5542	400	275.01	68.75%	0	623	
884	新科道	0	10kV-44	科41	5542	400	281.60	70.40%	0	532	
885	新科道	0	10kV-44	科42	5542	400	328.53	82.13%	0	0	
886	新科道	0	10kV-44	科43	5542	400	264.84	66.21%	0	764	
887	新科道	0	10kV-44	科44	5542	400	285.66	71.41%	0	476	
888	新科道	0	10kV-44	科45	5542	400	283.13	70.78%	0	511	
889	新科道	0	10kV-44	科46	5542	400	88.85	22.21%	0	3203	
890	新科道	0	10kV-44	科47	5542	400	289.31	72.33%	0	425	
891	新科道	0	10kV-44	科48	5542	400	67.50	16.88%	0	3498	
892	雅安道	0	10kV-41	雅11	5542	400	297.27	74.32%	0	315	
893	雅安道	0	10kV-41	雅12	5542	400	242.46	60.62%	0	1074	
894	雅安道	0	10kV-41	雅13	5542	400	215.19	53.80%	0	1452	
895	雅安道	0	10kV-41	雅14	5542	400	72.18	18.05%	0	3434	
896	雅安道	0	10kV-41	雅15	5542	400	233.54	58.38%	0	1198	
897	雅安道	0	10kV-41	雅16	5542	400	0.07	0.02%	0	4433	
898	雅安道	0	10kV-41	雅17	5542	400	0.07	0.02%	0	4433	
899	雅安道	0	10kV-41	雅18	5542	400	0.04	0.01%	0	4433	
900	雅安道	0	10kV-42	雅21	5542	400	210.76	52.69%	0	1513	
901	雅安道	0	10kV-42	雅22	5542	400	109.85	27.46%	0	2912	
902	雅安道	0	10kV-42	雅23	5542	400	0.06	0.01%	0	4433	
903	雅安道	0	10kV-42	雅24	5542	400	130.54	32.64%	0	2625	
904	雅安道	0	10kV-43	雅31	5542	400	251.12	62.78%	0	954	
905	雅安道	0	10kV-43	雅32	5542	400	0.07	0.02%	0	4433	
906	雅安道	0	10kV-43	雅33	5542	400	231.79	57.95%	0	1222	
907	雅安道	0	10kV-43	雅34	5542	400	0.03	0.01%	0	4433	
908	雅安道	0	10kV-44	雅41	5542	400	142.18	35.54%	0	2464	
909	雅安道	0	10kV-44	雅42	5542	400	31.69	7.92%	0	3995	
910	雅安道	0	10kV-44	雅43	5542	400	308.94	77.23%	0	153	
911	雅安道	0	10kV-44	雅44	5542	400	0.06	0.02%	0	4433	
912	雅安道	0	10kV-44	雅45	5542	400	148.40	37.10%	0	2378	
913	雅安道	0	10kV-44	雅46	5542	400	0.07	0.02%	0	4433	
914	雅安道	0	10kV-44	雅47	5542	400	0.07	0.02%	0	4433	
915	雅安道	0	10kV-44	雅48	5542	400	0.11	0.03%	0	4432	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
916	杨楼	0	10kV-4	531	5542	400	298.89	74.72%	0	292	
917	杨楼	0	10kV-5	532	5542	400	224.14	56.04%	0	1328	
918	杨楼	0	10kV-4	533	5542	400	285.91	71.48%	0	472	
919	杨楼	0	10kV-5	534	5542	400	174.69	43.67%	0	2013	
920	杨楼	0	10kV-4	535	5542	400	38.76	9.69%	0	3897	
921	杨楼	0	10kV-5	536	5542	400	315.80	78.95%	0	58	
922	杨楼	0	10kV-4	537	5542	400	154.05	38.51%	0	2299	
923	杨楼	0	10kV-5	538	5542	400	267.27	66.82%	0	731	
924	杨楼	0	10kV-4	539	5542	400	234.20	58.55%	0	1189	
925	杨楼	0	10kV-4	541	5542	400	307.54	76.88%	0	173	
926	杨楼	0	10kV-5	542	5542	400	324.32	81.08%	0	0	
927	杨楼	0	10kV-5	544	5542	400	46.20	11.55%	0	3794	
928	阳光	0	10kV-41	阳11	5542	400	262.28	65.57%	0	800	
929	阳光	0	10kV-41	阳12	5542	400	172.45	43.11%	0	2044	
930	阳光	0	10kV-41	阳13	5542	400	175.00	43.75%	0	2009	
931	阳光	0	10kV-41	阳14	5542	400	136.99	34.25%	0	2536	
932	阳光	0	10kV-41	阳15	5542	400	179.16	44.79%	0	1951	
933	阳光	0	10kV-41	阳16	5542	400	255.26	63.82%	0	897	
934	阳光	0	10kV-41	阳17	5542	400	175.54	43.88%	0	2002	
935	阳光	0	10kV-41	阳18	5542	400	127.50	31.88%	0	2667	
936	阳光	0	10kV-42	阳21	5542	400	291.61	72.90%	0	393	
937	阳光	0	10kV-42	阳22	5542	400	37.66	9.41%	0	3912	
938	阳光	0	10kV-42	阳23	5542	400	289.19	72.30%	0	427	
939	阳光	0	10kV-42	阳24	5542	400	251.04	62.76%	0	955	
940	阳光	0	10kV-43	阳31	5542	400	317.14	79.28%	0	40	
941	阳光	0	10kV-43	阳32	5542	400	298.30	74.57%	0	301	
942	阳光	0	10kV-43	阳33	5542	400	258.60	64.65%	0	851	
943	阳光	0	10kV-44	阳41	5542	400	169.92	42.48%	0	2079	
944	阳光	0	10kV-44	阳42	5542	400	91.22	22.81%	0	3170	
945	阳光	0	10kV-44	阳43	5542	400	123.22	30.80%	0	2726	
946	阳光	0	10kV-44	阳44	5542	400	278.69	69.67%	0	572	
947	阳光	0	10kV-44	阳45	5542	400	313.36	78.34%	0	92	
948	阳光	0	10kV-44	阳46	5542	400	166.96	41.74%	0	2120	
949	阳光	0	10kV-44	阳47	5542	400	294.16	73.54%	0	358	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
950	阳光	0	10kV-44	阳48	5542	400	302.50	75.62%	0	243	
951	冶金里	0	10kV-41	金11	5542	400	219.54	54.89%	0	1392	
952	冶金里	0	10kV-41	金12	5542	400	189.21	47.30%	0	1812	
953	冶金里	0	10kV-41	金13	5542	400	116.80	29.20%	0	2815	
954	冶金里	0	10kV-41	金14	5542	400	110.40	27.60%	0	2904	
955	冶金里	0	10kV-41	金15	5542	400	120.09	30.02%	0	2770	
956	冶金里	0	10kV-41	金16	5542	400	229.55	57.39%	0	1253	
957	冶金里	0	10kV-41	金17	5542	400	253.42	63.36%	0	922	
958	冶金里	0	10kV-41	金18	5542	400	105.07	26.27%	0	2978	
959	冶金里	0	10kV-42	金21	5542	400	263.26	65.81%	0	786	
960	冶金里	0	10kV-42	金22	5542	400	0.09	0.02%	0	4432	
961	冶金里	0	10kV-42	金23	5542	400	50.29	12.57%	0	3737	
962	冶金里	0	10kV-42	金24	5542	400	249.50	62.38%	0	977	
963	冶金里	0	10kV-43	金31	5542	400	134.23	33.56%	0	2574	
964	冶金里	0	10kV-43	金32	5542	400	173.98	43.49%	0	2023	
965	冶金里	0	10kV-43	金33	5542	400	16.67	4.17%	0	4203	
966	冶金里	0	10kV-43	金34	5542	400	273.45	68.36%	0	645	
967	冶金里	0	10kV-44	金41	5542	400	280.68	70.17%	0	545	
968	冶金里	0	10kV-44	金42	5542	400	281.01	70.25%	0	540	
969	冶金里	0	10kV-44	金43	5542	400	249.76	62.44%	0	973	
970	冶金里	0	10kV-44	金44	5542	400	125.01	31.25%	0	2702	
971	冶金里	0	10kV-44	金45	5542	400	111.97	27.99%	0	2882	
972	冶金里	0	10kV-44	金46	5542	400	250.68	62.67%	0	960	
973	冶金里	0	10kV-44	金47	5542	400	106.37	26.59%	0	2960	
974	冶金里	0	10kV-44	金48	5542	400	219.26	54.82%	0	1396	
975	迎水道	0	10kV-42	水25	5542	400	52.03	13.01%	0	3713	
976	迎水道	0	10kV-42	水26	5542	400	317.11	79.28%	0	40	
977	迎水道	0	10kV-42	水27	5542	400	296.44	74.11%	0	326	
978	迎水道	0	10kV-44	水42	5542	400	292.22	73.05%	0	385	
979	迎水道	0	10kV-44	水43	5542	400	166.64	41.66%	0	2125	
980	迎水道	0	10kV-44	水46	5542	400	263.32	65.83%	0	785	
981	迎水道	0	10kV-44	水49	5542	400	209.88	52.47%	0	1526	
982	玉门路	0	10kV-41	玉11	5542	400	182.64	45.66%	0	1903	
983	玉门路	0	10kV-41	玉12	5542	400	160.80	40.20%	0	2206	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
984	玉门路	0	10kV-41	玉13	5542	400	83.28	20.82%	0	3280	
985	玉门路	0	10kV-41	玉14	5542	400	239.28	59.82%	0	1118	
986	玉门路	0	10kV-41	玉17	5542	400	38.64	9.66%	0	3898	
987	玉门路	0	10kV-41	玉18	5542	400	126.00	31.50%	0	2688	
988	玉门路	0	10kV-42	玉21	5542	400	126.12	31.53%	0	2686	
989	玉门路	0	10kV-42	玉22	5542	400	72.36	18.09%	0	3431	
990	玉门路	0	10kV-42	玉24	5542	400	72.00	18.00%	0	3436	
991	玉门路	0	10kV-43	玉31	5542	400	147.72	36.93%	0	2387	
992	玉门路	0	10kV-43	玉32	5542	400	115.32	28.83%	0	2836	
993	玉门路	0	10kV-44	玉41	5542	400	139.20	34.80%	0	2505	
994	玉门路	0	10kV-44	玉42	5542	400	5.28	1.32%	0	4360	
995	玉门路	0	10kV-44	玉43	5542	400	166.68	41.67%	0	2124	
996	玉门路	0	10kV-44	玉44	5542	400	113.88	28.47%	0	2856	
997	玉门路	0	10kV-44	玉47	5542	400	49.20	12.30%	0	3752	
998	玉门路	0	10kV-44	玉48	5542	400	122.52	30.63%	0	2736	
999	园西路	0	10kV-41	园11	5542	400	123.53	30.88%	0	2722	
1000	园西路	0	10kV-41	园12	5542	400	9.50	2.37%	0	4302	
1001	园西路	0	10kV-41	园13	5542	400	177.62	44.41%	0	1973	
1002	园西路	0	10kV-41	园14	5542	400	180.44	45.11%	0	1934	
1003	园西路	0	10kV-41	园15	5542	400	196.27	49.07%	0	1714	
1004	园西路	0	10kV-41	园16	5542	400	8.79	2.20%	0	4312	
1005	园西路	0	10kV-41	园17	5542	400	99.54	24.88%	0	3054	
1006	园西路	0	10kV-42	园21	5542	400	239.53	59.88%	0	1115	
1007	园西路	0	10kV-42	园22	5542	400	77.73	19.43%	0	3357	
1008	园西路	0	10kV-43	园31	5542	400	125.22	31.30%	0	2699	
1009	园西路	0	10kV-43	园32	5542	400	0.00	0.00%	0	4434	
1010	园西路	0	10kV-43	园33	5542	400	137.53	34.38%	0	2528	
1011	园西路	0	10kV-44	园41	5542	400	2.81	0.70%	0	4395	
1012	园西路	0	10kV-44	园43	5542	400	148.43	37.11%	0	2377	
1013	园西路	0	10kV-44	园44	5542	400	94.26	23.57%	0	3128	
1014	园西路	0	10kV-44	园45	5542	400	105.17	26.29%	0	2977	
1015	园西路	0	10kV-44	园47	5542	400	257.47	64.37%	0	866	
1016	张家窝	0	10kV-42	窝21	5542	400	335.92	83.98%	0	0	
1017	张家窝	0	10kV-42	窝22	5542	400	300.48	75.12%	0	270	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
1018	张家窝	0	10kV-42	窝23	5542	400	290.99	72.75%	0	402	
1019	张家窝	0	10kV-42	窝24	5542	400	239.77	59.94%	0	1112	
1020	张家窝	0	10kV-43	窝31	5542	400	319.47	79.87%	0	7	
1021	张家窝	0	10kV-43	窝32	5542	400	276.46	69.11%	0	603	
1022	张家窝	0	10kV-43	窝33	5542	400	265.32	66.33%	0	758	
1023	张家窝	0	10kV-43	窝34	5542	400	36.80	9.20%	0	3924	
1024	张家窝	0	10kV-44	窝41	5542	400	304.35	76.09%	0	217	
1025	张家窝	0	10kV-44	窝42	5542	400	260.28	65.07%	0	827	
1026	张家窝	0	10kV-44	窝43	5542	400	222.31	55.58%	0	1353	
1027	张家窝	0	10kV-44	窝44	5542	400	318.86	79.71%	0	16	
1028	张家窝	0	10kV-44	窝45	5542	400	74.53	18.63%	0	3401	
1029	张家窝	0	10kV-44	窝46	5542	400	284.43	71.11%	0	493	
1030	张家窝	0	10kV-44	窝47	5542	400	269.54	67.39%	0	699	
1031	张家窝	0	10kV-44	窝48	5542	400	209.07	52.27%	0	1537	
1032	中北	0	10kV-4	北11	5542	400	199.03	49.76%	0	1676	
1033	中北	0	10kV-5	北12	5542	400	309.09	77.27%	0	151	
1034	中北	0	10kV-4	北13	5542	400	165.27	41.32%	0	2144	
1035	中北	0	10kV-5	北14	5542	400	180.57	45.14%	0	1932	
1036	中北	0	10kV-4	北15	5542	400	0.70	0.18%	0	4424	
1037	中北	0	10kV-5	北16	5542	400	211.16	52.79%	0	1508	
1038	中北	0	10kV-4	北17	5542	400	188.48	47.12%	0	1822	
1039	中北	0	10kV-5	北18	5542	400	162.63	40.66%	0	2180	
1040	中北	0	10kV-4	北19	5542	400	260.92	65.23%	0	819	
1041	中北	0	10kV-4	北21	5542	400	0.70	0.18%	0	4424	
1042	中北	0	10kV-5	北22	5542	400	222.94	55.73%	0	1345	
1043	中北	0	10kV-5	北24	5542	400	185.31	46.33%	0	1866	
1044	八里台	0	10kV-41	842	5542	400	223.90	55.98%	0	1331	
1045	八里台	0	10kV-41	846	5542	400	86.18	21.54%	0	3240	
1046	八里台	0	10kV-42	854	5542	400	251.35	62.84%	0	951	
1047	八里台	0	10kV-44	872	5542	400	200.86	50.21%	0	1651	
1048	八里台	0	10kV-44	876	5542	400	282.46	70.62%	0	520	
1049	曹庄子	0	10kV-4	曹11	5542	400	263.68	65.92%	0	780	
1050	曹庄子	0	10kV-5	曹12	5542	400	288.29	72.07%	0	439	
1051	曹庄子	0	10kV-4	曹13	5542	400	128.67	32.17%	0	2651	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
1052	曹庄子	0	10kV-5	曹14	5542	400	38.50	9.62%	0	3900	
1053	曹庄子	0	10kV-4	曹15	5542	400	162.07	40.52%	0	2188	
1054	曹庄子	0	10kV-5	曹16	5542	400	137.64	34.41%	0	2527	
1055	曹庄子	0	10kV-4	曹17	5542	400	193.89	48.47%	0	1747	
1056	曹庄子	0	10kV-5	曹18	5542	400	275.21	68.80%	0	621	
1057	曹庄子	0	10kV-4	曹19	5542	400	114.61	28.65%	0	2846	
1058	曹庄子	0	10kV-5	曹20	5542	400	162.95	40.74%	0	2176	
1059	曹庄子	0	10kV-4	曹21	5542	400	137.29	34.32%	0	2531	
1060	曹庄子	0	10kV-5	曹22	5542	400	127.62	31.90%	0	2665	
1061	辰远路	0	10kV-41	远10	5542	400	71.19	17.80%	0	3447	
1062	辰远路	0	10kV-41	远11	5542	400	166.99	41.75%	0	2120	
1063	辰远路	0	10kV-41	远12	5542	400	72.95	18.24%	0	3423	
1064	辰远路	0	10kV-41	远13	5542	400	282.13	70.53%	0	525	
1065	辰远路	0	10kV-42	远21	5542	400	174.03	43.51%	0	2022	
1066	辰远路	0	10kV-42	远22	5542	400	119.53	29.88%	0	2777	
1067	辰远路	0	10kV-43	远26	5542	400	116.02	29.00%	0	2826	
1068	辰远路	0	10kV-43	远27	5542	400	259.46	64.86%	0	839	
1069	辰远路	0	10kV-43	远28	5542	400	182.82	45.70%	0	1901	
1070	辰远路	0	10kV-44	远31	5542	400	245.22	61.30%	0	1036	
1071	辰远路	0	10kV-44	远32	5542	400	39.55	9.89%	0	3886	
1072	辰远路	0	10kV-44	远33	5542	400	286.53	71.63%	0	464	
1073	辰远路	0	10kV-44	远34	5542	400	226.76	56.69%	0	1292	
1074	海光寺	0	10kV-51	海65	5542	400	199.69	49.92%	0	1667	
1075	海光寺	0	10kV-51	海66	5542	400	303.40	75.85%	0	230	
1076	海光寺	0	10kV-41	海73	5542	400	233.09	58.27%	0	1204	
1077	海光寺	0	10kV-52	海81	5542	400	279.50	69.87%	0	561	
1078	海光寺	0	10kV-52	海83	5542	400	276.47	69.12%	0	603	
1079	海光寺	0	10kV-52	海84	5542	400	280.90	70.23%	0	542	
1080	芥园道	0	10kV-41	芥11	5542	400	175.61	43.90%	0	2001	
1081	芥园道	0	10kV-41	芥12	5542	400	286.88	71.72%	0	459	
1082	芥园道	0	10kV-41	芥13	5542	400	291.27	72.82%	0	398	
1083	芥园道	0	10kV-41	芥14	5542	400	148.54	37.13%	0	2376	
1084	芥园道	0	10kV-41	芥15	5542	400	66.97	16.74%	0	3506	
1085	芥园道	0	10kV-41	芥16	5542	400	62.58	15.64%	0	3567	

序号	变电站名称	主变最大负荷日后需预留容量(kVA)	所属母线	线路名称	线路允许容量(kVA)	允许电流(A)	历史最大电流(A)	最高负载率(%)	线路最大负荷日后需预留容量(kVA)	可开放容量(kVA)	备注
1086	芥园道	0	10kV-41	芥17	5542	400	240.47	60.12%	0	1102	
1087	芥园道	0	10kV-41	芥18	5542	400	240.65	60.16%	0	1099	
1088	芥园道	0	10kV-42	芥21	5542	400	236.61	59.15%	0	1155	
1089	芥园道	0	10kV-42	芥22	5542	400	157.85	39.46%	0	2247	
1090	芥园道	0	10kV-42	芥23	5542	400	120.59	30.15%	0	2763	
1091	芥园道	0	10kV-42	芥24	5542	400	154.51	38.63%	0	2293	
1092	芥园道	0	10kV-43	芥26	5542	400	229.40	57.35%	0	1255	
1093	芥园道	0	10kV-43	芥27	5542	400	308.91	77.23%	0	154	
1094	芥园道	0	10kV-43	芥28	5542	400	214.28	53.57%	0	1465	
1095	芥园道	0	10kV-44	芥31	5542	400	239.42	59.85%	0	1116	
1096	芥园道	0	10kV-44	芥32	5542	400	165.06	41.27%	0	2147	
1097	芥园道	0	10kV-44	芥33	5542	400	275.63	68.91%	0	615	
1098	芥园道	0	10kV-44	芥34	5542	400	286.88	71.72%	0	459	
1099	芥园道	0	10kV-44	芥35	5542	400	305.34	76.33%	0	203	
1100	芥园道	0	10kV-44	芥36	5542	400	308.85	77.21%	0	154	
1101	芥园道	0	10kV-44	芥37	5542	400	168.93	42.23%	0	2093	
1102	镇坪路	0	10kV-42	镇20	5542	400	32.85	8.21%	0	3978	
1103	镇坪路	0	10kV-42	镇22	5542	400	84.47	21.12%	0	3263	
1104	镇坪路	0	10kV-42	镇23	5542	400	156.39	39.10%	0	2267	
1105	镇坪路	0	10kV-43	镇31	5542	400	126.70	31.67%	0	2678	
1106	镇坪路	0	10kV-43	镇32	5542	400	166.75	41.69%	0	2123	
1107	镇坪路	0	10kV-43	镇33	5542	400	277.61	69.40%	0	587	
1108	镇坪路	0	10kV-43	镇35	5542	400	110.48	27.62%	0	2903	
1109	镇坪路	0	10kV-43	镇36	5542	400	203.58	50.90%	0	1613	
1110	镇坪路	0	10kV-44	镇41	5542	400	164.97	41.24%	0	2148	
1111	镇坪路	0	10kV-44	镇42	5542	400	168.70	42.17%	0	2096	
1112	镇坪路	0	10kV-44	镇43	5542	400	168.90	42.23%	0	2093	
1113	镇坪路	0	10kV-44	镇44	5542	400	115.35	28.84%	0	2835	
1114	镇坪路	0	10kV-44	镇51	5542	400	199.25	49.81%	0	1673	
1115	镇坪路	0	10kV-44	镇52	5542	400	247.82	61.96%	0	1000	
1116	镇坪路	0	10kV-44	镇53	5542	400	181.41	45.35%	0	1920	
1117	本溪路	0	10kV-43	本32	5542	400	137.42	34.35%	0	2530	