

城南供电公司10千伏配电线路可开放容量信息表(2025年第三季度)

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
1	220kV海光寺站	0	10-51	海61	8140	470	200.04	42.56%	0	3048	
2		0	10-51	海62	8140	470	46.76	9.95%	0	5702	
3		0	10-51	海63	8140	470	133.60	28.42%	0	4198	
4		0	10-51	海64	8140	470	70.31	14.96%	0	5294	
5		0	10-41	海71	8140	470	226.41	48.17%	0	2591	
6		0	10-41	海72	8140	470	62.93	13.39%	0	5422	
7		0	10-42	海74	8140	470	33.40	7.11%	0	5934	
8		0	10-42	海75	8140	470	116.72	24.83%	0	4491	
9		0	10-42	海76	8140	470	65.74	13.99%	0	5374	
10		0	10-52	海80	8140	470	78.05	16.61%	0	5161	
11		0	10-52	海82	8140	470	247.50	52.66%	0	2226	
12		0	10-52	海85	8140	470	141.33	30.07%	0	4064	
13		0	10-52	海86	8140	470	148.71	31.64%	0	3937	
14	220kV八里台站	0	10-41	841	6235	360	69.83	19.40%	0	3779	
15		0	10-41	843	8140	470	224.61	47.79%	0	2622	
16		0	10-41	844	8140	470	47.66	10.14%	0	5687	
17		0	10-41	845	8140	470	333.84	71.03%	0	730	
18		0	10-41	847	8140	470	50.82	10.81%	0	5632	
19		0	10-41	848	8140	470	267.17	56.84%	0	1885	
20		0	10-42	851	6235	360	281.94	78.32%	0	105	
21		0	10-42	852	8140	470	47.13	10.03%	0	5696	
22		0	10-42	853	8140	470	205.07	43.63%	0	2960	
23		0	10-43	861	8140	470	144.41	30.72%	0	4011	
24		0	10-43	862	8140	470	283.87	60.40%	0	1596	
25		0	10-43	863	8140	470	187.32	39.86%	0	3268	
26		0	10-44	871	8140	470	266.12	56.62%	0	1903	
27		0	10-44	873	8140	470	102.90	21.89%	0	4730	
28		0	10-44	874	8140	470	53.11	11.30%	0	5592	
29		0	10-44	875	8140	470	53.11	11.30%	0	5592	
30		0	10-44	877	8140	470	141.77	30.16%	0	4057	
31		0	10-44	878	8140	470	185.56	39.48%	0	3298	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
32	220kV陈塘庄站	0	10-41	441	8140	470	109.16	23.23%	0	4622	
33		0	10-41	442	8140	470	112.15	23.86%	0	4570	
34		0	10-41	443	8140	470	68.91	14.66%	0	5319	
35		0	10-41	444	8140	470	200.92	42.75%	0	3032	
36		0	10-41	445	8140	470	71.37	15.18%	0	5276	
37		0	10-41	446	8140	470	83.32	17.73%	0	5069	
38		0	10-41	447	8140	470	179.83	38.26%	0	3398	
39		0	10-41	448	8140	470	186.51	39.68%	0	3282	
40		0	10-42	451	8140	470	95.98	20.42%	0	4850	
41		0	10-42	452	8140	470	103.71	22.07%	0	4716	
42		0	10-42	453	8140	470	86.84	18.48%	0	5008	
43		0	10-42	454	8140	470	193.01	41.07%	0	3169	
44		0	10-43	455	8140	470	124.10	26.41%	0	4363	
45		0	10-43	456	8140	470	60.47	12.87%	0	5465	
46		0	10-43	457	8140	470	113.20	24.09%	0	4552	
47		0	10-43	458	8140	470	260.86	55.50%	0	1994	
48		0	10-44	461	8140	470	107.93	22.96%	0	4643	
49		0	10-44	462	8140	470	26.37	5.61%	0	6056	
50		0	10-44	463	8140	470	144.49	30.74%	0	4010	
51		0	10-44	464	8140	470	154.16	32.80%	0	3842	
52		0	10-44	465	8140	470	72.42	15.41%	0	5258	
53		0	10-44	466	8140	470	64.69	13.76%	0	5392	
54		0	10-44	467	8140	470	119.88	25.51%	0	4436	
55	220kV利民道站	0	10-41	利21	8140	470	168.35	35.82%	0	3597	
56		0	10-41	利22	8140	470	131.31	27.94%	0	4238	
57		0	10-41	利23	8140	470	140.22	29.83%	0	4084	
58		0	10-41	利24	8140	470	97.53	20.75%	0	4823	
59		0	10-41	利25	8140	470	76.91	16.36%	0	5180	
60		0	10-41	利26	8140	470	110.66	23.54%	0	4596	
61		0	10-42	利31	8140	470	59.06	12.57%	0	5489	
62		0	10-42	利32	8140	470	124.25	26.44%	0	4360	
63		0	10-42	利33	8140	470	132.72	28.24%	0	4214	
64		0	10-43	利34	8140	470	167.88	35.72%	0	3605	
65		0	10-43	利35	8140	470	232.13	49.39%	0	2492	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
66		0	10-43	利36	8140	470	66.13	14.07%	0	5367	
67		0	10-44	利41	5975	345	64.25	18.62%	0	3668	
68		0	10-44	利42	5975	345	92.85	26.91%	0	3172	
69		0	10-44	利43	8140	470	54.85	11.67%	0	5562	
70		0	10-44	利44	8140	470	110.19	23.44%	0	4604	
71		0	10-44	利45	8140	470	92.38	19.65%	0	4912	
72		0	10-44	利46	8140	470	145.85	31.03%	0	3986	
73	220kV延寿里站	0	10-41	延11	8140	470	93.03	19.79%	0	4901	
74		0	10-41	延12	8140	470	32.89	7.00%	0	5943	
75		0	10-41	延13	8140	470	94.62	20.13%	0	4874	
76		0	10-41	延14	8140	470	135.44	28.82%	0	4166	
77		0	10-41	延17	8140	470	88.46	18.82%	0	4980	
78		0	10-42	延21	8140	470	24.63	5.24%	0	6086	
79		0	10-42	延22	8140	470	198.75	42.29%	0	3070	
80		0	10-42	延23	8140	470	34.12	7.26%	0	5921	
81		0	10-43	延25	8140	470	94.09	20.02%	0	4883	
82		0	10-43	延26	8140	470	26.39	5.61%	0	6055	
83		0	10-44	延31	8140	470	138.43	29.45%	0	4115	
84		0	10-44	延33	8140	470	109.58	23.31%	0	4614	
85		0	10-44	延34	8140	470	80.55	17.14%	0	5117	
86	35kV南京路站	0	10-41	京11	6928	400	1.04	0.26%	0	5524	
87		0	10-41	京12	6928	400	198.40	49.60%	0	2106	
88		0	10-41	京13	6928	400	31.52	7.88%	0	4996	
89		0	10-41	京14	6928	400	0.00	0.00%	0	5542	
90		0	10-41	京15	6928	400	57.68	14.42%	0	4543	
91		0	10-41	京16	6928	400	96.88	24.22%	0	3864	
92		0	10-41	京18	6928	400	189.36	47.34%	0	2263	
93		0	10-42	京21	6928	400	124.64	31.16%	0	3384	
94		0	10-42	京22	6928	400	127.44	31.86%	0	3335	
95		0	10-43	京25	6928	400	239.44	59.86%	0	1395	
96		0	10-43	京26	6928	400	66.96	16.74%	0	4383	
97		0	10-44	京31	6928	400	88.32	22.08%	0	4013	
98		0	10-44	京32	6928	400	87.28	21.82%	0	4031	
99		0	10-44	京33	6928	400	9.84	2.46%	0	5372	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
100		0	10-44	京34	6928	400	126.96	31.74%	0	3343	
101		0	10-44	京35	6928	400	106.32	26.58%	0	3701	
102	35kV黄所站	0	10-4	41	8660	500	30.62	6.12%	0	6398	
103		0	10-5	42	8140	470	87.55	18.63%	0	4996	
104		0	10-4	43	8140	470	53.50	11.38%	0	5586	
105		0	10-5	44	8140	470	91.32	19.43%	0	4931	
106		0	10-4	45	8140	470	18.64	3.97%	0	6190	
107		0	10-5	46	8660	500	121.80	24.36%	0	4818	
108		0	10-4	47	8660	500	37.96	7.59%	0	6271	
109		0	10-5	48	6235	360	36.77	10.21%	0	4351	
110		0	10-4	49	8660	500	210.02	42.00%	0	3290	
111		0	10-4	51	8140	470	100.62	21.41%	0	4770	
112		0	10-5	52	8660	500	124.51	24.90%	0	4771	
113		0	10-4	53	8140	470	182.16	38.76%	0	3357	
114		0	10-5	54	8660	500	80.02	16.00%	0	5542	
115	35kV滨江道站	0	10-41	滨13	8660	500	2.28	0.46%	0	6889	
116		0	10-41	滨14	8140	470	94.32	20.07%	0	4879	
117		0	10-41	滨15	8140	470	123.36	26.25%	0	4376	
118		0	10-41	滨16	8140	470	0.00	0.00%	0	6512	
119		0	10-41	滨17	8140	470	119.40	25.40%	0	4444	
120		0	10-42	滨21	8140	470	8.16	1.74%	0	6371	
121		0	10-42	滨22	8140	470	15.36	3.27%	0	6246	
122		0	10-42	滨23	8140	470	4.80	1.02%	0	6429	
123		0	10-43	滨25	8140	470	221.76	47.18%	0	2671	
124		0	10-43	滨26	8140	470	194.40	41.36%	0	3145	
125		0	10-44	滨34	8140	470	6.96	1.48%	0	6392	
126		0	10-44	滨35	8140	470	0.00	0.00%	0	6512	
127		0	10-44	滨36	8140	470	201.00	42.77%	0	3031	
128		0	10-44	滨37	8140	470	89.28	19.00%	0	4966	
129		0	10-41	平11	8140	470	20.16	4.29%	0	6163	
130		0	10-41	平12	8140	470	20.16	4.29%	0	6163	
131		0	10-41	平13	8140	470	120.23	25.58%	0	4430	
132		0	10-41	平14	8140	470	30.70	6.53%	0	5981	
133		0	10-41	平15	8140	470	21.33	4.54%	0	6143	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
134	35kV和平路站	0	10-41	平16	8140	470	56.72	12.07%	0	5530	
135		0	10-41	平17	8140	470	2.58	0.55%	0	6468	
136		0	10-41	平18	8140	470	22.97	4.89%	0	6115	
137		0	10-42	平21	8140	470	91.88	19.55%	0	4921	
138		0	10-42	平22	8140	470	23.67	5.04%	0	6102	
139		0	10-42	平24	8140	470	18.28	3.89%	0	6196	
140		0	10-43	平32	6235	360	185.16	51.43%	0	1781	
141		0	10-44	平41	8140	470	151.88	32.31%	0	3882	
142		0	10-44	平42	8140	470	12.66	2.69%	0	6293	
143		0	10-44	平43	8140	470	111.33	23.69%	0	4584	
144		0	10-44	平45	8140	470	33.75	7.18%	0	5928	
145	35kV苏州道站	0	10-41	苏61	6928	400	140.32	35.08%	0	3112	
146		0	10-41	苏62	6928	400	223.60	55.90%	0	1670	
147		0	10-41	苏64	6928	400	78.40	19.60%	0	4185	
148		0	10-41	苏65	6928	400	137.36	34.34%	0	3163	
149		0	10-41	苏66	6928	400	42.32	10.58%	0	4809	
150		0	10-41	苏67	6928	400	64.24	16.06%	0	4430	
151		0	10-41	苏68	6928	400	50.80	12.70%	0	4663	
152		0	10-42	苏71	6928	400	68.64	17.16%	0	4354	
153		0	10-42	苏72	6928	400	135.84	33.96%	0	3190	
154		0	10-42	苏73	6928	400	89.36	22.34%	0	3995	
155		0	10-43	苏81	6928	400	33.04	8.26%	0	4970	
156		0	10-43	苏82	6928	400	172.88	43.22%	0	2548	
157		0	10-43	苏83	6928	400	14.40	3.60%	0	5293	
158		0	10-43	苏84	6928	400	65.60	16.40%	0	4406	
159		0	10-44	苏91	6928	400	77.36	19.34%	0	4203	
160		0	10-44	苏92	6928	400	95.12	23.78%	0	3895	
161		0	10-44	苏93	6928	400	39.60	9.90%	0	4857	
162		0	10-44	苏94	6928	400	99.36	24.84%	0	3821	
163		0	10-44	苏96	6928	400	125.84	31.46%	0	3363	
164		0	10-44	苏97	6928	400	130.88	32.72%	0	3276	
165		0	10-44	苏98	6928	400	117.76	29.44%	0	3503	
166		0	10-41	治51	6928	400	45.35	11.34%	0	4757	
167		0	10-41	治52	6928	400	16.52	4.13%	0	5256	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
168	35kV治安街站	0	10-41	治53	6928	400	31.99	8.00%	0	4988	
169		0	10-41	治54	6928	400	50.04	12.51%	0	4676	
170		0	10-41	治55	6928	400	152.11	38.03%	0	2908	
171		0	10-41	治56	6928	400	104.07	26.02%	0	3740	
172		0	10-41	治57	6928	400	33.75	8.44%	0	4958	
173		0	10-41	治58	6928	400	94.46	23.61%	0	3906	
174		0	10-42	治61	6928	400	67.03	16.76%	0	4381	
175		0	10-42	治62	6928	400	60.70	15.18%	0	4491	
176		0	10-43	治65	6928	400	125.75	31.44%	0	3364	
177		0	10-43	治66	6928	400	155.98	39.00%	0	2841	
178		0	10-43	治68	6928	400	13.95	3.49%	0	5301	
179		0	10-44	治71	6235	360	103.60	28.78%	0	3194	
180		0	10-44	治72	6928	400	34.45	8.61%	0	4946	
181		0	10-44	治73	6928	400	249.03	62.26%	0	1229	
182		0	10-44	治74	6928	400	84.38	21.09%	0	4081	
183	35kV西宁道站	0	10-41	宁51	6928	400	15.00	3.75%	0	5283	
184		0	10-41	宁52	6928	400	140.41	35.10%	0	3111	
185		0	10-41	宁53	6928	400	166.89	41.72%	0	2652	
186		0	10-41	宁54	6928	400	80.87	20.22%	0	4142	
187		0	10-41	宁55	6928	400	81.10	20.28%	0	4138	
188		0	10-41	宁58	6928	400	74.07	18.52%	0	4260	
189		0	10-42	宁61	6928	400	58.83	14.71%	0	4523	
190		0	10-42	宁62	6235	360	161.74	44.93%	0	2187	
191		0	10-42	宁63	6235	360	76.41	21.23%	0	3665	
192		0	10-42	宁64	6928	400	68.68	17.17%	0	4353	
193		0	10-43	宁65	6928	400	43.60	10.90%	0	4787	
194		0	10-43	宁67	6928	400	113.22	28.30%	0	3582	
195		0	10-43	宁68	6928	400	1.64	0.41%	0	5514	
196		0	10-44	宁71	6235	360	60.48	16.80%	0	3941	
197		0	10-44	宁72	6235	360	118.61	32.95%	0	2934	
198		0	10-44	宁73	6928	400	50.86	12.72%	0	4661	
199		0	10-44	宁74	6928	400	20.39	5.10%	0	5189	
200		0	10-44	宁76	6928	400	72.90	18.22%	0	4280	
201		0	10-44	宁78	6928	400	34.46	8.61%	0	4946	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
202	35kV云南路站	0	10-41	云11	6928	400	230.45	57.61%	0	1551	
203		0	10-41	云12	6928	400	22.99	5.75%	0	5144	
204		0	10-41	云13	6928	400	14.89	3.72%	0	5285	
205		0	10-41	云14	6928	400	113.81	28.45%	0	3571	
206		0	10-41	云17	6928	400	41.19	10.30%	0	4829	
207		0	10-41	云18	6235	360	183.15	50.88%	0	1816	
208		0	10-42	云21	6928	400	106.21	26.55%	0	3703	
209		0	10-42	云22	6928	400	84.28	21.07%	0	4083	
210		0	10-42	云23	6928	400	17.45	4.36%	0	5240	
211		0	10-42	云24	6928	400	214.50	53.62%	0	1827	
212		0	10-43	云25	6928	400	87.70	21.92%	0	4024	
213		0	10-43	云26	6928	400	108.58	27.15%	0	3662	
214		0	10-43	云27	6928	400	155.83	38.96%	0	2843	
215		0	10-44	云31	6928	400	107.09	26.77%	0	3688	
216		0	10-44	云32	6928	400	122.52	30.63%	0	3420	
217		0	10-44	云33	6928	400	23.86	5.96%	0	5129	
218		0	10-44	云34	6928	400	31.50	7.88%	0	4997	
219		0	10-44	云35	6928	400	65.78	16.45%	0	4403	
220		0	10-44	云36	6928	400	170.89	42.72%	0	2583	
221		0	10-44	云37	6928	400	99.03	24.76%	0	3827	
222		0	10-44	云38	6928	400	69.82	17.45%	0	4333	
223	35kV永安站	0	10-41	永71	6928	400	83.10	20.78%	0	4103	
224		0	10-41	永72	6235	360	70.09	19.47%	0	3774	
225		0	10-41	永73	6235	360	82.88	23.02%	0	3553	
226		0	10-41	永74	6928	400	150.54	37.64%	0	2935	
227		0	10-41	永75	6928	400	91.38	22.85%	0	3960	
228		0	10-41	永76	6928	400	51.02	12.76%	0	4659	
229		0	10-41	永77	6235	360	68.03	18.90%	0	3810	
230		0	10-41	永78	6235	360	201.00	55.83%	0	1507	
231		0	10-42	永81	6928	400	92.73	23.18%	0	3936	
232		0	10-43	永85	6928	400	200.00	50.00%	0	2078	
233		0	10-43	永88	6235	360	242.81	67.45%	0	783	
234		0	10-44	永94	6928	400	131.18	32.80%	0	3270	
235		0	10-44	永95	6928	400	166.98	41.74%	0	2650	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
236		0	10-44	永97	6235	360	166.48	46.24%	0	2105	
237		0	10-44	永98	6235	360	59.69	16.58%	0	3954	
238	35kV慎益街站	0	10-41	益11	6235	360	121.08	33.63%	0	2891	
239		0	10-41	益12	8140	470	114.70	24.40%	0	4526	
240		0	10-41	益13	8140	470	106.77	22.72%	0	4663	
241		0	10-41	益14	8140	470	45.46	9.67%	0	5725	
242		0	10-41	益15	8140	470	37.66	8.01%	0	5860	
243		0	10-41	益18	8140	470	71.95	15.31%	0	5266	
244		0	10-43	益25	8140	470	84.26	17.93%	0	5053	
245		0	10-44	益31	8140	470	88.74	18.88%	0	4975	
246		0	10-44	益34	8140	470	43.76	9.31%	0	5754	
247		0	10-44	益35	8140	470	31.07	6.61%	0	5974	
248		0	10-44	益36	8140	470	21.87	4.65%	0	6134	
249		0	10-44	益38	8140	470	11.85	2.52%	0	6307	
250	35kV青年宫站	0	10-41	宫11	8140	470	61.37	13.06%	0	5449	
251		0	10-41	宫12	8140	470	97.05	20.65%	0	4831	
252		0	10-41	宫13	8140	470	110.06	23.42%	0	4606	
253		0	10-43	宫25	8140	470	25.31	5.39%	0	6074	
254		0	10-44	宫31	8140	470	225.60	48.00%	0	2605	
255		0	10-44	宫32	8140	470	61.37	13.06%	0	5449	
256	35kV赤峰桥站	0	10-41	273	6928	400	48.00	12.00%	0	4711	
257		0	10-42	283	6928	400	132.00	33.00%	0	3256	
258		0	10-44	293	6928	400	35.00	8.75%	0	4936	
259		0	10-44	294	6928	400	47.00	11.75%	0	4728	
260	35kV十一经路 站	0	10-5	984	8140	470	100.00	21.28%	0	4780	
261		0	10-4	989	8140	470	116.00	24.68%	0	4503	
262		0	10-4	991	6928	400	148.00	37.00%	0	2979	
263	35kV琼州道站	0	10-4	琼11	8140	470	78.76	16.76%	0	5148	
264		0	10-5	琼12	8140	470	172.28	36.66%	0	3528	
265		0	10-4	琼13	8140	470	210.26	44.74%	0	2871	
266		0	10-5	琼14	8140	470	187.75	39.95%	0	3260	
267		0	10-4	琼15	8140	470	179.32	38.15%	0	3407	
268		0	10-5	琼16	8140	470	54.50	11.60%	0	5568	
269		0	10-4	琼17	8140	470	136.07	28.95%	0	4156	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
270		0	10-5	琼18	8660	500	116.73	23.35%	0	4906	
271		0	10-4	琼19	8140	470	59.77	12.72%	0	5477	
272		0	10-4	琼21	8140	470	40.79	8.68%	0	5806	
273		0	10-5	琼22	8140	470	115.32	24.54%	0	4515	
274		0	10-4	琼23	6235	360	36.57	10.16%	0	4355	
275		0	10-5	琼24	8140	470	44.30	9.43%	0	5745	
276		0	10-4	161	6235	360	166.80	46.33%	0	2099	
277	35kV绍兴道站	0	10-5	162	8140	470	72.00	15.32%	0	5265	
278		0	10-4	163	8140	470	73.80	15.70%	0	5234	
279		0	10-5	164	8660	500	116.40	23.28%	0	4912	
280		0	10-4	165	6235	360	110.40	30.67%	0	3076	
281		0	10-5	166	6235	360	78.60	21.83%	0	3627	
282		0	10-4	167	6235	360	145.80	40.50%	0	2463	
283		0	10-5	168	6235	360	120.60	33.50%	0	2899	
284		0	10-4	169	8660	500	205.20	41.04%	0	3374	
285		0	10-4	171	8140	470	148.80	31.66%	0	3935	
286		0	10-5	172	8660	500	64.20	12.84%	0	5816	
287		0	10-5	174	8660	500	23.40	4.68%	0	6523	
288	35kV友谊路站	0	10-4	781	8660	500	74.40	14.88%	0	5639	
289		0	10-5	782	8660	500	85.20	17.04%	0	5452	
290		0	10-4	783	8140	470	126.00	26.81%	0	4330	
291		0	10-5	784	8660	500	52.80	10.56%	0	6014	
292		0	10-4	785	6235	360	121.20	33.67%	0	2889	
293		0	10-5	786	8140	470	0.00	0.00%	0	6512	
294		0	10-4	787	6235	360	39.00	10.83%	0	4313	
295		0	10-5	788	6235	360	110.40	30.67%	0	3076	
296		0	10-4	789	8660	500	146.40	29.28%	0	4392	
297		0	10-4	791	8140	470	42.00	8.94%	0	5785	
298		0	10-5	792	8660	500	105.60	21.12%	0	5099	
299		0	10-4	793	8140	470	182.40	38.81%	0	3353	
300		0	10-5	794	8140	470	19.80	4.21%	0	6169	
301		0	10-5	796	8140	470	52.80	11.23%	0	5598	
302		0	10-5	916	8660	500	168.72	33.74%	0	4006	
303		0	10-5	918	8140	470	92.88	19.76%	0	4904	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
304	35kV黑牛城站	0	10-4	921	8140	470	110.16	23.44%	0	4604	
305		0	10-5	922	6235	360	151.08	41.97%	0	2371	
306		0	10-4	923	8660	500	337.08	67.42%	0	1090	
307		0	10-5	924	8660	500	91.44	18.29%	0	5344	
308		0	10-4	925	6235	360	198.60	55.17%	0	1548	
309		0	10-5	926	8140	470	144.60	30.77%	0	4008	
310		0	10-4	927	6235	360	0.00	0.00%	0	4988	
311		0	10-5	928	8140	470	30.96	6.59%	0	5976	
312		0	10-4	929	8140	470	167.16	35.57%	0	3617	
313	35kV双林站	0	10-41	双31	6928	400	125.60	31.40%	0	3367	
314		0	10-41	双32	6928	400	96.20	24.05%	0	3876	
315		0	10-41	双33	6928	400	166.60	41.65%	0	2657	
316		0	10-41	双34	6928	400	0.00	0.00%	0	5542	
317		0	10-41	双35	6928	400	165.00	41.25%	0	2685	
318		0	10-41	双36	6928	400	201.10	50.28%	0	2059	
319		0	10-41	双38	6928	400	107.20	26.80%	0	3686	
320		0	10-42	双41	6928	400	57.60	14.40%	0	4545	
321		0	10-42	双42	6928	400	89.30	22.33%	0	3996	
322		0	10-42	双44	6928	400	255.50	63.88%	0	1117	
323		0	10-43	双45	6928	400	0.00	0.00%	0	5542	
324		0	10-43	双46	6928	400	260.00	65.00%	0	1039	
325		0	10-43	双47	6928	400	151.60	37.90%	0	2917	
326		0	10-44	双51	6928	400	0.00	0.00%	0	5542	
327		0	10-44	双52	6928	400	177.80	44.45%	0	2463	
328		0	10-44	双53	6928	400	187.60	46.90%	0	2293	
329		0	10-44	双54	6928	400	115.70	28.93%	0	3538	
330		0	10-44	双55	6928	400	193.30	48.33%	0	2194	
331		0	10-44	双56	6928	400	54.60	13.65%	0	4597	
332		0	10-4	土21	8660	500	157.56	31.51%	0	4199	
333		0	10-4	土22	8660	500	75.48	15.10%	0	5621	
334		0	10-4	土23	6235	360	104.40	29.00%	0	3180	
335		0	10-4	土24	8660	500	30.60	6.12%	0	6398	
336		0	10-4	土25	8140	470	35.28	7.51%	0	5901	
337		0	10-4	土26	8140	470	264.48	56.27%	0	1932	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
338	35kV土城站	0	10-4	土27	8140	470	245.40	52.21%	0	2262	
339		0	10-5	土31	6235	360	44.76	12.43%	0	4213	
340		0	10-5	土32	6235	360	159.24	44.23%	0	2230	
341		0	10-5	土33	8140	470	147.00	31.28%	0	3966	
342		0	10-5	土34	8660	500	109.44	21.89%	0	5032	
343		0	10-5	土35	8660	500	132.00	26.40%	0	4642	
344		0	10-5	土36	8660	500	85.20	17.04%	0	5452	
345		0	10-41	轻71	6928	400	54.73	13.68%	0	4594	
346	35kV轻院东站	0	10-41	轻72	6928	400	63.26	15.82%	0	4447	
347		0	10-41	轻73	6928	400	71.24	17.81%	0	4309	
348		0	10-41	轻75	6928	400	167.76	41.94%	0	2637	
349		0	10-41	轻76	6928	400	218.37	54.59%	0	1760	
350		0	10-41	轻77	6235	360	190.76	52.99%	0	1684	
351		0	10-41	轻78	6928	400	83.87	20.97%	0	4090	
352		0	10-42	轻81	6928	400	58.01	14.50%	0	4538	
353		0	10-42	轻82	6928	400	121.65	30.41%	0	3435	
354		0	10-42	轻83	6928	400	37.65	9.41%	0	4890	
355		0	10-42	轻84	6928	400	132.75	33.19%	0	3243	
356		0	10-43	轻85	6928	400	119.96	29.99%	0	3465	
357		0	10-43	轻86	6928	400	194.55	48.64%	0	2173	
358		0	10-43	轻87	6928	400	96.39	24.10%	0	3873	
359		0	10-43	轻88	6928	400	183.80	45.95%	0	2359	
360		0	10-44	轻91	6928	400	33.39	8.35%	0	4964	
361		0	10-44	轻92	6928	400	131.22	32.81%	0	3270	
362		0	10-44	轻93	6928	400	41.48	10.37%	0	4824	
363		0	10-44	轻94	6928	400	59.49	14.87%	0	4512	
364		0	10-44	轻95	6928	400	27.59	6.90%	0	5065	
365		0	10-44	轻96	6928	400	237.38	59.35%	0	1431	
366		0	10-44	轻97	6928	400	123.66	30.92%	0	3401	
367		0	10-41	纪11	6928	400	31.06	7.76%	0	5005	
368		0	10-41	纪12	6928	400	83.91	20.98%	0	4089	
369		0	10-41	纪13	6928	400	153.75	38.44%	0	2879	
370		0	10-41	纪14	6928	400	9.96	2.49%	0	5370	
371		0	10-41	纪15	6928	400	167.47	41.87%	0	2642	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
372	35kV纪庄子站	0	10-41	纪16	6928	400	73.24	18.31%	0	4274	
373		0	10-41	纪18	6928	400	303.64	75.91%	0	283	
374		0	10-42	纪21	6928	400	103.13	25.78%	0	3756	
375		0	10-42	纪22	6928	400	269.54	67.38%	0	874	
376		0	10-43	纪25	6928	400	67.03	16.76%	0	4381	
377		0	10-43	纪26	6928	400	18.52	4.63%	0	5222	
378		0	10-43	纪27	6928	400	179.65	44.91%	0	2431	
379		0	10-43	纪28	6235	360	179.07	49.74%	0	1887	
380		0	10-44	纪31	6928	400	196.30	49.07%	0	2143	
381		0	10-44	纪32	6928	400	120.12	30.03%	0	3462	
382		0	10-44	纪33	6928	400	15.59	3.90%	0	5272	
383		0	10-44	纪34	6928	400	62.70	15.67%	0	4456	
384		0	10-44	纪36	6928	400	24.84	6.21%	0	5112	
385		0	10-44	纪37	6928	400	211.53	52.88%	0	1879	
386		0	10-44	纪38	6928	400	6.80	1.70%	0	5425	
387	35kV兰水站	0	10-41	兰11	6928	400	39.31	9.83%	0	4862	
388		0	10-41	兰12	6928	400	97.81	24.45%	0	3848	
389		0	10-41	兰13	6928	400	73.71	18.43%	0	4266	
390		0	10-41	兰14	6928	400	160.29	40.07%	0	2766	
391		0	10-41	兰15	6928	400	160.29	40.07%	0	2766	
392		0	10-41	兰17	6928	400	34.63	8.66%	0	4943	
393		0	10-41	兰18	6928	400	113.02	28.26%	0	3585	
394		0	10-42	兰21	6928	400	44.23	11.06%	0	4776	
395		0	10-42	兰22	6928	400	213.88	53.47%	0	1838	
396		0	10-42	兰23	6928	400	118.87	29.72%	0	3484	
397		0	10-42	兰24	6928	400	93.13	23.28%	0	3929	
398		0	10-43	兰25	6928	400	24.86	6.21%	0	5112	
399		0	10-43	兰26	6928	400	174.23	43.56%	0	2525	
400		0	10-43	兰27	6928	400	107.40	26.85%	0	3682	
401		0	10-43	兰28	6928	400	36.58	9.15%	0	4909	
402		0	10-44	兰31	6928	400	108.33	27.08%	0	3666	
403		0	10-44	兰32	6928	400	56.98	14.25%	0	4555	
404		0	10-44	兰33	6928	400	90.28	22.57%	0	3979	
405		0	10-44	兰34	6928	400	138.35	34.59%	0	3146	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
406		0	10-44	兰35	6928	400	152.42	38.10%	0	2903	
407		0	10-44	兰37	6928	400	105.05	26.26%	0	3723	
408		0	10-44	兰38	6928	400	202.60	50.65%	0	2033	
409	35kV珠江道站	0	10-41	江11	8140	470	114.00	24.26%	0	4538	
410		0	10-41	江12	8140	470	48.60	10.34%	0	5671	
411		0	10-41	江13	8140	470	42.00	8.94%	0	5785	
412		0	10-41	江14	8140	470	56.40	12.00%	0	5535	
413		0	10-41	江15	8140	470	4.20	0.89%	0	6440	
414		0	10-41	江16	8140	470	115.80	24.64%	0	4507	
415		0	10-41	江17	8140	470	58.80	12.51%	0	5494	
416		0	10-41	江18	8140	470	59.40	12.64%	0	5484	
417		0	10-42	江21	8140	470	60.60	12.89%	0	5463	
418		0	10-42	江22	8140	470	240.60	51.19%	0	2345	
419		0	10-42	江23	8140	470	36.00	7.66%	0	5889	
420		0	10-42	江24	8140	470	0.00	0.00%	0	6512	
421		0	10-43	江25	8140	470	150.60	32.04%	0	3904	
422		0	10-43	江26	8140	470	75.00	15.96%	0	5213	
423		0	10-43	江27	8140	470	4.80	1.02%	0	6429	
424		0	10-43	江28	8140	470	143.40	30.51%	0	4029	
425		0	10-44	江31	8140	470	0.00	0.00%	0	6512	
426		0	10-44	江32	8140	470	235.20	50.04%	0	2439	
427		0	10-44	江33	8140	470	22.80	4.85%	0	6117	
428		0	10-44	江34	8140	470	34.80	7.40%	0	5910	
429		0	10-44	江35	8140	470	168.60	35.87%	0	3592	
430		0	10-44	江37	8140	470	36.00	7.66%	0	5889	
431		0	10-44	江38	8140	470	36.60	7.79%	0	5878	
432	35kV隆昌路站	0	10-41	隆11	8140	470	87.56	18.63%	0	4996	
433		0	10-41	隆12	8140	470	41.31	8.79%	0	5797	
434		0	10-41	隆13	8140	470	158.78	33.78%	0	3762	
435		0	10-41	隆15	8140	470	37.27	7.93%	0	5867	
436		0	10-41	隆17	8140	470	146.47	31.16%	0	3975	
437		0	10-42	隆21	8140	470	84.58	17.99%	0	5047	
438		0	10-42	隆22	8140	470	49.59	10.55%	0	5653	
439		0	10-42	隆23	8140	470	229.80	48.89%	0	2532	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
440		0	10-43	隆25	8140	470	77.02	16.39%	0	5178	
441		0	10-44	隆31	8140	470	10.20	2.17%	0	6336	
442		0	10-44	隆32	8140	470	199.74	42.50%	0	3053	
443		0	10-44	隆38	8140	470	57.15	12.16%	0	5522	
444	35kV挂甲寺站	0	10-41	甲11	8140	470	61.24	13.03%	0	5452	
445		0	10-41	甲12	8140	470	80.28	17.08%	0	5122	
446		0	10-41	甲13	8140	470	88.85	18.90%	0	4973	
447		0	10-41	甲14	8140	470	75.77	16.12%	0	5200	
448		0	10-41	甲15	8140	470	51.80	11.02%	0	5615	
449		0	10-41	甲16	8140	470	136.10	28.96%	0	4155	
450		0	10-41	甲17	8140	470	108.18	23.02%	0	4639	
451		0	10-42	甲21	8140	470	81.86	17.42%	0	5095	
452		0	10-42	甲22	8140	470	43.67	9.29%	0	5756	
453		0	10-43	甲27	8140	470	37.31	7.94%	0	5866	
454		0	10-43	甲28	8140	470	60.43	12.86%	0	5466	
455		0	10-44	甲31	8140	470	122.94	26.16%	0	4383	
456		0	10-44	甲32	8140	470	12.10	2.57%	0	6303	
457		0	10-44	甲33	8140	470	140.27	29.84%	0	4083	
458		0	10-44	甲35	8140	470	57.24	12.18%	0	5521	
459		0	10-44	甲36	8140	470	136.49	29.04%	0	4148	
460		0	10-44	甲38	8140	470	110.62	23.54%	0	4596	
461	35kV长青站	0	10-41	长11	6928	400	212.45	53.11%	0	1863	
462		0	10-41	长12	6928	400	107.87	26.97%	0	3674	
463		0	10-41	长13	6928	400	10.79	2.70%	0	5356	
464		0	10-41	长14	6928	400	121.47	30.37%	0	3439	
465		0	10-41	长15	6928	400	283.03	70.76%	0	640	
466		0	10-41	长16	6928	400	74.57	18.64%	0	4251	
467		0	10-41	长17	6928	400	22.98	5.74%	0	5144	
468		0	10-41	长18	6928	400	71.75	17.94%	0	4300	
469		0	10-43	长25	6928	400	47.13	11.78%	0	4726	
470		0	10-43	长27	6928	400	92.86	23.21%	0	3934	
471		0	10-44	长31	6928	400	123.34	30.84%	0	3406	
472		0	10-44	长33	6928	400	59.09	14.77%	0	4519	
473		0	10-44	长35	6928	400	244.81	61.20%	0	1302	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
474		0	10-44	长36	6928	400	34.94	8.73%	0	4937	
475		0	10-44	长37	6928	400	25.79	6.45%	0	5096	
476		0	10-44	长38	6928	400	187.36	46.84%	0	2297	
477	35kV丽江道站	0	10-41	丽51	6928	400	20.86	5.21%	0	5181	
478		0	10-41	丽52	6928	400	46.87	11.72%	0	4731	
479		0	10-41	丽53	6928	400	224.34	56.09%	0	1657	
480		0	10-41	丽54	6928	400	1.15	0.29%	0	5523	
481		0	10-41	丽55	6928	400	108.17	27.04%	0	3669	
482		0	10-41	丽57	6928	400	148.68	37.17%	0	2967	
483		0	10-41	丽58	6928	400	115.74	28.94%	0	3538	
484		0	10-42	丽64	6928	400	191.32	47.83%	0	2229	
485		0	10-43	丽65	6928	400	18.49	4.62%	0	5222	
486		0	10-44	丽71	6928	400	37.68	9.42%	0	4890	
487		0	10-44	丽72	6928	400	232.19	58.05%	0	1521	
488		0	10-44	丽73	6928	400	0.77	0.19%	0	5529	
489		0	10-44	丽74	6928	400	37.30	9.33%	0	4896	
490		0	10-44	丽75	6928	400	168.24	42.06%	0	2628	
491		0	10-44	丽78	6928	400	108.20	27.05%	0	3668	
492	110kV小海地站	0	10-41	地11	8140	470	40.04	8.52%	0	5819	
493		0	10-42	地21	8140	470	27.31	5.81%	0	6039	
494		0	10-42	地24	8140	470	173.51	36.92%	0	3507	
495		0	10-42	地25	8660	500	102.64	20.53%	0	5150	
496		0	10-42	地26	6235	360	217.03	60.29%	0	1229	
497		0	10-43	地31	8140	470	44.76	9.52%	0	5737	
498		0	10-43	地32	8140	470	211.32	44.96%	0	2852	
499		0	10-43	地34	8660	500	189.74	37.95%	0	3642	
500		0	10-43	地35	8660	500	334.31	66.86%	0	1138	
501		0	10-41	地62	8140	470	170.46	36.27%	0	3560	
502		0	10-41	地63	8140	470	130.01	27.66%	0	4261	
503		0	10-41	地64	8140	470	204.95	43.61%	0	2963	
504		0	10-41	地65	8660	500	0.00	0.00%	0	6928	
505		0	10-41	地66	8140	470	181.52	38.62%	0	3368	
506	110kV东江道站	0	10-42	东65	6928	400	13.90	3.47%	0	5302	
507		0	10-44	东91	6928	400	6.60	1.65%	0	5428	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
508	110kV复兴门站	0	10-41	复15	8140	470	190.51	40.45%	0	3213	
509		0	10-41	复16	8140	470	66.89	14.23%	0	5354	
510		0	10-42	复23	8140	470	136.94	29.14%	0	4141	
511		0	10-42	复24	8140	470	120.12	25.56%	0	4432	
512		0	10-42	复35	8140	470	167.56	35.65%	0	3610	
513		0	10-42	复36	8140	470	83.85	17.84%	0	5060	
514		0	10-44	复43	8140	470	173.51	36.92%	0	3507	
515		0	10-44	复44	8140	470	135.18	28.76%	0	4171	
516		0	10-4	东21	6928	400	143.44	35.86%	0	3058	
517	35kV东周站	0	10-5	东23	6928	400	63.68	15.92%	0	4439	
518		0	10-4	东25	6928	400	164.88	41.22%	0	2687	
519		0	10-4	东27	6928	400	67.12	16.78%	0	4380	
520		0	10-4	东29	6928	400	179.68	44.92%	0	2430	
521		0	10-5	东22	6928	400	8.96	2.24%	0	5387	
522		0	10-5	东24	6928	400	234.72	58.68%	0	1477	
523		0	10-5	东26	6928	400	227.20	56.80%	0	1607	
524		0	10-4	东27	6928	400	67.12	16.78%	0	4380	
525		0	10-5	东28	6928	400	178.96	44.74%	0	2443	
526		0	10-5	东30	6928	400	40.16	10.04%	0	4847	
527		0	10-41	金971	8140	470	61.20	13.02%	0	5452	
528		0	10-41	金972	8140	470	164.44	34.99%	0	3664	
529	35kV金地站	0	10-41	金973	8140	470	66.36	14.12%	0	5363	
530		0	10-41	金975	8140	470	130.68	27.80%	0	4249	
531		0	10-41	金976	6235	360	51.97	14.44%	0	4088	
532		0	10-41	金977	6235	360	59.27	16.46%	0	3962	
533		0	10-41	金978	8140	470	39.95	8.50%	0	5820	
534		0	10-41	金979	8140	470	230.64	49.07%	0	2518	
535		0	10-42	金981	8140	470	129.60	27.57%	0	4268	
536		0	10-42	金985	8140	470	107.64	22.90%	0	4648	
537		0	10-43	金986	8660	500	65.31	13.06%	0	5797	
538		0	10-43	金987	6235	360	114.53	31.82%	0	3004	
539		0	10-43	金988	8140	470	97.66	20.78%	0	4821	
540		0	10-44	金991	8140	470	12.24	2.60%	0	6300	
541		0	10-44	金992	8140	470	39.07	8.31%	0	5836	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
542		0	10-44	金993	6235	360	28.44	7.90%	0	4496	
543		0	10-44	金995	8140	470	27.06	5.76%	0	6044	
544		0	10-44	金996	8140	470	125.16	26.63%	0	4345	
545		0	10-44	金997	8140	470	59.34	12.63%	0	5485	
546		0	10-44	金998	8140	470	329.28	70.06%	0	809	
547	35kV三合站	0	10-4	661	6928	400	101.72	25.43%	0	3781	
548		0	10-5	662	6928	400	42.89	10.72%	0	4800	
549		0	10-4	663	6928	400	169.21	42.30%	0	2612	
550		0	10-5	664	6928	400	82.38	20.60%	0	4116	
551		0	10-4	665	6928	400	45.00	11.25%	0	4763	
552		0	10-5	666	6928	400	63.98	16.00%	0	4434	
553		0	10-4	667	6928	400	23.09	5.77%	0	5143	
554		0	10-5	668	6928	400	76.76	19.19%	0	4213	
555		0	10-4	671	6928	400	93.16	23.29%	0	3929	
556		0	10-5	672	6928	400	125.27	31.32%	0	3373	
557	35kV双闸站	0	10-41	531	6928	400	34.23	8.56%	0	4950	
558		0	10-41	532	6928	400	30.01	7.50%	0	5023	
559		0	10-41	533	6928	400	118.39	29.60%	0	3492	
560		0	10-41	534	6928	400	44.31	11.08%	0	4775	
561		0	10-44	551	6928	400	130.31	32.58%	0	3285	
562		0	10-43	552	6928	400	170.16	42.54%	0	2595	
563		0	10-44	553	6928	400	93.87	23.47%	0	3917	
564		0	10-43	554	6928	400	74.41	18.60%	0	4254	
565		0	10-44	555	6928	400	143.67	35.92%	0	3054	
566		0	10-43	556	6928	400	45.23	11.31%	0	4759	
567		0	10-44	557	6928	400	58.24	14.56%	0	4534	
568		0	10-42	558	6928	400	52.50	13.13%	0	4633	
569		0	10-44	559	6928	400	37.97	9.49%	0	4885	
570		0	10-44	561	6928	400	1.99	0.50%	0	5508	
571		0	10-42	562	6928	400	21.33	5.33%	0	5173	
572		0	10-41	头61	8140	470	171.60	36.51%	0	3540	
573		0	10-41	头62	8660	500	0.48	0.10%	0	6920	
574		0	10-41	头63	6235	360	253.32	70.37%	0	601	
575		0	10-41	头64	6235	360	164.16	45.60%	0	2145	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
576	35kV头道沟站	0	10-41	头65	6235	360	56.64	15.73%	0	4007	
577		0	10-41	头66	8140	470	136.44	29.03%	0	4149	
578		0	10-41	头67	8140	470	177.36	37.74%	0	3440	
579		0	10-42	头68	6235	360	0.48	0.13%	0	4980	
580		0	10-42	头69	6235	360	229.68	63.80%	0	1010	
581		0	10-42	头71	6235	360	112.68	31.30%	0	3037	
582		0	10-42	头72	6235	360	166.80	46.33%	0	2099	
583		0	10-42	头73	8140	470	4.80	1.02%	0	6429	
584		0	10-42	头75	8140	470	283.08	60.23%	0	1609	
585		0	10-42	头76	6235	360	120.96	33.60%	0	2893	
586	35kV鑫港湾站	0	10-41	港11	8140	470	186.70	39.72%	0	3279	
587		0	10-41	港12	8140	470	35.86	7.63%	0	5891	
588		0	10-41	港13	8140	470	130.80	27.83%	0	4247	
589		0	10-41	港14	8140	470	157.52	33.51%	0	3784	
590		0	10-41	港15	8660	500	106.53	21.31%	0	5083	
591		0	10-41	港16	8140	470	81.92	17.43%	0	5093	
592		0	10-41	港17	8140	470	125.87	26.78%	0	4332	
593		0	10-42	港21	8140	470	28.48	6.06%	0	6019	
594		0	10-43	港25	6235	360	127.63	35.45%	0	2778	
595		0	10-43	港27	8140	470	2.46	0.52%	0	6470	
596		0	10-44	港31	6235	360	82.98	23.05%	0	3551	
597		0	10-44	港32	6235	360	132.90	36.92%	0	2686	
598		0	10-44	港33	6235	360	16.17	4.49%	0	4708	
599		0	10-44	港34	6235	360	147.67	41.02%	0	2430	
600		0	10-44	港35	8140	470	16.17	3.44%	0	6232	
601		0	10-44	港36	8140	470	86.85	18.48%	0	5008	
602	35kV咸水沽站	0	10-5	485	6928	400	16.17	4.04%	0	5262	
603		0	10-4	486	6928	400	0.00	0.00%	0	5542	
604		0	10-4	487	6928	400	97.74	24.43%	0	3850	
605		0	10-5	488	6928	400	140.40	35.10%	0	3111	
606		0	10-5	489	6928	400	71.25	17.81%	0	4308	
607		0	10-5	490	6928	400	5.27	1.32%	0	5451	
608		0	10-4	491	6928	400	27.77	6.94%	0	5061	
609		0	10-5	492	6928	400	146.14	36.53%	0	3011	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
610		0	10-4	493	6928	400	145.55	36.39%	0	3021	
611		0	10-5	494	6928	400	88.36	22.09%	0	4012	
612		0	10-4	495	6928	400	226.53	56.63%	0	1619	
613		0	10-5	496	6928	400	204.50	51.13%	0	2000	
614		0	10-4	497	6928	400	39.14	9.79%	0	4864	
615		0	10-5	498	6928	400	26.37	6.59%	0	5086	
616		0	10-4	499	6928	400	227.35	56.84%	0	1605	
617		0	10-41	站14	8660	500	34.63	6.93%	0	6328	
618	35kV小站站	0	10-41	站15	8140	470	76.99	16.38%	0	5179	
619		0	10-41	站16	8660	500	228.87	45.77%	0	2964	
620		0	10-41	站17	8660	500	140.10	28.02%	0	4501	
621		0	10-41	站18	8140	470	190.55	40.54%	0	3212	
622		0	10-42	站21	8660	500	46.41	9.28%	0	6124	
623		0	10-43	站25	8660	500	50.80	10.16%	0	6048	
624		0	10-43	站26	8660	500	207.78	41.56%	0	3329	
625		0	10-43	站27	8660	500	64.69	12.94%	0	5808	
626		0	10-43	站28	8140	470	271.41	57.75%	0	1811	
627		0	10-41	辛11	6928	400	112.90	28.22%	0	3587	
628	35kV辛庄站	0	10-41	辛12	6928	400	78.64	19.66%	0	4180	
629		0	10-41	辛13	6928	400	51.24	12.81%	0	4655	
630		0	10-41	辛14	6928	400	106.42	26.61%	0	3699	
631		0	10-41	辛15	6928	400	96.42	24.10%	0	3872	
632		0	10-41	辛16	6928	400	126.83	31.71%	0	3346	
633		0	10-41	辛17	6928	400	29.63	7.41%	0	5029	
634		0	10-42	辛21	6928	400	9.29	2.32%	0	5382	
635		0	10-43	辛26	6928	400	98.57	24.64%	0	3835	
636		0	10-43	辛28	6928	400	92.64	23.16%	0	3938	
637		0	10-44	辛31	6928	400	31.78	7.95%	0	4992	
638		0	10-44	辛32	6928	400	11.50	2.88%	0	5343	
639		0	10-44	辛34	6928	400	170.97	42.74%	0	2581	
640		0	10-44	辛35	6928	400	87.41	21.85%	0	4028	
641		0	10-44	辛36	6928	400	116.31	29.08%	0	3528	
642		0	10-44	辛37	6928	400	19.68	4.92%	0	5202	
643		0	10-44	辛38	6928	400	241.32	60.33%	0	1363	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
644	35kV裕盛站	0	10-42	裕21	8140	470	129.28	27.51%	0	4273	
645		0	10-42	裕22	8140	470	0.00	0.00%	0	6512	
646		0	10-42	裕23	6235	360	88.26	24.52%	0	3460	
647		0	10-43	裕24	8140	470	119.60	25.45%	0	4441	
648		0	10-43	裕25	8140	470	154.46	32.86%	0	3837	
649		0	10-43	裕26	6235	360	154.46	42.91%	0	2313	
650		0	10-43	裕27	8140	470	153.84	32.73%	0	3848	
651		0	10-42	裕28	8140	470	24.74	5.26%	0	6084	
652		0	10-44	裕31	6235	360	43.47	12.07%	0	4235	
653		0	10-44	裕32	8140	470	124.48	26.48%	0	4356	
654		0	10-44	裕33	8140	470	67.68	14.40%	0	5340	
655		0	10-44	裕34	8140	470	238.60	50.77%	0	2380	
656		0	10-44	裕35	6235	360	113.71	31.59%	0	3019	
657		0	10-44	裕36	6235	360	123.86	34.40%	0	2843	
658		0	10-44	裕37	8140	470	229.77	48.89%	0	2533	
659	35kV致业路站	0	10-41	业11	6235	360	133.86	37.18%	0	2670	
660		0	10-41	业12	6235	360	249.21	69.22%	0	672	
661		0	10-41	业13	6235	360	63.05	17.51%	0	3896	
662		0	10-41	业14	6235	360	48.28	13.41%	0	4152	
663		0	10-41	业15	6235	360	38.20	10.61%	0	4326	
664		0	10-42	业23	6235	360	217.57	60.44%	0	1220	
665		0	10-43	业25	6235	360	190.11	52.81%	0	1695	
666		0	10-43	业26	8140	470	3.75	0.80%	0	6447	
667		0	10-44	业31	6235	360	258.35	71.76%	0	514	
668		0	10-44	业32	6235	360	87.92	24.42%	0	3465	
669		0	10-44	业33	8140	470	3.05	0.65%	0	6460	
670		0	10-41	洋11	6928	400	69.61	17.40%	0	4337	
671		0	10-41	洋13	6928	400	158.32	39.58%	0	2800	
672		0	10-41	洋14	6928	400	82.97	20.74%	0	4105	
673		0	10-41	洋15	6928	400	135.94	33.98%	0	3188	
674		0	10-41	洋16	6928	400	142.27	35.57%	0	3078	
675		0	10-42	洋21	6928	400	49.92	12.48%	0	4678	
676		0	10-42	洋22	6928	400	94.34	23.58%	0	3908	
677		0	10-42	洋23	6928	400	55.78	13.95%	0	4576	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
678	110kV北洋园站	0	10-42	洋24	6928	400	78.87	19.72%	0	4176	
679		0	10-42	洋25	6928	400	122.23	30.56%	0	3425	
680		0	10-42	洋26	6928	400	64.57	16.14%	0	4424	
681		0	10-43	洋31	6928	400	47.46	11.87%	0	4720	
682		0	10-43	洋32	6928	400	201.33	50.33%	0	2055	
683		0	10-43	洋33	6928	400	186.33	46.58%	0	2315	
684		0	10-43	洋34	6928	400	110.04	27.51%	0	3637	
685		0	10-43	洋35	6928	400	64.57	16.14%	0	4424	
686		0	10-43	洋36	6928	400	187.38	46.85%	0	2297	
687		0	10-44	洋41	6928	400	194.88	48.72%	0	2167	
688		0	10-44	洋42	6928	400	20.98	5.24%	0	5179	
689		0	10-44	洋43	6928	400	100.66	25.17%	0	3799	
690		0	10-44	洋44	6928	400	196.76	49.19%	0	2135	
691		0	10-44	洋45	6928	400	154.45	38.61%	0	2867	
692		0	10-44	洋46	6928	400	145.90	36.47%	0	3015	
693		0	10-45	洋51	6928	400	224.77	56.19%	0	1649	
694		0	10-45	洋53	6928	400	204.14	51.04%	0	2007	
695		0	10-45	洋55	6928	400	0.00	0.00%	0	5542	
696		0	10-45	洋56	6928	400	106.17	26.54%	0	3704	
697		0	10-46	洋62	6928	400	184.92	46.23%	0	2340	
698		0	10-46	洋64	6928	400	127.97	31.99%	0	3326	
699		0	10-46	洋65	6928	400	171.80	42.95%	0	2567	
700	110kV北闸口站	0	10-4	81	6928	400	79.94	19.99%	0	4158	
701		0	10-5	82	8140	470	272.88	58.06%	0	1786	
702		0	10-4	83	6928	400	82.52	20.63%	0	4113	
703		0	10-5	84	6928	400	94.48	23.62%	0	3906	
704		0	10-4	85	6928	400	104.79	26.20%	0	3727	
705		0	10-5	86	6928	400	206.30	51.58%	0	1969	
706		0	10-4	87	6928	400	190.83	47.71%	0	2237	
707		0	10-5	88	6928	400	126.83	31.71%	0	3346	
708		0	10-4	89	8140	470	207.00	44.04%	0	2927	
709		0	10-4	91	6928	400	147.93	36.98%	0	2980	
710		0	10-5	92	6928	400	98.70	24.67%	0	3833	
711		0	10-5	94	6235	360	117.92	32.76%	0	2946	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
712	110kV李家圈站	0	10-41	李570	6928	400	158.61	39.65%	0	2795	
713		0	10-41	李571	6928	400	23.95	5.99%	0	5128	
714		0	10-41	李575	6928	400	257.42	64.36%	0	1084	
715		0	10-41	李576	6928	400	44.80	11.20%	0	4766	
716		0	10-41	李577	6928	400	44.29	11.07%	0	4775	
717		0	10-41	李578	6235	360	201.79	56.05%	0	1493	
718		0	10-41	李579	6235	360	163.46	45.41%	0	2157	
719		0	10-42	李581	6928	400	114.18	28.55%	0	3565	
720		0	10-42	李582	6928	400	225.77	56.44%	0	1632	
721		0	10-42	李583	6235	360	199.43	55.40%	0	1534	
722		0	10-42	李585	6235	360	153.43	42.62%	0	2331	
723		0	10-43	李586	6928	400	135.87	33.97%	0	3189	
724		0	10-43	李587	6928	400	54.55	13.64%	0	4598	
725		0	10-43	李588	6928	400	62.99	15.75%	0	4451	
726		0	10-43	李589	6928	400	287.64	71.91%	0	560	
727		0	10-44	李590	6928	400	195.61	48.90%	0	2154	
728		0	10-44	李592	6928	400	164.37	41.09%	0	2696	
729		0	10-44	李593	6235	360	113.14	31.43%	0	3029	
730		0	10-44	李595	6235	360	160.60	44.61%	0	2207	
731		0	10-44	李596	6928	400	212.50	53.13%	0	1862	
732		0	10-44	李597	6928	400	22.15	5.54%	0	5159	
733		0	10-44	李598	6928	400	166.43	41.61%	0	2660	
734		0	10-44	李599	6928	400	224.59	56.15%	0	1653	
735	110kV马集站	0	10-4	集51	6235	360	70.67	19.63%	0	3764	
736		0	10-5	集52	6235	360	103.01	28.61%	0	3204	
737		0	10-4	集53	6235	360	222.89	61.92%	0	1128	
738		0	10-5	集54	6235	360	276.86	76.91%	0	193	
739		0	10-4	集55	6235	360	263.15	73.10%	0	430	
740		0	10-5	集56	6235	360	6.86	1.90%	0	4869	
741		0	10-4	集57	8140	470	105.82	22.52%	0	4679	
742		0	10-5	集58	8140	470	89.12	18.96%	0	4969	
743		0	10-4	集59	8140	470	190.20	40.47%	0	3218	
744		0	10-4	集61	8140	470	175.78	37.40%	0	3468	
745		0	10-5	集62	8140	470	20.57	4.38%	0	6156	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
746		0	10-4	集63	6235	360	81.74	22.71%	0	3572	
747		0	10-5	集64	6235	360	266.14	73.93%	0	379	
748		0	10-4	集65	6235	360	0.00	0.00%	0	4988	
749		0	10-5	集66	6235	360	158.73	44.09%	0	2239	
750		0	10-5	集68	8140	470	85.78	18.25%	0	5027	
751		0	10-5	集72	8140	470	67.33	14.32%	0	5346	
752		0	10-4	951	6928	400	0.00	0.00%	0	5542	
753	10kV南八里台站	0	10-5	952	6928	400	261.10	65.28%	0	1020	
754		0	10-4	953	6928	400	249.85	62.46%	0	1215	
755		0	10-5	954	6928	400	89.07	22.27%	0	4000	
756		0	10-4	955	6928	400	138.99	34.75%	0	3135	
757		0	10-5	956	6928	400	71.72	17.93%	0	4300	
758		0	10-4	957	6928	400	123.52	30.88%	0	3403	
759		0	10-5	958	6928	400	59.53	14.88%	0	4511	
760		0	10-4	959	6928	400	258.76	64.69%	0	1061	
761		0	10-4	961	6928	400	25.78	6.45%	0	5096	
762		0	10-5	962	6928	400	71.29	17.82%	0	4308	
763		0	10-4	963	6928	400	75.24	18.81%	0	4239	
764		0	10-5	964	6928	400	118.60	29.65%	0	3488	
765		0	10-4	965	6928	400	133.13	33.28%	0	3237	
766		0	10-5	966	6928	400	132.89	33.22%	0	3241	
767		0	10-5	968	6928	400	160.32	40.08%	0	2766	
768		0	10-41	上810	8140	470	88.65	18.86%	0	4977	
769		0	10-41	上811	8140	470	198.64	42.26%	0	3072	
770		0	10-41	上812	8660	500	101.25	20.25%	0	5174	
771		0	10-41	上813	8140	470	48.34	10.29%	0	5675	
772		0	10-41	上814	8140	470	63.28	13.46%	0	5416	
773		0	10-41	上815	8140	470	281.25	59.84%	0	1641	
774		0	10-41	上816	8140	470	226.23	48.13%	0	2594	
775		0	10-42	上817	8140	470	176.14	37.48%	0	3462	
776		0	10-42	上818	8660	500	278.97	55.79%	0	2096	
777	110kV上刘庄站	0	10-42	上819	8140	470	199.87	42.52%	0	3051	
778		0	10-43	上821	8140	470	233.79	49.74%	0	2463	
779		0	10-43	上822	8140	470	271.94	57.86%	0	1802	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
780		0	10-43	上823	8140	470	126.67	26.95%	0	4318	
781		0	10-44	上831	8140	470	219.55	46.71%	0	2710	
782		0	10-44	上832	8140	470	232.56	49.48%	0	2484	
783		0	10-44	上833	8140	470	170.86	36.35%	0	3553	
784		0	10-44	上834	8140	470	169.28	36.02%	0	3580	
785		0	10-44	上835	8140	470	91.94	19.56%	0	4932	
786		0	10-44	上836	8140	470	68.73	14.62%	0	5322	
787		0	10-41	翟851	8140	470	344.08	73.21%	0	553	
788	110kV翟家甸站	0	10-41	翟852	8140	470	165.01	35.11%	0	3654	
789		0	10-41	翟853	8140	470	82.27	17.50%	0	5087	
790		0	10-41	翟854	8140	470	217.98	46.38%	0	2737	
791		0	10-41	翟858	8140	470	210.71	44.83%	0	2863	
792		0	10-42	翟861	6928	400	158.80	39.70%	0	2792	
793		0	10-42	翟862	6928	400	211.88	52.97%	0	1873	
794		0	10-42	翟863	6928	400	166.65	41.66%	0	2656	
795		0	10-42	翟864	6928	400	199.93	49.98%	0	2080	
796		0	10-43	翟865	6928	400	300.48	75.12%	0	338	
797		0	10-43	翟866	6928	400	214.70	53.67%	0	1824	
798		0	10-43	翟867	6928	400	264.39	66.10%	0	963	
799		0	10-43	翟868	6235	360	264.85	73.57%	0	401	
800		0	10-44	翟873	6928	400	296.38	74.09%	0	409	
801		0	10-44	翟875	6928	400	259.58	64.90%	0	1046	
802		0	10-44	翟876	6235	360	131.37	36.49%	0	0	
803		0	10-44	翟878	6928	400	228.64	57.16%	0	1582	
804	110kV正营站	0	10-41	正21	8660	500	53.63	10.73%	0	5999	
805		0	10-41	正22	8660	500	117.62	23.52%	0	4891	
806		0	10-41	正23	8660	500	175.82	35.16%	0	3883	
807		0	10-41	正24	8140	470	185.31	39.43%	0	3303	
808		0	10-41	正25	6235	360	106.90	29.69%	0	3137	
809		0	10-41	正26	8140	470	130.28	27.72%	0	4256	
810		0	10-42	正27	8140	470	129.23	27.50%	0	4274	
811		0	10-42	正28	8140	470	17.23	3.67%	0	6214	
812		0	10-42	正29	8140	470	41.32	8.79%	0	5797	
813		0	10-43	正32	6235	360	196.92	54.70%	0	1578	

序号	变电站名称	主变最大 负荷日后 需预留容 量（kVA）	所属母 线	线路名 称	线路允 许容量 （kVA）	允许电 流（A）	历史最大 电流（A）	最高负载 率（%）	线路最大负 荷日后需预 留容量 （kVA）	可开放容 量（kVA）	备注
814		0	10-43	正33	8140	470	126.24	26.86%	0	4326	
815	110kV西花园站	0	10-41	西11	6928	400	158.28	39.57%	0	2801	
816		0	10-41	西12	6928	400	34.33	8.58%	0	4948	
817		0	10-41	西13	6928	400	193.92	48.48%	0	2184	
818		0	10-41	西14	6928	400	118.90	29.73%	0	3483	
819		0	10-41	西15	6235	360	68.91	19.14%	0	3795	
820		0	10-41	西16	6235	360	76.20	21.17%	0	3668	
821		0	10-41	西17	6928	400	136.50	34.13%	0	3178	
822		0	10-41	西18	6928	400	206.32	51.58%	0	1969	
823		0	10-42	西21	6928	400	171.36	42.84%	0	2574	
824		0	10-42	西22	6928	400	78.82	19.70%	0	4177	
825		0	10-42	西23	6928	400	199.41	49.85%	0	2089	
826		0	10-42	西24	6928	400	83.89	20.97%	0	4090	
827		0	10-43	西25	6235	360	34.16	9.49%	0	4397	
828		0	10-43	西26	6235	360	139.54	38.76%	0	2571	
829		0	10-43	西27	6235	360	102.87	28.58%	0	3206	
830		0	10-43	西28	6928	400	249.21	62.30%	0	1226	
831		0	10-44	西31	6928	400	52.27	13.07%	0	4637	
832		0	10-44	西32	6928	400	158.44	39.61%	0	2798	
833		0	10-44	西33	6928	400	51.09	12.77%	0	4657	
834		0	10-44	西34	6928	400	40.78	10.20%	0	4836	
835		0	10-44	西35	6928	400	25.66	6.42%	0	5098	
836		0	10-44	西36	6928	400	79.81	19.95%	0	4160	
837		0	10-44	西37	6928	400	188.91	47.23%	0	2271	
838		0	10-44	西38	6928	400	54.49	13.62%	0	4599	
839		0	10-41	微11	6928	400	125.26	31.32%	0	3373	
840		0	10-41	微12	6928	400	118.62	29.66%	0	3488	
841		0	10-41	微13	6928	400	212.78	53.19%	0	1857	
842		0	10-41	微15	6928	400	91.72	22.93%	0	3954	
843		0	10-41	微17	8140	470	3.85	0.82%	0	6446	
844		0	10-42	微21	6928	400	208.69	52.17%	0	1928	
845		0	10-42	微22	6928	400	71.61	17.90%	0	4302	
846		0	10-42	微23	6928	400	108.27	27.07%	0	3667	
847		0	10-42	微26	6928	400	15.54	3.89%	0	5273	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
848	110kV微山路站	0	10-43	微31	6928	400	111.87	27.97%	0	3605	
849		0	10-43	微33	6928	400	101.73	25.43%	0	3780	
850		0	10-43	微35	6928	400	56.98	14.24%	0	4556	
851		0	10-43	微37	8140	470	5.23	1.11%	0	6422	
852		0	10-44	微41	6928	400	242.90	60.72%	0	1335	
853		0	10-44	微42	6928	400	193.00	48.25%	0	2200	
854		0	10-44	微43	6928	400	39.76	9.94%	0	4854	
855		0	10-44	微45	6928	400	66.33	16.58%	0	4394	
856		0	10-44	微46	6928	400	9.54	2.39%	0	5377	
857		0	10-45	微51	6928	400	47.87	11.97%	0	4713	
858		0	10-45	微52	6928	400	49.66	12.41%	0	4682	
859		0	10-45	微53	6928	400	55.34	13.84%	0	4584	
860		0	10-46	微61	6928	400	26.52	6.63%	0	5083	
861		0	10-46	微62	6928	400	46.82	11.71%	0	4731	
862	110kV景蓬道站	0	10-41	景11	6928	400	76.64	19.16%	0	4215	
863		0	10-41	景12	6928	400	79.84	19.96%	0	4160	
864		0	10-41	景13	6928	400	45.16	11.29%	0	4760	
865		0	10-41	景14	6928	400	26.08	6.52%	0	5091	
866		0	10-41	景15	6928	400	71.44	17.86%	0	4305	
867		0	10-43	景36	6928	400	8.24	2.06%	0	5400	
868		0	10-44	景41	6928	400	88.40	22.10%	0	4011	
869		0	10-44	景42	6928	400	26.76	6.69%	0	5079	
870		0	10-44	景43	6928	400	49.36	12.34%	0	4687	
871		0	10-44	景44	6928	400	118.28	29.57%	0	3494	
872		0	10-44	景45	6928	400	1.04	0.26%	0	5524	
873		0	10-44	景46	6928	400	15.16	3.79%	0	5280	
874		0	10-45	景51	6928	400	56.60	14.15%	0	4562	
875		0	10-45	景52	6928	400	180.16	45.04%	0	2422	
876		0	10-45	景53	6928	400	68.80	17.20%	0	4351	
877		0	10-45	景54	6928	400	56.56	14.14%	0	4563	
878		0	10-45	景55	6928	400	62.44	15.61%	0	4461	
879		0	10-45	景56	6928	400	47.36	11.84%	0	4722	
880		0	10-46	景61	8140	470	64.84	13.80%	0	5389	
881		0	10-46	景62	8140	470	28.52	6.07%	0	6018	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
882		0	10-46	景63	8140	470	38.12	8.11%	0	5852	
883		0	10-46	景64	6928	400	36.04	9.01%	0	4918	
884		0	10-46	景65	8140	470	19.00	4.04%	0	6183	
885		0	10-46	景66	8140	470	48.60	10.34%	0	5671	
886	110kV月牙河站	0	10-41	月12	6928	400	58.44	14.61%	0	4530	
887		0	10-41	月13	6928	400	172.35	43.09%	0	2557	
888		0	10-41	月14	6928	400	81.99	20.50%	0	4122	
889		0	10-41	月15	6928	400	255.37	63.84%	0	1119	
890		0	10-41	月16	6928	400	138.79	34.70%	0	3139	
891		0	10-42	月21	6928	400	97.16	24.29%	0	3860	
892		0	10-42	月22	6928	400	142.91	35.73%	0	3067	
893		0	10-42	月23	6928	400	60.23	15.06%	0	4499	
894		0	10-42	月25	6928	400	32.85	8.21%	0	4973	
895		0	10-42	月26	6928	400	178.85	44.71%	0	2445	
896		0	10-43	月31	6928	400	95.00	23.75%	0	3897	
897		0	10-43	月32	6928	400	25.17	6.29%	0	5107	
898		0	10-43	月33	6928	400	283.65	70.91%	0	630	
899		0	10-43	月34	6928	400	41.94	10.49%	0	4816	
900		0	10-43	月35	6928	400	77.83	19.46%	0	4194	
901		0	10-43	月36	6928	400	72.20	18.05%	0	4292	
902		0	10-44	月41	6928	400	38.19	9.55%	0	4881	
903		0	10-44	月43	6928	400	140.53	35.13%	0	3108	
904		0	10-44	月44	6928	400	130.92	32.73%	0	3275	
905		0	10-44	月45	6928	400	141.02	35.26%	0	3100	
906		0	10-44	月53	6928	400	189.24	47.31%	0	2265	
907		0	10-44	月55	6928	400	23.90	5.98%	0	5128	
908		0	10-46	月61	6928	400	104.49	26.12%	0	3733	
909		0	10-41	后11	8140	470	115.75	24.63%	0	4507	
910		0	10-41	后12	8140	470	121.71	25.90%	0	4404	
911		0	10-41	后13	8140	470	155.88	33.17%	0	3813	
912		0	10-41	后14	8140	470	71.26	15.16%	0	5278	
913		0	10-41	后15	6235	360	233.22	64.78%	0	949	
914		0	10-41	后16	6235	360	19.38	5.38%	0	4652	
915		0	10-42	后23	8140	470	89.47	19.04%	0	4963	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
916	110kV后三合站	0	10-42	后24	8140	470	5.43	1.15%	0	6418	
917		0	10-42	后25	8140	470	136.41	29.02%	0	4150	
918		0	10-42	后26	6235	360	237.66	66.02%	0	872	
919		0	10-43	后31	8140	470	108.74	23.14%	0	4629	
920		0	10-43	后32	8140	470	149.55	31.82%	0	3922	
921		0	10-43	后33	6235	360	186.27	51.74%	0	1762	
922		0	10-43	后34	6235	360	115.73	32.15%	0	2984	
923		0	10-43	后35	6235	360	42.23	11.73%	0	4257	
924		0	10-44	后42	8140	470	122.10	25.98%	0	4397	
925		0	10-44	后46	8140	470	117.05	24.90%	0	4485	
926		0	10-46	后65	8140	470	75.04	15.97%	0	5213	
927		0	10-46	后66	8140	470	39.11	8.32%	0	5835	
928	110kV东官房站	0	10-41	房11	8140	470	140.49	29.89%	0	4079	
929		0	10-41	房12	6928	400	129.15	32.29%	0	3306	
930		0	10-41	房13	8140	470	53.14	11.31%	0	5592	
931		0	10-41	房14	8140	470	27.13	5.77%	0	6042	
932		0	10-42	房21	6928	400	145.54	36.38%	0	3022	
933		0	10-42	房22	8140	470	49.54	10.54%	0	5654	
934		0	10-42	房23	8140	470	215.25	45.80%	0	2784	
935		0	10-42	房24	8140	470	64.99	13.83%	0	5387	
936		0	10-43	房31	6928	400	132.66	33.16%	0	3245	
937		0	10-43	房32	6928	400	156.00	39.00%	0	2841	
938		0	10-43	房33	8140	470	61.60	13.11%	0	5445	
939		0	10-44	房41	8140	470	115.35	24.54%	0	4514	
940		0	10-44	房42	8140	470	55.54	11.82%	0	5550	
941		0	10-44	房43	8140	470	59.73	12.71%	0	5478	
942		0	10-44	房44	8140	470	39.83	8.47%	0	5823	
943		0	10-44	房45	8140	470	1.64	0.35%	0	6484	
944		0	10-42	天21	6928	400	53.34	13.34%	0	4619	
945		0	10-42	天22	6928	400	43.42	10.85%	0	4790	
946		0	10-42	天25	6928	400	33.42	8.35%	0	4964	
947		0	10-42	天26	6928	400	58.13	14.53%	0	4536	
948		0	10-43	天31	6928	400	17.02	4.26%	0	5248	
949		0	10-43	天32	6928	400	105.45	26.36%	0	3716	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
950	110kV天嘉湖站	0	10-43	天33	6928	400	14.20	3.55%	0	5296	
951		0	10-43	天34	6928	400	85.84	21.46%	0	4056	
952		0	10-43	天35	6928	400	64.06	16.01%	0	4433	
953		0	10-44	天41	6928	400	56.05	14.01%	0	4572	
954		0	10-44	天42	6928	400	101.46	25.36%	0	3785	
955		0	10-44	天44	6928	400	73.50	18.38%	0	4269	
956		0	10-44	天45	6928	400	38.39	9.60%	0	4878	
957		0	10-44	天46	6928	400	52.97	13.24%	0	4625	
958		0	10-44	天51	6928	400	12.91	3.23%	0	5319	
959		0	10-44	天52	6928	400	91.73	22.93%	0	3954	
960		0	10-44	天53	6928	400	20.33	5.08%	0	5190	
961		0	10-44	天54	6928	400	33.87	8.47%	0	4956	
962		0	10-44	天55	6928	400	28.26	7.06%	0	5053	
963	110kV迎新站	0	10-42	迎21	8140	470	88.43	18.82%	0	4981	
964		0	10-42	迎22	8140	470	228.77	48.67%	0	2550	
965		0	10-42	迎23	8140	470	327.84	69.75%	0	834	
966		0	10-42	迎24	8140	470	75.55	16.08%	0	5204	
967		0	10-42	迎25	8140	470	191.17	40.67%	0	3201	
968		0	10-43	迎31	8140	470	30.07	6.40%	0	5992	
969		0	10-44	迎41	8140	470	186.02	39.58%	0	3290	
970		0	10-44	迎43	8140	470	10.32	2.20%	0	6334	
971		0	10-44	迎45	8140	470	17.87	3.80%	0	6203	
972		0	10-44	迎51	8140	470	146.98	31.27%	0	3967	
973		0	10-44	迎52	8140	470	237.57	50.55%	0	2398	
974		0	10-44	迎53	8140	470	195.21	41.53%	0	3131	
975	110kV官港站	0	10-43	官33	8140	470	178.53	37.99%	0	3420	
976		0	10-43	官34	8140	470	28.48	6.06%	0	6019	
977		0	10-43	官35	8140	470	228.99	48.72%	0	2546	
978		0	10-43	官36	6235	360	127.17	35.32%	0	2786	
979		0	10-44	官42	6235	360	44.51	12.36%	0	4217	
980		0	10-44	官43	6235	360	105.87	29.41%	0	3154	
981		0	10-44	官44	8140	470	145.26	30.91%	0	3996	
982		0	10-44	官45	6235	360	112.78	31.33%	0	3035	
983	110kV丰泽路站	0	10-42	丰21	6235	360	152.87	42.46%	0	2340	

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
984	110kV丰泽路站	0	10-44	丰42	6235	360	260.05	72.23%	0	484	