

城东供电公司10千伏配电线路可开放容量信息表（2025年第三季度）

序号	变电站名称	主变最大负荷日后需预留容量（kVA）	所属母线	线路名称	线路允许容量（kVA）	允许电流（A）	历史最大电流（A）	最高负载率（%）	线路最大负荷日后需预留容量（kVA）	可开放容量（kVA）	备注
1	赤峰桥	0	10kV-41	271	8833.20	510.00	110.8	21.7%	0	5147.76	
2	赤峰桥	0	10kV-41	274	8833.20	510.00	205.8	40.3%	0	3502.68	
3	赤峰桥	0	10kV-41	275	8833.20	510.00	180.1	35.3%	0	3946.77	
4	赤峰桥	0	10kV-41	276	8833.20	510.00	133.3	26.1%	0	4758.06	
5	赤峰桥	0	10kV-42	281	8833.20	510.00	34.5	6.8%	0	6468.49	
6	赤峰桥	0	10kV-42	282	8833.20	510.00	129.6	25.4%	0	4821.54	
7	赤峰桥	0	10kV-42	284	8833.20	510.00	231.0	45.3%	0	3066.43	
8	赤峰桥	0	10kV-43	285	6841.40	395.00	195.8	49.6%	0	2082.56	
9	赤峰桥	0	10kV-43	286	8833.20	510.00	147.7	29.0%	0	4508.23	
10	赤峰桥	0	10kV-44	291	8833.20	510.00	141.1	27.7%	0	4622.71	
11	赤峰桥	0	10kV-44	292	8833.20	510.00	202.0	39.6%	0	3568.37	
12	赤峰桥	0	10kV-44	295	8833.20	510.00	4.0	0.8%	0	6996.76	
13	赤峰桥	0	10kV-44	296	8833.20	510.00	204.2	40.0%	0	3530.61	
14	赤峰桥	0	10kV-44	297	8833.20	510.00	102.4	20.1%	0	5292.48	
15	赤峰桥	0	10kV-44	298	8833.20	510.00	110.6	21.7%	0	5151.33	
16	白庙	0	10kV-41	411	8833.20	510.00	160.2	31.4%	0	4292.60	
17	白庙	0	10kV-41	412	8833.20	510.00	85.3	16.7%	0	5589.11	
18	白庙	0	10kV-41	417	8833.20	510.00	312.0	61.2%	0	1662.72	
19	白庙	0	10kV-41	418	8833.20	510.00	120.3	23.6%	0	4982.34	
20	白庙	0	10kV-42	421	8833.20	510.00	63.5	12.4%	0	5967.30	
21	白庙	0	10kV-44	422	8833.20	510.00	266.4	52.2%	0	2452.86	
22	白庙	0	10kV-42	423	8833.20	510.00	127.4	25.0%	0	4859.16	
23	白庙	0	10kV-44	424	8833.20	510.00	158.8	31.1%	0	4315.84	
24	白庙	0	10kV-42	425	8833.20	510.00	130.4	25.6%	0	4807.22	
25	白庙	0	10kV-44	426	8833.20	510.00	67.4	13.2%	0	5899.79	
26	白庙	0	10kV-42	427	8833.20	510.00	257.4	50.5%	0	2608.30	
27	白庙	0	10kV-44	428	8833.20	510.00	262.3	51.4%	0	2523.69	
28	白庙	0	10kV-43	429	5022.80	290.00	60.6	20.9%	0	2969.45	
29	白庙	0	10kV-43	431	8833.20	510.00	221.8	43.5%	0	3224.19	
30	白庙	0	10kV-44	432	8833.20	510.00	179.7	35.2%	0	3954.10	
31	白庙	0	10kV-43	433	8833.20	510.00	267.4	52.4%	0	2435.33	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
32	白庙	0	10kV-44	434	8833.20	510.00	265.7	52.1%	0	2464.22	
33	白庙	0	10kV-43	435	8833.20	510.00	249.7	49.0%	0	2742.62	
34	小王庄	0	10kV-4	461	6841.40	395.00	202.1	51.2%	0	1973.17	
35	小王庄	0	10kV-5	462	6841.40	395.00	95.7	24.2%	0	3816.28	
36	小王庄	0	10kV-4	463	8833.20	510.00	124.9	24.5%	0	4903.84	
37	小王庄	0	10kV-5	464	6841.40	395.00	0.0	0.0%	0	5473.12	
38	小王庄	0	10kV-4	465	8833.20	510.00	0.0	0.0%	0	7066.56	
39	小王庄	0	10kV-5	466	8833.20	510.00	253.9	49.8%	0	2668.80	
40	小王庄	0	10kV-4	467	6841.40	395.00	16.1	4.1%	0	5194.70	
41	小王庄	0	10kV-5	468	8833.20	510.00	212.6	41.7%	0	3383.65	
42	小王庄	0	10kV-4	469	6841.40	395.00	134.4	34.0%	0	3144.84	
43	小王庄	0	10kV-4	471	6841.40	395.00	236.1	59.8%	0	1384.40	
44	小王庄	0	10kV-5	472	8833.20	510.00	145.4	28.5%	0	4548.94	
45	小王庄	0	10kV-4	473	8833.20	510.00	132.1	25.9%	0	4778.72	
46	小王庄	0	10kV-5	474	6841.40	395.00	288.6	73.1%	0	474.90	
47	韩家墅	0	10kV-4	531	7707.40	445.00	154.6	34.7%	0	3487.92	
48	韩家墅	0	10kV-5	532	6841.40	395.00	251.0	63.5%	0	1126.22	
49	韩家墅	0	10kV-4	533	7707.40	445.00	73.9	16.6%	0	4886.10	
50	韩家墅	0	10kV-5	534	6841.40	395.00	216.7	54.9%	0	1720.05	
51	韩家墅	0	10kV-4	535	7707.40	445.00	159.8	35.9%	0	3397.93	
52	韩家墅	0	10kV-5	536	7707.40	445.00	127.1	28.6%	0	3964.87	
53	韩家墅	0	10kV-5	538	7707.40	445.00	318.3	71.5%	0	653.22	
54	韩家墅	0	10kV-4	539	7707.40	445.00	285.0	64.0%	0	1229.40	
55	韩家墅	0	10kV-5	540	6841.40	395.00	196.9	49.8%	0	2063.50	
56	韩家墅	0	10kV-4	541	8833.20	510.00	254.6	49.9%	0	2657.14	
57	韩家墅	0	10kV-5	542	6841.40	395.00	234.3	59.3%	0	1415.36	
58	韩家墅	0	10kV-4	543	7707.40	445.00	28.5	6.4%	0	5671.83	
59	韩家墅	0	10kV-5	544	8833.20	510.00	312.5	61.3%	0	1653.65	
60	大张庄	0	10kV-4	581	7707.40	445.00	155.8	35.0%	0	3467.05	
61	大张庄	0	10kV-5	582	7707.40	445.00	273.9	61.6%	0	1422.00	
62	大张庄	0	10kV-4	583	7707.40	445.00	100.1	22.5%	0	4432.32	
63	大张庄	0	10kV-5	584	7707.40	445.00	342.5	77.0%	0	233.82	
64	大张庄	0	10kV-4	585	7707.40	445.00	198.1	44.5%	0	2734.98	
65	大张庄	0	10kV-5	586	7707.40	445.00	146.8	33.0%	0	3623.14	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
66	大张庄	0	10kV-4	587	7707.40	445.00	91.0	20.5%	0	4589.33	
67	大张庄	0	10kV-5	588	7707.40	445.00	239.2	53.7%	0	2023.37	
68	大张庄	0	10kV-5	590	7707.40	445.00	113.1	25.4%	0	4207.88	
69	万新村	0	10kV-4	601	6841.40	395.00	214.3	54.2%	0	1761.67	
70	万新村	0	10kV-4	602	6841.40	395.00	93.4	23.7%	0	3854.61	
71	万新村	0	10kV-4	603	6841.40	395.00	258.0	65.3%	0	1005.33	
72	万新村	0	10kV-4	604	6841.40	395.00	164.0	41.5%	0	2633.48	
73	万新村	0	10kV-4	605	8833.20	510.00	169.3	33.2%	0	4133.72	
74	万新村	0	10kV-4	606	6841.40	395.00	187.3	47.4%	0	2228.54	
75	万新村	0	10kV-5	611	8833.20	510.00	186.6	36.6%	0	3834.04	
76	万新村	0	10kV-5	612	8833.20	510.00	163.0	32.0%	0	4243.77	
77	万新村	0	10kV-5	613	6841.40	395.00	175.8	44.5%	0	2428.09	
78	万新村	0	10kV-5	614	6841.40	395.00	195.4	49.5%	0	2088.96	
79	万新村	0	10kV-5	615	8833.20	510.00	193.3	37.9%	0	3718.09	
80	万新村	0	10kV-5	616	8833.20	510.00	188.3	36.9%	0	3805.59	
81	何兴庄	0	10kV-41	651	8833.20	510.00	208.2	40.8%	0	3459.67	
82	何兴庄	0	10kV-41	652	8833.20	510.00	157.6	30.9%	0	4336.13	
83	何兴庄	0	10kV-41	653	8833.20	510.00	98.3	19.3%	0	5364.71	
84	何兴庄	0	10kV-41	654	8833.20	510.00	26.7	5.2%	0	6604.95	
85	何兴庄	0	10kV-41	655	8833.20	510.00	280.9	55.1%	0	2201.51	
86	何兴庄	0	10kV-41	656	8833.20	510.00	259.7	50.9%	0	2568.09	
87	何兴庄	0	10kV-41	657	8833.20	510.00	79.0	15.5%	0	5698.38	
88	何兴庄	0	10kV-44	661	8833.20	510.00	175.2	34.4%	0	4032.27	
89	何兴庄	0	10kV-44	662	8833.20	510.00	0.0	0.0%	0	7066.56	
90	何兴庄	0	10kV-44	663	8833.20	510.00	63.4	12.4%	0	5968.66	
91	何兴庄	0	10kV-44	665	8833.20	510.00	159.7	31.3%	0	4300.17	
92	何兴庄	0	10kV-44	666	8833.20	510.00	253.1	49.6%	0	2682.92	
93	何兴庄	0	10kV-44	667	8833.20	510.00	197.5	38.7%	0	3645.73	
94	何兴庄	0	10kV-44	668	8833.20	510.00	218.3	42.8%	0	3285.80	
95	何兴庄	0	10kV-42	672	8833.20	510.00	124.0	24.3%	0	4919.33	
96	何兴庄	0	10kV-42	673	8833.20	510.00	0.0	0.0%	0	7066.56	
97	何兴庄	0	10kV-42	674	8833.20	510.00	198.8	39.0%	0	3622.55	
98	何兴庄	0	10kV-43	675	8833.20	510.00	204.4	40.1%	0	3526.56	
99	何兴庄	0	10kV-43	677	8833.20	510.00	103.6	20.3%	0	5272.88	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
100	何兴庄	0	10kV-43	678	8833.20	510.00	252.3	49.5%	0	2696.54	
101	青光	0	10kV-5	70	8833.20	510.00	281.6	55.2%	0	2188.43	
102	青光	0	10kV-4	71	7707.40	445.00	342.6	77.0%	0	232.09	
103	青光	0	10kV-5	72	7707.40	445.00	335.8	75.5%	0	349.86	
104	程林庄	0	10kV-4	731	8833.20	510.00	220.1	43.2%	0	3254.79	
105	程林庄	0	10kV-5	732	8833.20	510.00	79.1	15.5%	0	5696.01	
106	程林庄	0	10kV-5	734	8833.20	510.00	168.8	33.1%	0	4143.77	
107	程林庄	0	10kV-4	735	8833.20	510.00	123.6	24.2%	0	4926.43	
108	程林庄	0	10kV-5	736	7707.40	445.00	136.9	30.8%	0	3794.34	
109	程林庄	0	10kV-4	737	5022.80	290.00	180.3	62.2%	0	895.87	
110	程林庄	0	10kV-5	738	8833.20	510.00	237.0	46.5%	0	2960.86	
111	程林庄	0	10kV-4	739	8833.20	510.00	223.8	43.9%	0	3190.36	
112	青光	0	10kV-4	73	8833.20	510.00	129.7	25.4%	0	4820.38	
113	程林庄	0	10kV-5	740	8833.20	510.00	248.1	48.6%	0	2769.81	
114	青光	0	10kV-5	74	7707.40	445.00	202.5	45.5%	0	2658.55	
115	青光	0	10kV-4	75	6841.40	395.00	309.8	78.4%	0	107.85	
116	青光	0	10kV-5	76	7707.40	445.00	131.1	29.5%	0	3895.63	
117	青光	0	10kV-4	77	7707.40	445.00	348.8	78.4%	0	125.49	
118	青光	0	10kV-5	78	8833.20	510.00	207.9	40.8%	0	3465.99	
119	青光	0	10kV-4	79	7707.40	445.00	0.0	0.0%	0	6165.92	
120	真理道	0	10kV-4	801	8833.20	510.00	342.4	67.1%	0	1136.82	
121	真理道	0	10kV-5	802	8833.20	510.00	305.9	60.0%	0	1768.40	
122	真理道	0	10kV-4	803	8833.20	510.00	362.6	71.1%	0	786.16	
123	真理道	0	10kV-5	804	6841.40	395.00	315.3	79.8%	0	12.99	
124	真理道	0	10kV-4	805	8833.20	510.00	248.0	48.6%	0	2770.90	
125	真理道	0	10kV-5	806	8833.20	510.00	221.6	43.5%	0	3228.03	
126	真理道	0	10kV-4	807	8833.20	510.00	208.7	40.9%	0	3452.58	
127	真理道	0	10kV-5	808	8833.20	510.00	142.0	27.8%	0	4607.23	
128	真理道	0	10kV-4	809	8833.20	510.00	142.3	27.9%	0	4601.77	
129	真理道	0	10kV-41	811	8833.20	510.00	15.4	3.0%	0	6799.34	
130	真理道	0	10kV-41	812	8833.20	510.00	12.3	2.4%	0	6854.03	
131	真理道	0	10kV-41	813	8833.20	510.00	5.5	1.1%	0	6970.63	
132	刘安庄	0	10kV-42	安21	7707.40	445.00	199.6	44.8%	0	2709.33	
133	刘安庄	0	10kV-42	安22	7707.40	445.00	131.0	29.4%	0	3897.66	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
134	刘安庄	0	10kV-43	安24	7707.40	445.00	315.4	70.9%	0	702.83	
135	刘安庄	0	10kV-43	安25	7707.40	445.00	308.1	69.2%	0	830.12	
136	刘安庄	0	10kV-43	安26	7707.40	445.00	148.8	33.4%	0	3588.67	
137	刘安庄	0	10kV-43	安27	7707.40	445.00	101.8	22.9%	0	4402.41	
138	刘安庄	0	10kV-44	安31	7707.40	445.00	233.8	52.5%	0	2116.72	
139	刘安庄	0	10kV-44	安32	7707.40	445.00	246.8	55.5%	0	1891.37	
140	刘安庄	0	10kV-44	安33	7707.40	445.00	254.2	57.1%	0	1763.61	
141	刘安庄	0	10kV-44	安34	7707.40	445.00	198.3	44.6%	0	2731.44	
142	刘安庄	0	10kV-44	安35	7707.40	445.00	251.9	56.6%	0	1802.48	
143	刘安庄	0	10kV-44	安36	7707.40	445.00	14.0	3.2%	0	5923.06	
144	泰昌路	0	10kV-42	昌32	8833.20	510.00	22.7	4.5%	0	6672.91	
145	泰昌路	0	10kV-41	昌33	8833.20	510.00	2.9	0.6%	0	7016.59	
146	泰昌路	0	10kV-41	昌34	8833.20	510.00	0.3	0.0%	0	7062.22	
147	泰昌路	0	10kV-41	昌36	8833.20	510.00	0.1	0.0%	0	7064.20	
148	泰昌路	0	10kV-41	昌41	8833.20	510.00	0.1	0.0%	0	7065.09	
149	泰昌路	0	10kV-41	昌42	8833.20	510.00	0.1	0.0%	0	7065.64	
150	泰昌路	0	10kV-43	昌43	8833.20	510.00	192.7	37.8%	0	3728.96	
151	泰昌路	0	10kV-43	昌44	8833.20	510.00	208.5	40.9%	0	3454.79	
152	泰昌路	0	10kV-43	昌45	8833.20	510.00	297.0	58.2%	0	1922.81	
153	泰昌路	0	10kV-41	昌46	8833.20	510.00	213.5	41.9%	0	3368.66	
154	泰昌路	0	10kV-44	昌52	8833.20	510.00	263.9	51.7%	0	2496.28	
155	泰昌路	0	10kV-41	昌53	8833.20	510.00	242.7	47.6%	0	2863.23	
156	泰昌路	0	10kV-41	昌54	8833.20	510.00	100.9	19.8%	0	5318.46	
157	泰昌路	0	10kV-44	昌55	8833.20	510.00	61.4	12.0%	0	6003.26	
158	泰昌路	0	10kV-41	昌56	8833.20	510.00	50.8	10.0%	0	6186.81	
159	泰昌路	0	10kV-41	昌61	8833.20	510.00	15.8	3.1%	0	6793.27	
160	泰昌路	0	10kV-41	昌62	8833.20	510.00	11.4	2.2%	0	6869.67	
161	泰昌路	0	10kV-41	昌63	8833.20	510.00	1.8	0.4%	0	7035.01	
162	泰昌路	0	10kV-44	昌64	8833.20	510.00	204.8	40.2%	0	3519.51	
163	泰昌路	0	10kV-44	昌65	8833.20	510.00	287.7	56.4%	0	2083.58	
164	泰昌路	0	10kV-41	昌66	8833.20	510.00	127.3	25.0%	0	4862.05	
165	朝阳路	0	10kV-41	朝11	8833.20	510.00	187.4	36.7%	0	3820.63	
166	朝阳路	0	10kV-41	朝12	8833.20	510.00	126.9	24.9%	0	4868.50	
167	朝阳路	0	10kV-44	朝13	7707.40	445.00	80.4	18.1%	0	4773.69	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
168	朝阳路	0	10kV-41	朝14	8833.20	510.00	44.6	8.8%	0	6293.58	
169	朝阳路	0	10kV-41	朝15	8833.20	510.00	119.0	23.3%	0	5005.25	
170	朝阳路	0	10kV-41	朝16	8833.20	510.00	109.4	21.4%	0	5172.59	
171	朝阳路	0	10kV-42	朝21	8833.20	510.00	113.4	22.2%	0	5102.14	
172	朝阳路	0	10kV-42	朝22	8833.20	510.00	183.5	36.0%	0	3887.58	
173	朝阳路	0	10kV-42	朝23	7707.40	445.00	126.6	28.5%	0	3973.13	
174	朝阳路	0	10kV-42	朝24	8833.20	510.00	108.0	21.2%	0	5195.26	
175	朝阳路	0	10kV-42	朝25	8833.20	510.00	99.3	19.5%	0	5345.86	
176	朝阳路	0	10kV-43	朝31	7707.40	445.00	45.6	10.2%	0	5376.08	
177	朝阳路	0	10kV-43	朝32	7707.40	445.00	73.4	16.5%	0	4894.88	
178	朝阳路	0	10kV-43	朝33	7707.40	445.00	69.2	15.6%	0	4967.04	
179	朝阳路	0	10kV-43	朝34	8833.20	510.00	165.6	32.5%	0	4198.69	
180	朝阳路	0	10kV-43	朝35	8833.20	510.00	147.3	28.9%	0	4514.66	
181	朝阳路	0	10kV-43	朝36	8833.20	510.00	118.5	23.2%	0	5013.32	
182	朝阳路	0	10kV-44	朝41	7707.40	445.00	163.2	36.7%	0	3340.05	
183	朝阳路	0	10kV-44	朝42	8833.20	510.00	329.0	64.5%	0	1368.33	
184	朝阳路	0	10kV-44	朝43	7707.40	445.00	275.0	61.8%	0	1402.44	
185	朝阳路	0	10kV-44	朝44	8833.20	510.00	366.9	71.9%	0	712.50	
186	朝阳路	0	10kV-44	朝45	8833.20	510.00	150.3	29.5%	0	4462.58	
187	朝阳路	0	10kV-44	朝46	8833.20	510.00	102.3	20.1%	0	5294.07	
188	朝阳路	0	10kV-41	朝51	8833.20	510.00	87.5	17.2%	0	5551.19	
189	朝阳路	0	10kV-41	朝52	8833.20	510.00	2.8	0.5%	0	7018.65	
190	朝阳路	0	10kV-41	朝53	8833.20	510.00	1.2	0.2%	0	7045.93	
191	朝阳路	0	10kV-41	朝54	8833.20	510.00	1.0	0.2%	0	7049.32	
192	大直沽	0	10kV-41	大11	8833.20	510.00	153.6	30.1%	0	4405.80	
193	大直沽	0	10kV-41	大12	8833.20	510.00	100.7	19.7%	0	5322.12	
194	大直沽	0	10kV-41	大13	8833.20	510.00	226.7	44.5%	0	3139.88	
195	大直沽	0	10kV-41	大14	8833.20	510.00	223.4	43.8%	0	3197.87	
196	大直沽	0	10kV-41	大15	8833.20	510.00	171.8	33.7%	0	4091.59	
197	大直沽	0	10kV-41	大16	8833.20	510.00	140.7	27.6%	0	4628.89	
198	大直沽	0	10kV-41	大17	6841.40	395.00	19.2	4.9%	0	5141.16	
199	大直沽	0	10kV-41	大18	8833.20	510.00	60.8	11.9%	0	6013.40	
200	大直沽	0	10kV-42	大21	8833.20	510.00	8.0	1.6%	0	6928.08	
201	大直沽	0	10kV-42	大22	7707.40	445.00	58.9	13.2%	0	5146.36	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
202	大直沽	0	10kV-42	大23	8833.20	510.00	181.8	35.7%	0	3916.95	
203	大直沽	0	10kV-43	大25	5022.80	290.00	185.5	64.0%	0	805.31	
204	大直沽	0	10kV-43	大26	6495.00	375.00	231.0	61.6%	0	1195.25	
205	大直沽	0	10kV-43	大27	8833.20	510.00	214.4	42.0%	0	3352.30	
206	大直沽	0	10kV-44	大31	8833.20	510.00	123.6	24.2%	0	4926.52	
207	大直沽	0	10kV-44	大32	8833.20	510.00	178.9	35.1%	0	3967.99	
208	大直沽	0	10kV-44	大33	8833.20	510.00	224.2	44.0%	0	3183.84	
209	大直沽	0	10kV-44	大34	8833.20	510.00	309.1	60.6%	0	1712.22	
210	大直沽	0	10kV-44	大35	8833.20	510.00	44.0	8.6%	0	6305.12	
211	大直沽	0	10kV-44	大36	8833.20	510.00	81.3	15.9%	0	5657.88	
212	大直沽	0	10kV-44	大37	8833.20	510.00	57.1	11.2%	0	6077.96	
213	大直沽	0	10kV-44	大38	8833.20	510.00	53.1	10.4%	0	6146.86	
214	千里堤	0	10kV-41	堤11	8833.20	510.00	23.7	4.7%	0	6655.44	
215	千里堤	0	10kV-41	堤12	8833.20	510.00	8.0	1.6%	0	6927.14	
216	千里堤	0	10kV-41	堤13	8833.20	510.00	5.0	1.0%	0	6980.36	
217	千里堤	0	10kV-41	堤14	8833.20	510.00	1.6	0.3%	0	7039.56	
218	千里堤	0	10kV-41	堤21	8833.20	510.00	0.3	0.1%	0	7061.29	
219	千里堤	0	10kV-41	堤22	8833.20	510.00	0.1	0.0%	0	7065.12	
220	千里堤	0	10kV-41	堤31	8833.20	510.00	0.1	0.0%	0	7065.31	
221	千里堤	0	10kV-41	堤32	8833.20	510.00	0.1	0.0%	0	7065.51	
222	千里堤	0	10kV-41	堤33	8833.20	510.00	0.0	0.0%	0	7066.12	
223	千里堤	0	10kV-41	堤41	8833.20	510.00	0.0	0.0%	0	7066.53	
224	千里堤	0	10kV-41	堤42	8833.20	510.00	0.0	0.0%	0	7066.56	
225	东堤	0	10kV-41	东11(东)	8833.20	510.00	0.0	0.0%	0	7066.56	
226	东堤	0	10kV-41	东12	7707.40	445.00	135.0	30.3%	0	3828.42	
227	东堤	0	10kV-41	东13(东)	8833.20	510.00	109.2	21.4%	0	5175.74	
228	东堤	0	10kV-41	东14	7707.40	445.00	80.9	18.2%	0	4765.19	
229	东堤	0	10kV-41	东17	7707.40	445.00	187.3	42.1%	0	2921.60	
230	东堤	0	10kV-43	东21	7707.40	445.00	116.6	26.2%	0	4145.64	
231	东堤	0	10kV-43	东22	7707.40	445.00	0.0	0.0%	0	6165.92	
232	东堤	0	10kV-43	东23	7707.40	445.00	140.8	31.6%	0	3726.93	
233	东堤	0	10kV-43	东24	7707.40	445.00	198.0	44.5%	0	2736.26	
234	东堤	0	10kV-43	东25	7707.40	445.00	0.0	0.0%	0	6165.92	
235	东堤	0	10kV-43	东26	7707.40	445.00	201.8	45.4%	0	2670.01	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
236	东堤	0	10kV-43	东27	7707.40	445.00	179.7	40.4%	0	3054.10	
237	万发	0	10kV-42	发31	7707.40	445.00	115.6	26.0%	0	4164.37	
238	万发	0	10kV-42	发32	7707.40	445.00	163.9	36.8%	0	3327.73	
239	万发	0	10kV-42	发33	8833.20	510.00	264.8	51.9%	0	2480.64	
240	万发	0	10kV-42	发34	8833.20	510.00	269.3	52.8%	0	2401.91	
241	万发	0	10kV-42	发35	8833.20	510.00	123.4	24.2%	0	4928.82	
242	万发	0	10kV-41	发36	8833.20	510.00	114.8	22.5%	0	5078.80	
243	万发	0	10kV-43	发41	8833.20	510.00	147.8	29.0%	0	4507.26	
244	万发	0	10kV-43	发42	8833.20	510.00	178.8	35.1%	0	3969.95	
245	万发	0	10kV-43	发43	8833.20	510.00	211.9	41.6%	0	3396.05	
246	万发	0	10kV-43	发44	8833.20	510.00	221.4	43.4%	0	3231.89	
247	万发	0	10kV-43	发45	7707.40	445.00	82.8	18.6%	0	4731.36	
248	万发	0	10kV-44	发51	8833.20	510.00	117.2	23.0%	0	5036.05	
249	万发	0	10kV-44	发52	8833.20	510.00	106.8	20.9%	0	5217.49	
250	万发	0	10kV-44	发53	8833.20	510.00	126.4	24.8%	0	4877.27	
251	万发	0	10kV-44	发54	8833.20	510.00	155.6	30.5%	0	4371.01	
252	万发	0	10kV-44	发55	8833.20	510.00	195.6	38.4%	0	3678.01	
253	万发	0	10kV-41	发56	8833.20	510.00	68.9	13.5%	0	5873.05	
254	万发	0	10kV-44	发61	8833.20	510.00	120.4	23.6%	0	4981.52	
255	万发	0	10kV-44	发62	8833.20	510.00	126.9	24.9%	0	4868.91	
256	群芳路	0	10kV-41	芳11	7707.40	445.00	215.3	48.4%	0	2437.15	
257	群芳路	0	10kV-41	芳12	8833.20	510.00	255.2	50.0%	0	2647.07	
258	群芳路	0	10kV-41	芳13	8833.20	510.00	196.5	38.5%	0	3663.69	
259	群芳路	0	10kV-41	芳14	8833.20	510.00	153.5	30.1%	0	4407.75	
260	群芳路	0	10kV-41	芳15	8833.20	510.00	117.7	23.1%	0	5027.32	
261	群芳路	0	10kV-41	芳16	8833.20	510.00	272.6	53.4%	0	2345.36	
262	群芳路	0	10kV-41	芳21	8833.20	510.00	0.1	0.0%	0	7065.29	
263	群芳路	0	10kV-42	芳31	8833.20	510.00	138.1	27.1%	0	4675.41	
264	群芳路	0	10kV-42	芳32	7707.40	445.00	267.1	60.0%	0	1539.01	
265	群芳路	0	10kV-42	芳33	8833.20	510.00	319.5	62.7%	0	1531.97	
266	群芳路	0	10kV-42	芳34	8833.20	510.00	238.4	46.7%	0	2937.43	
267	群芳路	0	10kV-42	芳35	8833.20	510.00	234.0	45.9%	0	3013.84	
268	群芳路	0	10kV-42	芳36	7707.40	445.00	214.3	48.2%	0	2454.61	
269	群芳路	0	10kV-43	芳41	8833.20	510.00	19.9	3.9%	0	6722.17	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
270	风电园	0	10kV-41	风11	8833.20	510.00	2.8	0.6%	0	7017.71	
271	风电园	0	10kV-41	风12	7707.40	445.00	309.1	69.5%	0	812.22	
272	风电园	0	10kV-41	风13	8833.20	510.00	255.6	50.1%	0	2639.28	
273	风电园	0	10kV-41	风14	8833.20	510.00	255.0	50.0%	0	2650.13	
274	风电园	0	10kV-41	风15	8833.20	510.00	315.3	61.8%	0	1604.78	
275	风电园	0	10kV-41	风16	8833.20	510.00	195.6	38.3%	0	3679.35	
276	风电园	0	10kV-42	风21	8833.20	510.00	95.7	18.8%	0	5409.28	
277	风电园	0	10kV-42	风22	7707.40	445.00	51.4	11.5%	0	5276.46	
278	风电园	0	10kV-42	风23	8833.20	510.00	181.7	35.6%	0	3918.94	
279	风电园	0	10kV-42	风24	8833.20	510.00	183.6	36.0%	0	3887.20	
280	风电园	0	10kV-42	风25	8833.20	510.00	10.4	2.0%	0	6886.16	
281	风电园	0	10kV-42	风26	8833.20	510.00	95.6	18.7%	0	5410.85	
282	风电园	0	10kV-43	风31	7707.40	445.00	324.3	72.9%	0	548.68	
283	风电园	0	10kV-43	风32	7707.40	445.00	70.5	15.8%	0	4945.12	
284	风电园	0	10kV-43	风33	8833.20	510.00	159.7	31.3%	0	4300.39	
285	风电园	0	10kV-43	风34	8833.20	510.00	64.0	12.6%	0	5957.26	
286	风电园	0	10kV-41	风35	8833.20	510.00	53.3	10.5%	0	6143.14	
287	风电园	0	10kV-44	风41	8833.20	510.00	251.2	49.3%	0	2715.38	
288	风电园	0	10kV-44	风43	8833.20	510.00	111.4	21.8%	0	5137.93	
289	风电园	0	10kV-44	风44	8833.20	510.00	165.5	32.4%	0	4200.75	
290	风电园	0	10kV-43	风45	8833.20	510.00	36.9	7.2%	0	6427.71	
291	风电园	0	10kV-44	风46	8833.20	510.00	203.8	40.0%	0	3536.91	
292	风电园	0	10kV-41	风53	8833.20	510.00	71.4	14.0%	0	5829.84	
293	金阜桥	0	10kV-41	阜11	8833.20	510.00	230.2	45.1%	0	3079.20	
294	金阜桥	0	10kV-41	阜12	8833.20	510.00	85.8	16.8%	0	5581.37	
295	金阜桥	0	10kV-41	阜13	8833.20	510.00	0.5	0.1%	0	7058.14	
296	金阜桥	0	10kV-41	阜15	8833.20	510.00	0.5	0.1%	0	7058.33	
297	金阜桥	0	10kV-41	阜16	8833.20	510.00	0.2	0.0%	0	7062.47	
298	金阜桥	0	10kV-41	阜21	8833.20	510.00	0.0	0.0%	0	7066.38	
299	金阜桥	0	10kV-42	阜31	8833.20	510.00	222.7	43.7%	0	3209.91	
300	金阜桥	0	10kV-41	阜32	8833.20	510.00	53.9	10.6%	0	6133.79	
301	金阜桥	0	10kV-41	阜33	8833.20	510.00	52.8	10.3%	0	6152.57	
302	金阜桥	0	10kV-41	阜36	8833.20	510.00	45.0	8.8%	0	6287.26	
303	金阜桥	0	10kV-41	阜41	8833.20	510.00	32.6	6.4%	0	6501.46	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
304	青年宫	0	10kV-44	宫33	8833.20	510.00	11.1	2.2%	0	6874.89	
305	古北道	0	10kV-4	古11	8833.20	510.00	31.8	6.2%	0	6515.80	
306	古北道	0	10kV-5	古12	8833.20	510.00	39.4	7.7%	0	6384.98	
307	古北道	0	10kV-5	古14	8833.20	510.00	45.1	8.8%	0	6284.99	
308	古北道	0	10kV-4	古17	8833.20	510.00	334.9	65.7%	0	1265.82	
309	古北道	0	10kV-5	古18	8833.20	510.00	16.1	3.1%	0	6788.43	
310	小北河	0	10kV-41	河11	8833.20	510.00	366.9	71.9%	0	711.55	
311	小北河	0	10kV-41	河12	7707.40	445.00	184.8	41.5%	0	2964.66	
312	小北河	0	10kV-41	河13	7707.40	445.00	205.4	46.2%	0	2608.86	
313	小北河	0	10kV-41	河14	7707.40	445.00	293.7	66.0%	0	1078.80	
314	小北河	0	10kV-42	河21	8833.20	510.00	357.3	70.1%	0	878.32	
315	小北河	0	10kV-42	河22	8833.20	510.00	247.4	48.5%	0	2782.09	
316	小北河	0	10kV-42	河23	7707.40	445.00	246.5	55.4%	0	1896.54	
317	小北河	0	10kV-42	河24	7707.40	445.00	184.6	41.5%	0	2968.00	
318	小北河	0	10kV-43	河25	7707.40	445.00	334.6	75.2%	0	370.72	
319	小北河	0	10kV-43	河26	7707.40	445.00	150.1	33.7%	0	3566.46	
320	小北河	0	10kV-44	河31	7707.40	445.00	271.9	61.1%	0	1457.28	
321	小北河	0	10kV-44	河32	8833.20	510.00	208.7	40.9%	0	3452.55	
322	小北河	0	10kV-44	河33	7707.40	445.00	250.6	56.3%	0	1826.11	
323	小北河	0	10kV-44	河34	7707.40	445.00	216.6	48.7%	0	2414.48	
324	虎丘路	0	10kV-41	虎11	8833.20	510.00	241.8	47.4%	0	2879.15	
325	虎丘路	0	10kV-41	虎12	8833.20	510.00	161.4	31.6%	0	4270.94	
326	虎丘路	0	10kV-41	虎13	8833.20	510.00	48.4	9.5%	0	6227.60	
327	虎丘路	0	10kV-41	虎14	8833.20	510.00	143.6	28.2%	0	4579.05	
328	虎丘路	0	10kV-41	虎15	7707.40	445.00	123.4	27.7%	0	4029.39	
329	虎丘路	0	10kV-41	虎16	8833.20	510.00	92.0	18.0%	0	5473.25	
330	虎丘路	0	10kV-41	虎17	8833.20	510.00	237.2	46.5%	0	2958.11	
331	虎丘路	0	10kV-41	虎18	5022.80	290.00	208.5	71.9%	0	407.76	
332	虎丘路	0	10kV-42	虎21	8833.20	510.00	230.2	45.1%	0	3078.87	
333	虎丘路	0	10kV-42	虎22	8833.20	510.00	280.2	54.9%	0	2214.04	
334	虎丘路	0	10kV-42	虎23	8833.20	510.00	213.3	41.8%	0	3372.23	
335	虎丘路	0	10kV-42	虎24	6495.00	375.00	132.7	35.4%	0	2896.96	
336	虎丘路	0	10kV-43	虎25	8833.20	510.00	219.9	43.1%	0	3258.52	
337	虎丘路	0	10kV-43	虎26	8833.20	510.00	171.4	33.6%	0	4097.51	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
338	虎丘路	0	10kV-43	虎27	8833.20	510.00	197.1	38.6%	0	3652.77	
339	虎丘路	0	10kV-43	虎28	8833.20	510.00	88.7	17.4%	0	5531.02	
340	虎丘路	0	10kV-44	虎31	8833.20	510.00	301.5	59.1%	0	1844.36	
341	虎丘路	0	10kV-44	虎32	8833.20	510.00	257.4	50.5%	0	2607.69	
342	虎丘路	0	10kV-44	虎33	8833.20	510.00	185.7	36.4%	0	3849.45	
343	虎丘路	0	10kV-44	虎35	8833.20	510.00	229.5	45.0%	0	3090.96	
344	虎丘路	0	10kV-44	虎36	8833.20	510.00	72.9	14.3%	0	5803.65	
345	虎丘路	0	10kV-44	虎37	8833.20	510.00	119.4	23.4%	0	4997.88	
346	虎丘路	0	10kV-44	虎38	6841.40	395.00	155.4	39.3%	0	2781.82	
347	淮南路	0	10kV-41	淮11	8833.20	510.00	220.8	43.3%	0	3242.41	
348	淮南路	0	10kV-41	淮12	8833.20	510.00	81.5	16.0%	0	5654.46	
349	淮南路	0	10kV-41	淮13	8833.20	510.00	198.3	38.9%	0	3632.08	
350	淮南路	0	10kV-41	淮14	8833.20	510.00	87.7	17.2%	0	5547.05	
351	淮南路	0	10kV-41	淮15	8833.20	510.00	235.9	46.3%	0	2980.77	
352	淮南路	0	10kV-41	淮16	8833.20	510.00	148.1	29.0%	0	4501.21	
353	淮南路	0	10kV-41	淮17	8833.20	510.00	121.9	23.9%	0	4955.37	
354	淮南路	0	10kV-42	淮21	8833.20	510.00	116.5	22.8%	0	5049.22	
355	淮南路	0	10kV-42	淮22	8833.20	510.00	0.0	0.0%	0	7066.56	
356	淮南路	0	10kV-41	淮23	8833.20	510.00	0.0	0.0%	0	7066.56	
357	淮南路	0	10kV-42	淮24	8833.20	510.00	157.3	30.9%	0	4341.42	
358	淮南路	0	10kV-43	淮25	8833.20	510.00	119.3	23.4%	0	4999.57	
359	淮南路	0	10kV-43	淮26	8833.20	510.00	125.8	24.7%	0	4886.90	
360	淮南路	0	10kV-43	淮27	8833.20	510.00	105.1	20.6%	0	5246.78	
361	淮南路	0	10kV-43	淮28	8833.20	510.00	157.8	30.9%	0	4334.28	
362	淮南路	0	10kV-44	淮31	8833.20	510.00	156.5	30.7%	0	4355.90	
363	淮南路	0	10kV-44	淮32	8833.20	510.00	132.2	25.9%	0	4776.13	
364	淮南路	0	10kV-44	淮33	8833.20	510.00	178.9	35.1%	0	3967.88	
365	淮南路	0	10kV-44	淮34	7707.40	445.00	57.8	13.0%	0	5164.65	
366	淮南路	0	10kV-44	淮35	8833.20	510.00	156.1	30.6%	0	4362.49	
367	淮南路	0	10kV-44	淮36	8833.20	510.00	81.7	16.0%	0	5651.48	
368	淮南路	0	10kV-44	淮37	7707.40	445.00	273.4	61.4%	0	1431.18	
369	淮南路	0	10kV-44	淮38	8833.20	510.00	52.9	10.4%	0	6150.03	
370	环东	0	10kV-41	环11	8833.20	510.00	216.7	42.5%	0	3313.85	
371	环东	0	10kV-41	环12	8833.20	510.00	229.2	44.9%	0	3096.48	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
372	环东	0	10kV-41	环13(东)	8833.20	510.00	120.9	23.7%	0	4972.82	
373	环东	0	10kV-42	环21	8833.20	510.00	0.9	0.2%	0	7050.64	
374	环东	0	10kV-42	环22	8833.20	510.00	212.7	41.7%	0	3382.62	
375	环东	0	10kV-42	环23	8833.20	510.00	74.4	14.6%	0	5778.65	
376	环东	0	10kV-41	环24(东)	8833.20	510.00	47.5	9.3%	0	6244.62	
377	环东	0	10kV-41	环25(东)	8833.20	510.00	3.1	0.6%	0	7012.28	
378	环东	0	10kV-41	环26(东)	8833.20	510.00	2.1	0.4%	0	7030.81	
379	环东	0	10kV-41	环27(东)	8833.20	510.00	1.4	0.3%	0	7042.87	
380	环东	0	10kV-41	环28(东)	8833.20	510.00	0.4	0.1%	0	7059.01	
381	环东	0	10kV-41	环35(东)	8833.20	510.00	0.1	0.0%	0	7064.43	
382	环东	0	10kV-44	环36	7707.40	445.00	278.9	62.7%	0	1335.65	
383	环东	0	10kV-44	环37	7707.40	445.00	239.8	53.9%	0	2012.41	
384	嘉海	0	10kV-41	嘉11	8833.20	510.00	112.4	22.0%	0	5119.87	
385	嘉海	0	10kV-41	嘉12	8833.20	510.00	141.3	27.7%	0	4619.06	
386	嘉海	0	10kV-41	嘉13	8833.20	510.00	127.0	24.9%	0	4866.48	
387	嘉海	0	10kV-41	嘉14	8833.20	510.00	139.3	27.3%	0	4654.00	
388	嘉海	0	10kV-41	嘉15	8833.20	510.00	93.0	18.2%	0	5454.99	
389	嘉海	0	10kV-41	嘉16	8833.20	510.00	78.4	15.4%	0	5708.64	
390	嘉海	0	10kV-41	嘉17	8833.20	510.00	136.3	26.7%	0	4706.53	
391	嘉海	0	10kV-41	嘉18	8833.20	510.00	175.5	34.4%	0	4026.95	
392	嘉海	0	10kV-42	嘉21	8833.20	510.00	50.8	10.0%	0	6185.88	
393	嘉海	0	10kV-42	嘉22	8833.20	510.00	158.8	31.1%	0	4315.89	
394	嘉海	0	10kV-42	嘉23	6841.40	395.00	0.0	0.0%	0	5473.12	
395	嘉海	0	10kV-42	嘉24	8833.20	510.00	124.9	24.5%	0	4902.74	
396	嘉海	0	10kV-43	嘉25	8833.20	510.00	100.9	19.8%	0	5319.53	
397	嘉海	0	10kV-44	嘉31	8833.20	510.00	74.2	14.5%	0	5781.95	
398	嘉海	0	10kV-44	嘉32	8833.20	510.00	244.0	47.8%	0	2840.53	
399	嘉海	0	10kV-44	嘉33	8833.20	510.00	164.6	32.3%	0	4216.13	
400	嘉海	0	10kV-44	嘉34	8833.20	510.00	117.4	23.0%	0	5033.61	
401	嘉海	0	10kV-44	嘉35	8833.20	510.00	131.4	25.8%	0	4791.22	
402	嘉海	0	10kV-44	嘉37	8833.20	510.00	34.8	6.8%	0	6463.71	
403	嘉海	0	10kV-44	嘉38	8833.20	510.00	141.5	27.7%	0	4616.58	
404	靖江路	0	10kV-41	江11	8833.20	510.00	126.4	24.8%	0	4877.77	
405	靖江路	0	10kV-41	江12	8833.20	510.00	188.2	36.9%	0	3807.31	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
406	靖江路	0	10kV-41	江13	8833.20	510.00	186.3	36.5%	0	3839.73	
407	靖江路	0	10kV-42	江31	8833.20	510.00	172.5	33.8%	0	4079.72	
408	靖江路	0	10kV-42	江32	8833.20	510.00	357.7	70.1%	0	870.74	
409	靖江路	0	10kV-42	江33	8833.20	510.00	33.4	6.5%	0	6488.17	
410	靖江路	0	10kV-41	江45	8833.20	510.00	11.4	2.2%	0	6868.62	
411	东南郊	0	10kV-4	郊12	8833.20	510.00	210.1	41.2%	0	3427.96	
412	东南郊	0	10kV-4	郊15	8833.20	510.00	164.8	32.3%	0	4213.05	
413	东南郊	0	10kV-4	郊16	8833.20	510.00	142.3	27.9%	0	4601.28	
414	东南郊	0	10kV-4	郊21	8833.20	510.00	129.0	25.3%	0	4833.07	
415	东南郊	0	10kV-4	郊25	8833.20	510.00	238.4	46.8%	0	2936.61	
416	东南郊	0	10kV-4	郊26	7707.40	445.00	118.9	26.7%	0	4105.79	
417	东南郊	0	10kV-5	郊31	7707.40	445.00	98.2	22.1%	0	4465.07	
418	东南郊	0	10kV-5	郊32	7707.40	445.00	153.7	34.5%	0	3503.42	
419	东南郊	0	10kV-5	郊33	7707.40	445.00	277.5	62.4%	0	1359.09	
420	东南郊	0	10kV-5	郊34	6841.40	395.00	210.7	53.3%	0	1824.09	
421	东南郊	0	10kV-5	郊35	8833.20	510.00	166.4	32.6%	0	4184.65	
422	东南郊	0	10kV-5	郊36	8833.20	510.00	284.5	55.8%	0	2139.42	
423	东南郊	0	10kV-5	郊41	8833.20	510.00	164.5	32.3%	0	4216.89	
424	东南郊	0	10kV-5	郊45	8833.20	510.00	72.0	14.1%	0	5819.73	
425	华捷道	0	10kV-41	捷11	7707.40	445.00	203.4	45.7%	0	2643.26	
426	华捷道	0	10kV-41	捷12	8833.20	510.00	153.3	30.1%	0	4411.05	
427	华捷道	0	10kV-41	捷13	8833.20	510.00	83.4	16.4%	0	5622.05	
428	华捷道	0	10kV-41	捷14	8833.20	510.00	101.8	20.0%	0	5303.35	
429	华捷道	0	10kV-41	捷15	8833.20	510.00	122.0	23.9%	0	4953.58	
430	华捷道	0	10kV-41	捷16	8833.20	510.00	234.9	46.1%	0	2997.74	
431	华捷道	0	10kV-41	捷18	8833.20	510.00	198.5	38.9%	0	3628.58	
432	华捷道	0	10kV-42	捷21	8833.20	510.00	275.5	54.0%	0	2295.50	
433	华捷道	0	10kV-43	捷25	8833.20	510.00	103.1	20.2%	0	5281.58	
434	华捷道	0	10kV-44	捷31	8833.20	510.00	38.2	7.5%	0	6404.34	
435	华捷道	0	10kV-44	捷32	8833.20	510.00	123.9	24.3%	0	4921.32	
436	华捷道	0	10kV-44	捷34	8833.20	510.00	241.7	47.4%	0	2880.70	
437	华捷道	0	10kV-44	捷35	8833.20	510.00	160.4	31.4%	0	4288.52	
438	华捷道	0	10kV-44	捷37	8833.20	510.00	65.6	12.9%	0	5930.45	
439	华捷道	0	10kV-44	捷38	8833.20	510.00	93.1	18.2%	0	5454.64	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
440	解放桥	0	10kV-41	解11	6841.40	395.00	312.9	79.2%	0	53.23	
441	解放桥	0	10kV-41	解12	6841.40	395.00	162.5	41.1%	0	2658.22	
442	解放桥	0	10kV-41	解13	6841.40	395.00	151.8	38.4%	0	2843.56	
443	解放桥	0	10kV-41	解14	8833.20	510.00	181.0	35.5%	0	3931.47	
444	解放桥	0	10kV-41	解16	8833.20	510.00	258.9	50.8%	0	2583.10	
445	解放桥	0	10kV-42	解21	8833.20	510.00	152.5	29.9%	0	4425.48	
446	解放桥	0	10kV-42	解22	8833.20	510.00	133.7	26.2%	0	4750.34	
447	解放桥	0	10kV-42	解23	8833.20	510.00	132.0	25.9%	0	4780.58	
448	解放桥	0	10kV-42	解24	8833.20	510.00	81.3	15.9%	0	5658.57	
449	解放桥	0	10kV-43	解26	8833.20	510.00	71.5	14.0%	0	5828.84	
450	解放桥	0	10kV-44	解31	6841.40	395.00	129.8	32.9%	0	3224.18	
451	解放桥	0	10kV-44	解32	8833.20	510.00	144.6	28.4%	0	4561.93	
452	解放桥	0	10kV-44	解33	8833.20	510.00	0.0	0.0%	0	7066.56	
453	解放桥	0	10kV-44	解34	6841.40	395.00	127.8	32.4%	0	3259.28	
454	解放桥	0	10kV-44	解35	8833.20	510.00	157.8	30.9%	0	4334.00	
455	解放桥	0	10kV-44	解36	8833.20	510.00	70.0	13.7%	0	5853.33	
456	金家窑	0	10kV-41	金11	8833.20	510.00	128.0	25.1%	0	4848.93	
457	金家窑	0	10kV-41	金12	6841.40	395.00	202.0	51.1%	0	1974.64	
458	金家窑	0	10kV-41	金13	6841.40	395.00	111.8	28.3%	0	3536.06	
459	金家窑	0	10kV-41	金14	8833.20	510.00	263.2	51.6%	0	2507.85	
460	金家窑	0	10kV-41	金16	8833.20	510.00	127.6	25.0%	0	4856.37	
461	金家窑	0	10kV-42	金21	8833.20	510.00	198.9	39.0%	0	3622.19	
462	金家窑	0	10kV-42	金22	6841.40	395.00	228.4	57.8%	0	1516.72	
463	金家窑	0	10kV-42	金23	6841.40	395.00	94.0	23.8%	0	3845.59	
464	金家窑	0	10kV-42	金24	8833.20	510.00	224.0	43.9%	0	3186.93	
465	金家窑	0	10kV-43	金25	8833.20	510.00	111.8	21.9%	0	5130.88	
466	金家窑	0	10kV-43	金26	8833.20	510.00	117.2	23.0%	0	5037.21	
467	金家窑	0	10kV-43	金27	8833.20	510.00	116.8	22.9%	0	5043.78	
468	金家窑	0	10kV-44	金31	8833.20	510.00	168.6	33.1%	0	4146.59	
469	金家窑	0	10kV-44	金32	8833.20	510.00	110.5	21.7%	0	5153.07	
470	金家窑	0	10kV-44	金33	6841.40	395.00	170.2	43.1%	0	2525.29	
471	金家窑	0	10kV-44	金34	8833.20	510.00	132.9	26.1%	0	4764.19	
472	金家窑	0	10kV-44	金35	8833.20	510.00	249.0	48.8%	0	2754.02	
473	金家窑	0	10kV-44	金36	6841.40	395.00	41.1	10.4%	0	4761.30	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
474	金家窑	0	10kV-44	金37	8833.20	510.00	21.0	4.1%	0	6702.65	
475	京福路	0	10kV-41	京11	7707.40	445.00	66.2	14.9%	0	5020.01	
476	京福路	0	10kV-41	京12	7707.40	445.00	295.7	66.5%	0	1044.24	
477	京福路	0	10kV-41	京13	7707.40	445.00	180.5	40.6%	0	3039.28	
478	京福路	0	10kV-41	京14	7707.40	445.00	202.9	45.6%	0	2652.15	
479	京福路	0	10kV-41	京15	8833.20	510.00	147.5	28.9%	0	4511.55	
480	京福路	0	10kV-41	京16	7707.40	445.00	184.6	41.5%	0	2968.22	
481	京福路	0	10kV-41	京17	7707.40	445.00	142.8	32.1%	0	3692.36	
482	京福路	0	10kV-41	京18	8833.20	510.00	116.3	22.8%	0	5052.59	
483	京福路	0	10kV-42	京21	8833.20	510.00	140.9	27.6%	0	4626.79	
484	京福路	0	10kV-41	京22	8833.20	510.00	9.6	1.9%	0	6899.53	
485	京福路	0	10kV-43	京25	8833.20	510.00	115.9	22.7%	0	5059.08	
486	京福路	0	10kV-41	京26	8833.20	510.00	60.2	11.8%	0	6023.09	
487	京福路	0	10kV-44	京31	8833.20	510.00	216.7	42.5%	0	3313.46	
488	京福路	0	10kV-44	京32	7707.40	445.00	330.0	74.2%	0	449.51	
489	京福路	0	10kV-44	京33	7707.40	445.00	138.1	31.0%	0	3773.45	
490	京福路	0	10kV-44	京34	7707.40	445.00	167.4	37.6%	0	3266.88	
491	京福路	0	10kV-44	京35	7707.40	445.00	199.4	44.8%	0	2712.00	
492	京福路	0	10kV-44	京36	7707.40	445.00	123.3	27.7%	0	4029.62	
493	京福路	0	10kV-44	京37	8833.20	510.00	175.2	34.4%	0	4031.72	
494	京福路	0	10kV-44	京38	8833.20	510.00	216.1	42.4%	0	3323.81	
495	均胜路	0	10kV-41	均11	7707.40	445.00	90.7	20.4%	0	4595.81	
496	均胜路	0	10kV-41	均12	8833.20	510.00	184.7	36.2%	0	3868.18	
497	均胜路	0	10kV-41	均13	8833.20	510.00	198.5	38.9%	0	3628.75	
498	均胜路	0	10kV-41	均14	8833.20	510.00	186.6	36.6%	0	3834.30	
499	均胜路	0	10kV-41	均15	8833.20	510.00	200.6	39.3%	0	3591.86	
500	均胜路	0	10kV-41	均16	8833.20	510.00	167.0	32.8%	0	4173.63	
501	均胜路	0	10kV-41	均18	7707.40	445.00	147.8	33.2%	0	3606.62	
502	均胜路	0	10kV-43	均25	8833.20	510.00	146.8	28.8%	0	4523.50	
503	均胜路	0	10kV-44	均31	8833.20	510.00	199.5	39.1%	0	3610.60	
504	均胜路	0	10kV-44	均32	7707.40	445.00	272.3	61.2%	0	1449.63	
505	均胜路	0	10kV-44	均33	8833.20	510.00	245.9	48.2%	0	2807.74	
506	均胜路	0	10kV-44	均35	8833.20	510.00	226.2	44.3%	0	3149.41	
507	均胜路	0	10kV-44	均36	8833.20	510.00	178.5	35.0%	0	3974.81	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
508	均胜路	0	10kV-44	均37	7707.40	445.00	222.1	49.9%	0	2319.12	
509	均胜路	0	10kV-44	均38	7707.40	445.00	242.1	54.4%	0	1972.35	
510	双口	0	10kV-41	口11	7707.40	445.00	292.7	65.8%	0	1096.28	
511	双口	0	10kV-41	口12	7707.40	445.00	85.3	19.2%	0	4689.33	
512	双口	0	10kV-41	口13	7707.40	445.00	207.7	46.7%	0	2568.35	
513	双口	0	10kV-41	口14	7707.40	445.00	53.9	12.1%	0	5232.85	
514	双口	0	10kV-41	口15	7707.40	445.00	147.2	33.1%	0	3616.01	
515	双口	0	10kV-41	口16	7707.40	445.00	260.0	58.4%	0	1663.20	
516	双口	0	10kV-41	口17	7707.40	445.00	78.3	17.6%	0	4809.96	
517	双口	0	10kV-44	口31	7707.40	445.00	274.0	61.6%	0	1421.09	
518	双口	0	10kV-44	口32	7707.40	445.00	90.6	20.4%	0	4595.99	
519	双口	0	10kV-44	口33	7707.40	445.00	348.3	78.3%	0	133.17	
520	双口	0	10kV-44	口34	8833.20	510.00	224.0	43.9%	0	3187.61	
521	双口	0	10kV-44	口35	7707.40	445.00	163.9	36.8%	0	3326.68	
522	双口	0	10kV-44	口36	7707.40	445.00	1.0	0.2%	0	6149.45	
523	刘快庄	0	10kV-43	快31	7707.40	445.00	268.4	60.3%	0	1517.29	
524	刘快庄	0	10kV-43	快32	7707.40	445.00	192.2	43.2%	0	2836.80	
525	刘快庄	0	10kV-43	快33	7707.40	445.00	261.0	58.6%	0	1646.22	
526	刘快庄	0	10kV-43	快35	7707.40	445.00	206.2	46.3%	0	2594.39	
527	刘快庄	0	10kV-43	快36	7707.40	445.00	151.7	34.1%	0	3538.96	
528	刘快庄	0	10kV-44	快41	7707.40	445.00	176.6	39.7%	0	3107.63	
529	刘快庄	0	10kV-44	快42	7707.40	445.00	96.4	21.7%	0	4496.34	
530	刘快庄	0	10kV-41	快46	8833.20	510.00	86.0	16.9%	0	5577.21	
531	刘快庄	0	10kV-45	快51	7707.40	445.00	348.8	78.4%	0	125.49	
532	刘快庄	0	10kV-45	快52	7707.40	445.00	315.9	71.0%	0	694.23	
533	刘快庄	0	10kV-45	快53	7707.40	445.00	216.0	48.5%	0	2424.95	
534	刘快庄	0	10kV-45	快55	7707.40	445.00	311.8	70.1%	0	766.33	
535	刘快庄	0	10kV-45	快56	7707.40	445.00	247.9	55.7%	0	1872.73	
536	刘快庄	0	10kV-46	快61	7707.40	445.00	348.8	78.4%	0	125.49	
537	昆纬路	0	10kV-41	昆11	8833.20	510.00	207.1	40.6%	0	3480.14	
538	昆纬路	0	10kV-41	昆12	8833.20	510.00	153.5	30.1%	0	4407.24	
539	昆纬路	0	10kV-41	昆13	8833.20	510.00	87.5	17.2%	0	5551.58	
540	昆纬路	0	10kV-41	昆14	8833.20	510.00	214.4	42.0%	0	3353.12	
541	昆纬路	0	10kV-41	昆15	8833.20	510.00	84.9	16.7%	0	5595.72	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
542	昆纬路	0	10kV-41	昆16	8833.20	510.00	147.6	28.9%	0	4510.14	
543	昆纬路	0	10kV-41	昆18	8833.20	510.00	89.8	17.6%	0	5511.30	
544	昆纬路	0	10kV-42	昆21	8833.20	510.00	242.9	47.6%	0	2859.13	
545	昆纬路	0	10kV-44	昆31	8833.20	510.00	47.3	9.3%	0	6246.97	
546	昆纬路	0	10kV-44	昆32	8833.20	510.00	83.8	16.4%	0	5615.52	
547	昆纬路	0	10kV-44	昆33	7707.40	445.00	0.0	0.0%	0	6165.92	
548	昆纬路	0	10kV-44	昆34	8833.20	510.00	161.9	31.7%	0	4262.73	
549	昆纬路	0	10kV-44	昆35	8833.20	510.00	52.6	10.3%	0	6154.94	
550	昆纬路	0	10kV-44	昆36	8833.20	510.00	57.1	11.2%	0	6077.39	
551	昆纬路	0	10kV-44	昆37	8833.20	510.00	61.8	12.1%	0	5996.41	
552	昆纬路	0	10kV-44	昆38	8833.20	510.00	305.1	59.8%	0	1782.32	
553	郎园	0	10kV-41	郎11	7707.40	445.00	36.3	8.2%	0	5537.45	
554	郎园	0	10kV-41	郎12	7707.40	445.00	50.7	11.4%	0	5288.06	
555	郎园	0	10kV-41	郎13	7707.40	445.00	140.6	31.6%	0	3729.96	
556	郎园	0	10kV-41	郎14	7707.40	445.00	46.0	10.3%	0	5368.76	
557	郎园	0	10kV-41	郎15	7707.40	445.00	7.1	1.6%	0	6043.77	
558	郎园	0	10kV-41	郎16	8833.20	510.00	106.5	20.9%	0	5222.73	
559	郎园	0	10kV-41	郎17	8833.20	510.00	220.0	43.1%	0	3255.68	
560	郎园	0	10kV-41	郎18	8833.20	510.00	33.3	6.5%	0	6489.06	
561	郎园	0	10kV-42	郎21	7707.40	445.00	202.3	45.5%	0	2662.67	
562	郎园	0	10kV-42	郎22	8833.20	510.00	181.4	35.6%	0	3925.39	
563	郎园	0	10kV-42	郎23	7707.40	445.00	48.3	10.9%	0	5328.96	
564	郎园	0	10kV-42	郎24	7707.40	445.00	48.2	10.8%	0	5331.00	
565	郎园	0	10kV-43	郎25	7707.40	445.00	0.5	0.1%	0	6156.73	
566	郎园	0	10kV-43	郎26	7707.40	445.00	36.6	8.2%	0	5532.64	
567	郎园	0	10kV-43	郎27	6841.40	395.00	204.0	51.6%	0	1940.10	
568	郎园	0	10kV-43	郎28	8833.20	510.00	136.4	26.7%	0	4704.20	
569	郎园	0	10kV-44	郎31	8833.20	510.00	206.4	40.5%	0	3492.26	
570	柳滩	0	10kV-41	柳11	8833.20	510.00	142.2	27.9%	0	4603.13	
571	柳滩	0	10kV-41	柳12	8833.20	510.00	89.8	17.6%	0	5511.98	
572	柳滩	0	10kV-41	柳13	8833.20	510.00	120.2	23.6%	0	4984.87	
573	柳滩	0	10kV-41	柳14	8833.20	510.00	105.5	20.7%	0	5239.57	
574	柳滩	0	10kV-41	柳15	8833.20	510.00	29.6	5.8%	0	6553.05	
575	柳滩	0	10kV-41	柳16	8833.20	510.00	250.4	49.1%	0	2729.62	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
576	柳滩	0	10kV-42	柳21	7707.40	445.00	177.8	39.9%	0	3087.01	
577	柳滩	0	10kV-42	柳22	8833.20	510.00	189.3	37.1%	0	3787.90	
578	柳滩	0	10kV-43	柳25	8833.20	510.00	160.3	31.4%	0	4290.42	
579	柳滩	0	10kV-43	柳26	8833.20	510.00	229.1	44.9%	0	3097.86	
580	柳滩	0	10kV-43	柳27	7707.40	445.00	192.2	43.2%	0	2836.86	
581	柳滩	0	10kV-44	柳28	8833.20	510.00	102.7	20.1%	0	5287.84	
582	柳滩	0	10kV-44	柳31	8833.20	510.00	389.5	76.4%	0	319.73	
583	柳滩	0	10kV-44	柳32	8833.20	510.00	385.1	75.5%	0	397.19	
584	柳滩	0	10kV-44	柳33	8833.20	510.00	384.9	75.5%	0	399.50	
585	柳滩	0	10kV-44	柳34	8833.20	510.00	385.5	75.6%	0	389.68	
586	柳滩	0	10kV-44	柳35	8833.20	510.00	388.2	76.1%	0	342.95	
587	柳滩	0	10kV-44	柳36	8833.20	510.00	401.2	78.7%	0	117.26	
588	柳滩	0	10kV-44	柳37	8833.20	510.00	401.5	78.7%	0	112.58	
589	柳滩	0	10kV-41	柳38	8833.20	510.00	159.1	31.2%	0	4311.54	
590	龙顺	0	10kV-41	龙11	8833.20	510.00	66.0	12.9%	0	5924.13	
591	龙顺	0	10kV-41	龙12	7707.40	445.00	139.4	31.3%	0	3751.61	
592	龙顺	0	10kV-41	龙13	7707.40	445.00	188.9	42.5%	0	2893.58	
593	龙顺	0	10kV-41	龙14	6841.40	395.00	93.5	23.7%	0	3853.39	
594	龙顺	0	10kV-41	龙15	8833.20	510.00	88.6	17.4%	0	5532.71	
595	龙顺	0	10kV-41	龙16	8833.20	510.00	110.4	21.6%	0	5154.30	
596	龙顺	0	10kV-42	龙21	8833.20	510.00	117.5	23.0%	0	5031.21	
597	龙顺	0	10kV-42	龙22	7707.40	445.00	52.0	11.7%	0	5265.04	
598	龙顺	0	10kV-42	龙23	7707.40	445.00	118.0	26.5%	0	4122.23	
599	龙顺	0	10kV-42	龙24	8833.20	510.00	182.7	35.8%	0	3901.41	
600	龙顺	0	10kV-43	龙25	8833.20	510.00	218.8	42.9%	0	3276.27	
601	龙顺	0	10kV-43	龙26	8833.20	510.00	316.7	62.1%	0	1581.94	
602	龙顺	0	10kV-43	龙27	7707.40	445.00	50.9	11.4%	0	5285.16	
603	芦新河	0	10kV-4	芦11	7707.40	445.00	109.7	24.6%	0	4266.59	
604	芦新河	0	10kV-4	芦12	7707.40	445.00	0.0	0.0%	0	6165.92	
605	芦新河	0	10kV-4	芦13	8833.20	510.00	207.9	40.8%	0	3465.34	
606	芦新河	0	10kV-4	芦14	7707.40	445.00	144.0	32.4%	0	3672.10	
607	芦新河	0	10kV-4	芦15	7707.40	445.00	180.9	40.7%	0	3032.09	
608	芦新河	0	10kV-4	芦16	7707.40	445.00	161.2	36.2%	0	3374.78	
609	芦新河	0	10kV-5	芦21	7707.40	445.00	129.9	29.2%	0	3915.37	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
610	芦新河	0	10kV-5	芦22	7707.40	445.00	206.9	46.5%	0	2582.26	
611	芦新河	0	10kV-5	芦23	7707.40	445.00	281.7	63.3%	0	1287.33	
612	芦新河	0	10kV-5	芦24	7707.40	445.00	139.0	31.2%	0	3758.27	
613	芦新河	0	10kV-5	芦26	8833.20	510.00	75.2	14.7%	0	5764.51	
614	律纬路	0	10kV-41	律11	8833.20	510.00	167.3	32.8%	0	4169.34	
615	律纬路	0	10kV-41	律12	8833.20	510.00	169.4	33.2%	0	4132.13	
616	律纬路	0	10kV-41	律13	8833.20	510.00	17.6	3.4%	0	6761.96	
617	律纬路	0	10kV-44	律31	8833.20	510.00	100.7	19.7%	0	5322.46	
618	律纬路	0	10kV-44	律32	7707.40	445.00	152.7	34.3%	0	3521.76	
619	律纬路	0	10kV-41	律33	8833.20	510.00	26.7	5.2%	0	6604.38	
620	律纬路	0	10kV-41	律34	8833.20	510.00	14.0	2.7%	0	6823.77	
621	律纬路	0	10kV-41	律37	8833.20	510.00	4.8	0.9%	0	6984.20	
622	满江道	0	10kV-41	满13	8833.20	510.00	269.2	52.8%	0	2403.58	
623	满江道	0	10kV-41	满14	8833.20	510.00	210.9	41.4%	0	3413.72	
624	满江道	0	10kV-41	满16	8833.20	510.00	100.6	19.7%	0	5324.21	
625	满江道	0	10kV-42	满21	8833.20	510.00	259.8	50.9%	0	2566.10	
626	满江道	0	10kV-42	满22	8833.20	510.00	191.0	37.5%	0	3758.50	
627	满江道	0	10kV-42	满23	8833.20	510.00	80.1	15.7%	0	5679.00	
628	满江道	0	10kV-42	满24	8833.20	510.00	7.7	1.5%	0	6933.19	
629	满江道	0	10kV-43	满32	7707.40	445.00	72.8	16.4%	0	4904.53	
630	满江道	0	10kV-43	满33	8833.20	510.00	99.7	19.6%	0	5339.30	
631	满江道	0	10kV-43	满34	8833.20	510.00	316.5	62.1%	0	1584.09	
632	满江道	0	10kV-43	满35	8833.20	510.00	2.0	0.4%	0	7032.54	
633	满江道	0	10kV-44	满41	8833.20	510.00	87.5	17.2%	0	5551.51	
634	满江道	0	10kV-44	满42	8833.20	510.00	141.1	27.7%	0	4622.64	
635	满江道	0	10kV-44	满43	8833.20	510.00	328.9	64.5%	0	1369.28	
636	满江道	0	10kV-41	满44	8833.20	510.00	52.6	10.3%	0	6155.61	
637	金贸园	0	10kV-41	贸11	8833.20	510.00	41.2	8.1%	0	6353.42	
638	金贸园	0	10kV-41	贸31	8833.20	510.00	32.1	6.3%	0	6509.74	
639	金贸园	0	10kV-41	贸32	8833.20	510.00	29.2	5.7%	0	6560.29	
640	金贸园	0	10kV-41	贸34	8833.20	510.00	18.4	3.6%	0	6748.20	
641	龙门道	0	10kV-41	门26	8833.20	510.00	6.7	1.3%	0	6950.33	
642	龙门道	0	10kV-42	门31	8833.20	510.00	182.9	35.9%	0	3897.99	
643	龙门道	0	10kV-42	门32	8833.20	510.00	205.2	40.2%	0	3512.53	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
644	龙门道	0	10kV-42	门33	8833.20	510.00	139.0	27.3%	0	4658.73	
645	龙门道	0	10kV-42	门34	8833.20	510.00	64.7	12.7%	0	5945.90	
646	龙门道	0	10kV-42	门35	8833.20	510.00	237.7	46.6%	0	2948.92	
647	龙门道	0	10kV-42	门36	8833.20	510.00	205.4	40.3%	0	3509.37	
648	龙门道	0	10kV-43	门41	8833.20	510.00	185.0	36.3%	0	3862.16	
649	龙门道	0	10kV-43	门42	8833.20	510.00	215.5	42.3%	0	3333.88	
650	龙门道	0	10kV-43	门43	8833.20	510.00	186.6	36.6%	0	3835.44	
651	龙门道	0	10kV-43	门44	8833.20	510.00	160.8	31.5%	0	4281.80	
652	龙门道	0	10kV-43	门45	8833.20	510.00	153.6	30.1%	0	4406.60	
653	龙门道	0	10kV-44	门51	8833.20	510.00	26.6	5.2%	0	6605.01	
654	龙门道	0	10kV-44	门52	8833.20	510.00	183.1	35.9%	0	3894.53	
655	龙门道	0	10kV-44	门53	8833.20	510.00	205.1	40.2%	0	3514.08	
656	龙门道	0	10kV-44	门54	8833.20	510.00	209.0	41.0%	0	3446.93	
657	龙门道	0	10kV-44	门55	8833.20	510.00	183.3	35.9%	0	3891.43	
658	龙门道	0	10kV-41	门56	8833.20	510.00	13.8	2.7%	0	6828.26	
659	龙门道	0	10kV-44	门61	8833.20	510.00	133.3	26.1%	0	4757.90	
660	龙门道	0	10kV-44	门62	8833.20	510.00	210.0	41.2%	0	3429.17	
661	龙门道	0	10kV-44	门63	8833.20	510.00	253.8	49.8%	0	2671.48	
662	龙门道	0	10kV-44	门64	8833.20	510.00	79.1	15.5%	0	5696.75	
663	龙门道	0	10kV-44	门65	8833.20	510.00	101.5	19.9%	0	5308.88	
664	平河	0	10kV-41	平11	8833.20	510.00	24.7	4.8%	0	6639.35	
665	平河	0	10kV-41	平12	8833.20	510.00	80.3	15.7%	0	5676.51	
666	平河	0	10kV-41	平13	8833.20	510.00	6.0	1.2%	0	6962.79	
667	平河	0	10kV-41	平14	8833.20	510.00	109.4	21.5%	0	5171.25	
668	平河	0	10kV-41	平15	8833.20	510.00	177.2	34.7%	0	3997.25	
669	平河	0	10kV-41	平16	8833.20	510.00	151.6	29.7%	0	4441.29	
670	平河	0	10kV-41	平17	8833.20	510.00	229.4	45.0%	0	3093.92	
671	平河	0	10kV-41	平18	8833.20	510.00	0.0	0.0%	0	7066.56	
672	平河	0	10kV-42	平21	8833.20	510.00	32.5	6.4%	0	6503.77	
673	平河	0	10kV-42	平22	8833.20	510.00	71.6	14.0%	0	5826.37	
674	平河	0	10kV-42	平23	8833.20	510.00	64.3	12.6%	0	5952.90	
675	平河	0	10kV-42	平24	8833.20	510.00	293.5	57.6%	0	1982.75	
676	平河	0	10kV-43	平25	8833.20	510.00	257.2	50.4%	0	2611.35	
677	平河	0	10kV-43	平26	8833.20	510.00	17.4	3.4%	0	6765.30	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
678	平河	0	10kV-43	平27	8833.20	510.00	62.4	12.2%	0	5985.53	
679	平河	0	10kV-43	平28	8833.20	510.00	108.5	21.3%	0	5186.55	
680	平河	0	10kV-44	平31	8833.20	510.00	123.1	24.1%	0	4934.96	
681	平河	0	10kV-44	平32	8833.20	510.00	122.4	24.0%	0	4945.94	
682	平河	0	10kV-44	平33	8833.20	510.00	38.3	7.5%	0	6403.83	
683	平河	0	10kV-44	平34	8833.20	510.00	105.7	20.7%	0	5235.81	
684	平河	0	10kV-44	平35	8833.20	510.00	108.7	21.3%	0	5183.33	
685	平河	0	10kV-44	平36	8833.20	510.00	139.0	27.3%	0	4659.11	
686	平河	0	10kV-44	平37	8833.20	510.00	66.2	13.0%	0	5920.02	
687	南大桥	0	10kV-41	桥14	8833.20	510.00	169.5	33.2%	0	4130.07	
688	南大桥	0	10kV-41	桥15	8833.20	510.00	131.4	25.8%	0	4791.37	
689	南大桥	0	10kV-41	桥16	8833.20	510.00	229.9	45.1%	0	3084.80	
690	南大桥	0	10kV-41	桥17	8833.20	510.00	257.4	50.5%	0	2608.31	
691	南大桥	0	10kV-42	桥23	8833.20	510.00	170.3	33.4%	0	4117.55	
692	南大桥	0	10kV-42	桥24	8833.20	510.00	144.0	28.2%	0	4572.16	
693	南大桥	0	10kV-43	桥27	8833.20	510.00	193.1	37.9%	0	3721.65	
694	南大桥	0	10kV-43	桥28	8833.20	510.00	211.0	41.4%	0	3411.64	
695	南大桥	0	10kV-44	桥33	8833.20	510.00	222.0	43.5%	0	3222.33	
696	南大桥	0	10kV-44	桥34	8833.20	510.00	52.7	10.3%	0	6153.18	
697	南大桥	0	10kV-44	桥35	8833.20	510.00	269.3	52.8%	0	2402.32	
698	南大桥	0	10kV-44	桥38	8833.20	510.00	180.8	35.5%	0	3934.53	
699	王秦庄	0	10kV-41	秦12	8833.20	510.00	216.9	42.5%	0	3310.28	
700	王秦庄	0	10kV-41	秦15	8833.20	510.00	11.9	2.3%	0	6860.82	
701	王秦庄	0	10kV-41	秦26	8833.20	510.00	1.6	0.3%	0	7038.71	
702	王秦庄	0	10kV-43	秦31	8833.20	510.00	259.8	50.9%	0	2566.89	
703	王秦庄	0	10kV-43	秦32	8833.20	510.00	178.6	35.0%	0	3972.95	
704	王秦庄	0	10kV-43	秦33	8833.20	510.00	132.9	26.1%	0	4764.47	
705	王秦庄	0	10kV-43	秦34	8833.20	510.00	138.8	27.2%	0	4662.07	
706	王秦庄	0	10kV-43	秦35	8833.20	510.00	167.0	32.7%	0	4174.80	
707	王秦庄	0	10kV-43	秦36	8833.20	510.00	287.8	56.4%	0	2082.39	
708	王秦庄	0	10kV-44	秦41	8833.20	510.00	18.7	3.7%	0	6743.10	
709	王秦庄	0	10kV-44	秦42	8833.20	510.00	65.7	12.9%	0	5928.89	
710	王秦庄	0	10kV-44	秦43	8833.20	510.00	361.8	70.9%	0	800.43	
711	王秦庄	0	10kV-44	秦44	8833.20	510.00	78.0	15.3%	0	5715.44	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
712	王秦庄	0	10kV-44	秦45	8833.20	510.00	17.1	3.4%	0	6769.87	
713	王秦庄	0	10kV-44	秦46	8833.20	510.00	197.1	38.7%	0	3652.23	
714	王秦庄	0	10kV-45	秦51	7707.40	445.00	218.5	49.1%	0	2381.94	
715	王秦庄	0	10kV-45	秦52	8833.20	510.00	122.0	23.9%	0	4953.98	
716	王秦庄	0	10kV-45	秦53	8833.20	510.00	336.0	65.9%	0	1247.29	
717	王秦庄	0	10kV-45	秦54	8833.20	510.00	0.0	0.0%	0	7066.56	
718	王秦庄	0	10kV-45	秦55	8833.20	510.00	169.5	33.2%	0	4130.75	
719	王秦庄	0	10kV-45	秦56	8833.20	510.00	405.0	79.4%	0	52.61	
720	王秦庄	0	10kV-46	秦61	8833.20	510.00	235.8	46.2%	0	2982.00	
721	王秦庄	0	10kV-46	秦63	8833.20	510.00	240.8	47.2%	0	2895.17	
722	王秦庄	0	10kV-46	秦64	8833.20	510.00	98.8	19.4%	0	5355.16	
723	王秦庄	0	10kV-46	秦65	7707.40	445.00	0.2	0.1%	0	6161.78	
724	王秦庄	0	10kV-46	秦66	8833.20	510.00	203.3	39.9%	0	3545.71	
725	光荣道	0	10kV-43	荣34	8833.20	510.00	121.7	23.9%	0	4959.43	
726	光荣道	0	10kV-44	荣41	8833.20	510.00	0.0	0.0%	0	7066.56	
727	瑞祥	0	10kV-41	瑞11	8833.20	510.00	52.5	10.3%	0	6157.45	
728	瑞祥	0	10kV-41	瑞12	8833.20	510.00	33.7	6.6%	0	6482.74	
729	瑞祥	0	10kV-41	瑞13	8833.20	510.00	260.3	51.0%	0	2557.60	
730	瑞祥	0	10kV-41	瑞14	8833.20	510.00	259.3	50.8%	0	2575.57	
731	瑞祥	0	10kV-41	瑞15	8833.20	510.00	117.9	23.1%	0	5024.94	
732	瑞祥	0	10kV-41	瑞16	8833.20	510.00	137.2	26.9%	0	4689.70	
733	瑞祥	0	10kV-41	瑞17	8833.20	510.00	45.7	9.0%	0	6274.59	
734	瑞祥	0	10kV-41	瑞18	8833.20	510.00	190.0	37.3%	0	3775.93	
735	瑞祥	0	10kV-42	瑞23	8833.20	510.00	141.1	27.7%	0	4622.67	
736	瑞祥	0	10kV-43	瑞25	8833.20	510.00	227.9	44.7%	0	3119.29	
737	瑞祥	0	10kV-43	瑞28	8833.20	510.00	23.5	4.6%	0	6660.18	
738	瑞祥	0	10kV-44	瑞31	8833.20	510.00	199.5	39.1%	0	3612.06	
739	瑞祥	0	10kV-44	瑞32	8833.20	510.00	284.3	55.7%	0	2142.66	
740	瑞祥	0	10kV-44	瑞33	8833.20	510.00	85.8	16.8%	0	5580.27	
741	瑞祥	0	10kV-44	瑞34	8833.20	510.00	101.5	19.9%	0	5309.13	
742	瑞祥	0	10kV-44	瑞35	8833.20	510.00	0.0	0.0%	0	7066.56	
743	瑞祥	0	10kV-44	瑞37	8833.20	510.00	126.4	24.8%	0	4877.95	
744	瑞祥	0	10kV-44	瑞38	8833.20	510.00	207.1	40.6%	0	3479.36	
745	山青道	0	10kV-41	山11	8833.20	510.00	117.8	23.1%	0	5025.53	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
746	山青道	0	10kV-41	山15	8833.20	510.00	266.5	52.3%	0	2450.86	
747	山青道	0	10kV-41	山16	8833.20	510.00	127.3	25.0%	0	4861.91	
748	山青道	0	10kV-43	山34	8833.20	510.00	52.6	10.3%	0	6155.95	
749	山青道	0	10kV-43	山35	8833.20	510.00	157.5	30.9%	0	4337.90	
750	山青道	0	10kV-43	山36	8833.20	510.00	155.5	30.5%	0	4372.68	
751	山青道	0	10kV-44	山41	8833.20	510.00	147.4	28.9%	0	4514.26	
752	上河头	0	10kV-4	上11	8833.20	510.00	230.9	45.3%	0	3067.07	
753	上河头	0	10kV-4	上12	8833.20	510.00	276.4	54.2%	0	2278.66	
754	上河头	0	10kV-4	上13	8833.20	510.00	99.8	19.6%	0	5338.23	
755	上河头	0	10kV-4	上14	8833.20	510.00	207.3	40.7%	0	3475.71	
756	上河头	0	10kV-4	上15	8833.20	510.00	99.2	19.5%	0	5347.77	
757	上河头	0	10kV-4	上21	8833.20	510.00	304.1	59.6%	0	1799.88	
758	上河头	0	10kV-4	上22	8833.20	510.00	93.8	18.4%	0	5441.93	
759	上河头	0	10kV-5	上31	8833.20	510.00	283.9	55.7%	0	2148.85	
760	上河头	0	10kV-5	上32	8833.20	510.00	0.0	0.0%	0	7066.56	
761	上河头	0	10kV-5	上33	8833.20	510.00	83.0	16.3%	0	5629.60	
762	上河头	0	10kV-5	上34	8833.20	510.00	121.7	23.9%	0	4957.96	
763	上河头	0	10kV-5	上35	8833.20	510.00	208.4	40.9%	0	3456.68	
764	上河头	0	10kV-5	上36	8833.20	510.00	220.4	43.2%	0	3249.57	
765	曙光	0	10kV-4	曙11	7707.40	445.00	304.7	68.5%	0	888.08	
766	曙光	0	10kV-4	曙12	7707.40	445.00	336.0	75.5%	0	345.68	
767	曙光	0	10kV-4	曙13	7707.40	445.00	344.8	77.5%	0	194.74	
768	曙光	0	10kV-4	曙14	7707.40	445.00	239.8	53.9%	0	2012.88	
769	曙光	0	10kV-4	曙15	7707.40	445.00	169.3	38.1%	0	3232.92	
770	曙光	0	10kV-4	曙16	8833.20	510.00	68.9	13.5%	0	5873.13	
771	曙光	0	10kV-5	曙21	7707.40	445.00	198.8	44.7%	0	2723.18	
772	曙光	0	10kV-5	曙22	7707.40	445.00	254.3	57.1%	0	1762.05	
773	曙光	0	10kV-5	曙23	8833.20	510.00	173.9	34.1%	0	4054.47	
774	曙光	0	10kV-5	曙24	7707.40	445.00	240.0	53.9%	0	2008.93	
775	曙光	0	10kV-5	曙25	7707.40	445.00	246.8	55.5%	0	1891.27	
776	双街	0	10kV-42	双21	7707.40	445.00	0.0	0.0%	0	6165.92	
777	双街	0	10kV-42	双22	8833.20	510.00	95.3	18.7%	0	5415.63	
778	双街	0	10kV-42	双23	8833.20	510.00	153.0	30.0%	0	4416.68	
779	双街	0	10kV-42	双24	8833.20	510.00	176.0	34.5%	0	4018.98	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
780	双街	0	10kV-42	双25	8833.20	510.00	231.5	45.4%	0	3056.54	
781	双街	0	10kV-42	双26	7707.40	445.00	224.8	50.5%	0	2272.21	
782	双街	0	10kV-42	双27	7707.40	445.00	205.2	46.1%	0	2611.37	
783	双街	0	10kV-42	双28	7707.40	445.00	348.8	78.4%	0	125.49	
784	双街	0	10kV-44	双31	8833.20	510.00	203.9	40.0%	0	3534.97	
785	双街	0	10kV-44	双32	7707.40	445.00	277.6	62.4%	0	1357.74	
786	双街	0	10kV-44	双33	7707.40	445.00	348.8	78.4%	0	125.49	
787	双街	0	10kV-44	双34	7707.40	445.00	251.7	56.6%	0	1805.62	
788	双街	0	10kV-44	双35	7707.40	445.00	191.0	42.9%	0	2856.96	
789	双街	0	10kV-44	双36	8833.20	510.00	266.4	52.2%	0	2452.20	
790	双街	0	10kV-44	双37	7707.40	445.00	239.6	53.9%	0	2015.27	
791	双街	0	10kV-44	双38	7707.40	445.00	252.4	56.7%	0	1793.68	
792	万松	0	10kV-41	松11	8833.20	510.00	93.4	18.3%	0	5449.30	
793	万松	0	10kV-41	松12	8833.20	510.00	55.0	10.8%	0	6113.54	
794	万松	0	10kV-41	松13	8833.20	510.00	84.7	16.6%	0	5599.80	
795	万松	0	10kV-41	松14	8833.20	510.00	73.1	14.3%	0	5800.10	
796	万松	0	10kV-41	松15	8833.20	510.00	130.5	25.6%	0	4806.13	
797	万松	0	10kV-41	松16	8833.20	510.00	224.1	43.9%	0	3185.65	
798	万松	0	10kV-41	松17	8833.20	510.00	246.9	48.4%	0	2790.98	
799	万松	0	10kV-41	松18	8833.20	510.00	253.9	49.8%	0	2669.61	
800	万松	0	10kV-42	松21	8833.20	510.00	0.0	0.0%	0	7066.56	
801	万松	0	10kV-42	松22	8833.20	510.00	74.1	14.5%	0	5782.97	
802	万松	0	10kV-42	松23	8833.20	510.00	243.4	47.7%	0	2851.48	
803	万松	0	10kV-42	松24	8833.20	510.00	200.2	39.3%	0	3599.50	
804	万松	0	10kV-43	松25	8833.20	510.00	104.1	20.4%	0	5264.14	
805	万松	0	10kV-43	松26	8833.20	510.00	71.5	14.0%	0	5827.68	
806	万松	0	10kV-43	松27	8833.20	510.00	207.8	40.8%	0	3466.92	
807	万松	0	10kV-44	松31	8833.20	510.00	70.5	13.8%	0	5845.34	
808	万松	0	10kV-44	松32	8833.20	510.00	131.2	25.7%	0	4794.73	
809	万松	0	10kV-44	松33	8833.20	510.00	114.1	22.4%	0	5090.11	
810	万松	0	10kV-44	松34	8833.20	510.00	122.3	24.0%	0	4948.27	
811	万松	0	10kV-44	松35	8833.20	510.00	244.8	48.0%	0	2827.20	
812	万松	0	10kV-44	松36	8833.20	510.00	166.2	32.6%	0	4188.30	
813	万松	0	10kV-44	松37	8833.20	510.00	205.0	40.2%	0	3515.91	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
814	万松	0	10kV-44	松38	6841.40	395.00	194.2	49.2%	0	2108.89	
815	小孙庄	0	10kV-41	孙11	7707.40	445.00	196.6	44.2%	0	2760.00	
816	小孙庄	0	10kV-41	孙12	8833.20	510.00	241.9	47.4%	0	2877.44	
817	小孙庄	0	10kV-41	孙13	8833.20	510.00	273.3	53.6%	0	2332.62	
818	小孙庄	0	10kV-41	孙14	8833.20	510.00	263.8	51.7%	0	2497.05	
819	小孙庄	0	10kV-41	孙15	8833.20	510.00	268.4	52.6%	0	2417.92	
820	小孙庄	0	10kV-42	孙21	8833.20	510.00	103.5	20.3%	0	5273.26	
821	小孙庄	0	10kV-42	孙22	8833.20	510.00	221.6	43.5%	0	3227.68	
822	小孙庄	0	10kV-42	孙23	8833.20	510.00	65.7	12.9%	0	5928.16	
823	小孙庄	0	10kV-43	孙25	8833.20	510.00	46.8	9.2%	0	6255.29	
824	小孙庄	0	10kV-43	孙26	8833.20	510.00	147.7	29.0%	0	4508.02	
825	小孙庄	0	10kV-43	孙27	8833.20	510.00	176.3	34.6%	0	4013.74	
826	小孙庄	0	10kV-43	孙28	8833.20	510.00	53.6	10.5%	0	6138.85	
827	小孙庄	0	10kV-44	孙31	7707.40	445.00	108.3	24.3%	0	4290.64	
828	小孙庄	0	10kV-44	孙32	7707.40	445.00	150.4	33.8%	0	3561.09	
829	小孙庄	0	10kV-44	孙33	8833.20	510.00	48.2	9.5%	0	6231.34	
830	小孙庄	0	10kV-44	孙34	8833.20	510.00	204.0	40.0%	0	3533.34	
831	小孙庄	0	10kV-44	孙35	8833.20	510.00	210.2	41.2%	0	3425.04	
832	小孙庄	0	10kV-44	孙36	7707.40	445.00	288.7	64.9%	0	1165.31	
833	盛泰	0	10kV-41	泰11	8833.20	510.00	60.0	11.8%	0	6027.91	
834	盛泰	0	10kV-41	泰12	8833.20	510.00	182.1	35.7%	0	3912.48	
835	盛泰	0	10kV-41	泰13	8833.20	510.00	41.9	8.2%	0	6340.80	
836	盛泰	0	10kV-41	泰14	8833.20	510.00	197.2	38.7%	0	3650.68	
837	盛泰	0	10kV-41	泰16	8833.20	510.00	71.0	13.9%	0	5837.31	
838	盛泰	0	10kV-41	泰17	8833.20	510.00	53.1	10.4%	0	6147.47	
839	盛泰	0	10kV-41	泰21	8833.20	510.00	44.1	8.7%	0	6301.99	
840	盛泰	0	10kV-41	泰25	8833.20	510.00	3.2	0.6%	0	7010.65	
841	盛泰	0	10kV-44	泰31	8833.20	510.00	70.0	13.7%	0	5853.93	
842	盛泰	0	10kV-44	泰32	8833.20	510.00	0.0	0.0%	0	7066.56	
843	盛泰	0	10kV-41	泰33	8833.20	510.00	0.0	0.0%	0	7066.56	
844	盛泰	0	10kV-44	泰34	8833.20	510.00	272.0	53.3%	0	2355.83	
845	盛泰	0	10kV-41	泰35	8833.20	510.00	82.2	16.1%	0	5643.58	
846	盛泰	0	10kV-44	泰36	8833.20	510.00	25.5	5.0%	0	6624.92	
847	唐口	0	10kV-41	唐11	8833.20	510.00	184.4	36.2%	0	3872.64	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
848	唐口	0	10kV-41	唐12	8833.20	510.00	47.8	9.4%	0	6237.93	
849	唐口	0	10kV-41	唐13	8833.20	510.00	114.9	22.5%	0	5076.16	
850	唐口	0	10kV-41	唐14	8833.20	510.00	179.5	35.2%	0	3958.02	
851	唐口	0	10kV-41	唐15	8833.20	510.00	203.8	40.0%	0	3537.29	
852	唐口	0	10kV-41	唐16	8833.20	510.00	116.1	22.8%	0	5056.27	
853	唐口	0	10kV-41	唐17	8833.20	510.00	109.0	21.4%	0	5178.53	
854	唐口	0	10kV-42	唐21	8833.20	510.00	106.1	20.8%	0	5228.44	
855	唐口	0	10kV-42	唐22	8833.20	510.00	293.2	57.5%	0	1988.80	
856	唐口	0	10kV-42	唐23	8833.20	510.00	403.5	79.1%	0	77.94	
857	唐口	0	10kV-43	唐26	8833.20	510.00	209.8	41.1%	0	3433.08	
858	唐口	0	10kV-44	唐31	7707.40	445.00	201.7	45.3%	0	2672.32	
859	唐口	0	10kV-44	唐32	8833.20	510.00	78.3	15.4%	0	5709.57	
860	唐口	0	10kV-44	唐33	8833.20	510.00	261.3	51.2%	0	2540.57	
861	唐口	0	10kV-44	唐34	8833.20	510.00	169.4	33.2%	0	4132.55	
862	唐口	0	10kV-44	唐36	8833.20	510.00	124.2	24.4%	0	4915.34	
863	唐口	0	10kV-41	唐37	8833.20	510.00	65.0	12.7%	0	5941.00	
864	天山路	0	10kV-41	天11	8833.20	510.00	213.8	41.9%	0	3363.28	
865	天山路	0	10kV-41	天12	8833.20	510.00	158.9	31.2%	0	4313.94	
866	天山路	0	10kV-41	天13	8833.20	510.00	35.7	7.0%	0	6448.14	
867	天山路	0	10kV-41	天14	8833.20	510.00	163.2	32.0%	0	4240.44	
868	天山路	0	10kV-41	天16	8833.20	510.00	138.2	27.1%	0	4672.20	
869	天山路	0	10kV-41	天17	8833.20	510.00	98.5	19.3%	0	5359.70	
870	天山路	0	10kV-42	天21	8833.20	510.00	94.2	18.5%	0	5435.81	
871	天山路	0	10kV-42	天22	8833.20	510.00	67.1	13.2%	0	5903.59	
872	天山路	0	10kV-42	天24	8833.20	510.00	172.7	33.9%	0	4076.08	
873	天山路	0	10kV-43	天25	8833.20	510.00	47.3	9.3%	0	6246.55	
874	天山路	0	10kV-43	天26	8833.20	510.00	102.6	20.1%	0	5289.66	
875	天山路	0	10kV-43	天27	6841.40	395.00	194.3	49.2%	0	2107.87	
876	天山路	0	10kV-43	天28	8833.20	510.00	108.0	21.2%	0	5195.91	
877	天山路	0	10kV-44	天31	8833.20	510.00	154.7	30.3%	0	4387.88	
878	天山路	0	10kV-44	天32	8833.20	510.00	62.6	12.3%	0	5983.04	
879	天山路	0	10kV-44	天33	8833.20	510.00	198.6	38.9%	0	3626.66	
880	天山路	0	10kV-44	天34	8833.20	510.00	86.9	17.0%	0	5561.92	
881	天山路	0	10kV-44	天35	8833.20	510.00	254.1	49.8%	0	2664.99	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
882	天山路	0	10kV-44	天36	8833.20	510.00	111.9	21.9%	0	5128.21	
883	天山路	0	10kV-44	天37	8833.20	510.00	103.7	20.3%	0	5270.39	
884	天山路	0	10kV-44	天38	8833.20	510.00	244.6	48.0%	0	2830.79	
885	铁东路	0	10kV-41	铁11	6841.40	395.00	246.4	62.4%	0	1205.70	
886	铁东路	0	10kV-41	铁12	8833.20	510.00	149.4	29.3%	0	4479.22	
887	铁东路	0	10kV-41	铁13	7707.40	445.00	178.5	40.1%	0	3073.55	
888	铁东路	0	10kV-41	铁14	7707.40	445.00	59.7	13.4%	0	5132.39	
889	铁东路	0	10kV-41	铁15	8833.20	510.00	215.4	42.2%	0	3336.43	
890	铁东路	0	10kV-41	铁16	8833.20	510.00	77.7	15.2%	0	5719.98	
891	铁东路	0	10kV-41	铁17	8833.20	510.00	131.7	25.8%	0	4786.13	
892	铁东路	0	10kV-42	铁21	7707.40	445.00	216.7	48.7%	0	2412.45	
893	铁东路	0	10kV-42	铁22	7707.40	445.00	348.8	78.4%	0	125.49	
894	铁东路	0	10kV-42	铁23	8833.20	510.00	82.2	16.1%	0	5642.76	
895	铁东路	0	10kV-43	铁26	8833.20	510.00	189.3	37.1%	0	3787.16	
896	铁东路	0	10kV-43	铁27	8833.20	510.00	256.1	50.2%	0	2631.52	
897	铁东路	0	10kV-44	铁31	7707.40	445.00	212.6	47.8%	0	2483.88	
898	铁东路	0	10kV-44	铁32	7707.40	445.00	170.9	38.4%	0	3206.65	
899	铁东路	0	10kV-44	铁33	8833.20	510.00	162.8	31.9%	0	4246.36	
900	铁东路	0	10kV-44	铁34	8833.20	510.00	187.3	36.7%	0	3822.65	
901	铁东路	0	10kV-44	铁35	7707.40	445.00	238.0	53.5%	0	2043.28	
902	铁东路	0	10kV-44	铁37	8833.20	510.00	264.8	51.9%	0	2480.99	
903	丰通	0	10kV-41	通11	7707.40	445.00	155.8	35.0%	0	3467.96	
904	丰通	0	10kV-41	通12	8833.20	510.00	321.5	63.0%	0	1498.45	
905	丰通	0	10kV-41	通13	7707.40	445.00	348.8	78.4%	0	125.49	
906	丰通	0	10kV-41	通14	8833.20	510.00	124.6	24.4%	0	4907.79	
907	丰通	0	10kV-41	通15	5802.20	335.00	88.8	26.5%	0	3104.27	
908	丰通	0	10kV-42	通21	8833.20	510.00	324.2	63.6%	0	1451.34	
909	丰通	0	10kV-42	通22	7707.40	445.00	103.5	23.3%	0	4373.91	
910	丰通	0	10kV-42	通23	7707.40	445.00	160.3	36.0%	0	3389.67	
911	丰通	0	10kV-42	通24	7707.40	445.00	161.6	36.3%	0	3366.60	
912	丰通	0	10kV-42	通26	8833.20	510.00	238.1	46.7%	0	2941.80	
913	丰通	0	10kV-45	通51	5802.20	335.00	248.1	74.1%	0	344.64	
914	丰通	0	10kV-45	通52	7707.40	445.00	282.5	63.5%	0	1272.26	
915	丰通	0	10kV-45	通53	8833.20	510.00	197.1	38.6%	0	3652.59	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
916	丰通	0	10kV-45	通54	8833.20	510.00	265.4	52.0%	0	2470.00	
917	丰通	0	10kV-45	通55	8833.20	510.00	288.9	56.6%	0	2062.57	
918	丰通	0	10kV-45	通56	8833.20	510.00	12.1	2.4%	0	6856.69	
919	丰通	0	10kV-46	通61	7707.40	445.00	314.1	70.6%	0	726.09	
920	丰通	0	10kV-46	通62	8833.20	510.00	363.6	71.3%	0	769.71	
921	丰通	0	10kV-46	通64	8833.20	510.00	279.6	54.8%	0	2224.15	
922	丰通	0	10kV-46	通65	8833.20	510.00	136.0	26.7%	0	4710.26	
923	丰通	0	10kV-46	通66	7707.40	445.00	222.8	50.1%	0	2306.89	
924	张湾	0	10kV-41	湾11	7707.40	445.00	175.7	39.5%	0	3123.34	
925	张湾	0	10kV-41	湾12	8833.20	510.00	47.0	9.2%	0	6252.86	
926	张湾	0	10kV-41	湾13	8833.20	510.00	63.8	12.5%	0	5962.28	
927	张湾	0	10kV-41	湾14	8833.20	510.00	26.6	5.2%	0	6605.48	
928	张湾	0	10kV-41	湾15	8833.20	510.00	90.6	17.8%	0	5497.93	
929	张湾	0	10kV-41	湾16	8833.20	510.00	322.3	63.2%	0	1484.25	
930	张湾	0	10kV-42	湾21	8833.20	510.00	171.6	33.7%	0	4093.66	
931	张湾	0	10kV-42	湾22	8833.20	510.00	228.7	44.8%	0	3105.08	
932	张湾	0	10kV-42	湾23	8833.20	510.00	116.5	22.8%	0	5049.28	
933	张湾	0	10kV-43	湾31	8833.20	510.00	13.2	2.6%	0	6838.47	
934	张湾	0	10kV-43	湾32	8833.20	510.00	8.1	1.6%	0	6926.74	
935	张湾	0	10kV-43	湾34	8833.20	510.00	37.0	7.2%	0	6426.23	
936	张湾	0	10kV-43	湾35	8833.20	510.00	92.3	18.1%	0	5467.43	
937	张湾	0	10kV-43	湾36	8833.20	510.00	7.1	1.4%	0	6943.75	
938	张湾	0	10kV-44	湾41	8833.20	510.00	77.3	15.2%	0	5728.29	
939	张湾	0	10kV-44	湾42	8833.20	510.00	177.2	34.7%	0	3997.90	
940	万河道	0	10kV-41	万11	8833.20	510.00	0.4	0.1%	0	7060.38	
941	万河道	0	10kV-41	万13	8833.20	510.00	1.4	0.3%	0	7042.14	
942	万河道	0	10kV-41	万15	8833.20	510.00	87.3	17.1%	0	5555.31	
943	万河道	0	10kV-41	万17	8833.20	510.00	81.4	16.0%	0	5656.11	
944	万河道	0	10kV-41	万18	8833.20	510.00	211.7	41.5%	0	3400.12	
945	万河道	0	10kV-42	万22	8833.20	510.00	9.9	1.9%	0	6895.68	
946	万河道	0	10kV-42	万23	8833.20	510.00	44.8	8.8%	0	6290.43	
947	万河道	0	10kV-41	万24	8833.20	510.00	28.6	5.6%	0	6570.71	
948	万河道	0	10kV-41	万25	8833.20	510.00	8.7	1.7%	0	6915.91	
949	万河道	0	10kV-41	万27	8833.20	510.00	8.0	1.6%	0	6927.49	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
950	万河道	0	10kV-42	万28	8833.20	510.00	249.2	48.9%	0	2749.96	
951	万河道	0	10kV-43	万31	8833.20	510.00	302.2	59.2%	0	1833.06	
952	万河道	0	10kV-43	万33	8833.20	510.00	74.7	14.6%	0	5773.22	
953	万河道	0	10kV-43	万35	8833.20	510.00	296.2	58.1%	0	1937.13	
954	万河道	0	10kV-43	万36	8833.20	510.00	10.0	2.0%	0	6892.97	
955	万河道	0	10kV-43	万38	8833.20	510.00	158.4	31.1%	0	4322.46	
956	万河道	0	10kV-44	万43	8833.20	510.00	290.4	56.9%	0	2036.33	
957	万河道	0	10kV-41	万44	8833.20	510.00	55.2	10.8%	0	6110.60	
958	万河道	0	10kV-41	万45	8833.20	510.00	50.5	9.9%	0	6191.86	
959	万河道	0	10kV-41	万47	8833.20	510.00	10.9	2.1%	0	6878.34	
960	万河道	0	10kV-44	万48	8833.20	510.00	221.1	43.4%	0	3236.43	
961	吴嘴	0	10kV-42	吴24	8833.20	510.00	126.3	24.8%	0	4878.51	
962	吴嘴	0	10kV-44	吴42	7707.40	445.00	0.0	0.0%	0	6165.92	
963	喜逢台	0	10kV-41	喜25	8833.20	510.00	0.0	0.0%	0	7066.56	
964	喜逢台	0	10kV-41	喜26	8833.20	510.00	0.0	0.0%	0	7066.56	
965	喜逢台	0	10kV-43	喜31	8833.20	510.00	269.0	52.7%	0	2407.99	
966	喜逢台	0	10kV-43	喜32	8833.20	510.00	109.1	21.4%	0	5176.17	
967	喜逢台	0	10kV-43	喜33	8833.20	510.00	99.5	19.5%	0	5342.65	
968	喜逢台	0	10kV-43	喜34	7707.40	445.00	110.1	24.7%	0	4258.73	
969	喜逢台	0	10kV-43	喜35	7707.40	445.00	111.5	25.1%	0	4234.89	
970	喜逢台	0	10kV-43	喜36	8833.20	510.00	109.7	21.5%	0	5166.92	
971	喜逢台	0	10kV-44	喜41	8833.20	510.00	2.7	0.5%	0	7020.32	
972	喜逢台	0	10kV-44	喜42	8833.20	510.00	94.7	18.6%	0	5425.81	
973	喜逢台	0	10kV-44	喜43	8833.20	510.00	66.1	13.0%	0	5921.51	
974	喜逢台	0	10kV-44	喜44	8833.20	510.00	72.9	14.3%	0	5804.77	
975	喜逢台	0	10kV-44	喜45	8833.20	510.00	105.8	20.8%	0	5233.32	
976	喜逢台	0	10kV-44	喜46	8833.20	510.00	74.6	14.6%	0	5775.05	
977	喜逢台	0	10kV-45	喜51	8833.20	510.00	250.2	49.1%	0	2733.04	
978	喜逢台	0	10kV-45	喜52	7707.40	445.00	70.7	15.9%	0	4942.17	
979	喜逢台	0	10kV-45	喜53	7707.40	445.00	257.4	57.8%	0	1707.38	
980	喜逢台	0	10kV-45	喜54	6841.40	395.00	202.3	51.2%	0	1969.86	
981	喜逢台	0	10kV-45	喜55	7707.40	445.00	231.5	52.0%	0	2155.73	
982	喜逢台	0	10kV-45	喜56	8833.20	510.00	105.1	20.6%	0	5246.75	
983	喜逢台	0	10kV-46	喜61	8833.20	510.00	47.3	9.3%	0	6247.82	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
984	喜逢台	0	10kV-46	喜62	8833.20	510.00	123.7	24.3%	0	4924.26	
985	喜逢台	0	10kV-46	喜63	8833.20	510.00	28.8	5.7%	0	6567.02	
986	喜逢台	0	10kV-46	喜64	8833.20	510.00	168.3	33.0%	0	4151.75	
987	喜逢台	0	10kV-46	喜65	8833.20	510.00	179.5	35.2%	0	3957.51	
988	喜逢台	0	10kV-41	喜66	8833.20	510.00	36.8	7.2%	0	6429.64	
989	华夏之林	0	10kV-41	夏11	8833.20	510.00	135.9	26.6%	0	4713.21	
990	华夏之林	0	10kV-41	夏13	6841.40	395.00	11.4	2.9%	0	5275.93	
991	华夏之林	0	10kV-41	夏14	6841.40	395.00	61.1	15.5%	0	4415.22	
992	华夏之林	0	10kV-41	夏15	8833.20	510.00	85.6	16.8%	0	5584.70	
993	华夏之林	0	10kV-41	夏17	8833.20	510.00	86.5	17.0%	0	5568.08	
994	华夏之林	0	10kV-41	夏18	8833.20	510.00	119.8	23.5%	0	4991.04	
995	华夏之林	0	10kV-42	夏21	8833.20	510.00	52.8	10.3%	0	6152.47	
996	华夏之林	0	10kV-42	夏22	8833.20	510.00	63.2	12.4%	0	5971.43	
997	华夏之林	0	10kV-42	夏23	8833.20	510.00	179.1	35.1%	0	3964.22	
998	华夏之林	0	10kV-42	夏24	8833.20	510.00	0.0	0.0%	0	7066.56	
999	华夏之林	0	10kV-43	夏25	8833.20	510.00	55.7	10.9%	0	6102.15	
1000	华夏之林	0	10kV-43	夏26	8833.20	510.00	188.3	36.9%	0	3805.62	
1001	华夏之林	0	10kV-43	夏27	8833.20	510.00	65.9	12.9%	0	5925.17	
1002	华夏之林	0	10kV-43	夏28	8833.20	510.00	53.9	10.6%	0	6132.31	
1003	华夏之林	0	10kV-44	夏31	8833.20	510.00	115.6	22.7%	0	5065.18	
1004	华夏之林	0	10kV-44	夏32	6841.40	395.00	14.7	3.7%	0	5218.51	
1005	华夏之林	0	10kV-44	夏33	8833.20	510.00	172.9	33.9%	0	4071.95	
1006	华夏之林	0	10kV-44	夏34	8833.20	510.00	120.3	23.6%	0	4983.31	
1007	华夏之林	0	10kV-44	夏35	8833.20	510.00	95.3	18.7%	0	5415.56	
1008	华夏之林	0	10kV-44	夏36	8833.20	510.00	0.0	0.0%	0	7066.56	
1009	华夏之林	0	10kV-44	夏37	8833.20	510.00	132.6	26.0%	0	4769.74	
1010	华夏之林	0	10kV-44	夏38	8833.20	510.00	50.8	10.0%	0	6185.85	
1011	兴辰	0	10kV-41	兴11	8833.20	510.00	148.6	29.1%	0	4492.47	
1012	兴辰	0	10kV-41	兴12	7707.40	445.00	89.3	20.1%	0	4619.41	
1013	兴辰	0	10kV-41	兴13	7707.40	445.00	126.3	28.4%	0	3978.65	
1014	兴辰	0	10kV-41	兴14	7707.40	445.00	87.9	19.8%	0	4642.63	
1015	兴辰	0	10kV-41	兴15	8833.20	510.00	142.7	28.0%	0	4594.58	
1016	兴辰	0	10kV-41	兴16	7707.40	445.00	34.0	7.6%	0	5577.89	
1017	兴辰	0	10kV-41	兴17	8833.20	510.00	72.2	14.1%	0	5816.90	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1018	兴辰	0	10kV-42	兴21	7707.40	445.00	128.8	28.9%	0	3935.26	
1019	兴辰	0	10kV-42	兴22	8833.20	510.00	71.1	13.9%	0	5834.88	
1020	兴辰	0	10kV-41	兴27	8833.20	510.00	27.2	5.3%	0	6595.34	
1021	兴辰	0	10kV-43	兴28	8833.20	510.00	255.3	50.1%	0	2645.27	
1022	兴辰	0	10kV-44	兴31	7707.40	445.00	58.7	13.2%	0	5150.02	
1023	兴辰	0	10kV-44	兴32	7707.40	445.00	78.2	17.6%	0	4811.60	
1024	兴辰	0	10kV-44	兴33	7707.40	445.00	14.5	3.3%	0	5915.16	
1025	兴辰	0	10kV-44	兴34	8833.20	510.00	121.0	23.7%	0	4970.92	
1026	兴辰	0	10kV-44	兴35	8833.20	510.00	111.4	21.8%	0	5137.80	
1027	兴辰	0	10kV-44	兴36	8833.20	510.00	168.5	33.0%	0	4147.65	
1028	兴辰	0	10kV-44	兴37	8833.20	510.00	79.1	15.5%	0	5696.77	
1029	晨阳道	0	10kV-41	阳11	7707.40	445.00	213.0	47.9%	0	2477.28	
1030	晨阳道	0	10kV-41	阳12	7707.40	445.00	225.6	50.7%	0	2258.67	
1031	晨阳道	0	10kV-41	阳13	8833.20	510.00	198.5	38.9%	0	3628.66	
1032	晨阳道	0	10kV-41	阳14	8833.20	510.00	233.4	45.8%	0	3023.41	
1033	晨阳道	0	10kV-41	阳15	8833.20	510.00	210.2	41.2%	0	3425.80	
1034	晨阳道	0	10kV-41	阳16	8833.20	510.00	158.9	31.2%	0	4314.37	
1035	晨阳道	0	10kV-41	阳17	8833.20	510.00	140.7	27.6%	0	4629.37	
1036	晨阳道	0	10kV-41	阳18	8833.20	510.00	239.1	46.9%	0	2925.23	
1037	晨阳道	0	10kV-43	阳27	8833.20	510.00	94.3	18.5%	0	5433.83	
1038	晨阳道	0	10kV-43	阳28	8833.20	510.00	178.3	35.0%	0	3977.88	
1039	晨阳道	0	10kV-44	阳31	8833.20	510.00	83.1	16.3%	0	5627.51	
1040	晨阳道	0	10kV-44	阳32	8833.20	510.00	5.2	1.0%	0	6977.27	
1041	晨阳道	0	10kV-44	阳33	6841.40	395.00	118.7	30.0%	0	3417.90	
1042	晨阳道	0	10kV-44	阳34	8833.20	510.00	181.1	35.5%	0	3929.34	
1043	晨阳道	0	10kV-44	阳35	8833.20	510.00	216.6	42.5%	0	3315.03	
1044	晨阳道	0	10kV-44	阳36	8833.20	510.00	173.9	34.1%	0	4054.78	
1045	晨阳道	0	10kV-44	阳37	8833.20	510.00	2.8	0.6%	0	7017.21	
1046	宜兴埠	0	10kV-41	宜61	6841.40	395.00	311.5	78.9%	0	77.94	
1047	宜兴埠	0	10kV-41	宜63	7707.40	445.00	166.1	37.3%	0	3289.21	
1048	宜兴埠	0	10kV-41	宜64	8833.20	510.00	183.7	36.0%	0	3884.05	
1049	宜兴埠	0	10kV-41	宜65	7707.40	445.00	191.4	43.0%	0	2850.31	
1050	宜兴埠	0	10kV-41	宜66	8833.20	510.00	106.3	20.8%	0	5224.97	
1051	宜兴埠	0	10kV-42	宜71	8833.20	510.00	271.5	53.2%	0	2364.83	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1052	宜兴埠	0	10kV-42	宜72	8833.20	510.00	247.9	48.6%	0	2772.91	
1053	宜兴埠	0	10kV-43	宜81	8833.20	510.00	282.5	55.4%	0	2174.29	
1054	宜兴埠	0	10kV-43	宜82	8833.20	510.00	290.5	57.0%	0	2035.21	
1055	宜兴埠	0	10kV-43	宜83	8833.20	510.00	192.2	37.7%	0	3737.88	
1056	宜兴埠	0	10kV-44	宜91	8833.20	510.00	332.6	65.2%	0	1306.15	
1057	宜兴埠	0	10kV-44	宜92	7707.40	445.00	248.8	55.9%	0	1856.75	
1058	宜兴埠	0	10kV-44	宜93	8833.20	510.00	297.6	58.4%	0	1911.44	
1059	宜兴埠	0	10kV-44	宜94	7707.40	445.00	281.6	63.3%	0	1288.08	
1060	宜兴埠	0	10kV-44	宜95	8833.20	510.00	213.7	41.9%	0	3365.25	
1061	宜兴埠	0	10kV-44	宜96	8833.20	510.00	1.7	0.3%	0	7037.67	
1062	于所	0	10kV-41	于11	8833.20	510.00	133.7	26.2%	0	4751.64	
1063	于所	0	10kV-41	于12	8833.20	510.00	110.8	21.7%	0	5147.85	
1064	于所	0	10kV-41	于13	8833.20	510.00	194.9	38.2%	0	3690.03	
1065	于所	0	10kV-41	于14	8833.20	510.00	198.6	38.9%	0	3627.24	
1066	于所	0	10kV-41	于15	8833.20	510.00	51.4	10.1%	0	6176.66	
1067	于所	0	10kV-42	于21	8833.20	510.00	350.0	68.6%	0	1005.39	
1068	于所	0	10kV-42	于23	8833.20	510.00	358.2	70.2%	0	862.23	
1069	于所	0	10kV-43	于33	8833.20	510.00	86.9	17.0%	0	5561.88	
1070	于所	0	10kV-43	于34	6841.40	395.00	213.9	54.2%	0	1768.45	
1071	于所	0	10kV-43	于35	6841.40	395.00	194.1	49.1%	0	2111.05	
1072	于所	0	10kV-43	于36	6841.40	395.00	216.6	54.8%	0	1721.62	
1073	于所	0	10kV-44	于41	8833.20	510.00	82.9	16.3%	0	5631.09	
1074	于所	0	10kV-44	于43	8833.20	510.00	86.3	16.9%	0	5571.36	
1075	刘园	0	10kV-41	园11	8833.20	510.00	381.2	74.7%	0	464.96	
1076	刘园	0	10kV-41	园12	8833.20	510.00	85.7	16.8%	0	5582.02	
1077	刘园	0	10kV-41	园13	8833.20	510.00	138.6	27.2%	0	4666.35	
1078	刘园	0	10kV-41	园15	8833.20	510.00	109.1	21.4%	0	5177.77	
1079	刘园	0	10kV-41	园16	8833.20	510.00	80.1	15.7%	0	5679.78	
1080	刘园	0	10kV-41	园17	8833.20	510.00	131.5	25.8%	0	4788.83	
1081	刘园	0	10kV-41	园18	8833.20	510.00	123.7	24.3%	0	4923.56	
1082	刘园	0	10kV-42	园21	8833.20	510.00	275.7	54.1%	0	2290.82	
1083	刘园	0	10kV-42	园22	8833.20	510.00	231.6	45.4%	0	3055.71	
1084	刘园	0	10kV-42	园24	8833.20	510.00	179.5	35.2%	0	3957.51	
1085	刘园	0	10kV-43	园25	8833.20	510.00	24.2	4.7%	0	6647.97	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1086	刘园	0	10kV-43	园26	8833.20	510.00	45.7	9.0%	0	6274.44	
1087	刘园	0	10kV-43	园27	8833.20	510.00	91.9	18.0%	0	5474.25	
1088	刘园	0	10kV-43	园28	8833.20	510.00	0.9	0.2%	0	7050.18	
1089	刘园	0	10kV-44	园31	8833.20	510.00	69.8	13.7%	0	5858.34	
1090	刘园	0	10kV-44	园32	8833.20	510.00	208.9	41.0%	0	3448.24	
1091	刘园	0	10kV-44	园33	8833.20	510.00	89.3	17.5%	0	5520.15	
1092	刘园	0	10kV-44	园34	8833.20	510.00	62.1	12.2%	0	5991.10	
1093	刘园	0	10kV-44	园35	8833.20	510.00	191.7	37.6%	0	3746.78	
1094	刘园	0	10kV-44	园36	8833.20	510.00	197.2	38.7%	0	3651.52	
1095	刘园	0	10kV-44	园37	8833.20	510.00	229.9	45.1%	0	3084.41	
1096	辰远路	0	10kV-41	远15	8833.20	510.00	228.7	44.8%	0	3105.56	
1097	辰远路	0	10kV-41	远16	8833.20	510.00	141.9	27.8%	0	4609.31	
1098	辰远路	0	10kV-41	远17	8833.20	510.00	230.1	45.1%	0	3082.08	
1099	辰远路	0	10kV-41	远18	8833.20	510.00	68.3	13.4%	0	5882.78	
1100	辰远路	0	10kV-42	远23	8833.20	510.00	184.6	36.2%	0	3869.42	
1101	辰远路	0	10kV-42	远24	8833.20	510.00	188.7	37.0%	0	3797.55	
1102	辰远路	0	10kV-43	远25	8833.20	510.00	123.5	24.2%	0	4928.40	
1103	辰远路	0	10kV-43	远27	8833.20	510.00	326.6	64.0%	0	1409.42	
1104	辰远路	0	10kV-43	远28	8833.20	510.00	154.5	30.3%	0	4390.47	
1105	辰远路	0	10kV-44	远35	8833.20	510.00	251.8	49.4%	0	2705.29	
1106	辰远路	0	10kV-44	远36	7707.40	445.00	159.1	35.8%	0	3409.84	
1107	辰远路	0	10kV-44	远37	8833.20	510.00	133.7	26.2%	0	4750.22	
1108	辰远路	0	10kV-44	远38	8833.20	510.00	223.4	43.8%	0	3197.65	
1109	增产道	0	10kV-41	增11	6841.40	395.00	239.8	60.7%	0	1320.28	
1110	增产道	0	10kV-41	增12	6841.40	395.00	144.1	36.5%	0	2977.96	
1111	增产道	0	10kV-41	增13	6841.40	395.00	32.5	8.2%	0	4910.29	
1112	增产道	0	10kV-41	增15	6841.40	395.00	111.6	28.2%	0	3540.55	
1113	增产道	0	10kV-41	增16	8833.20	510.00	212.7	41.7%	0	3382.83	
1114	增产道	0	10kV-41	增17	8833.20	510.00	246.1	48.3%	0	2803.65	
1115	增产道	0	10kV-41	增18	6495.00	375.00	0.0	0.0%	0	5196.00	
1116	增产道	0	10kV-42	增21	6495.00	375.00	153.3	40.9%	0	2540.06	
1117	增产道	0	10kV-42	增22	8833.20	510.00	219.2	43.0%	0	3270.03	
1118	增产道	0	10kV-42	增23	8833.20	510.00	186.0	36.5%	0	3845.02	
1119	增产道	0	10kV-43	增25	6841.40	395.00	102.1	25.8%	0	3705.17	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1120	增产道	0	10kV-43	增26	6841.40	395.00	96.6	24.5%	0	3799.81	
1121	增产道	0	10kV-43	增27	7707.40	445.00	118.3	26.6%	0	4116.85	
1122	增产道	0	10kV-44	增31	6841.40	395.00	252.8	64.0%	0	1095.04	
1123	增产道	0	10kV-44	增32	6841.40	395.00	249.4	63.2%	0	1152.72	
1124	增产道	0	10kV-44	增33	8833.20	510.00	246.1	48.3%	0	2803.49	
1125	增产道	0	10kV-44	增34	8833.20	510.00	115.6	22.7%	0	5065.13	
1126	增产道	0	10kV-44	增35	8833.20	510.00	237.3	46.5%	0	2957.38	
1127	赵沽里	0	10kV-41	赵13	7707.40	445.00	290.6	65.3%	0	1132.61	
1128	赵沽里	0	10kV-41	赵14	8833.20	510.00	197.9	38.8%	0	3638.26	
1129	赵沽里	0	10kV-41	赵15	7707.40	445.00	348.8	78.4%	0	125.49	
1130	赵沽里	0	10kV-41	赵16	8833.20	510.00	216.4	42.4%	0	3317.85	
1131	赵沽里	0	10kV-41	赵17	8833.20	510.00	130.9	25.7%	0	4799.15	
1132	赵沽里	0	10kV-41	赵18	8833.20	510.00	95.3	18.7%	0	5415.73	
1133	赵沽里	0	10kV-42	赵21	8833.20	510.00	132.2	25.9%	0	4776.40	
1134	赵沽里	0	10kV-42	赵22	8833.20	510.00	132.6	26.0%	0	4770.66	
1135	赵沽里	0	10kV-42	赵24	8833.20	510.00	260.4	51.1%	0	2556.53	
1136	赵沽里	0	10kV-43	赵25	8833.20	510.00	162.4	31.8%	0	4253.94	
1137	赵沽里	0	10kV-43	赵26	8833.20	510.00	182.5	35.8%	0	3905.03	
1138	赵沽里	0	10kV-44	赵31	8833.20	510.00	94.4	18.5%	0	5430.96	
1139	赵沽里	0	10kV-44	赵32	8833.20	510.00	234.5	46.0%	0	3005.36	
1140	赵沽里	0	10kV-44	赵33	8833.20	510.00	129.2	25.3%	0	4828.44	
1141	赵沽里	0	10kV-44	赵34	8833.20	510.00	174.0	34.1%	0	4052.18	
1142	赵沽里	0	10kV-44	赵35	8833.20	510.00	129.2	25.3%	0	4829.56	
1143	赵沽里	0	10kV-44	赵36	8833.20	510.00	15.0	2.9%	0	6806.58	
1144	赵沽里	0	10kV-44	赵37	8833.20	510.00	70.5	13.8%	0	5846.16	
1145	赵沽里	0	10kV-44	赵38	6841.40	395.00	0.5	0.1%	0	5464.68	
1146	郑庄子	0	10kV-43	郑31	8833.20	510.00	261.6	51.3%	0	2535.90	
1147	郑庄子	0	10kV-43	郑33	8833.20	510.00	325.6	63.8%	0	1426.91	
1148	郑庄子	0	10kV-43	郑36	8833.20	510.00	224.2	44.0%	0	3184.07	
1149	郑庄子	0	10kV-44	郑41	8833.20	510.00	272.2	53.4%	0	2352.59	
1150	郑庄子	0	10kV-45	郑52	8833.20	510.00	247.7	48.6%	0	2777.24	
1151	郑庄子	0	10kV-45	郑56	8833.20	510.00	246.8	48.4%	0	2791.19	
1152	郑庄子	0	10kV-46	郑61	8833.20	510.00	271.7	53.3%	0	2360.50	
1153	中山路	0	10kV-41	中11	6841.40	395.00	174.7	44.2%	0	2446.76	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1154	中山路	0	10kV-41	中12	6841.40	395.00	121.6	30.8%	0	3366.21	
1155	中山路	0	10kV-41	中13	6841.40	395.00	21.4	5.4%	0	5102.08	
1156	中山路	0	10kV-41	中14	6841.40	395.00	95.0	24.0%	0	3827.97	
1157	中山路	0	10kV-41	中15	8833.20	510.00	95.6	18.7%	0	5410.59	
1158	中山路	0	10kV-41	中16	8833.20	510.00	32.9	6.5%	0	6496.51	
1159	中山路	0	10kV-41	中17	8833.20	510.00	70.6	13.8%	0	5844.02	
1160	中山路	0	10kV-41	中18	8833.20	510.00	153.5	30.1%	0	4408.12	
1161	中山路	0	10kV-42	中21	6841.40	395.00	109.5	27.7%	0	3576.28	
1162	中山路	0	10kV-42	中22	6841.40	395.00	96.0	24.3%	0	3809.98	
1163	中山路	0	10kV-42	中23	8833.20	510.00	26.6	5.2%	0	6606.42	
1164	中山路	0	10kV-42	中24	8833.20	510.00	0.5	0.1%	0	7058.09	
1165	中山路	0	10kV-43	中25	8833.20	510.00	64.8	12.7%	0	5944.77	
1166	中山路	0	10kV-43	中26	8833.20	510.00	128.3	25.2%	0	4844.41	
1167	中山路	0	10kV-43	中27	8833.20	510.00	77.3	15.1%	0	5728.50	
1168	中山路	0	10kV-44	中33	8833.20	510.00	0.5	0.1%	0	7058.67	
1169	大王庄	0	10kV-41	庄11	7707.40	445.00	62.3	14.0%	0	5086.21	
1170	大王庄	0	10kV-41	庄12	7707.40	445.00	241.1	54.2%	0	1990.26	
1171	大王庄	0	10kV-41	庄13	8833.20	510.00	154.3	30.3%	0	4394.09	
1172	大王庄	0	10kV-41	庄14	8833.20	510.00	58.7	11.5%	0	6049.85	
1173	大王庄	0	10kV-41	庄15	8833.20	510.00	139.8	27.4%	0	4644.73	
1174	大王庄	0	10kV-41	庄16	8833.20	510.00	248.7	48.8%	0	2758.55	
1175	大王庄	0	10kV-41	庄17	8833.20	510.00	51.0	10.0%	0	6182.97	
1176	大王庄	0	10kV-41	庄18	8833.20	510.00	193.5	37.9%	0	3714.56	
1177	大王庄	0	10kV-42	庄24	8833.20	510.00	134.0	26.3%	0	4745.54	
1178	大王庄	0	10kV-42	庄25	8833.20	510.00	213.6	41.9%	0	3367.49	
1179	大王庄	0	10kV-44	庄31	8833.20	510.00	267.5	52.5%	0	2432.96	
1180	大王庄	0	10kV-44	庄32	8833.20	510.00	166.5	32.6%	0	4183.15	
1181	大王庄	0	10kV-44	庄33	8833.20	510.00	35.0	6.9%	0	6460.33	
1182	大王庄	0	10kV-44	庄34	8833.20	510.00	107.4	21.1%	0	5206.71	
1183	大王庄	0	10kV-44	庄35	8833.20	510.00	111.4	21.8%	0	5137.19	
1184	崂山道	0	10kV-41	崂11	6841.40	395.00	131.1	33.2%	0	3203.04	
1185	崂山道	0	10kV-41	崂12	8833.20	510.00	142.2	27.9%	0	4602.99	
1186	崂山道	0	10kV-41	崂13	8833.20	510.00	150.5	29.5%	0	4460.72	
1187	崂山道	0	10kV-41	崂14	8833.20	510.00	81.9	16.1%	0	5648.16	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1188	崂山道	0	10kV-41	崂15	6841.40	395.00	177.4	44.9%	0	2400.75	
1189	崂山道	0	10kV-41	崂16	6841.40	395.00	220.4	55.8%	0	1655.03	
1190	崂山道	0	10kV-41	崂17	8833.20	510.00	206.1	40.4%	0	3497.39	
1191	崂山道	0	10kV-41	崂18	8833.20	510.00	107.6	21.1%	0	5202.72	
1192	崂山道	0	10kV-43	崂25	8833.20	510.00	89.5	17.5%	0	5516.52	
1193	崂山道	0	10kV-44	崂31	6841.40	395.00	207.6	52.5%	0	1878.03	
1194	崂山道	0	10kV-44	崂32	8833.20	510.00	100.3	19.7%	0	5329.92	
1195	崂山道	0	10kV-44	崂33	8833.20	510.00	309.0	60.6%	0	1714.07	
1196	崂山道	0	10kV-44	崂34	8833.20	510.00	128.7	25.2%	0	4837.01	
1197	崂山道	0	10kV-44	崂35	8833.20	510.00	91.6	18.0%	0	5479.70	
1198	崂山道	0	10kV-44	崂36	8833.20	510.00	140.4	27.5%	0	4634.88	
1199	崂山道	0	10kV-44	崂37	8833.20	510.00	196.6	38.5%	0	3661.56	
1200	崂山道	0	10kV-44	崂38	8833.20	510.00	152.9	30.0%	0	4418.20	