

滨海供电公司10千伏配电线路可开放容量信息表(2025年第三季度)

序号	变电站名称	主变最大 负荷日后 需预留容 量 (kVA)	所属母线	线路名称	线路允许容 量 (kVA)	允许电流 (A)	历史最大 电流 (A)	最高负 载率 (%)	线路最大 负荷日后 需预留容 量 (kVA)	可开放容量 (kVA)	备注
1	安达	0	10kV-1	831	6928	400	233.40	58.35%	0	1500	
2		0		832	6928	400	90.23	22.56%	0	3980	
3		0		833	6928	400	214.00	53.50%	0	1836	
4		0		834	6928	400	231.00	57.75%	0	1541	
5		0	10kV-2	841	6928	400	222.07	55.52%	0	3082	
6		0	10kV-3	845	6928	400	132.00	33.00%	0	3256	
7		0		846	6928	400	186.00	46.50%	0	2321	
8		0		848	6928	400	288.00	72.00%	0	554	
9		0	10kV-4	851	6928	400	228.13	57.03%	0	1591	
10		0		852	6928	400	133.01	33.25%	0	3239	
11		0		853	6928	400	258.28	64.57%	0	2455	
12		0		854	6928	400	248.00	62.00%	0	1247	
13		0		855	6928	400	155.27	38.82%	0	2853	
14	宝山道	0	10kV-41	宝11	8140.4	470	61.00	12.98%	0	5456	
15		0		宝12	8140.4	470	20.00	4.26%	0	6166	
16		0		宝13	8140.4	470	64.00	13.62%	0	5404	
17		0		宝14	8140.4	470	277.00	58.94%	0	1715	
18		0		宝17	8140.4	470	144.00	30.64%	0	4018	
19		0		宝18	8140.4	470	154.41	32.85%	0	3838	
20		0	10kV-42	宝21	8140.4	470	132.00	28.09%	0	4226	
21		0		宝22	9006.4	520	172.00	33.08%	0	4226	
22		0		宝23	9006.4	520	195.56	37.61%	0	3818	
23		0	10kV-43	宝25	8140.4	470	325.00	69.15%	0	883	
24		0	10kV-44	宝31	8140.4	470	117.00	24.89%	0	4486	
25		0		宝32	8140.4	470	80.00	17.02%	0	5127	
26		0		宝33	8140.4	470	228.00	48.51%	0	2563	
27		0		宝34	8140.4	470	129.79	27.61%	0	4264	
28		0		宝35	8140.4	470	171.00	36.38%	0	3551	
29		0		宝36	8140.4	470	136.00	28.94%	0	4157	
30		0		宝37	8140.4	470	99.00	21.06%	0	4798	
31		0	10kV-41	茶11	6928	400	162.00	40.50%	0	2737	
32		0		茶12	6928	400	80.00	20.00%	0	4157	
33		0		茶13	6928	400	220.00	55.00%	0	1732	
34		0		茶14	7257.08	419	284.00	67.78%	0	887	
35		0		茶15	6373.76	368	222.00	60.33%	0	1254	
36		0		茶16	7257.08	419	311.00	74.22%	0	419	
37		0		茶17	6928	400	95.00	23.75%	0	3897	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
38	茶淀	0	10kV-42	茶18	5975.4	345	23.00	6.67%	0	4382	
39		0		茶21	6928	400	71.00	17.75%	0	4313	
40		0		茶22	6928	400	39.00	9.75%	0	4867	
41		0		茶23	6928	400	188.00	47.00%	0	2286	
42		0		茶24	6373.76	368	138.00	37.50%	0	2709	
43		0	10kV-43	茶25	6373.76	368	274.00	74.46%	0	353	
44		0		茶26	6373.76	368	276.00	75.00%	0	319	
45		0		茶27	6373.76	368	186.56	50.70%	0	1868	
46		0		茶28	6928	400	280.00	70.00%	0	693	
47	厂东路	0	10kV-41	厂13	7499.56	433	0.00	0.00%	0	6000	
48		0		厂14	8140.4	470	31.47	6.69%	0	5967	
49		0		厂15	9006.4	520	45.18	8.69%	0	6423	
50		0	10kV-42	厂21	7499.56	433	190.00	43.88%	0	2709	
51		0		厂22	10392	600	4.00	0.67%	0	8244	
52		0		厂23	7499.56	433	143.00	33.03%	0	3523	
53		0		厂24	17320	1000	298.32	29.83%	0	8689	
54		0	10kV-43	厂34	9006.4	520	0.00	0.00%	0	7205	
55		0		厂35	9006.4	520	75.61	14.54%	0	5896	
56		0	10kV-44	厂41	17320	1000	275.46	27.55%	0	9085	
57		0		厂42	17320	1000	21.09	2.11%	0	13491	
58		0		厂43	6373.76	368	22.00	5.98%	0	4718	
59	潮音寺	0	10kV-4	潮10	6928	400	63.00	15.75%	0	4451	
60		0		潮12	6928	400	28.11	7.03%	0	5056	
61		0		潮13	6928	400	196.00	49.00%	0	2148	
62		0		潮14	6928	400	106.00	26.50%	0	3706	
63		0		潮15	6928	400	158.00	39.50%	0	2806	
64		0		潮16	6928	400	304.00	76.00%	0	277	
65		0		潮17	6928	400	253.00	63.25%	0	1160	
66		0		潮18	6928	400	0.22	0.06%	0	5539	
67		0		潮19	6928	400	195.00	48.75%	0	2165	
68		0		潮20	6928	400	282.00	70.50%	0	2044	
69		0	10kV-5	潮30	6928	400	58.11	14.53%	0	4536	
70		0		潮32	6928	400	230.85	57.71%	0	1544	
71		0		潮33	6928	400	272.00	68.00%	0	831	
72		0		潮34	6928	400	210.00	52.50%	0	1905	
73		0		潮35	6928	400	318.00	79.50%	0	35	
74		0		潮36	6928	400	125.00	31.25%	0	3377	
75		0		潮37	6928	400	42.00	10.50%	0	4815	
76		0		潮38	6928	400	214.00	53.50%	0	1836	
77		0		潮39	5975.4	345	167.00	48.41%	0	1888	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
78		0		潮40	6928	400	288.00	72.00%	0	554	
79	潮宗桥	0	10kV-4	宗11	6373.76	368	238.60	64.84%	0	966	
80		0		宗12	6668.2	385	234.32	60.86%	0	1276	
81		0		宗14	6373.76	368	75.00	20.38%	0	3800	
82		0		宗15	6928	400	36.00	9.00%	0	4919	
83		0		宗16	6373.76	368	15.00	4.08%	0	4839	
84		0	10kV-5	宗21	6373.76	368	212.00	57.61%	0	1427	
85		0		宗22	6928	400	153.63	38.41%	0	2882	
86		0		宗24	6373.76	368	201.00	54.62%	0	1618	
87		0		宗26	6373.76	368	223.37	60.70%	0	1230	
88		0	10kV-41	崇11	8573.4	495	144.00	29.09%	0	4365	
89	崇义路	0	10kV-43	崇31	8573.4	495	315.00	63.64%	0	1403	
90	大丰路	0		丰31	6928	400	47.00	11.75%	0	4728	
91		0		丰32	6928	400	134.00	33.50%	0	3222	
92		0		丰33	6928	400	51.00	12.75%	0	4659	
93		0		丰34	6928	400	167.00	41.75%	0	2650	
94		0		丰35	6928	400	202.03	50.51%	0	2043	
95		0		丰36	6928	400	61.17	15.29%	0	4483	
96		0	10kV-44	丰41	6928	400	184.00	46.00%	0	2356	
97		0		丰42	6928	400	182.00	45.50%	0	2390	
98		0		丰43	6928	400	122.00	30.50%	0	3429	
99		0		丰44	6928	400	219.00	54.75%	0	1749	
100		0		丰45	6928	400	98.00	24.50%	0	3845	
101		0		丰46	6928	400	2.00	0.50%	0	5508	
102		0	10kV-45	丰51	6928	400	83.00	20.75%	0	4105	
103		0		丰52	6928	400	178.00	44.50%	0	2459	
104		0		丰53	6928	400	39.49	9.87%	0	4858	
105		0		丰54	6928	400	89.00	22.25%	0	4001	
106		0		丰55	6928	400	59.00	14.75%	0	4521	
107		0		丰56	6928	400	3.00	0.75%	0	5490	
108		0	10kV-46	丰61	6928	400	58.00	14.50%	0	4538	
109		0		丰62	6928	400	141.00	35.25%	0	3100	
110		0		丰63	6928	400	81.00	20.25%	0	4139	
111		0		丰65	6928	400	61.17	15.29%	0	4483	
112	大学城	0	10kV-41	大13	6928	400	143.21	35.80%	0	3062	
113		0		大15	6928	400	139.63	34.91%	0	3124	
114		0		大16	6928	400	287.00	71.75%	0	572	
115		0		大17	6928	400	227.00	56.75%	0	1611	
116		0		大18	6928	400	39.00	9.75%	0	4867	
117		0		大21	6928	400	178.40	44.60%	0	2453	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
118		0	10kV-42	大22	6668.2	385	59.00	15.32%	0	4313	
119		0		大24	6928	400	339.00	84.75%	0	0	
120		0	10kV-43	大25	6928	400	243.00	60.75%	0	1334	
121	大众园	0	10kV-41	众11	17320	1000	569.00	56.90%	0	4001	
122		0		众12	15657.28	904	3.22	0.36%	0	12470	
123		0		众13	7499.56	433	235.06	54.29%	0	1928	
124		0		众15	9006.4	520	0.00	0.00%	0	7205	
125		0		众16	7499.56	433	192.35	44.42%	0	2668	
126		0	10kV-42	众22	9266.2	535	118.67	22.18%	0	5358	
127		0		众23	7499.56	433	0.00	0.00%	0	6000	
128		0	10kV-43	众31	17320	1000	549.00	54.90%	0	4347	
129		0		众34	9006.4	520	0.00	0.00%	0	7205	
130		0		众35	10392	600	38.00	6.33%	0	7655	
131		0	10kV-44	众42	17320	1000	619.00	61.90%	0	3135	
132	邓善沽	0	10kV-42	邓21	8140.4	470	204.00	43.40%	0	2979	
133		0		邓22	6373.76	368	253.00	68.75%	0	717	
134		0		邓23	7257.08	419	258.00	61.58%	0	2789	
135		0		邓24	6373.76	368	247.00	67.12%	0	821	
136		0	10kV-43	邓25	8140.4	470	225.00	47.87%	0	2615	
137		0		邓26	8140.4	470	292.00	62.13%	0	1455	
138		0		邓27	8227	475	135.00	28.42%	0	4243	
139		0	10kV-44	邓31	7257.08	419	169.00	40.33%	0	2879	
140		0		邓32	6373.76	368	249.00	67.66%	0	786	
141		0		邓33	7257.08	419	267.00	63.72%	0	1181	
142		0		邓34	8140.4	470	164.00	34.89%	0	3672	
143		0		邓35	8140.4	470	93.00	19.79%	0	4902	
144		0		邓36	8140.4	470	244.00	51.91%	0	2286	
145		0		邓37	8227	475	61.00	12.84%	0	5525	
146	东尹站	0	10kV-42	尹21	6373.76	368	127.00	34.51%	0	2899	
147		0		尹22	6373.76	368	241.00	65.49%	0	925	
148		0		尹23	6373.76	368	195.00	52.99%	0	1722	
149		0	10kV-44	尹35	6373.76	368	219.00	59.51%	0	1306	
150		0		尹36	6373.76	368	213.00	57.88%	0	1410	
151		0		尹37	6373.76	368	173.00	47.01%	0	2103	
152	窦庄子	0	10kV-4	窦11	6373.76	368	89.00	24.18%	0	3558	
153		0		窦16	6928	400	0.00	0.00%	0	5542	
154		0	10kV-5	窦21	6373.76	368	174.00	47.28%	0	2085	
155		0		窦22	6373.76	368	96.68	26.27%	0	3425	
156		0		窦23	6928	400	167.81	41.95%	0	2636	
157		0		福11	6928	400	205.00	51.25%	0	1992	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
158	福州道	0	10kV-41	福13	6928	400	49.00	12.25%	0	4694	
159		0		福14	6928	400	245.00	61.25%	0	1299	
160		0		福15	6928	400	142.00	35.50%	0	3083	
161		0		福16	6928	400	70.00	17.50%	0	4330	
162		0		福17	6928	400	89.00	22.25%	0	4001	
163		0		福18	6928	400	64.00	16.00%	0	4434	
164		0	10kV-42	福21	6928	400	111.00	27.75%	0	3620	
165		0		福23	6928	400	275.00	68.75%	0	779	
166		0	10kV-43	福26	6928	400	71.00	17.75%	0	4313	
167		0		福27	6928	400	126.00	31.50%	0	3360	
168		0	10kV-44	福28	6928	400	255.00	63.75%	0	1126	
169		0		福31	6928	400	125.00	31.25%	0	3377	
170		0		福32	6928	400	217.00	54.25%	0	1784	
171		0		福34	6928	400	194.00	48.50%	0	2182	
172		0		福35	6928	400	130.00	32.50%	0	3291	
173		0		福38	6928	400	155.27	38.82%	0	2853	
174	付庄	0	10kV-4	付14	6373.76	368	86.00	23.37%	0	3609	
175		0		付15	5196	300	196.00	65.33%	0	762	
176		0		付16	6373.76	368	173.92	47.26%	0	2087	
177		0		付17	5196	300	210.00	70.00%	0	520	
178		0	10kV-5	付21	5196	300	0.00	0.00%	0	4157	
179		0		付22	5196	300	79.00	26.33%	0	2789	
180		0		付23	6373.76	368	161.00	43.75%	0	2310	
181		0		付24	6373.76	368	107.92	29.33%	0	3230	
182		0		付25	6928	400	219.00	54.75%	0	1749	
183	港发站	0	10kV-41	发11	6373.76	368	29.00	7.88%	0	4597	
184		0		发12	6373.76	368	210.41	57.18%	0	1455	
185		0		发13	6373.76	368	142.38	38.69%	0	2633	
186		0		发14	6373.76	368	115.00	31.25%	0	3107	
187		0		发15	6373.76	368	168.00	45.65%	0	2189	
188		0		发16	8278.96	478	273.00	57.11%	0	1895	
189		0		发17	8140.4	470	48.00	10.21%	0	5681	
190		0		发18	8140.4	470	2.11	0.45%	0	6476	
191		0	10kV-44	发31	8140.4	470	226.23	48.13%	0	2594	
192		0		发32	6373.76	368	198.00	53.80%	0	1670	
193		0		发33	6373.76	368	0.00	0.00%	0	5099	
194		0		发34	6373.76	368	305.00	82.88%	0	0	
195		0		发35	6373.76	368	93.00	25.27%	0	3488	
196		0		发36	8278.96	478	256.00	53.56%	0	2189	
197		0		发37	8140.4	470	0.00	0.00%	0	6512	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
198	港塘路	0	10kV-5	610	5196	300	132.00	44.00%	0	1871	
199		0		612	5196	300	20.70	6.90%	0	3798	
200		0	10kV-4	615	5196	300	115.00	38.33%	0	2165	
201		0		619	5196	300	98.00	32.67%	0	2459	
202	港湾	0	10kV-41	湾11	8140.4	470	50.00	10.64%	0	5646	
203		0		湾12	7257.08	419	317.18	75.70%	0	312	
204		0		湾13	8140.4	470	172.55	36.71%	0	3524	
205		0		湾14	6373.76	368	228.00	61.96%	0	1150	
206		0		湾15	6373.76	368	155.22	42.18%	0	2411	
207		0		湾16	8140.4	470	115.06	24.48%	0	4520	
208		0		湾17	8140.4	470	297.00	63.19%	0	1368	
209		0		湾18	8140.4	470	140.74	29.94%	0	4075	
210		0	10kV-42	湾21	8140.4	470	11.52	2.45%	0	6313	
211		0		湾22	8140.4	470	118.70	25.26%	0	4456	
212		0		湾23	8140.4	470	259.00	55.11%	0	2026	
213		0		湾24	6373.76	368	127.00	34.51%	0	2899	
214		0	10kV-43	湾25	6373.76	368	253.00	68.75%	0	717	
215		0		湾26	8140.4	470	132.30	28.15%	0	4221	
216		0		湾27	8140.4	470	310.00	65.96%	0	1143	
217		0		湾28	8140.4	470	64.70	13.77%	0	5392	
218		0		高31	6928	400	7.48	1.87%	0	5413	
219		0		高32	6529.64	377	81.00	21.49%	0	3821	
220		0		高33	6928	400	127.00	31.75%	0	3343	
221		0		高36	6529.64	377	151.00	40.05%	0	2608	
222	高新园	0	10kV-44	高41	6928	400	213.00	53.25%	0	1853	
223		0		高42	6928	400	12.40	3.10%	0	5328	
224		0		高43	6928	400	10.45	2.61%	0	5361	
225		0		高44	6928	400	55.00	13.75%	0	4590	
226		0		高45	6928	400	244.00	61.00%	0	1316	
227		0		高46	6928	400	73.00	18.25%	0	4278	
228		0	10kV-45	高52	6928	400	72.00	18.00%	0	4295	
229		0		高53	6928	400	136.00	34.00%	0	3187	
230		0		高54	6928	400	91.70	22.93%	0	3954	
231		0	10kV-46	高61	6928	400	280.00	70.00%	0	693	
232		0		高62	6928	400	187.00	46.75%	0	2304	
233		0		高63	6928	400	135.00	33.75%	0	3204	
234		0		高64	6529.64	377	171.00	45.36%	0	2262	
235		0		高65	6928	400	136.00	34.00%	0	3187	
236		0		工11	6928	400	51.56	12.89%	0	4649	
237		0		工12	6928	400	223.00	55.75%	0	1680	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
238	工农村	0	10kV-41	工13	6928	400	278.00	69.50%	0	727	
239		0		工14	6928	400	300.00	75.00%	0	346	
240		0		工15	6373.76	368	165.00	44.84%	0	2241	
241		0		工16	6928	400	0.00	0.00%	0	5542	
242		0		工17	6928	400	217.73	54.43%	0	1771	
243		0		工18	6928	400	86.95	21.74%	0	4036	
244		0	10kV-42	工21	6928	400	85.08	21.27%	0	4069	
245		0		工22	6928	400	255.94	63.98%	0	1110	
246		0		工23	6928	400	158.91	39.73%	0	2790	
247		0		工24	6928	400	145.43	36.36%	0	3024	
248		0	10kV-43	工25	6373.76	368	221.00	60.05%	0	1271	
249		0		工26	6928	400	280.00	70.00%	0	693	
250		0		工27	6928	400	268.71	67.18%	0	888	
251		0		工28	6928	400	0.00	0.00%	0	5542	
252	光辉	0	10kV-41	光11	8053.8	465	96.18	20.68%	0	4777	
253		0		光12	10166.84	587	203.00	34.58%	0	4618	
254		0		光13	10166.84	587	214.00	36.46%	0	4427	
255		0		光14	6928	400	185.00	46.25%	0	2338	
256		0		光15	7967.2	460	0.00	0.00%	0	6374	
257		0		光21	10166.84	587	63.00	10.73%	0	7042	
258		0		光22	10166.84	587	29.10	4.96%	0	7629	
259		0		光23	7309.04	422	54.00	12.80%	0	4912	
260		0	10kV-43	光41	10166.84	587	93.60	15.95%	0	6512	
261		0		光42	10166.84	587	25.84	4.40%	0	7686	
262		0		光46	9006.4	520	0.00	0.00%	0	7205	
263		0	10kV-44	光51	8053.8	465	112.00	24.09%	0	4503	
264		0		光52	10166.84	587	70.00	11.93%	0	6921	
265		0		光53	6928	400	252.00	63.00%	0	1178	
266		0		光54	6928	400	161.00	40.25%	0	2754	
267		0		光55	7967.2	460	0.00	0.00%	0	6374	
268		0		光61	7309.04	422	52.00	12.32%	0	4947	
269	郭庄子	0	10kV-4	郭11	6373.76	368	34.49	9.37%	0	4502	
270		0		郭12	6373.76	368	106.69	28.99%	0	3251	
271		0		郭13	6373.76	368	141.60	38.48%	0	2647	
272		0		郭14	6373.76	368	97.57	26.51%	0	3409	
273		0		郭15	6928	400	202.71	50.68%	0	2031	
274		0		郭16	6928	400	113.00	28.25%	0	3585	
275		0	10kV-5	郭22	6373.76	368	88.36	24.01%	0	3569	
276		0		郭23	6928	400	92.71	23.18%	0	3937	
277		0		郭25	6373.76	368	129.34	35.15%	0	2859	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
278	海滨浴场	0	10kV-4	郭26	6373.76	368	205.16	55.75%	0	1546	
279		0		783	5888.8	340	224.00	65.88%	0	831	
280	海防路	0	10kV-41	防11	6373.76	368	75.00	20.38%	0	3800	
281		0		防12	6633.56	383	69.00	18.02%	0	4112	
282		0		防13	8140.4	470	51.15	10.88%	0	5626	
283		0	10kV-42	防21	6373.76	368	44.30	12.04%	0	4332	
284	海景路	0		防23	8140.4	470	92.00	19.57%	0	4919	
285		0	10kV-41	海11	6928	400	202.00	50.50%	0	2044	
286		0		海12	6928	400	82.50	20.63%	0	4114	
287		0		海14	6668.2	385	0.00	0.00%	0	5335	
288		0		海15	6928	400	25.66	6.42%	0	5098	
289		0		海16	6928	400	287.00	71.75%	0	572	
290		0	10kV-42	海21	6928	400	194.00	48.50%	0	2182	
291		0		海22	6928	400	316.00	79.00%	0	69	
292		0		海23	6928	400	94.00	23.50%	0	3914	
293		0		海24	6928	400	82.00	20.50%	0	4122	
294		0	10kV-43	海33	6928	400	82.00	20.50%	0	4122	
295		0		海34	6668.2	385	80.00	20.78%	0	3949	
296		0		海35	6928	400	74.41	18.60%	0	4254	
297		0		海36	6928	400	270.00	67.50%	0	866	
298		0	10kV-44	海41	6928	400	214.00	53.50%	0	1836	
299		0		海42	6928	400	249.00	62.25%	0	1230	
300		0		海43	6928	400	139.00	34.75%	0	3135	
301		0		海44	6928	400	83.00	20.75%	0	4105	
302	海平路	0	10kV-41	平11	7309.04	422	165.00	39.10%	0	2989	
303		0	10kV-42	平31	7309.04	422	236.00	55.92%	0	1760	
304	海洋	0	10kV-2甲	421	6373.76	368	133.00	36.14%	0	2795	
305		0		422	6373.76	368	124.85	33.93%	0	2937	
306		0		423	8140.4	470	152.00	32.34%	0	3880	
307		0		424	8140.4	470	57.17	12.16%	0	5522	
308		0	10kV-2乙	425	8140.4	470	213.00	45.32%	0	2823	
309		0		426	8140.4	470	248.00	52.77%	0	2217	
310		0		427	8140.4	470	58.94	12.54%	0	5491	
311		0		428	8140.4	470	196.02	41.71%	0	3117	
312		0	10kV-3	431	8140.4	470	93.85	19.97%	0	4887	
313		0		432	6373.76	368	223.00	60.60%	0	1237	
314		0		433	8140.4	470	186.00	39.57%	0	3291	
315		0		434	8140.4	470	118.00	25.11%	0	4469	
316		0		435	8140.4	470	142.90	30.40%	0	4037	
317		0		436	8140.4	470	193.00	41.06%	0	3170	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
318	航园	0	437	437	8140.4	470	133.93	28.49%	0	4193	
319		0		438	6373.76	368	187.11	50.85%	0	1858	
320		0	10kV-41	航11	8313.6	480	90.00	18.75%	0	5092	
321		0		航12	6373.76	368	51.11	13.89%	0	4214	
322		0		航13	6373.76	368	0.00	0.00%	0	5099	
323		0		航14	8140.4	470	194.00	41.28%	0	3152	
324		0		航16	8417.52	486	143.00	29.42%	0	4257	
325		0		航17	6373.76	368	244.00	66.30%	0	873	
326		0		航18	6373.76	368	198.00	53.80%	0	1670	
327		0	10kV-42	航21	7534.2	435	150.00	34.48%	0	3429	
328		0		航22	7534.2	435	51.11	11.75%	0	5142	
329		0		航23	8313.6	480	10.00	2.08%	0	6478	
330		0		航24	8140.4	470	51.11	10.87%	0	5627	
331		0		航25	8417.52	486	100.09	20.59%	0	5001	
332		0	10kV-43	航27	8140.4	470	32.41	6.90%	0	5951	
333		0		航28	8140.4	470	2.88	0.61%	0	6462	
334		0		航31	8140.4	470	181.00	38.51%	0	3377	
335		0	10kV-44	航32	8417.52	486	182.15	37.48%	0	3579	
336		0		航33	8140.4	470	55.44	11.80%	0	5552	
337		0		航34	8140.4	470	129.00	27.45%	0	4278	
338		0		航35	8400.2	485	379.00	78.14%	0	156	
339		0		航36	9006.4	520	244.00	46.92%	0	2979	
340		0		航37	8140.4	470	172.99	36.81%	0	3516	
341		0		航38	8140.4	470	261.00	55.53%	0	1992	
342		0	10kV-41	畅11	6928	400	203.89	50.97%	0	2011	
343		0		畅12	6928	400	232.00	58.00%	0	1524	
344		0		畅13	6928	400	307.00	76.75%	0	225	
345		0		畅14	6928	400	155.00	38.75%	0	2858	
346		0		畅15	6928	400	10.44	2.61%	0	5362	
347		0		畅16	6928	400	241.00	60.25%	0	1368	
348		0	10kV-42	畅21	6928	400	168.00	42.00%	0	2633	
349		0		畅22	6928	400	251.00	62.75%	0	1195	
350		0		畅23	6928	400	219.86	54.97%	0	1734	
351		0		畅24	6928	400	109.00	27.25%	0	3655	
352		0		畅25	6928	400	243.23	60.81%	0	2715	
353		0	10kV-43	畅31	6928	400	152.46	38.12%	0	2902	
354		0		畅32	6928	400	61.86	15.47%	0	4471	
355		0		畅33	6928	400	191.97	47.99%	0	2218	
356		0		畅34	6928	400	120.85	30.21%	0	3449	
357		0		畅36	6928	400	189.00	47.25%	0	2269	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
358	和畅路	0	10kV-44	畅41	6928	400	168.79	42.20%	0	2619	
359		0		畅42	6928	400	203.00	50.75%	0	2026	
360		0		畅43	6928	400	338.76	84.69%	0	0	
361		0		畅44	6928	400	163.00	40.75%	0	2719	
362		0		畅45	6928	400	6.51	1.63%	0	5430	
363		0		畅46	6928	400	269.00	67.25%	0	883	
364		0	10kV-45	畅51	6928	400	134.78	33.69%	0	3208	
365		0		畅52	6928	400	215.15	53.79%	0	1816	
366		0		畅53	6928	400	211.09	52.77%	0	1886	
367		0		畅54	6928	400	179.00	44.75%	0	2442	
368		0		畅55	6928	400	270.08	67.52%	0	865	
369		0		畅56	6928	400	156.74	39.19%	0	2828	
370		0	10kV-46	畅61	6928	400	205.00	51.25%	0	1992	
371		0		畅62	6928	400	60.61	15.15%	0	4493	
372		0		畅63	6928	400	214.00	53.50%	0	1836	
373		0		畅64	6928	400	194.85	48.71%	0	2168	
374		0		畅65	6928	400	50.34	12.58%	0	4671	
375		0		畅66	6928	400	168.00	42.00%	0	2633	
376	后沽	0	10kV-4	后15	6373.76	368	77.00	20.92%	0	3765	
377		0		后16	6373.76	368	62.00	16.85%	0	4025	
378		0		后17	6373.76	368	155.00	42.12%	0	2414	
379		0	10kV-5	后21	6373.76	368	154.00	41.85%	0	2432	
380		0		后22	6373.76	368	75.00	20.38%	0	3800	
381		0		后23	6373.76	368	50.62	13.75%	0	4222	
382		0		后27	5975.4	345	12.00	3.48%	0	4572	
383	胡家园	0	10kV-41	胡11	6928	400	0.00	0.00%	0	5542	
384		0		胡12	6928	400	0.00	0.00%	0	5542	
385		0		胡13	6928	400	179.88	44.97%	0	2427	
386		0		胡15	6928	400	190.43	47.61%	0	2244	
387		0		胡16	6928	400	308.00	77.00%	0	208	
388		0	10kV-42	胡20	6928	400	273.00	68.25%	0	814	
389		0		胡21	6928	400	263.00	65.75%	0	987	
390		0		胡22	6598.92	381	124.69	32.73%	0	3120	
391		0		胡23	6928	400	118.95	29.74%	0	3482	
392		0		胡24	6928	400	70.78	17.70%	0	4316	
393		0	10kV-43	胡25	6373.76	368	292.00	79.35%	0	42	
394		0		胡26	6928	400	298.00	74.50%	0	381	
395		0		胡27	6928	400	132.07	33.02%	0	3255	
396		0		胡28	6928	400	169.45	42.36%	0	2607	
397		0		胡31	6373.76	368	269.00	73.10%	0	440	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
398		0	10kV-44	胡32	6928	400	54.00	13.50%	0	4607	
399		0		胡33	6928	400	302.00	75.50%	0	312	
400		0		胡34	6512.32	376	250.00	66.49%	0	880	
401		0		胡35	6928	400	62.11	15.53%	0	4467	
402		0		胡36	6373.76	368	239.65	65.12%	0	948	
403		0		胡37	6928	400	239.00	59.75%	0	1403	
404		0		胡38	6928	400	236.00	59.00%	0	1455	
405	琥珀溪	0	10kV-42	琥31	9785.8	565	172.00	30.44%	0	4850	
406		0		琥32	9162.28	529	107.96	20.41%	0	5460	
407		0		琥33	8278.96	478	19.63	4.11%	0	6283	
408		0		琥34	9647.24	557	181.00	32.50%	0	4583	
409		0		琥35	7794	450	31.00	6.89%	0	5698	
410		0	10kV-43	琥41	8278.96	478	60.00	12.55%	0	5584	
411		0		琥42	9006.4	520	294.00	56.54%	0	2113	
412		0		琥43	9266.2	535	0.77	0.14%	0	7400	
413		0		琥45	8400.2	485	16.00	3.30%	0	6443	
414		0		琥46	9266.2	535	37.00	6.92%	0	6772	
415		0	10kV-44	琥51	9266.2	535	233.00	43.55%	0	3377	
416		0		琥52	9266.2	535	323.00	60.37%	0	1819	
417		0		琥53	8278.96	478	35.00	7.32%	0	6017	
418		0		琥54	9006.4	520	215.00	41.35%	0	3481	
419		0		琥55	8400.2	485	61.00	12.58%	0	5664	
420		0		琥61	8278.96	478	59.00	12.34%	0	5601	
421		0		琥62	9006.4	520	183.00	35.19%	0	4036	
422		0		琥63	9266.2	535	0.79	0.15%	0	7399	
423		0		琥64	9006.4	520	54.00	10.38%	0	6270	
424		0		琥65	8400.2	485	17.00	3.51%	0	6426	
425		0		琥66	9266.2	535	116.00	21.68%	0	5404	
426	花园	0	10kV-1	711	6928	400	164.00	41.00%	0	2702	
427		0		712	6928	400	193.00	48.25%	0	2200	
428		0		714	6928	400	253.00	63.25%	0	1160	
429		0		716	6928	400	221.00	55.25%	0	1715	
430		0		717	6928	400	18.76	4.69%	0	5218	
431		0	10kV-2甲	721	6928	400	49.00	12.25%	0	4694	
432		0		722	6928	400	27.66	6.92%	0	5063	
433		0		723	6928	400	139.14	34.78%	0	3133	
434		0	10kV-2乙	725	6928	400	267.00	66.75%	0	918	
435		0		727	6928	400	27.00	6.75%	0	5075	
436		0		731	6928	400	224.00	56.00%	0	1663	
437		0		732	6928	400	161.00	40.25%	0	2754	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
438		0	10kV-3	733	6928	400	168.00	42.00%	0	2633	
439		0		734	6928	400	112.18	28.04%	0	3600	
440		0		735	6928	400	85.00	21.25%	0	4070	
441		0		736	6928	400	185.00	46.25%	0	2338	
442		0		737	6928	400	40.67	10.17%	0	4838	
443		0		738	6928	400	45.95	11.49%	0	4747	
444	华山道	0	10kV-41	山11	6373.76	368	120.00	32.61%	0	3021	
445		0		山12	6373.76	368	244.00	66.30%	0	873	
446		0		山13	6928	400	174.00	43.50%	0	2529	
447		0		山14	6928	400	185.46	46.37%	0	2330	
448		0		山15	6928	400	218.00	54.50%	0	1767	
449		0		山16	6928	400	214.00	53.50%	0	1836	
450		0	10kV-42	山21	6928	400	103.00	25.75%	0	3758	
451		0		山22	6928	400	235.00	58.75%	0	1472	
452		0		山23	6928	400	173.00	43.25%	0	2546	
453		0		山24	6928	400	65.00	16.25%	0	4417	
454		0		山25	6928	400	4.00	1.00%	0	5473	
455		0		山26	6928	400	191.25	47.81%	0	2230	
456		0	10kV-45	山51	6928	400	125.51	31.38%	0	3369	
457		0		山52	6928	400	216.00	54.00%	0	1801	
458		0		山53	6373.76	368	184.22	50.06%	0	1908	
459		0		山54	6928	400	250.00	62.50%	0	1212	
460		0		山55	6928	400	216.00	54.00%	0	1801	
461		0		山56	6928	400	4.00	1.00%	0	5473	
462		0	10kV-46	山61	6928	400	38.00	9.50%	0	4884	
463		0		山62	6373.76	368	13.00	3.53%	0	4874	
464		0		山63	6928	400	78.40	19.60%	0	4185	
465		0		山64	6928	400	290.00	72.50%	0	520	
466		0		山65	6928	400	188.09	47.02%	0	2285	
467		0		山66	10392	600	44.00	7.33%	0	7552	
468	化工园	0	10kV-4	952	6928	400	53.00	13.25%	0	4624	
469		0		953	6928	400	176.00	44.00%	0	2494	
470		0		956	6928	400	24.22	6.05%	0	5123	
471		0	10kV-5	961	6373.76	368	179.00	48.64%	0	1999	
472		0		962	6928	400	204.88	51.22%	0	1994	
473		0		963	6928	400	261.72	65.43%	0	1009	
474		0		966	6928	400	7.62	1.90%	0	5410	
475		0	10kV-43	惠31	8140.4	470	257.00	54.68%	0	2061	
476		0		惠32	7794	450	2.00	0.44%	0	6201	
477		0		惠34	9526	550	288.00	52.36%	0	2633	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
478	惠居站	0	10kV-44	惠41	7482.24	432	280.90	65.02%	0	1121	
479		0		惠42	8763.92	506	110.00	21.74%	0	5106	
480		0		惠43	7828.64	452	157.00	34.73%	0	3544	
481		0		惠45	8763.92	506	148.00	29.25%	0	4448	
482		0	10kV-45	惠51	9266.2	535	317.00	59.25%	0	1923	
483		0		惠53	9266.2	535	292.00	54.58%	0	2356	
484		0		惠54	9526	550	246.00	44.73%	0	3360	
485		0	10kV-46	惠61	7828.64	452	200.00	44.25%	0	2799	
486		0		惠62	7828.64	452	179.00	39.60%	0	3163	
487		0		惠63	8763.92	506	219.00	43.28%	0	3218	
488		0		惠64	7326.36	423	290.00	68.56%	0	838	
489		0		惠65	9959	575	0.00	0.00%	0	7967	
490	碱渣山	0	10kV-41	碱11	8140.4	470	141.00	30.00%	0	4070	
491		0		碱12	8140.4	470	31.00	6.60%	0	5975	
492		0		碱13	8140.4	470	120.00	25.53%	0	4434	
493		0		碱14	7828.64	452	136.00	30.09%	0	3907	
494		0		碱15	8400.2	485	121.00	24.95%	0	4624	
495		0	10kV-43	碱31	8140.4	470	47.74	10.16%	0	5686	
496		0		碱32	6287.16	363	110.89	30.55%	0	3109	
497		0		碱33	8140.4	470	114.53	24.37%	0	4529	
498		0		碱34	8140.4	470	62.00	13.19%	0	5438	
499		0		碱35	8140.4	470	154.00	32.77%	0	3845	
500		0		碱36	8140.4	470	169.12	35.98%	0	3583	
501		0		碱37	8140.4	470	81.61	17.36%	0	5099	
502		0		碱38	8140.4	470	121.00	25.74%	0	4417	
503		0	10kV-44	碱41	8140.4	470	84.44	17.97%	0	5050	
504		0		碱42	6287.16	363	44.61	12.29%	0	4257	
505		0		碱43	8140.4	470	63.44	13.50%	0	5414	
506		0		碱44	8140.4	470	227.00	48.30%	0	2581	
507		0		碱45	8140.4	470	147.00	31.28%	0	3966	
508		0		碱46	8140.4	470	49.96	10.63%	0	5647	
509		0		碱47	8140.4	470	100.51	21.38%	0	4772	
510		0		碱48	8140.4	470	144.00	30.64%	0	4018	
511		0	10kV-45	碱51	8140.4	470	164.24	34.94%	0	3668	
512		0		碱52	8140.4	470	68.63	14.60%	0	5324	
513		0		碱53	8140.4	470	191.00	40.64%	0	3204	
514		0		碱54	8140.4	470	218.00	46.38%	0	2737	
515		0		碱55	6287.16	363	112.46	30.98%	0	3082	
516		0		碱56	8140.4	470	201.00	42.77%	0	3031	
517		0		碱57	8140.4	470	71.78	15.27%	0	5269	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
518		0	10kV-46	碱58	8140.4	470	90.85	19.33%	0	4939	
519		0		碱61	8140.4	470	207.93	44.24%	0	2911	
520		0		碱62	8140.4	470	128.65	27.37%	0	4284	
521		0		碱63	8140.4	470	47.82	10.18%	0	5684	
522		0		碱64	8140.4	470	41.44	8.82%	0	5795	
523		0		碱65	6287.16	363	33.42	9.21%	0	4451	
524		0		碱66	8140.4	470	22.87	4.86%	0	6116	
525		0		碱67	7828.64	452	90.90	20.11%	0	4688	
526		0		碱68	8140.4	470	51.06	10.86%	0	5628	
527	金源路	0	10kV-41	源11	6928	400	83.00	20.75%	0	4105	
528		0		源12	6928	400	0.00	0.00%	0	5542	
529		0		源13	6373.76	368	184.00	50.00%	0	1912	
530		0		源14	6928	400	0.00	0.00%	0	5542	
531		0		源15	6928	400	0.00	0.00%	0	5542	
532		0		源16	6373.76	368	146.00	39.67%	0	2570	
533		0		源17	6373.76	368	214.00	58.15%	0	1393	
534		0		源18	6928	400	0.00	0.00%	0	5542	
535		0	10kV-42	源21	6928	400	5.00	1.25%	0	5456	
536		0		源22	6928	400	275.00	68.75%	0	779	
537		0		源23	6373.76	368	167.99	45.65%	0	2189	
538		0		源24	6373.76	368	238.99	64.94%	0	960	
539		0	10kV-43	源25	6373.76	368	0.00	0.00%	0	5099	
540		0		源26	6928	400	102.00	25.50%	0	3776	
541		0		源27	6928	400	265.00	66.25%	0	953	
542		0		源28	6373.76	368	196.00	53.26%	0	1704	
543		0	10kV-44	源31	7257.08	419	310.00	73.99%	0	436	
544		0		源32	6373.76	368	59.00	16.03%	0	4077	
545		0		源34	6928	400	1.17	0.29%	0	5522	
546		0		源35	6928	400	1.16	0.29%	0	5522	
547	精细园	0	10kV-41	精11	8140.4	470	188.39	40.08%	0	3249	
548		0		精12	8140.4	470	126.00	26.81%	0	4330	
549		0		精13	7880.6	455	82.90	18.22%	0	4869	
550		0		精14	9924.36	573	2.00	0.35%	0	7905	
551		0		精15	8278.96	478	81.00	16.95%	0	5220	
552		0	10kV-42	精21	7880.6	455	103.07	22.65%	0	4519	
553		0		精22	7326.36	423	0.00	0.00%	0	5861	
554		0		精23	7880.6	455	144.23	31.70%	0	3806	
555		0		精24	10392	600	98.64	16.44%	0	6605	
556		0		精31	8140.4	470	185.00	39.36%	0	3308	
557		0		精32	8140.4	470	278.00	59.15%	0	1697	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
558	科学园	0	10kV-43	精33	7880.6	455	73.00	16.04%	0	5040	
559		0		精34	9924.36	573	2.00	0.35%	0	7905	
560		0		精35	8278.96	478	269.00	56.28%	0	1964	
561		0		精36	8573.4	495	22.00	4.44%	0	6478	
562		0	10kV-44	精41	7880.6	455	233.00	51.21%	0	2269	
563		0		精42	7326.36	423	0.00	0.00%	0	5861	
564		0		精43	7880.6	455	47.75	10.49%	0	5478	
565		0		精44	7880.6	455	86.40	18.99%	0	4808	
566		0		精45	5369.2	310	1.43	0.46%	0	4271	
567		0		精46	9266.2	535	199.00	37.20%	0	3966	
568		0	10kV-42	科21	6373.76	368	59.00	16.03%	0	4077	
569		0		科22	6373.76	368	220.00	59.78%	0	1289	
570		0		科23	6928	400	108.00	27.00%	0	3672	
571		0		科24	6928	400	133.00	33.25%	0	3239	
572		0	10kV-43	科25	6928	400	277.00	69.25%	0	745	
573		0		科26	6928	400	157.00	39.25%	0	2823	
574		0		科27	6928	400	111.00	27.75%	0	3620	
575		0	10kV-44	科31	6928	400	18.87	4.72%	0	5216	
576		0		科32	6373.76	368	194.00	52.72%	0	1739	
577		0		科33	6373.76	368	179.00	48.64%	0	1999	
578		0		科34	6928	400	167.00	41.75%	0	2650	
579		0		科35	6928	400	45.00	11.25%	0	4763	
580		0		科36	6928	400	171.00	42.75%	0	2581	
581		0		科37	6928	400	215.00	53.75%	0	1819	
582	临津园	0	10kV-4	津11	6373.76	368	256.00	69.57%	0	665	
583		0		津12	7499.56	433	11.00	2.54%	0	5809	
584		0		津13	7499.56	433	299.99	69.28%	0	804	
585		0		津14	7187.8	415	25.80	6.22%	0	5303	
586		0	10kV-5	津21	6373.76	368	251.00	68.21%	0	752	
587		0		津22	7499.56	433	158.40	36.58%	0	3256	
588		0		津23	7499.56	433	256.79	59.31%	0	1552	
589		0		津24	7897.92	456	327.00	71.71%	0	655	
590	刘岗	0	10kV-4	刘11	6062	350	188.00	53.71%	0	1593	
591		0		刘13	6373.76	368	143.09	38.88%	0	2621	
592		0		刘14	6373.76	368	195.00	52.99%	0	1722	
593		0	10kV-5	刘22	6373.76	368	2.00	0.54%	0	5064	
594		0		刘23	6373.76	368	124.00	33.70%	0	2951	
595		0		刘24	6062	350	232.00	66.29%	0	831	
596		0		刘25	7794	450	0.35	0.08%	0	6229	
597		0		美11	6928	400	152.00	38.00%	0	2910	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
598	美洲路	0	10kV-41	美12	6928	400	84.02	21.01%	0	4087	
599		0		美16	6928	400	95.00	23.75%	0	3897	
600		0		美17	6928	400	66.45	16.61%	0	4392	
601		0		美18	6928	400	36.80	9.20%	0	4905	
602		0		美21	6928	400	71.00	17.75%	0	4313	
603		0	10kV-42	美22	6928	400	56.95	14.24%	0	4556	
604		0		美23	6928	400	57.00	14.25%	0	4555	
605		0		美25	6928	400	155.00	38.75%	0	2858	
606		0	10kV-43	美26	6928	400	104.00	26.00%	0	3741	
607		0		南11	6928	400	56.00	14.00%	0	4572	
608	南环	0	10kV-41	南12	6928	400	141.00	35.25%	0	3100	
609		0		南13	6928	400	267.77	66.94%	0	905	
610		0		南14	6928	400	210.00	52.50%	0	1905	
611		0		南15	6928	400	135.00	33.75%	0	3204	
612		0		南16	6928	400	148.00	37.00%	0	2979	
613		0		南17	6928	400	217.00	54.25%	0	1784	
614		0		南18	6928	400	0.00	0.00%	0	5542	
615		0	10kV-42	南21	6928	400	0.00	0.00%	0	5542	
616		0		南22	6928	400	0.00	0.00%	0	5542	
617		0		南23	6928	400	146.00	36.50%	0	3014	
618		0		南24	6373.76	368	56.00	15.22%	0	4129	
619		0		南25	6373.76	368	188.32	51.17%	0	1837	
620		0	10kV-43	南26	6928	400	67.00	16.75%	0	4382	
621		0		南27	6928	400	120.00	30.00%	0	3464	
622		0		南28	6928	400	74.77	18.69%	0	4247	
623	宁车沽	0	10kV-4	车11	5196	300	211.00	70.33%	0	502	
624		0		车12	6373.76	368	73.92	20.09%	0	3819	
625		0	10kV-5	车21	5196	300	72.00	24.00%	0	2910	
626		0		车22	5196	300	195.00	65.00%	0	779	
627	宁夏道	0	10kV-42	夏31	7534.2	435	87.00	20.00%	0	4521	
628		0		夏32	8573.4	495	44.71	9.03%	0	6084	
629		0		夏33	9560.64	552	50.00	9.06%	0	6783	
630		0		夏34	7395.64	427	209.00	48.95%	0	2297	
631		0	10kV-43	夏41	9924.36	573	86.68	15.13%	0	6438	
632		0		夏42	8278.96	478	102.78	21.50%	0	4843	
633		0	10kV-44	夏51	8573.4	495	53.24	10.76%	0	5937	
634		0		夏52	7534.2	435	107.00	24.60%	0	4174	
635		0		夏53	9560.64	552	40.78	7.39%	0	6942	
636		0		夏54	7395.64	427	212.00	49.65%	0	2245	
637		0		夏61	9006.4	520	53.00	10.19%	0	6287	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
638		0		夏62	8278.96	478	35.00	7.32%	0	6017	
639		0		夏63	6495	375	61.00	16.27%	0	4139	
640	农场	0	10kV-4	农11	5196	300	190.00	63.33%	0	866	
641		0		农12	5196	300	46.85	15.62%	0	3345	
642		0	10kV-5	农21	5196	300	190.28	63.43%	0	861	
643		0		农22	5196	300	220.00	73.33%	0	346	
644		0		农23	5196	300	195.00	65.00%	0	779	
645		0		农24	5196	300	39.55	13.18%	0	3472	
646		0	10kV-41	纺14	6928	400	165.00	41.25%	0	2685	
647		0		纺15	4347.32	251	61.00	24.30%	0	2421	
648	轻纺城	0		纺16	6928	400	127.16	31.79%	0	3340	
649		0		纺17	6928	400	134.00	33.50%	0	3222	
650		0	10kV-42	纺24	6928	400	38.00	9.50%	0	4884	
651		0		纺25	6928	400	109.11	27.28%	0	3653	
652		0		纺26	6928	400	135.00	33.75%	0	3204	
653	清河	0	10kV-4	931	4330	250	73.59	29.44%	0	2189	
654		0	10kV-5	932	4156.8	240	79.00	32.92%	0	1957	
655		0	10kV-4	933	3464	200	132.00	66.00%	0	485	
656		0	10kV-5	934	3464	200	125.00	62.50%	0	606	
657		0	10kV-4	935	3464	200	56.02	28.01%	0	1801	
658		0	10kV-5	936	3464	200	25.08	12.54%	0	2337	
659		0	10kV-4	937	4156.8	240	92.00	38.33%	0	1732	
660		0	10kV-5	938	3464	200	60.00	30.00%	0	1732	
661	三道桥	0	10kV-41	桥11	6373.76	368	136.00	36.96%	0	2743	
662		0		桥13	8140.4	470	179.00	38.09%	0	3412	
663		0		桥15	8140.4	470	181.00	38.51%	0	3377	
664		0		桥16	6373.76	368	56.00	15.22%	0	4129	
665		0		桥17	8140.4	470	212.00	45.11%	0	2840	
666		0	10kV-42	桥22	6373.76	368	109.00	29.62%	0	3211	
667		0		桥24	6373.76	368	197.58	53.69%	0	1677	
668		0	10kV-43	桥25	6373.76	368	243.00	66.03%	0	890	
669		0		桥26	7257.08	419	286.17	68.30%	0	849	
670		0		桥27	8140.4	470	180.00	38.30%	0	3395	
671		0	10kV-44	桥31	8140.4	470	187.00	39.79%	0	3273	
672		0		桥32	6373.76	368	272.00	73.91%	0	388	
673		0		桥33	8140.4	470	168.00	35.74%	0	3603	
674		0		桥34	6373.76	368	226.58	61.57%	0	1175	
675	沙井子	0	10kV-4	井11	6373.76	368	185.95	50.53%	0	1878	
676		0		井12	6928	400	220.00	55.00%	0	1732	
677		0		井21	6373.76	368	87.00	23.64%	0	3592	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
678		0	10kV-5	井22	6373.76	368	169.00	45.92%	0	2172	
679		0		井23	6373.76	368	99.00	26.90%	0	3384	
680	胜利村	0	10kV-4	640	6928	400	75.00	18.75%	0	4243	
681		0		641	6373.76	368	364.00	98.91%	0	0	
682		0	10kV-5	642	6373.76	368	314.00	85.33%	0	0	
683		0	10kV-4	643	6373.76	368	315.00	85.60%	0	0	
684		0	10kV-5	644	6373.76	368	224.00	60.87%	0	1219	
685		0	10kV-4	645	6373.76	368	343.00	93.21%	0	0	
686		0	10kV-5	646	6373.76	368	103.00	27.99%	0	3315	
687		0	10kV-4	647	6928	400	313.00	78.25%	0	121	
688		0	10kV-5	648	6928	400	198.00	49.50%	0	2113	
689		0		652	7620.8	440	339.00	77.05%	0	225	
690		0		654	6373.76	368	175.00	47.55%	0	2068	
691		0	10kV-4	双11	6373.76	368	4.57	1.24%	0	5020	
692	双桥站	0	10kV-5	双27	5196	300	214.32	71.44%	0	445	
693	太平村	0	10kV-4	太11	6373.76	368	176.00	47.83%	0	2051	
694		0		太13	6373.76	368	174.00	47.28%	0	2085	
695		0		太14	6373.76	368	121.12	32.91%	0	3001	
696		0	10kV-5	太21	6373.76	368	227.00	61.68%	0	1167	
697		0		太22	6373.76	368	259.44	70.50%	0	606	
698		0		太23	6373.76	368	200.00	54.35%	0	1635	
699		0									
700	塘沽	0	10kV-1	141	8140.4	470	173.00	36.81%	0	3516	
701		0		142	8140.4	470	276.00	58.72%	0	1732	
702		0		143	8140.4	470	151.56	32.25%	0	3887	
703		0		144	8140.4	470	131.00	27.87%	0	4243	
704		0		145	8140.4	470	161.00	34.26%	0	3724	
705		0		146	8140.4	470	159.00	33.83%	0	3758	
706		0		147	6373.76	368	241.00	65.49%	0	925	
707		0		148	8140.4	470	277.00	58.94%	0	1715	
708		0	10kV-2甲	151	8140.4	470	63.00	13.40%	0	5421	
709		0		152	8140.4	470	220.31	46.88%	0	2696	
710		0		153	6373.76	368	269.00	73.10%	0	440	
711		0		154	6373.76	368	81.00	22.01%	0	3696	
712		0	10kV-2乙	155	8140.4	470	36.36	7.74%	0	5883	
713		0		156	8140.4	470	183.00	38.94%	0	3343	
714		0		157	8140.4	470	198.00	42.13%	0	3083	
715		0		158	6373.76	368	157.00	42.66%	0	2380	
716		0		161	6373.76	368	281.00	76.36%	0	232	
717		0		162	8140.4	470	272.51	57.98%	0	1792	
		0		163	8140.4	470	229.91	48.92%	0	2530	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
718		0	10kV-3	164	8140.4	470	248.00	52.77%	0	2217	
719		0		165	8140.4	470	219.00	46.60%	0	2719	
720		0		166	8140.4	470	308.00	65.53%	0	1178	
721		0		167	8140.4	470	126.00	26.81%	0	4330	
722		0		168	6373.76	368	240.47	65.35%	0	934	
723		0		深31	11604.4	670	243.00	36.27%	0	5075	
724	腾深	0	10kV-43	深32	10651.8	615	165.00	26.83%	0	5664	
725		0		深34	6200.56	358	77.34	21.60%	0	3621	
726		0		深41	4416.6	255	8.15	3.20%	0	3392	
727		0	10kV-44	深45	9266.2	535	133.00	24.86%	0	5109	
728		0		深46	9006.4	520	204.95	39.41%	0	3655	
729		0		深51	11604.4	670	250.00	37.31%	0	4954	
730		0	10kV-45	深52	10651.8	615	112.00	18.21%	0	6582	
731		0		深54	9266.2	535	211.00	39.44%	0	3758	
732		0		深61	4416.6	255	13.89	5.45%	0	3293	
733		0	10kV-46	深64	7309.04	422	4.00	0.95%	0	5778	
734		0		深66	9006.4	520	176.00	33.85%	0	4157	
735			10kV-41	体11	7828.64	452	174.00	38.50%	0	3249	
736				体12	9093	525	38.00	7.24%	0	6616	
737				体13	9093	525	144.00	27.43%	0	4780	
738				体14	7828.64	452	2.46	0.54%	0	6220	
739				体31	7828.64	452	128.00	28.32%	0	4046	
740	体育场		10kV-44	体32	9093	525	84.00	16.00%	0	5820	
741				体33	9093	525	117.00	22.29%	0	5248	
742				体34	7828.64	452	5.00	1.11%	0	6176	
743		0	10kV-41	填11	6928	400	92.75	23.19%	0	3936	
744		0		填12	9266.2	535	40.00	7.48%	0	6720	
745		0		填13	7499.56	433	132.00	30.48%	0	3713	
746	填海站	0		填18	7724.72	446	44.00	9.87%	0	5418	
747		0	10kV-42	填21	7499.56	433	49.00	11.32%	0	5151	
748		0		填22	9266.2	535	10.37	1.94%	0	7233	
749		0		填23	7499.56	433	168.00	38.80%	0	3090	
750		0		填27	7724.72	446	18.69	4.19%	0	5856	
751		0		填28	7724.72	446	1.26	0.28%	0	6158	
752	同进	0	10kV-41	同11	8278.96	478	96.76	20.24%	0	4947	
753		0		同12	8278.96	478	250.00	52.30%	0	2293	
754		0		同13	9093	525	56.00	10.67%	0	6304	
755		0		同14	8278.96	478	10.00	2.09%	0	6450	
756		0		同15	6495	375	98.56	26.28%	0	3489	
757		0		同31	8278.96	478	159.00	33.26%	0	3869	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
758		0	10kV-42	同32	8278.96	478	194.00	40.59%	0	3263	
759		0		同33	9093	525	69.84	13.30%	0	6065	
760		0		同34	8278.96	478	51.00	10.67%	0	5740	
761		0		同35	6495	375	237.00	63.20%	0	1091	
762		0		同36	8227	475	181.00	38.11%	0	3447	
763	团结路	0	10kV-41	团11	6373.76	368	174.00	47.28%	0	2085	
764		0		团12	6373.76	368	168.75	45.86%	0	2176	
765		0		团14	6373.76	368	29.00	7.88%	0	4597	
766		0		团15	8140.4	470	70.31	14.96%	0	5295	
767		0		团16	6373.76	368	1.06	0.29%	0	5081	
768		0		团17	8278.96	478	242.00	50.63%	0	2432	
769		0		团18	8140.4	470	142.21	30.26%	0	4049	
770		0	10kV-42	团21	6373.76	368	19.51	5.30%	0	4761	
771		0		团22	8140.4	470	200.92	42.75%	0	3032	
772		0		团23	6373.76	368	0.00	0.00%	0	5099	
773		0		团24	8278.96	478	81.31	17.01%	0	5215	
774		0	10kV-43	团25	8140.4	470	71.71	15.26%	0	5270	
775		0		团26	6373.76	368	94.21	25.60%	0	3467	
776		0		团27	6373.76	368	0.00	0.00%	0	5099	
777		0		团28	6373.76	368	81.21	22.07%	0	3692	
778	王庄镇	0	10kV-4	王11	6373.76	368	39.10	10.63%	0	4422	
779		0		王12	6373.76	368	60.20	16.36%	0	4056	
780		0		王14	6373.76	368	91.00	24.73%	0	3523	
781		0		王15	6928	400	101.22	25.31%	0	3789	
782		0	10kV-5	王21	6373.76	368	85.00	23.10%	0	3627	
783		0		王22	6235.2	360	120.00	33.33%	0	2910	
784		0		王24	6373.76	368	125.00	33.97%	0	2934	
785		0		王25	6373.76	368	214.00	58.15%	0	1393	
786		0		王26	6373.76	368	81.63	22.18%	0	3685	
787	西	0	10kV-41	西11	6928	400	65.98	16.49%	0	4400	
788		0		西12	6928	400	187.00	46.75%	0	2304	
789		0		西13	6928	400	81.00	20.25%	0	4139	
790		0		西14	6928	400	161.00	40.25%	0	2754	
791		0		西15	6928	400	43.24	10.81%	0	4793	
792		0		西16	6928	400	247.00	61.75%	0	1264	
793		0	10kV-42	西21	6928	400	123.00	30.75%	0	3412	
794		0		西22	6928	400	31.00	7.75%	0	5005	
795		0		西23	6928	400	288.00	72.00%	0	554	
796		0		西24	6928	400	252.00	63.00%	0	1178	
797		0		西25	6928	400	117.00	29.25%	0	3516	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
798	西河	0	10kV-43	西26	6928	400	127.00	31.75%	0	3343	
799		0		西31	6928	400	73.95	18.49%	0	4262	
800		0		西32	6928	400	243.00	60.75%	0	1334	
801		0		西33	6928	400	105.70	26.43%	0	3712	
802		0		西34	6928	400	216.00	54.00%	0	1801	
803		0		西35	6928	400	238.00	59.50%	0	1420	
804		0	10kV-44	西36	6928	400	33.87	8.47%	0	4956	
805		0		西41	6928	400	128.00	32.00%	0	3325	
806		0		西42	6928	400	109.00	27.25%	0	3655	
807		0		西43	6928	400	33.87	8.47%	0	4956	
808		0		西44	6928	400	128.00	32.00%	0	3325	
809	新北路	0	10kV-5	582	6928	400	148.13	37.03%	0	2977	
810		0		583	6373.76	368	87.00	23.64%	0	3592	
811		0		584	6373.76	368	181.00	49.18%	0	1964	
812		0		585	6373.76	368	278.00	75.54%	0	284	
813		0		586	6373.76	368	165.00	44.84%	0	2241	
814		0	10kV-4	588	6373.76	368	13.00	3.53%	0	4874	
815		0		589	6373.76	368	48.00	13.04%	0	4268	
816		0		590	6373.76	368	240.00	65.22%	0	942	
817		0		591	6928	400	44.53	11.13%	0	4771	
818		0		592	6373.76	368	288.00	78.26%	0	111	
819		0		593	6373.76	368	198.00	53.80%	0	1670	
820	新村	0	10kV-41	村11	8140.4	470	87.40	18.59%	0	4999	
821		0		村13	8140.4	470	286.87	61.04%	0	1544	
822		0		村14	8140.4	470	139.19	29.61%	0	4102	
823		0		村15	8140.4	470	116.00	24.68%	0	4503	
824		0		村16	8140.4	470	32.47	6.91%	0	5950	
825		0		村17	6373.76	368	142.88	38.83%	0	2624	
826		0	10kV-42	村21	8140.4	470	228.00	48.51%	0	2563	
827		0		村22	8140.4	470	118.00	25.11%	0	4469	
828		0	10kV-43	村25	8140.4	470	132.00	28.09%	0	4226	
829		0		村26	8140.4	470	163.00	34.68%	0	3689	
830		0		村27	8140.4	470	18.95	4.03%	0	6184	
831		0		村28	8140.4	470	139.00	29.57%	0	4105	
832		0	10kV-44	村31	8140.4	470	97.00	20.64%	0	4832	
833		0		村32	8140.4	470	45.00	9.57%	0	5733	
834		0		村33	6373.76	368	140.00	38.04%	0	2674	
835		0		村34	8140.4	470	312.00	66.38%	0	1108	
836		0		村35	8140.4	470	210.30	44.74%	0	2870	
837		0		村36	8140.4	470	83.42	17.75%	0	5067	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
838		0		村38	8140.4	470	8.74	1.86%	0	6361	
839	新港	0	10kV-41	港11	8140.4	470	214.63	45.67%	0	2795	
840		0		港12	8140.4	470	48.69	10.36%	0	5669	
841		0		港13	8140.4	470	90.00	19.15%	0	4954	
842		0		港14	8140.4	470	170.00	36.17%	0	3568	
843		0		港17	8140.4	470	259.45	55.20%	0	2019	
844		0		港18	8140.4	470	136.00	28.94%	0	4157	
845		0	10kV-42	港21	8140.4	470	273.00	58.09%	0	1784	
846		0		港24	8140.4	470	220.00	46.81%	0	2702	
847		0	10kV-43	港25	8140.4	470	323.00	68.72%	0	918	
848		0		港26	8140.4	470	178.00	37.87%	0	3429	
849		0		港27	8140.4	470	306.00	65.11%	0	1212	
850		0		港28	8140.4	470	193.00	41.06%	0	3170	
851		0	10kV-41	河11	6373.76	368	184.00	50.00%	0	1912	
852	新河	0		河12	8140.4	470	86.66	18.44%	0	5011	
853		0		河13	6373.76	368	149.00	40.49%	0	2518	
854		0		河14	6373.76	368	176.00	47.83%	0	2051	
855		0		河15	8140.4	470	210.00	44.68%	0	2875	
856		0		河16	8140.4	470	31.47	6.69%	0	5967	
857		0		河17	8140.4	470	259.00	55.11%	0	2026	
858		0	10kV-42	河21	7309.04	422	224.00	53.08%	0	1968	
859		0		河23	8140.4	470	59.00	12.55%	0	5490	
860		0		河24	8140.4	470	122.17	25.99%	0	4396	
861		0	10kV-43	河25	6373.76	368	192.00	52.17%	0	1774	
862		0		河26	8140.4	470	172.79	36.76%	0	3520	
863		0		河27	6373.76	368	193.00	52.45%	0	1756	
864		0	10kV-44	河31	8140.4	470	261.00	55.53%	0	1992	
865		0		河32	8140.4	470	0.00	0.00%	0	6512	
866		0		河33	8140.4	470	271.00	57.66%	0	1819	
867		0		河34	7309.04	422	18.00	4.27%	0	5535	
868		0		河36	8140.4	470	178.00	37.87%	0	3429	
869		0		河37	8140.4	470	118.00	25.11%	0	4469	
870		0		461	9266.2	535	109.00	20.37%	0	5525	
871		0		462	9266.2	535	235.00	43.93%	0	3343	
872		0	10kV-41	471	6373.76	368	213.92	58.13%	0	1394	
873		0		472	6928	400	45.00	11.25%	0	4763	
874		0		473	9266.2	535	264.00	49.35%	0	2840	
875		0		474	9266.2	535	90.00	16.82%	0	5854	
876		0	10kV-42	481	8140.4	470	99.36	21.14%	0	4791	
877		0		482	6373.76	368	198.00	53.80%	0	1670	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
878	新民路	0	10kV-42	483	6373.76	368	248.00	67.39%	0	804	
879		0		484	6373.76	368	261.12	70.96%	0	576	
880		0	10kV-43	485	8140.4	470	220.00	46.81%	0	2702	
881		0		486	8140.4	470	222.00	47.23%	0	2667	
882		0		487	6373.76	368	127.04	34.52%	0	2899	
883		0		488	7326.36	423	262.00	61.94%	0	1323	
884		0	10kV-44	491	6373.76	368	318.00	86.41%	0	0	
885		0		492	10392	600	148.00	24.67%	0	5750	
886		0		493	6373.76	368	207.00	56.25%	0	2789	
887		0		494	9543.32	551	21.00	3.81%	0	7271	
888		0		495	8140.4	470	229.76	48.89%	0	2533	
889		0		496	8140.4	470	196.00	41.70%	0	3118	
890		0		497	8140.4	470	199.00	42.34%	0	3066	
891		0		498	7326.36	423	264.00	62.41%	0	1289	
892	新圣路	0	10kV-41	圣13	8781.24	507	293.00	57.79%	0	1950	
893		0	10kV-42	圣21	6373.76	368	168.85	45.88%	0	2174	
894		0		圣23	6633.56	383	163.00	42.56%	0	2484	
895		0		圣24	8140.4	470	251.00	53.40%	0	2165	
896		0	10kV-43	圣25	6373.76	368	124.88	33.93%	0	2936	
897		0		圣26	6633.56	383	106.00	27.68%	0	3471	
898		0		圣27	8729.28	504	250.99	49.80%	0	2636	
899		0		圣28	6633.56	383	68.00	17.75%	0	4129	
900		0	10kV-44	圣31	6373.76	368	87.54	23.79%	0	3583	
901		0		圣32	8140.4	470	164.00	34.89%	0	3672	
902		0		圣33	8140.4	470	287.00	61.06%	0	1541	
903		0		圣34	9006.4	520	303.00	58.27%	0	1957	
904		0		圣35	8781.24	507	165.00	32.54%	0	4167	
905		0		圣36	8140.4	470	147.00	31.28%	0	3966	
906		0		圣37	9006.4	520	186.00	35.77%	0	3984	
907		0		圣38	6633.56	383	209.00	54.57%	0	1687	
908		0	10kV-41	兴11	6928	400	265.00	66.25%	0	953	
909		0		兴12	6373.76	368	164.88	44.81%	0	2243	
910		0		兴13	6928	400	161.60	40.40%	0	2743	
911		0		兴14	6928	400	318.00	79.50%	0	35	
912		0		兴15	6928	400	5.00	1.25%	0	5456	
913		0	10kV-42	兴21	6928	400	56.00	14.00%	0	4572	
914		0		兴22	6928	400	250.00	62.50%	0	1212	
915		0		兴23	6928	400	208.00	52.00%	0	1940	
916		0		兴24	6928	400	253.00	63.25%	0	1160	
917		0		兴25	6928	400	20.00	5.00%	0	5196	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
918	兴塘	0	10kV-43	兴32	6928	400	199.92	49.98%	0	2080	
919		0		兴33	6928	400	16.00	4.00%	0	5265	
920		0		兴34	6928	400	188.00	47.00%	0	2286	
921		0		兴35	6373.76	368	96.00	26.09%	0	3436	
922		0		兴36	6928	400	281.00	70.25%	0	675	
923		0	10kV-44	兴41	6928	400	5.00	1.25%	0	5456	
924		0		兴42	6928	400	97.03	24.26%	0	3862	
925		0		兴43	6928	400	269.06	67.27%	0	882	
926		0		兴44	6928	400	101.25	25.31%	0	3789	
927		0		兴45	6373.76	368	133.95	36.40%	0	2779	
928		0		兴46	6928	400	99.00	24.75%	0	3828	
929	杨柳庄	0	10kV-4	杨11	6928	400	72.00	18.00%	0	4295	
930		0		杨12	6373.76	368	207.06	56.27%	0	1513	
931		0		杨13	6373.76	368	68.00	18.48%	0	3921	
932		0		杨14	6373.76	368	120.26	32.68%	0	3016	
933		0		杨15	6373.76	368	215.00	58.42%	0	1375	
934		0	10kV-5	杨21	6928	400	185.00	46.25%	0	2338	
935		0		杨22	6928	400	267.00	66.75%	0	918	
936		0		杨23	6373.76	368	257.00	69.84%	0	648	
937		0		杨24	6373.76	368	141.32	38.40%	0	2651	
938		0		杨25	6373.76	368	127.00	34.51%	0	2899	
939	营城	0	10kV-42	营21	7967.2	460	129.58	28.17%	0	4129	
940		0		营22	7967.2	460	209.00	45.43%	0	2754	
941		0		营23	7967.2	460	298.00	64.78%	0	1212	
942		0		营24	6373.76	368	97.23	26.42%	0	3415	
943		0	10kV-43	营25	6373.76	368	212.00	57.61%	0	2702	
944		0		营26	6754.8	390	238.00	61.03%	0	1282	
945		0		营27	7794	450	53.00	11.78%	0	5317	
946		0		营28	9266.2	535	0.00	0.00%	0	7413	
947		0	10kV-44	营31	9266.2	535	85.98	16.07%	0	5924	
948		0		营32	6373.76	368	98.11	26.66%	0	3400	
949		0		营33	6373.76	368	214.00	58.15%	0	2667	
950		0		营34	7967.2	460	10.73	2.33%	0	6188	
951		0		营36	6754.8	390	224.00	57.44%	0	1524	
952		0		营37	7794	450	11.00	2.44%	0	6045	
953		0		营38	9006.4	520	0.00	0.00%	0	7205	
954	永兴路	0	10kV-41	永13	7499.56	433	209.40	48.36%	0	2373	
955		0		永14	7447.6	430	240.00	55.81%	0	1801	
956		0		永22	7759.36	448	204.16	45.57%	0	2672	
957		0	10kV-42	永33	7863.28	454	304.00	66.96%	0	1025	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
958	游乐港	0	10kV-41	乐11	10392	600	3.42	0.57%	0	8254	
959		0		乐12	6928	400	297.00	74.25%	0	398	
960		0		乐13	6928	400	58.00	14.50%	0	4538	
961		0		乐14	6928	400	264.00	66.00%	0	970	
962		0		乐15	6928	400	96.00	24.00%	0	3880	
963		0		乐16	6928	400	142.00	35.50%	0	3083	
964		0	10kV-42	乐21	10392	600	3.19	0.53%	0	8258	
965		0		乐22	6928	400	294.00	73.50%	0	450	
966		0		乐23	6928	400	226.00	56.50%	0	1628	
967		0		乐24	6928	400	226.00	56.50%	0	1628	
968		0		乐25	6928	400	99.00	24.75%	0	3828	
969		0		乐26	6928	400	56.00	14.00%	0	4572	
970		0	10kV-43	乐31	6928	400	263.00	65.75%	0	987	
971	友谊路	0	10kV-4	561	6928	400	94.00	23.50%	0	3914	
972		0		562	6373.76	368	175.00	47.55%	0	2068	
973		0		563	6373.76	368	210.00	57.07%	0	1462	
974		0		564	6373.76	368	191.00	51.90%	0	1791	
975		0	10kV-5	565	6373.76	368	191.28	51.98%	0	1786	
976		0		566	6928	400	152.22	38.05%	0	2906	
977		0		567	6928	400	196.00	49.00%	0	2148	
978		0		568	6928	400	197.00	49.25%	0	2130	
979	于家堡	0	10kV-41	于11	6928	400	160.00	40.00%	0	2771	
980		0		于12	6928	400	264.26	66.06%	0	965	
981		0		于13	6928	400	53.70	13.43%	0	4612	
982		0		于14	6928	400	264.00	66.00%	0	970	
983		0	10kV-42	于21	6928	400	46.00	11.50%	0	4746	
984		0		于22	6928	400	28.51	7.13%	0	5049	
985		0		于23	6928	400	41.00	10.25%	0	4832	
986		0		于24	6928	400	69.00	17.25%	0	4347	
987		0		于25	6928	400	50.74	12.69%	0	4664	
988		0		于26	6928	400	53.00	13.25%	0	4624	
989		0	10kV-43	于31	6928	400	37.95	9.49%	0	4885	
990		0		于32	6928	400	47.07	11.77%	0	4727	
991		0		于33	6928	400	50.00	12.50%	0	4676	
992		0		于34	6928	400	58.00	14.50%	0	4538	
993		0		于35	6928	400	17.18	4.30%	0	5245	
994		0	10kV-44	于41	6928	400	126.00	31.50%	0	3360	
995		0		于42	6928	400	77.00	19.25%	0	4209	
996		0		于43	6928	400	60.00	15.00%	0	4503	
997		0		于44	6928	400	60.00	15.00%	0	4503	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
998	渔港	0	10kV-41	鲤11	8140.4	470	117.00	24.89%	0	4486	
999		0		鲤12	6373.76	368	179.00	48.64%	0	1999	
1000		0		鲤13	8140.4	470	130.00	27.66%	0	4261	
1001		0		鲤14	7326.36	423	138.00	32.62%	0	3471	
1002		0		鲤15	7880.6	455	194.00	42.64%	0	2944	
1003		0		鲤16	7326.36	423	19.00	4.49%	0	5532	
1004		0		鲤17	7326.36	423	11.00	2.60%	0	5671	
1005		0	10kV-42	鲤21	8140.4	470	231.00	49.15%	0	2511	
1006		0		鲤22	6373.76	368	146.00	39.67%	0	2570	
1007		0	10kV-44	鲤31	8140.4	470	110.00	23.40%	0	4607	
1008		0		鲤32	6373.76	368	98.04	26.64%	0	3401	
1009		0		鲤33	7326.36	423	40.00	9.46%	0	5168	
1010		0		鲤36	7326.36	423	21.00	4.96%	0	5497	
1011		0		鲤37	7326.36	423	9.00	2.13%	0	5705	
1012	玉辰	0	10kV-42	辰31	9266.2	535	265.42	49.61%	0	2816	
1013		0		辰32	9266.2	535	339.06	63.37%	0	1541	
1014		0		辰33	9266.2	535	420.00	78.50%	0	139	
1015		0		辰34	7361	425	30.83	7.25%	0	5355	
1016		0		辰35	7915.24	457	109.91	24.05%	0	4429	
1017		0		辰36	9006.4	520	120.00	23.08%	0	5127	
1018		0	10kV-43	辰41	9266.2	535	2.65	0.49%	0	7367	
1019		0		辰42	9266.2	535	275.03	51.41%	0	2649	
1020		0		辰44	7915.24	457	81.24	17.78%	0	4925	
1021		0		辰46	9924.36	573	129.00	22.51%	0	5705	
1022		0	10kV-44	辰51	10392	600	453.00	75.50%	0	468	
1023		0		辰52	9266.2	535	330.00	61.68%	0	1697	
1024		0		辰53	9266.2	535	268.00	50.09%	0	2771	
1025		0		辰54	7361	425	48.00	11.29%	0	5057	
1026		0		辰55	7915.24	457	59.45	13.01%	0	5302	
1027		0		辰56	9006.4	520	1.00	0.19%	0	7188	
1028		0		辰63	9266.2	535	343.78	64.26%	0	1459	
1029		0		辰64	7915.24	457	122.00	26.70%	0	4219	
1030		0		辰66	9924.36	573	47.00	8.20%	0	7125	
1031		0	10kV-41	漳11	8140.4	470	217.00	46.17%	0	2754	
1032		0		漳12	8140.4	470	191.00	40.64%	0	3204	
1033		0		漳13	8140.4	470	229.00	48.72%	0	2546	
1034		0		漳14	8140.4	470	216.00	45.96%	0	2771	
1035		0		漳15	8140.4	470	174.00	37.02%	0	3499	
1036		0		漳16	8140.4	470	239.24	50.90%	0	2369	
1037		0		漳17	8140.4	470	202.00	42.98%	0	3014	

序号	变电站名称	主变最大负荷日后需预留容量 (kVA)	所属母线	线路名称	线路允许容量 (kVA)	允许电流 (A)	历史最大电流 (A)	最高负载率 (%)	线路最大负荷日后需预留容量 (kVA)	可开放容量 (kVA)	备注
1038	漳州道	0	10kV-43	漳18	6928	400	40.43	10.11%	0	4842	
1039		0		漳21	8140.4	470	254.00	54.04%	0	2113	
1040		0		漳22	8140.4	470	158.00	33.62%	0	3776	
1041		0		漳23	8140.4	470	122.00	25.96%	0	4399	
1042		0		漳24	8140.4	470	201.00	42.77%	0	3031	
1043		0		漳25	8140.4	470	186.00	39.57%	0	3291	
1044		0		漳26	6928	400	4.04	1.01%	0	5472	
1045		0		漳27	8140.4	470	106.52	22.66%	0	4667	
1046		0		漳28	6529.64	377	223.00	59.15%	0	1361	
1047	中塘	0	10kV-41	中11	6373.76	368	178.00	48.37%	0	2016	
1048		0		中15	6373.76	368	217.00	58.97%	0	1341	
1049		0		中17	6373.76	368	218.00	59.24%	0	1323	
1050		0	10kV-42	中21	6373.76	368	183.00	49.73%	0	1929	
1051		0		中22	7257.08	419	275.39	65.73%	0	1036	
1052		0	10kV-43	中24	7880.6	455	230.00	50.55%	0	2321	
1053		0		中26	8833.2	510	346.00	67.84%	0	1074	
1054		0	10kV-44	中31	7880.6	455	128.61	28.27%	0	4077	
1055		0		中32	6373.76	368	244.34	66.40%	0	867	
1056		0		中34	6373.76	368	184.00	50.00%	0	1912	
1057		0		中36	7257.08	419	272.46	65.03%	0	1087	
1058	珠江道	0	10kV-41	珠11	6928	400	68.00	17.00%	0	4365	
1059		0		珠12	6928	400	270.10	67.53%	0	864	
1060		0		珠13	6928	400	144.58	36.15%	0	3038	
1061		0		珠14	7620.8	440	189.00	42.95%	0	4347	
1062		0		珠15	9266.2	535	276.00	51.59%	0	2633	
1063		0	10kV-42	珠21	6928	400	205.00	51.25%	0	1992	
1064		0		珠22	6928	400	114.73	28.68%	0	3555	
1065		0		珠23	6928	400	60.00	15.00%	0	4503	
1066		0		珠24	9006.4	520	227.00	43.65%	0	3273	
1067		0	10kV-45	珠51	6928	400	96.00	24.00%	0	3880	
1068		0		珠52	6928	400	147.00	36.75%	0	2996	
1069		0		珠53	6928	400	114.00	28.50%	0	3568	
1070		0		珠54	9006.4	520	331.82	63.81%	0	1458	
1071		0	10kV-46	珠61	6928	400	120.00	30.00%	0	3464	
1072		0		珠62	6928	400	131.00	32.75%	0	3273	
1073		0		珠63	6928	400	39.86	9.96%	0	4852	
1074		0		珠64	9266.2	535	286.00	53.46%	0	2459	